

5-30-90

T-ENG-90-15
Rev 0

UNIT ONE TRAIN A
DCP 88-V1N0070 SEQUENCER FUNCTIONAL
TEST

D.W. HINES

Expiration Date: April 20, 1990

Approval: J. Berkhoff Date: 3/25/90

JC - CSO - hold position skip 523 on 11 3/25/90

Released for testing per NRC Paul M. Kelly
3/28/90

Attach to MWO 18903678

READ AND DESTROY

9202190577 920116
PDR ADOCK 05000424
S PDR

1.0 PURPOSE:

This procedure will test the U/V RESET SWITCH and the remote U/V reset relay (K311) installed in Unit One Train A Sequencer. A Sequencer Operability Check along with this procedure will complete the functional test requirements of DCP 88-V1N0070 for Train A. The DG Brkr Fail To Close relay (K317) and the U/V Reset Enable relay (K306) will also be tested in this procedure.

2.0 PRECAUTIONS AND LIMITATIONS:

- 2.1 This test, once begun, shall be carried through to completion. If the test must be interrupted, then a detailed explanation of the interruption must be entered into the log.
- 2.2 Operator assistance should be obtained to operate equipment as required.
- 2.3 Observe all appropriate precautions and limitations in the plant operating procedures for the equipment operated during this test.
- 2.4 Prior to the start of the test, the Responsible Engineer shall review the Prerequisites and Initial Conditions, Section 4.0.
- 2.5 All procedural steps may be signed off by the Responsible Engineer, Shift Supervisor, or designated individual.
- 2.6 All switches and lights are located on the Unit One Train A Sequencer Test Panel unless otherwise stated.
- 2.7 Train B 4160Vac (1BA03) is meeting the electrical needs of Unit One. Train A 4160Vac (1AA02) switchgear will be de-energized during this procedure.
- 2.8 Alarms generated during performance of this procedure may be reset at the discretion of the Responsible Engineer.
- 2.9 Relay K311 may be removed to connect and disconnect the temporary power supply.

3.0 MEASUREMENT AND TEST EQUIPMENT

- 3.1 Volt-ohm meter, Simpson model 260 or equivalent, for monitoring a K317 spare normally open contact. This meter will check the operation of K317 relay and will be referred to as relay K317 in this procedure.
- 3.2 Volt-ohm meter, Simpson model 260 or equivalent, for monitoring a K306 spare normally open contact. This meter will check the operation of K306 relay and will be referred to as relay K306 in this procedure.
- 3.3 Stop Watch. The stop watch will be used to check the approximate time of relay and light operation.
- 3.4 A 48Vdc power supply to operate the remote U/V reset relay K306.
- 3.5 A switched jumper that will be used to simulate DG1A breaker (1AA0219) is closed.

4.0 PREREQUISITES OR INITIAL CONDITIONS:

- 4.1 The Responsible Engineer has reviewed Section 2.0

Delt / 3/29/90

- 4.2 The Unit One Train A Sequencer is in normal operating mode.

Delt / 3/29/90

- 4.3 The Diesel Generator Output Brkr, 1AA0219, is open.

Delt / 3/29/90

- 4.4 Establish communications, using sound powered phones, from the Unit One Train A Sequencer panel to the control room.

Delt / 3/29/90

- 4.5 The Unit One Shift Supervisor has given permission to perform this test.

[Signature] / 3/27/90 / 1306
SS Signature Date Time

5.0 TEST SECTION

5.1 Initial Setup

- 5.1.1 Connect a VOM across a spare normally open contact, 8 and 9, of relay K317.

DWH / 3/29/90

- 5.1.2 Connect a VOM across a spare normally open contact, 4 and 5, of relay K306.

DWH / 3/29/90

- 5.1.3 Set the DC voltage supply for approximately 48Vdc.

DWH / 3/29/90

- 5.1.4 Connect a 48Vdc supply, supply turned off, across the coil, 6 and 7, of relay K311.

DWH / 3/29/90

Section 5.1 Complete

[Signature] / 3/29/90
sign date

5.2 SEQUENCER TEST - U/V RESET WITH DE-ENERGIZED BUSS AND DIESEL GENERATOR 1A NOT RUNNING

- 5.2.1 Place DG1A OUTPUT BRKR (HS-1AA0219 at QEAB) into PTL.

DWH / 3/29/90

- 5.2.2 Place the DG1A in the LOCAL MAINTENANCE mode.

DWH / 3/29/90

NOTE:
THE FOLLOWING STEP
WILL DE-ENERGIZE
BUSS 1AA02.

OC ✓
HOLD POINT

CSO JN # 234222
3-29-90

5.2.3 Open the PREF NORM INCM BRKR (1AA0205)

DWH / 3/29/90

5.2.4 Wait 60 seconds for time delay relays to operate.

DWH / 3/29/90

5.2.5 Using the toggle switch located on the card in slot A4-2, reset the "3 UV in 2 hours" card.

DWH / 3/29/90

5.2.6 Verify relays K317 and K306 are energized.

DWH / 3/29/90

5.2.7 Verify the UV RESET SWITCH is illuminated.

DWH / 3/29/90

NOTE
Step 5.2.11 will occur approximately 15 seconds after step 5.2.8 is performed. Start the stopwatch at step 5.2.8

5.2.8 Depress the UV RESET SWITCH.

DWH / 3/29/90

5.2.9 Verify relays K317 and X306 de-energize.

DWH / 3/29/90

5.2.10 Verify the UV RESET SWITCH is not illuminated.

DWH / 3/29/90

5.2.11 Verify relay K317 energizes approximately 15 seconds after the UV RESET SWITCH was depressed.

Dwlt / 3/29/90

5.2.12 Verify relay K306 energizes and the UV RESET SWITCH illuminates approximately 60 seconds after the UV RESET SWITCH was depressed.

Dwlt / 3/29/90

NOTE

Step 5.2.16 will occur approximately 15 seconds after step 5.2.13 is performed. Start the stopwatch at step 5.2.13.

5.2.13 Momentarily energize relay K311.

Dwlt / 3/29/90

5.2.14 Verify relays K317 and K306 de-energize.

Dwlt / 3/29/90

5.2.15 Verify the UV RESET SWITCH is not illuminated.

Dwlt / 3/29/90

5.2.16 Verify relay K317 energizes approximately 15 seconds after relay K311 is energized.

Dwlt / 3/29/90

5.2.17 Verify relay K306 energizes and the UV RESET SWITCH illuminates approximately 60 seconds after relay K311 is energized.

Dwlt / 3/29/90

5.3.6 Verify that the Sequencer does not reset by observing the Elapsed Timer does not restart from 0.

DWH / 3/29/90

5.3.7 Remove the jumper from 1TB51-1 to 1TB51-3.

DWH / 3/27/90

MZJ / 3/29/90
IVOR

5.3.8 After the UV RESET SWITCH illuminates, push the UV RESET SWITCH to stop the timer.

DWH / 3/29/90

Section 5.3 Complete

DWH
sign

3/29/90
date

6.0 RESTORATION

6.1 Inform the Unit One Shift Supervisor of the completion of this test and 1AA02 may be returned to service.

6.2 Remove all test equipment.

DWH / 3/27/90

1) VOM connected to relay K317

DWH / 3/29/90

MZJ / 3/29/90
IVOR

2) VOM connected to relay K306

DWH / 3/29/90

MZJ / 3/29/90
IVOR

3) Power supply connected to relay K311

DLH / 3/29/90
MZF / 3/29/90
IVOR

6.3 Verify K311 is installed correctly.

DLH / 3/29/90
MZF / 3/29/90
IVOR

7.0 ACCEPTANCE CRITERIA

7.1 All steps have been completed satisfactorily.

DLH / 3/29/90

Quality Control Inspection Report

VOGTLE GENERATING PLANT—UNITS 1 & 2

34222

Page 1 of 1

MWO/ODR/DR No. 18903678	Building CONTROL	Procedure/Spec. No./Rev. T-ENG-90-15 Rev 0
Room Nr./Level No. 7A-48 LEVEL A	Sys./Start-Up Designator	Tag No. 1A0205
Drawing No./Rev. N/A	Vendor Manual Log No. N/A	Other N/A

- Inspector will use separate form for each completed inspection function(s) and insert original with work package, use continuation sheets when needed.
- Use simple narrative type report procedure. Reference all applicable drawing numbers, specifications, special instructions, etc., connected with your inspection. Use sketches, when applicable, showing dimensions checked, alignment, physical location of defects found, etc. N/A all blocks not used.
- Upon completion of the inspection activity, enter results below and sign and date.

Remarks *Method VISUAL*

VERIFIED 1A0205 PRCF NORM INCH BREATHER CLOSED WHEN UNIT ONE TRAIN # SEQUENCER FUNCTIONAL TEST WAS PERFORMED DEP-88-V170070

Sketch

N/A

Inspection Results

SAT. UNSAT—ODR/DR NO.(S):

95-33-9D
 Patsy Co. 3-31-90
 Notes Akum Plant Out 44

42

TR	STATUS	ELAPSED	MSEC	VOOITL	UNIT	NO.2	20 MAR 90
TR	LT-0539						
TR	LT-0553						
TR	LT-0537						
TR	LT-0548						
TR	LT-0547						
TR	LT-0554						
TR	LT-0548						
TR	LT-0517						
TR	LT-0538						
TR	LT-0549						
TR	LT-0549						

TR	STATUS	ELAPSED	MSEC	VOOITL	UNIT	NO.2	20 MAR 90
TR	EMERGENCY	0.					
TR	TRIP	26.				55:3	
TR	TRIP	35.				55:23	
TR	TRIP	40.				55:32	
TR	INACTON	46.				55:44	
TR	OPEN	60.				55:72	
TR	OPEN	71.					
TR	TRIP	77.					
TR	OPEN	89.					
TR	INACTON	94.					
TR	OPEN	99.					
TR	OPEN	103.					
TR	OPEN	104.					
TR	TRIPPED	119.					
TR	CLOSED	162.					
TR	CLOSED	167.					
TR	CLOSED	189.					
TR	CLOSED	189.					
TR	TRIP	239.					
TR	RESET	245.					
TR	CLOSED	343.					
TR	RESET	370.					
TR	CLOSED	373.					
TR	CLOSED	381.					
TR	CLOSED	396.					
TR	CLOSED	399.					
TR	CLOSED	400.					
TR	CLOSED	408.					
TR	CLOSED	457.					
TR	RESET	519.					
TR	RESET	537.					
TR	TRIP	596.					
TR	RESET	614.					
TR	FAILURE	624.					
TR	RUNNING	741.					
TR	TRIP	741.					

1044 CRAC 4 85.50

RS: 51 - By your check area
 #1241 RCB all

SEQUENCE OF EVENTS TRIP TIME 83 08:19:53:3

SEQ. OF EVTS.	TRIP TIME	STATUS	ELAPSED	MSEC	VOOITL	UNIT	NO.2
01. 60Hz	08:19:53:3	TRIP	0.				
02. 60Hz	08:19:53:3	TRIP	26.				
03. 60Hz	08:19:53:3	TRIP	35.				
04. 60Hz	08:19:53:3	TRIP	40.				
05. 60Hz	08:19:53:3	INACTON	46.				
06. 60Hz	08:19:53:3	OPEN	60.				
07. 60Hz	08:19:53:3	OPEN	71.				
08. 60Hz	08:19:53:3	TRIP	77.				
09. 60Hz	08:19:53:3	OPEN	89.				
10. 60Hz	08:19:53:3	INACTON	94.				
11. 60Hz	08:19:53:3	OPEN	99.				
12. 60Hz	08:19:53:3	OPEN	103.				
13. 60Hz	08:19:53:3	OPEN	104.				
14. 60Hz	08:19:53:3	TRIPPED	119.				
15. 60Hz	08:19:53:3	CLOSED	162.				
16. 60Hz	08:19:53:3	CLOSED	167.				
17. 60Hz	08:19:53:3	CLOSED	189.				
18. 60Hz	08:19:53:3	CLOSED	189.				
19. 60Hz	08:19:53:3	TRIP	239.				
20. 60Hz	08:19:53:3	RESET	245.				
21. 60Hz	08:19:53:3	CLOSED	343.				
22. 60Hz	08:19:53:3	RESET	370.				
23. 60Hz	08:19:53:3	CLOSED	373.				
24. 60Hz	08:19:53:3	CLOSED	381.				
25. 60Hz	08:19:53:3	CLOSED	396.				
26. 60Hz	08:19:53:3	CLOSED	399.				
27. 60Hz	08:19:53:3	CLOSED	400.				
28. 60Hz	08:19:53:3	CLOSED	408.				
29. 60Hz	08:19:53:3	CLOSED	457.				
30. 60Hz	08:19:53:3	RESET	519.				
31. 60Hz	08:19:53:3	RESET	537.				
32. 60Hz	08:19:53:3	TRIP	596.				
33. 60Hz	08:19:53:3	RESET	614.				
34. 60Hz	08:19:53:3	FAILURE	624.				
35. 60Hz	08:19:53:3	RUNNING	741.				
36. 60Hz	08:19:53:3	TRIP	741.				

SEQ. OF EVTS. 202211 4.16KV BUS 28A05 ALT INCR BRKR CLOSED 976.

08121 TGR STAT SLOT 7 DEVIATION AVG = 1.59.6 DEGF HI LIM 147.1 DEGF
 SEQ. OF EVTS. 202299 WPK FW PMP 3 RUNNING 1653.
 LO LIM 133.1 DEGF

SEQ. OF EVTS. 202301 EPC REG OVERSPEED TRIP TRIPPED 2776.
 SEQ. OF EVTS. 202304 EPC 60 RT HOUSE FUMER NORMAL 2791.
 SEQ. OF EVTS. 202308 EPC ELECTRICAL MALFUNCTION TRIP 2791.
 SEQ. OF EVTS. 202301 EPC LOSS OF 24VDC POWER RESET 2782.
 SEQ. OF EVTS. 202306 EPC COMBINED TRIP BUS TRIP 2783.
 SEQ. OF EVTS. 202301 EPC FAST CLOSING IV SIGNAL INACTION 2827.

SEQ. OF EVTS. 202301 EPC GEN LOSS OF STATOR CLO PRE-TRIP 2848.

25001 13002 13004 13005 13006 13007 13008 13009 13010 13011 13012
 SEQ. OF EVTS. 212802 GENREX ONLY REG MANUAL 7733.
 130. 137. 134. 155. 152. 154. 152. 157.
 SEQ. OF EVTS. 202794 4.16KV BUS 28A03 DG B BRKR 19 CLOSED 7875.

SEQ. OF EVTS. 202797 AUX TW PMP 2 RUNNING 28443.

END SEQUENCE OF EVENTS PRINTOUT

13013 13014 13015 13016 13017 13018 13019 13020 13021 13022 13023 13024

1 0811:45:0 SEQUENCE OF EVENTS TRIP TYPE => 08:19:55:03 STATUS ELAPSED MSEC VOOSTLE UNITY NO.2 20 MAR 90.
 135. 135. 137. 136. 146. 141. 139. 137. 134. 137. 137. 137.
 SEQ. OF EVTS. 200380 TRIP 1 P9 CAUSE RE TR 0. 55.5

13025 13026 13027 13028 13029 13030 13031 13032 13033 13034 13035 13036
 131. 139. 137. 141. 135. 141. 140. 139. XXXXX 135. 138. 139. 139.

SEQ. OF EVTS. 202915 XFMR 28A00X FDR BRKR 28A00X TRIP 130.
 13037 13038 13039 13040 13041 13042 13043 13044 13045 13046 13047 13048
 147. 145. 147. 138. 137. 137. 137. 140. 142. 141. 128. 128.

13049 13050 13051 13052 13053 13054 13055 13056 13057 13058 13059 13060
 140. 137. 135. 136. 135. 140. 140. 141. 135. 137. 136. 137.
 SEQ. OF EVTS. 200007 RX MAIN TRIP BRKR B TR 66. 65.1

SEQ. OF EVTS. 200006 RX MAIN TRIP BRKR A TR 103.

13061 13062 13063 13064 13065 13066 13067 13068 13069 13070 13071 13072
 136. 139. 141. 141. 137. 133. 141. 141. 145. 134. 137. 143.

SEQ. OF EVTS. 200029 FWR RMC CHAN HI 0 RATE RE TR 502.
 SEQ. OF EVTS. 200390 TURB TRIP & P9 CAUSE RE NOT 512.
 SEQ. OF EVTS. 200324 RCP BUS UNDER V & P7 RELAY TR 592.
 SEQ. OF EVTS. 200425 REL LO FLOW 1/2 P7 RX TRIP TR 541.

SEQ. OF EVTS. 200438 PRZR LO PRESS & P7 TR 2216.
 SEQ. OF EVTS. 202915 XFMR 28A00X FDR BRKR 28A00X CLOSED 2134.
 SEQ. OF EVTS. 200428 PRZR LO PRESS & P7 NOT TR 3538.

SEQ. OF EVTS. 200427 PRZR LO PRESS & P7 TR 7208.
 SEQ. OF EVTS. 200447 5TH GEN 2 LO-LO LEVEL TRIP TR 7356.
 SEQ. OF EVTS. 200467 5TH GEN 3 LO-LO LEVEL TRIP TR 7445.
 SEQ. OF EVTS. 200487 5TH GEN 4 LO-LO LEVEL TRIP TR 7528.

SEQ. OF EVTS. 200495 PRZR LO PRESS & P7 TR 7586.
 SEQ. OF EVTS. 200498 PRZR LO PRESS & P7 NOT TR 14191.
 SEQ. OF EVTS. 200500 PRZR LO PRESS & P7 TR 19894.

T3013 T3014 T3015 T3016 T3017 T3018 T3019 T3020 T3021 T3022 T3023 T3024
 117. 118. 117. 122. 120. 121. 120. 119. 119. 115. 119. 119.

T3025 T3026 T3027 T3028 T3029 T3030 T3031 T3032 T3033 T3034 T3035 T3036
 110. 119. 120. 125. 117. 119. 120. 118. XXXXB 117. 120. 126.

T3037 T3038 T3039 T3040 T3041 T3042 T3043 T3044 T3045 T3046 T3047 T3048
 127. 126. 128. 119. 118. 118. 119. 120. 123. 124. 116. 109.

T3049 T3050 T3051 T3052 T3053 T3054 T3055 T3056 T3057 T3058 T3059 T3060
 120. 126. 116. 118. 118. 118. 120. 133. 119. 117. 118. 117.

T3061 T3062 T3063 T3064 T3065 T3066 T3067 T3068 T3069 T3070 T3071 T3072
 117. 121. 119. 123. 118. 116. 120. 121. 131. 116. 118. 121.

68 TIME 01118V U118H U118D
 68 MW RM
 68 08:51:12 0 3407 34035

J 08:59:21:4 SEQUENCE OF EVENTS TRIP TIME => 08:58:14.8 STATUS ELAPSED MSEC VIGGILE UNIT NO.2 20 PAR 50A
 SEQ. OF EVTS. PD2021 ERC LOW ETS PRESS TRIP RESET 0.
 SEQ. OF EVTS. PD2021 ERC LOW ETS PRESS TRIP TRIPPED 7.
 END SEQUENCE OF EVENTS PRINTOUT

68 TIME 01118V U118H U118D
 68 MW RM
 68 09:01:17 0 1183 34035
 68 TIME 01118V U118H U118D
 68 MW RM
 68 09:11:11 0 1183 34035

J 09:13:32:1 SEQUENCE OF EVENTS TRIP TIME => 09:12:25:1 STATUS ELAPSED MSEC VIGGILE UNIT NO.2 20 PAR 50A
 SEQ. OF EVTS. YD2040 TURNING GEAR MOTOR CONTROL LOCAL 8408.
 SEQ. OF EVTS. YD2040 TURNING GEAR MOTOR CONTROL REMOTE 14133.
 END SEQUENCE OF EVENTS PRINTOUT

09:16 YGR STAY SLOT Y DEVIATION AVG = 116.7 DEGE HI LIM 123.8 DEGE
 LO LIM 109.8 DEGE

T3001 T3002 T3003 T3004 T3005 T3006 T3007 T3008 T3009 T3010 T3011 T3012
 115. 115. 110. 114. 114. 112. 132. 134. 133. 130. 130. 135.

T3013 T3014 T3015 T3016 T3017 T3018 T3019 T3020 T3021 T3022 T3023 T3024
 115. 115. 115. 119. 117. 118. 117. 116. 115. 111. 115. 115.

T3025 T3026 T3027 T3028 T3029 T3030 T3031 T3032 T3033 T3034 T3035 T3036
 107. 115. 116. 121. 114. 114. 116. 115. XXXXB 113. 116. 116. 118.

Elect Stat rep

IRF - Printer Lost Power

09:13:00	Z09420	SPRAY ADDITIVE TANK OUTLET TRAIN B CLOSED
09:13:05	Z09420	SPRAY ADDITIVE TANK OUTLET TRAIN B OFF
09:13:18	Z09420	SPRAY ADDITIVE TANK OUTLET TRAIN B NOT OFF
09:13:25	Z09420	SPRAY ADDITIVE TANK OUTLET TRAIN B CLOSED
09:17:15	Z09547	ELEC SWGR & MCC RM LEVEL I TRAIN A COOLER OFF
09:17:50	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER ON
09:25:45	Z09543	ELEC SWGR & MCC RM LEVEL E TRAIN A COOLER OFF
09:39:13	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER ON
09:47:35	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER ON
09:52:02	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN 7 COOLER OFF
10:01:55	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER OFF
10:08:25	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER ON
10:19:55	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER OFF
10:41:40	Z09543	ELEC SWGR & MCC RM LEVEL I TRAIN B COOLER ON
10:43:03	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER ON
10:46:25	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER ON
10:48:50	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER OFF
10:50:23	Z09543	ELEC SWGR & MCC RM LEVEL I TRAIN B COOLER OFF
10:51:00	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER OFF
11:08:40	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER ON
11:09:35	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER ON
11:16:13	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER OFF
11:20:45	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER OFF
11:36:25	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER ON
11:42:55	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER OFF
11:48:10	Z09549	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER ON
12:01:53	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER OFF
12:02:53	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER ON
12:08:58	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER OFF
12:27:28	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER ON
12:32:18	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER ON
12:38:56	Z09547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER OFF
12:45:03	Z09543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER OFF

13:09:30	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	ON
13:09:30	03/19/90	ZD9327	BORIC ACID TO CHARGING PUMP B	OPEN
13:09:30	03/19/90	ZD9329	BORIC ACID TO CHARGING PUMP B	NOT CLOSED
13:09:33	03/19/90	ZD9327	BORIC ACID TO CHARGING PUMP B	NOT OPEN
13:09:33	03/19/90	ZD9328	BORIC ACID TO CHARGING PUMP B	CLOSED
13:14:50	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
13:18:50	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
13:27:20	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	OFF
13:34:45	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
13:40:30	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
13:41:38	03/19/90	ZD8726	BORIC ACID TRANSFER PUMP TRAIN B	RUNNING
13:41:45	03/19/90	ZD9327	BORIC ACID TO CHARGING PUMP B	OPEN
13:41:45	03/19/90	ZD9328	BORIC ACID TO CHARGING PUMP B	NOT CLOSED
13:41:48	03/19/90	ZD9327	BORIC ACID TO CHARGING PUMP B	NOT OPEN
13:41:48	03/19/90	ZD9328	BORIC ACID TO CHARGING PUMP B	CLOSED
13:58:30	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
14:01:58	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
14:03:28	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	ON
14:15:53	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
14:19:33	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
14:19:45	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	OFF
14:32:50	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
14:36:35	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
14:47:35	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
14:50:53	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	ON
14:51:55	03/19/90	ZD9553	ELEC SWGR & MCC RM LEVEL I TRAIN B COOLER	ON
14:54:28	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
15:03:53	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	OFF
15:09:10	03/19/90	ZD9553	ELEC SWGR & MCC RM LEVEL I TRAIN B COOLER	OFF
15:09:28	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
15:18:43	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
15:31:03	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	ON

15:47:05	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
16:05:23	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	OFF
16:06:59	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
16:14:58	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
16:35:40	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
16:44:55	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
16:52:79	03/19/90	ZD9547	FLEC SWGR & MCC RM LEVEL C TRAIN A COOLER	ON
17:07:53	03/19/90	ZD9543	FLEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
17:14:09	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
17:23:28	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	OFF
17:31:23	03/19/90	ZD9449	NSCW TOWER A BLOWDOWN	NOT CLOSED
17:39:35	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
17:39:45	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
17:53:59	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
18:04:13	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	OFF
18:13:08	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	ON
18:28:46	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
18:28:53	03/19/90	ZD9553	ELEC SWGR & MCC RM LEVEL I TRAIN B COOLER	ON
18:33:15	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	OFF
18:35:29	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
18:45:48	03/19/90	ZD9553	ELEC SWGR & MCC RM LEVEL I TRAIN B COOLER	OFF
18:54:36	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
18:59:36	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
19:11:29	03/19/90	ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	ON
19:15:48	03/19/90	ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON
19:16:17	03/19/90	ZD9120	PRESSURIZER LIQUID SPACE SAMPLE TRN A	NOT CLOSED
19:16:17	03/19/90	ZD9122	PRESSURIZER LIQUID SPACE SAMPLE TRN B	NOT CLOSED
19:21:00		ZD9547	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER	OFF
19:29:13		ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	OFF
19:33:37		ZD9543	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER	ON

207106 VLV 1506 TO CONDENSER A CLOSED

207107 VLV 1506 TO CONDENSER B CLOSED

207108 VLV 1506 TO CONDENSER C CLOSED

207109 VLV 1506 TO CONDENSER D CLOSED

207110 VLV 1506 TO CONDENSER E CLOSED

207111 VLV 1506 TO CONDENSER F CLOSED

207112 VLV 1506 TO CONDENSER G CLOSED

207113 VLV 1506 TO CONDENSER H CLOSED

207114 VLV 1506 TO CONDENSER I CLOSED

207115 VLV 1506 TO CONDENSER J CLOSED

207116 VLV 1506 TO CONDENSER K CLOSED

207117 VLV 1506 TO CONDENSER L CLOSED

207118 VLV 1506 TO CONDENSER M CLOSED

207119 VLV 1506 TO CONDENSER N CLOSED

207120 VLV 1506 TO CONDENSER O CLOSED

207121 VLV 1506 TO CONDENSER P CLOSED

207122 VLV 1506 TO CONDENSER Q CLOSED

207123 VLV 1506 TO CONDENSER R CLOSED

207124 VLV 1506 TO CONDENSER S CLOSED

207125 VLV 1506 TO CONDENSER T CLOSED

207126 VLV 1506 TO CONDENSER U CLOSED

207127 VLV 1506 TO CONDENSER V CLOSED

207128 VLV 1506 TO CONDENSER W CLOSED

207129 VLV 1506 TO CONDENSER X CLOSED

207130 VLV 1506 TO CONDENSER Y CLOSED

207131 VLV 1506 TO CONDENSER Z CLOSED

Types Lost Power



Types Lost Power }
}

08122126	08122127	08122128	08122129	08122130	08122131	08122132	08122133	08122134	08122135	08122136	08122137	08122138	08122139	08122140	08122141	08122142	08122143	08122144	08122145	08122146	08122147	08122148	08122149
ZB847	ZB848	ZB849	ZB850	ZB851	ZB852	ZB853	ZB854	ZB855	ZB856	ZB857	ZB858	ZB859	ZB860	ZB861	ZB862	ZB863	ZB864	ZB865	ZB866	ZB867	ZB868	ZB869	ZB870
1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500
UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP	UP
TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A	TRAIN A
NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN	NOT OPEN



88:50:18.018 03/20/90

21337 F0610 TO CHARGING PUMP F NOT CLOSED

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F CLOSED

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

21337 F0610 TO CHARGING PUMP F NOT OPEN

88:50:18.018

03/20/90



Manual - per RP Smith



Manual per RP Smith

09:48:13 03/20/90 709406 MD AUX FEED PUMP B MINIFLOW VALVE CLOSED

09:48:13	03/20/90	709406 MD AUX FEED PUMP B MINIFLOW VALVE	NOT OPEN
09:48:13	03/20/90	709406 MD AUX FEED PUMP B MINIFLOW VALVE	CLOSED
09:49:01.302	03/20/90	Z08551 PRESSURIZER HEATERS CONTROL GROUP C	ON
09:50:17.060	03/20/90	Z08552 PRESSURIZER HEATERS BACKUP GROUP A	ON
09:50:17.060	03/20/90	Z08553 PRESSURIZER HEATERS BACKUP GROUP B	ON
09:50:17.073	03/20/90	Z08554 PRESSURIZER HEATERS BACKUP GROUP D	ON
09:50:48.028	03/20/90	Z08552 PRESSURIZER HEATERS BACKUP GROUP A	OFF
09:50:48.041	03/20/90	Z08553 PRESSURIZER HEATERS BACKUP GROUP B	OFF
09:50:48.048	03/20/90	Z08554 PRESSURIZER HEATERS BACKUP GROUP D	OFF
09:53:41.199	03/20/90	709406 MD AUX FEED PUMP B DISCH VALV TO S02	CLOSED
09:53:44.557	03/20/90	Z08553 PRESSURIZER HEATERS BACKUP GROUP B	ON
09:53:44.560	03/20/90	Z08552 PRESSURIZER HEATERS BACKUP GROUP A	ON
09:53:44.573	03/20/90	Z08554 PRESSURIZER HEATERS BACKUP GROUP D	ON
09:53:45	03/20/90	709406 MD AUX FEED PUMP B MINIFLOW VALVE	NOT CLOSED
09:53:53	03/20/90	709405 MD AUX FEED PUMP B MINIFLOW VALVE	OPEN
09:54:20.187	03/20/90	Z08552 PRESSURIZER HEATERS BACKUP GROUP A	OFF
09:54:20.190	03/20/90	Z08553 PRESSURIZER HEATERS BACKUP GROUP B	OFF
09:54:20.197	03/20/90	Z08554 PRESSURIZER HEATERS BACKUP GROUP D	OFF
09:59:43.266	03/20/90	Z08553 PRESSURIZER HEATERS BACKUP GROUP B	ON
09:59:43.274	03/20/90	Z08552 PRESSURIZER HEATERS BACKUP GROUP A	ON
09:59:43.282	03/20/90	Z08554 PRESSURIZER HEATERS BACKUP GROUP D	ON
10:00:13.281	03/20/90	Z08552 PRESSURIZER HEATERS BACKUP GROUP A	OFF
10:00:13.294	03/20/90	Z08554 PRESSURIZER HEATERS BACKUP GROUP D	OFF
10:00:13.306	03/20/90	Z08553 PRESSURIZER HEATERS BACKUP GROUP B	OFF
10:06:27.751	03/20/90	Z08553 PRESSURIZER HEATERS BACKUP GROUP B	ON
10:06:27.753	03/20/90	Z08552 PRESSURIZER HEATERS BACKUP GROUP A	ON
10:06:27.765	03/20/90	Z08554 PRESSURIZER HEATERS BACKUP GROUP D	ON
10:07:03.554	03/20/90	Z08552 PRESSURIZER HEATERS BACKUP GROUP A	OFF
10:07:03.564	03/20/90	Z08554 PRESSURIZER HEATERS BACKUP GROUP D	OFF
10:07:03.572	03/20/90	Z08553 PRESSURIZER HEATERS BACKUP GROUP B	OFF

10:08:23	03/20/90	Z0853	ELL 5604 A MW PUMP LEVEL 1 100% B 100% ON
10:10:21.823	03/20/90	Z0852	PRESSURIZER HEATERS BACKUP GROUP A ON
10:10:31.823	03/20/90	Z0853	PRESSURIZER HEATERS BACKUP GROUP B ON
10:10:31.837	03/20/90	Z0854	PRESSURIZER HEATERS BACKUP GROUP D ON
10:11:07.222	03/20/90	Z0852	PRESSURIZER HEATERS BACKUP GROUP A OFF
10:11:07.225	03/20/90	Z0854	PRESSURIZER HEATERS BACKUP GROUP D OFF
10:11:07.241	03/20/90	Z0853	PRESSURIZER HEATERS BACKUP GROUP B OFF
10:14:28	03/20/90	Z0873	AUX FW PUMP HOUSE TRAIN A SUPPLY FAN ON
10:15:10	03/20/90	Z0873	AUX FW PUMP HOUSE TRAIN A SUPPLY FAN OFF
10:15:25.197	03/20/90	Z0853	PRESSURIZER HEATERS BACKUP GROUP B ON
10:15:25.198	03/20/90	Z0852	PRESSURIZER HEATERS BACKUP GROUP A ON
10:15:25.212	03/20/90	Z0854	PRESSURIZER HEATERS BACKUP GROUP D ON
10:15:25.910	03/20/90	Z0852	PRESSURIZER HEATERS BACKUP GROUP A OFF
10:15:25.923	03/20/90	Z0854	PRESSURIZER HEATERS BACKUP GROUP D OFF
10:15:25.929	03/20/90	Z0853	PRESSURIZER HEATERS BACKUP GROUP B OFF
10:21:49.844	03/20/90	Z0852	PRESSURIZER HEATERS BACKUP GROUP A ON
10:21:49.844	03/20/90	Z0853	PRESSURIZER HEATERS BACKUP GROUP B ON
10:21:49.860	03/20/90	Z0854	PRESSURIZER HEATERS BACKUP GROUP D ON
10:22:22.920	03/20/90	Z0853	PRESSURIZER HEATERS BACKUP GROUP B OFF
10:22:22.929	03/20/90	Z0852	PRESSURIZER HEATERS BACKUP GROUP A OFF
10:22:22.941	03/20/90	Z0854	PRESSURIZER HEATERS BACKUP GROUP D OFF
10:25:28	03/20/90	Z0877	AUX FW PUMP HOUSE TRAIN B SUPPLY FAN ON
10:26:25	03/20/90	Z0877	AUX FW PUMP HOUSE TRAIN B SUPPLY FAN OFF
10:26:27.715	03/20/90	Z0853	PRESSURIZER HEATERS BACKUP GROUP B ON
10:26:27.716	03/20/90	Z0852	PRESSURIZER HEATERS BACKUP GROUP A ON
10:26:27.731	03/20/90	Z0854	PRESSURIZER HEATERS BACKUP GROUP D ON
10:27:09.608	03/20/90	Z0853	PRESSURIZER HEATERS BACKUP GROUP B OFF
10:27:09.610	03/20/90	Z0852	PRESSURIZER HEATERS BACKUP GROUP A OFF
10:27:09.622	03/20/90	Z0854	PRESSURIZER HEATERS BACKUP GROUP D OFF
10:31:15	03/20/90	Z0873	AUX FW PUMP HOUSE TRAIN A SUPPLY FAN ON
10:31:55	03/20/90	Z0873	AUX FW PUMP HOUSE TRAIN A SUPPLY FAN OFF
10:33:20.228	03/20/90	Z0853	PRESSURIZER HEATERS BACKUP GROUP B ON
10:33:20.231	03/20/90	Z0852	PRESSURIZER HEATERS BACKUP GROUP A ON

10:23:20.143	03/20/90	ZD954	PRESSURIZER HEATERS BACKUP GROUP B OFF
10:24:48.972	03/20/90	ZD953	PRESSURIZER HEATERS BACKUP GROUP B OFF
10:3:42.975	03/20/90	ZD952	PRESSURIZER HEATERS BACKUP GROUP A OFF
10:33:48.288	03/20/90	ZD954	PRESSURIZER HEATERS BACKUP GROUP D OFF
10:40:55	03/20/90	ZD957	AUX FW PUMP HOUSE TRAIN B SUPPLY FAN ON
10:41:53.076	03/20/90	ZD953	PRESSURIZER HEATERS BACKUP GROUP B ON
10:41:53.090	03/20/90	ZD952	PRESSURIZER HEATERS BACKUP GROUP A ON
10:41:53.103	03/20/90	ZD954	PRESSURIZER HEATERS BACKUP GROUP D ON
10:41:55	03/20/90	ZD957	AUX FW PUMP HOUSE TRAIN B SUPPLY FAN OFF
10:42:24.172	03/20/90	ZD952	PRESSURIZER HEATERS BACKUP GROUP A OFF
10:42:24.187	03/20/90	ZD954	PRESSURIZER HEATERS BACKUP GROUP D OFF
10:42:24.207	03/20/90	ZD953	PRESSURIZER HEATERS BACKUP GROUP B OFF
10:43:23	03/20/90	ZD953	AUX FW PUMP HOUSE TRAIN A SUPPLY FAN ON
10:46:05	03/20/90	ZD953	AUX FW PUMP HOUSE TRAIN A SUPPLY FAN OFF
10:51:25	03/20/90	ZD943	ELEC SWGR & MCC RM LEVEL D TRAIN A COOLER OFF
10:53:45.163	03/20/90	ZD953	PRESSURIZER HEATERS BACKUP GROUP B ON
10:53:45.176	03/20/90	ZD952	PRESSURIZER HEATERS BACKUP GROUP A ON
10:53:45.183	03/20/90	ZD954	PRESSURIZER HEATERS BACKUP GROUP D ON
10:54:13.575	03/20/90	ZD953	PRESSURIZER HEATERS BACKUP GROUP B OFF
10:54:13.588	03/20/90	ZD952	PRESSURIZER HEATERS BACKUP GROUP A OFF
10:54:13.597	03/20/90	ZD954	PRESSURIZER HEATERS BACKUP GROUP D OFF
10:54:23	03/20/90	ZD957	AUX FW PUMP HOUSE TRAIN B SUPPLY FAN ON
10:55:28	03/20/90	ZD957	AUX FW PUMP HOUSE TRAIN B SUPPLY FAN OFF
10:56:28	03/20/90	ZD953	ELEC SWGR & MCC RM LEVEL I TRAIN B COOLER OFF
10:59:03	03/20/90	ZD953	AUX FW PUMP HOUSE TRAIN A SUPPLY FAN ON
10:59:45	03/20/90	ZD953	AUX FW PUMP HOUSE TRAIN A SUPPLY FAN OFF
11:00:16.573	03/20/90	ZD956	CIRCULATING WATER PUMP 2 STOPPED
11:00:43	03/20/90	ZD954	ELEC SWGR & MCC RM LEVEL C TRAIN A COOLER OFF

03:17:51 CLEARLY L.A. 15 ASSIGNED 5 TEN 4 AND 19 (04 TREND
 03:17:54 ALARM ZD4000 FROTUS/REF TIME SYNC BID
 03:17:57 RETURN ZD4000 FROTUS/REF TIME SYNC BID
 08:16:51 1.601 NEW TRAIN 6 SUPPLY A/B 67.3 DEFE
 08:16:51 1.601 NEW TRAIN 6 SUPPLY A/B 67.3 DEFE
 08:16:51 1.601 NEW TRAIN 6 SUPPLY A/B 67.3 DEFE

TIME	DESCRIPTION	STATUS	STEPS	VOLTAGE
08:17:50	HIR 10 LEAKIN FLOW	TRIP	1, 28	1.60 VOLTAGE
08:17:52	HIR 10 LEAKIN FLOW	TRIP	2, 41	1.60 VOLTAGE
08:17:54	HIR 10 LEAKIN FLOW	TRIP	1, 28	1.60 VOLTAGE
08:17:56	HIR 10 LEAKIN FLOW	TRIP	1, 28	1.60 VOLTAGE
08:17:58	HIR 10 LEAKIN FLOW	TRIP	1, 28	1.60 VOLTAGE
08:18:00	GENERATING UNIT FRI DIFF	TRIP	1, 28	1.60 VOLTAGE
08:18:02	TURB HYD OIL LO PRESS 1	TRIP	1, 28	1.60 VOLTAGE
08:18:04	TURB HYD OIL LO PRESS 2	TRIP	1, 28	1.60 VOLTAGE
08:18:06	TURB HYD OIL LO PRESS 3	TRIP	1, 28	1.60 VOLTAGE
08:18:08	EHC LOW OIL PRESS TRIP	TRIP	1, 28	1.60 VOLTAGE
08:18:10	MEMO 2NAG03X TURB RROR 2NAG02	OPEN	156	225. STEPS
08:18:12	S/D ROD BK A GROUP 1 FOS I02	ENERGIZE	156	225. STEPS
08:18:14	EHC 125VDC TRIP BUS	TRIP	1, 28	1.60 VOLTAGE
08:18:16	EHC COMBINED TRIP BUS	TRIP	1, 28	1.60 VOLTAGE
08:18:18	TURB STOP VLV 2 SHUT RELAY	TRIP	1, 28	1.60 VOLTAGE
08:18:20	TURB STOP VLV 3 SHUT RELAY	TRIP	1, 28	1.60 VOLTAGE
08:18:22	TURB STOP VLV 4 SHUT RELAY	TRIP	1, 28	1.60 VOLTAGE
08:18:24	RK MAIN TRIP BRKR B	TRIP	1, 28	1.60 VOLTAGE
08:18:26	S/D ROD BK A GROUP 1 FOS M14	TRIP	1, 28	1.60 VOLTAGE
08:18:28	MN TURB SV 1 (CH1)	TRIP	1, 28	1.60 VOLTAGE
08:18:30	MN TURB SV 2	TRIP	1, 28	1.60 VOLTAGE
08:18:32	S/D ROD BK A GROUP 2 FOS R04	TRIP	1, 28	1.60 VOLTAGE
08:18:34	MN TURB SV 3 (CH2)	TRIP	1, 28	1.60 VOLTAGE
08:18:36	MN TURB SV 4 (CH3)	TRIP	1, 28	1.60 VOLTAGE
08:18:38	MN TURB SV 5	TRIP	1, 28	1.60 VOLTAGE
08:18:40	S/D ROD BK A GROUP 2 FOS D14	TRIP	1, 28	1.60 VOLTAGE
08:18:42	MN TURB SV 3	TRIP	1, 28	1.60 VOLTAGE
08:18:44	MN TURB EMERG BRG OIL PHP	RUNNING	1, 28	1.60 VOLTAGE
08:18:46	MN TURB REHEAT INTMD SV 3	CLOSED	1, 28	1.60 VOLTAGE
08:18:48	MN TURB REHEAT INTMD SV 4	CLOSED	1, 28	1.60 VOLTAGE
08:18:50	MN TURB REHEAT INTMD SV 5	CLOSED	1, 28	1.60 VOLTAGE
08:18:52	S/D ROD BK A GROUP 2 FOS P12	CLOSED	1, 28	1.60 VOLTAGE
08:18:54	MN TURB REHEAT INTMD SV 6	CLOSED	1, 28	1.60 VOLTAGE
08:18:56	MN TURB REHEAT IV 1	CLOSED	1, 28	1.60 VOLTAGE
08:18:58	MN TURB REHEAT IV 2	CLOSED	1, 28	1.60 VOLTAGE
08:19:00	S/D ROD BK A GROUP 2 FOS M02	CLOSED	1, 28	1.60 VOLTAGE
08:19:02	MN TURB REHEAT IV 2	CLOSED	1, 28	1.60 VOLTAGE
08:19:04	MN TURB REHEAT IV 4	CLOSED	1, 28	1.60 VOLTAGE
08:19:06	MN TURB REHEAT IV 5	CLOSED	1, 28	1.60 VOLTAGE
08:19:08	MN TURB REHEAT IV 6	CLOSED	1, 28	1.60 VOLTAGE
08:19:10	S/D ROD BK B GROUP 1 FOS G03	CLOSED	1, 28	1.60 VOLTAGE
08:19:12	MN TURB SV 1	CLOSED	1, 28	1.60 VOLTAGE
08:19:14	SAFETY SYS BY-PASSED TRAIN A	YES	1, 28	1.60 VOLTAGE
08:19:16	S/D B/B 100 VALVE	OPEN	9, 17	10.50 VOLTAGE
08:19:18	LP TURB A STAGE 12 TURB END EATR	STOPPED	12	225. STEPS
08:19:20	NORMAL AIR CHILLER 3	CLOSED	1, 28	1.60 VOLTAGE
08:19:22	S/D ROD BK B GROUP 1 FOS D02	OPEN	1, 28	1.60 VOLTAGE
08:19:24	NEW RETURN TO CLOG TRIN B	OPEN	1, 28	1.60 VOLTAGE
08:19:26	NEW RETURN TO CLOG TRIN B	OPEN	1, 28	1.60 VOLTAGE
08:19:28	4.100V BUS 2NAG05 NORM INTR BRKR	OPEN	1, 28	1.60 VOLTAGE
08:19:30	S/D ROD BK B GROUP 1 FOS A13	OPEN	0	225. STEPS
08:19:32	4.100V BUS 2NAG01 NORM INTR BRKR	OPEN	1, 28	1.60 VOLTAGE
08:19:34	4.100V BUS 2NAG06 NORM INTR BRKR	OPEN	1, 28	1.60 VOLTAGE
08:19:36	4.100V BUS 2NAG08 NORM INTR BRKR	OPEN	1, 28	1.60 VOLTAGE
08:19:38	4.100V BUS 2NAG09 ALT INTR BRKR	CLOSED	1, 28	1.60 VOLTAGE
08:19:40	4.100V BUS 2NAG04 NORM INTR BRKR	OPEN	1, 28	1.60 VOLTAGE
08:19:42	4.100V BUS 2NAG05 ALT INTR BRKR	OPEN	1, 28	1.60 VOLTAGE

Time	Alarm	Description	Status	Steps
03:10:20	ALARM	SWR 2BB16 INCH BRKR 2BB1601	NOT IR	225. STEPS
03:10:20	ALARM	FWR BNG CHAN 2 HI 0 LO SEIPI	NOT IR	225. STEPS
03:10:20	ALARM	FWR BNG CHAN 4 HI 0 LO SEIPI	NOT IR	225. STEPS
03:10:20	ALARM	MUC FWR 1 RX TRIP P2 PART	RESET	225. STEPS
03:10:20	ALARM	MUC FWR 2 RX TRIP P10 PART	RESET	225. STEPS
03:10:20	ALARM	MUC FWR 3 RX TRIP P10 PART	RESET	225. STEPS
03:10:20	ALARM	MUC FWR 4 RX TRIP P2 PART	RESET	225. STEPS
03:10:20	ALARM	MUC FWR 5 RX TRIP P2 PART	RESET	225. STEPS
03:10:20	ALARM	MUC FWR 6 RX TRIP P2 PART	RESET	225. STEPS
03:10:20	ALARM	MUC FWR 7 RX TRIP P2 PART	RESET	225. STEPS
03:10:20	ALARM	MUC FWR 8 RX TRIP P2 PART	RESET	225. STEPS
03:10:20	ALARM	MUC FWR 9 PERMISSIVE	RESET	225. STEPS
03:10:20	ALARM	S/D ROD BK B GROUP 2 POS J02	RESET	225. STEPS
03:10:20	ALARM	S/D ROD BK C GROUP 1 POS C11	RESET	225. STEPS
03:10:20	ALARM	MUC FWR 4 RX TRIP P10 PART	RESET	225. STEPS
03:10:20	ALARM	S/D ROD BK C GROUP 1 POS L13	IR	225. STEPS
03:10:20	ALARM	S/D ROD BK C GROUP 1 POS N02	IR	225. STEPS
03:10:20	ALARM	BOP 2 BUS UNDER V RELAY	IR	225. STEPS
03:10:20	ALARM	RCP 4 BUS UNDER V RELAY	IR	225. STEPS
03:10:20	ALARM	S/D ROD BK B GROUP 1 POS D05	ALARM	225. STEPS
03:10:20	ALARM	4.16KV BUS BRGD UNDERVOLTAGE	TR	225. STEPS
03:10:20	ALARM	RY MAIN TRIP BRKR 0	TR	225. STEPS
03:10:20	ALARM	S/D ROD BK E GROUP 1 POS E13	TRIP	225. STEPS
03:10:20	ALARM	ERC ELECTRICAL MALFUNCTION	TRIP	225. STEPS
03:10:20	ALARM	ERC FACY CLOSING TO E13NRL	TRIP	225. STEPS
03:10:20	ALARM	S/D ROD BK D GROUP 1 POS N11	TRIP	225. STEPS
03:10:20	ALARM	AUX SW FMR 3	RUNNING	225. STEPS
03:10:20	ALARM	S/D ROD BK E GROUP 1 POS D03	NOTEN	225. STEPS
03:10:20	ALARM	SS 2 B/T 125 VALVE	STOPPED	225. STEPS
03:10:20	ALARM	NSM SWF 2	STOPPED	225. STEPS
03:10:20	ALARM	S/D ROD BK E GROUP 1 POS H0W	STOPPED	225. STEPS
03:10:20	ALARM	NSM SWF 2	STOPPED	225. STEPS

TIME	DESCRIPTION	VALUE	UNIT	STATUS	SETPOINT	ALARM	REMARKS
08:20:01	GEN 14 AV3	584.01	589.50	DEGF			
08:20:01	MIN GEN STATOR CLG WTR OUT BAR 47	139.		DEGF			
08:20:01	CG 3 B/E 120 VALVE						
08:20:01	S/D ROD BK C GROUP 1 POS E03	0.	225.	STEPS			
08:20:01	S/D ROD BK A GROUP 1 POS F04	0.	225.	STEPS			
08:20:01	REL2 CH 11 FI-0425 FLOW	61.4	20.0	PC			
08:20:01	REL2 CH 11 FI-0425 FLOW	61.4	20.0	PC			
08:20:01	REL2 CH 11 FI-0424 FLOW	61.4	20.0	PC			
08:20:01	REL2 CH 11 FI-0424 FLOW	61.4	20.0	PC			
08:20:01	MEPT B HYDRAULIC AND BRO OIL	5.	14.	PSIG			
08:20:01	REL1 1 TAVG	582.2	589.5	DEGF			
08:20:02	13.8KV BUS 2NAB UNDERVOLTAGE						
08:20:02	5.18KV BUS 2NA04 UNDERVOLTAGE						
08:20:02	MSDT B DRN TO CNDSR						
08:20:02	HTR 1A DRN TO CNDSR						
08:20:02	HTR 1C DRN TO CNDSR						
08:20:02	CONDENSATE PMP C						
08:20:02	RPSM 14 TURBINE TRIP						
08:20:02	ROD ALARM CCO						
08:20:02	RCL4 CH III FI-0446 FLOW	57.1	90.0	PC			
08:20:02	RCL4 CH III FI-0446 FLOW	57.1	90.0	PC			
08:20:02	GEN HYDROGEN	-79	-50	VOLTAGE			
08:20:03	REL4 1 TAVG	582.03	589.50	DEGF			
08:20:03	REL4 OVERTEMP DELTA 1 1 SETPT	127.8	120.0	PC			
08:20:03	REL4 OVERTEMP DELTA 1 1 SETPT	127.8	120.0	PC			
08:20:03	HTR DRN PMP B FLOW	1.34	1.50	VOLTAJE			
08:20:03	MIN GEN STATOR CLG WTR OUT BAR 8	136.	139.	DEGF			
08:20:03	MIN GEN STATOR CLG WTR OUT BAR 32	137.	139.	DEGF			
08:20:03	MSDT A DRN TO CNDSR						
08:20:03	MSDT C DRN TO CNDSR						
08:20:03	HTR 1B DRN TO CNDSR						
08:20:03	STM GEN 2 LO-LO CH III LT-0528						
08:20:03	RCL2 DELTA 1 TILT	5678.2	3.2	PC			
08:20:03	RCL4 DELTA 1 TILT	5827.6	3.2	PC			
08:20:04	RCL CNIL MAX TAVG DEV FROM MEAS	-6.0	-3.0	DEGF			
08:20:04	MFP B SWLT	663.	635.	PSIG			
08:20:04	MFP A SWLT	2092.0	2100.0	PSIG			
08:20:04	MFP A SWLT	680.69	682.00	PSIG			
08:20:04	RCL1 OVERTEMP DELTA 1 1 SETPT	153.0	120.0	PC			
08:20:04	RCL1 OVERTEMP DELTA 1 1 SETPT	153.0	120.0	PC			
08:20:04	REL2 1 TAVG	578.05	589.50	DEGF			
08:20:04	MIN GEN 1 LO-LO CH III LT-0524						
08:20:04	MIN GEN 1 LO-LO CH III LT-0510						
08:20:04	STM GEN 1 LO-LO CH III LT-0505						


dl 5-5-80

3.183

08:22:47	SENSOR RETURN	T8052	CAB25 CLG RTD 2	19.18		
08:22:47	SENSOR RETURN	T8051	CAB25 CLG RTD 1	19.18		
08:22:42	RETURN	ZD2264	HTR 1C DRN TO CNDSR	CLOSED		
08:22:44	SENSOR RETURN	F2245	HTR 1A DRN TO CNDSR	11.28		
08:22:43	SENSOR RETURN	F2247	HTR 4B DRN TO CNDSR	11.28		
08:22:42	HI ALERT RETURN	W8088	HTR 1A DRN TO CNDSR			
08:22:30	ALARM	L80718	RMP 10 ROL 4			
08:22:30	ALARM	L80711	RMP 11 ROL 4			
08:22:30	ALARM	L80713	RMP 12 ROL 4			
08:22:30	ALARM	L80718	RMP 10 PRESSURIZER 1			
08:22:30	HI ALERT	F0237	HTR 25 DRN TO CNDSR			
08:22:32	ALARM	ZD2274	HTR 25 DRN TO CNDSR			
08:22:27	ALARM	ZD2297	HTR DRN TO CNDSR			
08:22:29	HI ALERT	F0237	RCP2 SEAL INJECTION WTR FLOW			
08:22:29	HI ALERT	F0231	RCP1 SEAL INJECTION WTR FLOW			
08:22:29	ALARM	L80507	RMP 07 ROL 4	ALARM		
08:22:29	RETURN	L80513	RMP 10 ROL 4	NORMAL		
08:22:29	RETURN	L80518	RMP 10 PRESSURIZER 1	NORMAL		
08:22:21	RETURN	F10489	FCR LO PRESS 2	NOT TR		
08:22:22	RETURN	F10486	FCR LO PRESS 2	NOT TR		
08:22:04	ALARM	ZD2147	MS BYPASS 1 TO CNDSR A	CLOSED		
08:22:04	ALARM	ZD2151	MS BYPASS 1 TO CNDSR C	CLOSED		
08:22:04	ALARM	ZD2153	MS BYPASS 2 TO CNDSR A	CLOSED		
08:22:04	ALARM	ZD2155	MS BYPASS 2 TO CNDSR B	CLOSED		
08:22:04	ALARM	ZD2501	RCP 1	ALARM		
08:22:04	ALARM	ZD2167	MS BYPASS 4 TO CNDSR B	CLOSED		
08:22:04	LO ALERT	T0426	RCL4 WIDE RNG COLD LEG TEMP	EXCEEDED		
08:22:04	LO ALERT	T0406	RCL1 WIDE RNG COLD LEG TEMP	EXCEEDED		
08:22:04	LO ALERT	T0406	RCL1 WIDE RNG COLD LEG TEMP	EXCEEDED		
08:22:00	ALARM	ZD2157	MS BYPASS 2 TO CNDSR C	CLOSED		
08:22:00	ALARM	ZD2159	MS BYPASS 3 TO CNDSR A	CLOSED		
08:22:00	ALARM	ZD2161	MS BYPASS 3 TO CNDSR B	CLOSED		
08:22:00	ALARM	ZD2163	MS BYPASS 3 TO CNDSR C	CLOSED		
08:22:00	ALARM	ZD2145	MS BYPASS 4 TO CNDSR A	CLOSED		
08:22:00	ALARM	ZD2149	MS BYPASS 4 TO CNDSR C	CLOSED		
08:22:07	HI ALERT	F2465	HTR DRN PMP A DISCH			
08:22:06	ALARM	ZD2241	AUX FW PMP 3 DISCH TO RAIN B	NORMAL		
08:22:00	HI ALERT	F0127	RCP2 SEAL INJECTION WTR FLOW			
08:22:00	HI ALERT	F0121	RCP1 SEAL INJECTION WTR FLOW			
08:22:00	ALARM	ZD2254	HTR 1B DRN TO CNDSR	CLOSED		
08:22:00	ALARM	ZD2243	AUX FW PMP 3 DISCH TO RAIN A	OPEN		
08:22:00	RETURN	ZD2274	HTR 25 DRN TO CNDSR	CLOSED		
08:22:00	LO ALERT RETURN	F0142	CHARGING PMP DISCH HOR PRESS	23.05	23.05	
08:22:00	LO RETURN	F0142	CHARGING PMP DISCH HOR PRESS	23.05	23.05	
08:22:10	LO ALERT RETURN	T0426	RCL2 WIDE RNG COLD LEG TEMP	22.12	22.12	
08:22:10	LO ALERT RETURN	T0406	RCL1 WIDE RNG COLD LEG TEMP	22.12	22.12	
08:22:11	LO ALERT RETURN	T3159	MN GEN STATOR CLG WTR OUT BAR 53	11.2	11.2	
08:22:12	LO ALERT RETURN	T3134	MN GEN STATOR CLG WTR OUT BAR 25	11.2	11.2	
08:22:12	LO ALERT RETURN	T3144	MN GEN STATOR CLG WTR OUT BAR 45	11.2	11.2	
08:22:12	HI ALERT	T3144	MN GEN STATOR CLG WTR OUT BAR 45	11.2	11.2	
08:22:12	LO ALERT RETURN	T3111	MN GEN STATOR CLG WTR OUT BAR 11	11.2	11.2	
08:22:12	RETURN	ZD2254	HTR 1A DRN TO CNDSR	CLOSED		
08:22:12	ALARM	ZD2245	AUX FW PMP 3 DISCH TO RAIN A	OPEN		
08:22:13	LO ALERT RETURN	T3135	MN GEN STATOR CLG WTR OUT BAR 25	11.2	11.2	
08:22:13	LO ALERT RETURN	T3165	MN GEN STATOR CLG WTR OUT BAR 65	11.2	11.2	
08:22:14	SENSOR LO ALARM	F2247	HTR 1C DRN TO CNDSR	11.28		
08:22:14	ALARM	ZD2339	AUX FW PMP 3 DISCH TO RAIN B	OPEN		
08:22:14	RETURN	ZD2147	MS BYPASS 1 TO CNDSR A	CLOSED		
08:22:14	RETURN	ZD2151	MS BYPASS 1 TO CNDSR C	CLOSED		
08:22:14	RETURN	ZD2153	MS BYPASS 2 TO CNDSR A	CLOSED		
08:22:14	RETURN	ZD2155	MS BYPASS 2 TO CNDSR B	CLOSED		
08:22:14	RETURN	ZD3501	RCP 1	ALARM		
08:22:14	RETURN	ZD2167	MS BYPASS 4 TO CNDSR B	CLOSED		

Time	Event	Code	Description	Alarm
09:29:13	ALARM	L00717	REFM 17 PAR AND HI FLUX RATE TR	ALARM
09:29:41	ALARM	T00350	MAN TURN EMERG BUS CTRL STOP	ALARM
09:29:51	HI ALERT RETURN	T3120	MAN DEN STATOR D-C WTS BUS TRM	ALARM
09:30:19	LO ALERT RETURN	L0420	RCL2 UNCLAMP FLOW 2277	ALARM
09:30:26	RETURN	L00717	RPSM 17 PAR AND HI FLUX RATE TR	ALARM
09:30:41	HI ALARM	F0452	RCL2 CH 111 FI-0334 FLGA	ALARM
09:31:21	ALARM	L00717	RPSM 17 PAR AND HI FLUX RATE TR	ALARM
09:31:26	HI RETURN	F0452	RCL2 CH 111 FI-0334 FLGA	ALARM
09:31:24	HI ALARM	F0452	RCL3 CH 111 FI-0434 FLGA	ALARM
09:32:12	RETURN	L00717	RPSM 17 PAR AND HI FLUX RATE TR	ALARM
09:32:22	HI ALARM	F0452	RCL3 CH 111 FI-0318 FLGA	ALARM
09:32:45	HI ALARM	F0452	RC 3 CH 111 FI-0328 FLGA	ALARM
09:33:19	ALARM	L00717	RPSM 17 PAR AND HI FLUX RATE TR	ALARM
09:34:26	HI RETURN	F0452	RCL3 CH 111 FI-0334 FLGA	ALARM
09:34:52	SENSOR RETURN	F2257	STR TR TRG12 FLOW	ALARM
09:37:16	ALARM	L00510	REF 10 BEL TAVG	ALARM
09:37:29	SENSOR LO ALARM	F4637	STR 33 REGRIN FLGA	ALARM
09:38:32	HI ALARM	F0452	RCL2 CH 111 FI-0476 FLGA	ALARM
09:38:40	LO ALARM	T0452	PRESSURE SURGE WINE TRM	ALARM

NO.	DESCRIPTION	DATE	AMOUNT	CHECK NO.	DEBIT	CREDIT	BALANCE
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



TOTAL 77.4
 DEBIT 77.4
 CREDIT
 BALANCE 0.00

PAID BY BANK OF AMERICA
 001 2007 1000 2240001

Account	Description	Amount	Balance
100000
100001
100002
100003
100004
100005
100006
100007
100008
100009
100010
100011
100012
100013
100014
100015
100016
100017
100018
100019
100020
100021
100022
100023
100024
100025
100026
100027
100028
100029
100030
100031
100032
100033
100034
100035
100036
100037
100038
100039
100040
100041
100042
100043
100044
100045
100046
100047
100048
100049
100050



DATE: 10/10/00
 TIME: 10:00 AM
 FROM: [unclear]
 TO: [unclear]

LINE	DESCRIPTION	UNIT	STATUS	REMARKS	TIME	REMARKS
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

05-33-90
Proteus Alarm print 01-02

08:16:14 ALARM 2 GROUP DISPLAY/ASSIGN/REVIEW
 08:16:17 RETURN 2 SELECTED: 50 & EQP 587
 08:16:18 BY 2 GROUP 22 SENSOR LO ALARM
 08:17:15 ALARM 22 SENSOR RETURN
 08:18:12 ALARM 22 SENSOR RETURN
 08:19:12 ALARM 22 SENSOR RETURN
 08:19:15 ALARM 22 SENSOR RETURN
 08:19:16 ALARM 22 SENSOR RETURN
 08:19:17 ALARM 22 SENSOR RETURN
 08:19:18 ALARM 22 SENSOR RETURN
 08:19:19 ALARM 22 SENSOR RETURN
 08:19:20 ALARM 22 SENSOR RETURN
 08:19:21 ALARM 22 SENSOR RETURN
 08:19:22 ALARM 22 SENSOR RETURN
 08:19:23 ALARM 22 SENSOR RETURN
 08:19:24 ALARM 22 SENSOR RETURN
 08:19:25 ALARM 22 SENSOR RETURN
 08:19:26 ALARM 22 SENSOR RETURN
 08:19:27 ALARM 22 SENSOR RETURN
 08:19:28 ALARM 22 SENSOR RETURN
 08:19:29 ALARM 22 SENSOR RETURN
 08:19:30 ALARM 22 SENSOR RETURN
 08:19:31 ALARM 22 SENSOR RETURN
 08:19:32 ALARM 22 SENSOR RETURN
 08:19:33 ALARM 22 SENSOR RETURN
 08:19:34 ALARM 22 SENSOR RETURN
 08:19:35 ALARM 22 SENSOR RETURN
 08:19:36 ALARM 22 SENSOR RETURN
 08:19:37 ALARM 22 SENSOR RETURN
 08:19:38 ALARM 22 SENSOR RETURN
 08:19:39 ALARM 22 SENSOR RETURN
 08:19:40 ALARM 22 SENSOR RETURN
 08:19:41 ALARM 22 SENSOR RETURN
 08:19:42 ALARM 22 SENSOR RETURN
 08:19:43 ALARM 22 SENSOR RETURN
 08:19:44 ALARM 22 SENSOR RETURN
 08:19:45 ALARM 22 SENSOR RETURN
 08:19:46 ALARM 22 SENSOR RETURN
 08:19:47 ALARM 22 SENSOR RETURN
 08:19:48 ALARM 22 SENSOR RETURN
 08:19:49 ALARM 22 SENSOR RETURN
 08:19:50 ALARM 22 SENSOR RETURN
 08:19:51 ALARM 22 SENSOR RETURN
 08:19:52 ALARM 22 SENSOR RETURN
 08:19:53 ALARM 22 SENSOR RETURN
 08:19:54 ALARM 22 SENSOR RETURN
 08:19:55 ALARM 22 SENSOR RETURN
 08:19:56 ALARM 22 SENSOR RETURN
 08:19:57 ALARM 22 SENSOR RETURN
 08:19:58 ALARM 22 SENSOR RETURN
 08:19:59 ALARM 22 SENSOR RETURN
 09:00:00 ALARM 22 SENSOR RETURN

TIME	DESCRIPTION	STATUS	LOCATION
08:16:14	ALARM 2 GROUP DISPLAY/ASSIGN/REVIEW	SELECTED: 50 & EQP 587	
08:17:15	SENSOR LO ALARM		HIR 1A DRAIN FLOW
08:18:12	SENSOR RETURN		HIR 1A DRAIN FLOW
08:19:12	SENSOR RETURN		HIR 1A DRAIN FLOW
08:19:15	SENSOR RETURN		HIR 1A DRAIN FLOW
08:19:16	SENSOR RETURN		GENERATING UNIT FRI DIFF
08:19:17	SENSOR RETURN		TURB HYD OIL LO PRESS 1
08:19:18	SENSOR RETURN		TURB HYD OIL LO PRESS 2
08:19:19	SENSOR RETURN		TURB HYD OIL LO PRESS 3
08:19:20	SENSOR RETURN		EHC LOW ETR PRESS TRIP
08:19:21	SENSOR RETURN		EHC 1-5VDC TRIP BUS
08:19:22	SENSOR RETURN		EHC 1-5VDC TRIP BUS
08:19:23	SENSOR RETURN		TURB STOP VLV 3 SHUT DOWN
08:19:24	SENSOR RETURN		TURB STOP VLV 4 SHUT DOWN
08:19:25	SENSOR RETURN		TRIP MAIN TRIP BRKR B
08:19:26	SENSOR RETURN		S/D ROD BK A GROUP 1 F05 F14
08:19:27	SENSOR RETURN		MN TURB SV 1 (CH1)
08:19:28	SENSOR RETURN		MN TURB SV 2
08:19:29	SENSOR RETURN		S/D ROD BK A GROUP 2 F05 B04
08:19:30	SENSOR RETURN		MN TURB SV 3 (CH2)
08:19:31	SENSOR RETURN		MN TURB SV 4 (CH3)
08:19:32	SENSOR RETURN		MN TURB SV 4
08:19:33	SENSOR RETURN		MN TURB SV 4 (CH4)
08:19:34	SENSOR RETURN		S/D ROD BK A GROUP 3 F05 D14
08:19:35	SENSOR RETURN		MN TURB CV 3
08:19:36	SENSOR RETURN		MN TURB EMERG BLO OIL FMP
08:19:37	SENSOR RETURN		MN TURB REHEAT INTMD SV 2
08:19:38	SENSOR RETURN		MN TURB REHEAT INTMD SV 4
08:19:39	SENSOR RETURN		MN TURB REHEAT INTMD SV 5
08:19:40	SENSOR RETURN		S/D ROD BK A GROUP 2 F05 F12
08:19:41	SENSOR RETURN		MN TURB REHEAT INTMD SV 6
08:19:42	SENSOR RETURN		M4 TURB REHEAT IV 1
08:19:43	SENSOR RETURN		M4 TURB REHEAT IV 2
08:19:44	SENSOR RETURN		S/D ROD BK A GROUP 3 F05 B02
08:19:45	SENSOR RETURN		MN TURB REHEAT IV 2
08:19:46	SENSOR RETURN		MN TURB REHEAT IV 2
08:19:47	SENSOR RETURN		MN TURB REHEAT IV 4
08:19:48	SENSOR RETURN		MN TURB REHEAT IV 2
08:19:49	SENSOR RETURN		MN TURB REHEAT IV 6
08:19:50	SENSOR RETURN		S/D ROD BK B GROUP 1 F05 G02
08:19:51	SENSOR RETURN		MN TURB CV 1
08:19:52	SENSOR RETURN		SAFETY SYS BY-PASSED TRIN A
08:19:53	SENSOR RETURN		S/D B/D 150 VALVE
08:19:54	SENSOR RETURN		LC TURB A STAGE 12 TRIP CALL
08:19:55	SENSOR RETURN		MONITOR TRIP CALLED
08:19:56	SENSOR RETURN		S/D ROD BK B GROUP 2 F05 C09
08:19:57	SENSOR RETURN		MN TURB CV 1
08:19:58	SENSOR RETURN		MN TURB CV 1
08:19:59	SENSOR RETURN		MN TURB CV 1
09:00:00	SENSOR RETURN		MN TURB CV 1

Code	Alarm Name	Description	Unit
0611	ALARM	HAI B HI BELL NEWS	TR
0811	ALARM	TURB STOP VLV 1	TR
0911	ALARM	RCF BUS UNDER V 3	TR
0912	ALARM	RCF BUS UNDER V 4	TR
0913	ALARM	RCF BUS UNDER V 5	TR
0914	ALARM	RCF BUS UNDER V 6	TR
0915	ALARM	RCF BUS UNDER V 7	TR
0916	ALARM	RCF BUS UNDER V 8	TR
0917	ALARM	RCF BUS UNDER V 9	TR
0918	ALARM	RCF BUS UNDER V 10	TR
0919	ALARM	RCF BUS UNDER V 11	TR
0920	ALARM	RCF BUS UNDER V 12	TR
0921	ALARM	RCF BUS UNDER V 13	TR
0922	ALARM	RCF BUS UNDER V 14	TR
0923	ALARM	RCF BUS UNDER V 15	TR
0924	ALARM	RCF BUS UNDER V 16	TR
0925	ALARM	RCF BUS UNDER V 17	TR
0926	ALARM	RCF BUS UNDER V 18	TR
0927	ALARM	RCF BUS UNDER V 19	TR
0928	ALARM	RCF BUS UNDER V 20	TR
0929	ALARM	RCF BUS UNDER V 21	TR
0930	ALARM	RCF BUS UNDER V 22	TR
0931	ALARM	RCF BUS UNDER V 23	TR
0932	ALARM	RCF BUS UNDER V 24	TR
0933	ALARM	RCF BUS UNDER V 25	TR
0934	ALARM	RCF BUS UNDER V 26	TR
0935	ALARM	RCF BUS UNDER V 27	TR
0936	ALARM	RCF BUS UNDER V 28	TR
0937	ALARM	RCF BUS UNDER V 29	TR
0938	ALARM	RCF BUS UNDER V 30	TR
0939	ALARM	RCF BUS UNDER V 31	TR
0940	ALARM	RCF BUS UNDER V 32	TR
0941	ALARM	RCF BUS UNDER V 33	TR
0942	ALARM	RCF BUS UNDER V 34	TR
0943	ALARM	RCF BUS UNDER V 35	TR
0944	ALARM	RCF BUS UNDER V 36	TR
0945	ALARM	RCF BUS UNDER V 37	TR
0946	ALARM	RCF BUS UNDER V 38	TR
0947	ALARM	RCF BUS UNDER V 39	TR
0948	ALARM	RCF BUS UNDER V 40	TR
0949	ALARM	RCF BUS UNDER V 41	TR
0950	ALARM	RCF BUS UNDER V 42	TR
0951	ALARM	RCF BUS UNDER V 43	TR
0952	ALARM	RCF BUS UNDER V 44	TR
0953	ALARM	RCF BUS UNDER V 45	TR
0954	ALARM	RCF BUS UNDER V 46	TR
0955	ALARM	RCF BUS UNDER V 47	TR
0956	ALARM	RCF BUS UNDER V 48	TR
0957	ALARM	RCF BUS UNDER V 49	TR
0958	ALARM	RCF BUS UNDER V 50	TR
0959	ALARM	RCF BUS UNDER V 51	TR
0960	ALARM	RCF BUS UNDER V 52	TR
0961	ALARM	RCF BUS UNDER V 53	TR
0962	ALARM	RCF BUS UNDER V 54	TR
0963	ALARM	RCF BUS UNDER V 55	TR
0964	ALARM	RCF BUS UNDER V 56	TR
0965	ALARM	RCF BUS UNDER V 57	TR
0966	ALARM	RCF BUS UNDER V 58	TR
0967	ALARM	RCF BUS UNDER V 59	TR
0968	ALARM	RCF BUS UNDER V 60	TR
0969	ALARM	RCF BUS UNDER V 61	TR
0970	ALARM	RCF BUS UNDER V 62	TR
0971	ALARM	RCF BUS UNDER V 63	TR
0972	ALARM	RCF BUS UNDER V 64	TR
0973	ALARM	RCF BUS UNDER V 65	TR
0974	ALARM	RCF BUS UNDER V 66	TR
0975	ALARM	RCF BUS UNDER V 67	TR
0976	ALARM	RCF BUS UNDER V 68	TR
0977	ALARM	RCF BUS UNDER V 69	TR
0978	ALARM	RCF BUS UNDER V 70	TR
0979	ALARM	RCF BUS UNDER V 71	TR
0980	ALARM	RCF BUS UNDER V 72	TR
0981	ALARM	RCF BUS UNDER V 73	TR
0982	ALARM	RCF BUS UNDER V 74	TR
0983	ALARM	RCF BUS UNDER V 75	TR
0984	ALARM	RCF BUS UNDER V 76	TR
0985	ALARM	RCF BUS UNDER V 77	TR
0986	ALARM	RCF BUS UNDER V 78	TR
0987	ALARM	RCF BUS UNDER V 79	TR
0988	ALARM	RCF BUS UNDER V 80	TR
0989	ALARM	RCF BUS UNDER V 81	TR
0990	ALARM	RCF BUS UNDER V 82	TR
0991	ALARM	RCF BUS UNDER V 83	TR
0992	ALARM	RCF BUS UNDER V 84	TR
0993	ALARM	RCF BUS UNDER V 85	TR
0994	ALARM	RCF BUS UNDER V 86	TR
0995	ALARM	RCF BUS UNDER V 87	TR
0996	ALARM	RCF BUS UNDER V 88	TR
0997	ALARM	RCF BUS UNDER V 89	TR
0998	ALARM	RCF BUS UNDER V 90	TR
0999	ALARM	RCF BUS UNDER V 91	TR
1000	ALARM	RCF BUS UNDER V 92	TR

Account No.	Description	Amount	Balance
110624	STIM GEN 1	100.00	100.00
110625	STIM GEN 2	100.00	200.00
110626	STIM GEN 3	100.00	300.00
110627	STIM GEN 4	100.00	400.00
110628	STIM GEN 5	100.00	500.00
110629	STIM GEN 6	100.00	600.00
110630	STIM GEN 7	100.00	700.00
110631	STIM GEN 8	100.00	800.00
110632	STIM GEN 9	100.00	900.00
110633	STIM GEN 10	100.00	1000.00
110634	STIM GEN 11	100.00	1100.00
110635	STIM GEN 12	100.00	1200.00
110636	STIM GEN 13	100.00	1300.00
110637	STIM GEN 14	100.00	1400.00
110638	STIM GEN 15	100.00	1500.00
110639	STIM GEN 16	100.00	1600.00
110640	STIM GEN 17	100.00	1700.00
110641	STIM GEN 18	100.00	1800.00
110642	STIM GEN 19	100.00	1900.00
110643	STIM GEN 20	100.00	2000.00
110644	STIM GEN 21	100.00	2100.00
110645	STIM GEN 22	100.00	2200.00
110646	STIM GEN 23	100.00	2300.00
110647	STIM GEN 24	100.00	2400.00
110648	STIM GEN 25	100.00	2500.00
110649	STIM GEN 26	100.00	2600.00
110650	STIM GEN 27	100.00	2700.00
110651	STIM GEN 28	100.00	2800.00
110652	STIM GEN 29	100.00	2900.00
110653	STIM GEN 30	100.00	3000.00
110654	STIM GEN 31	100.00	3100.00
110655	STIM GEN 32	100.00	3200.00
110656	STIM GEN 33	100.00	3300.00
110657	STIM GEN 34	100.00	3400.00
110658	STIM GEN 35	100.00	3500.00
110659	STIM GEN 36	100.00	3600.00
110660	STIM GEN 37	100.00	3700.00
110661	STIM GEN 38	100.00	3800.00
110662	STIM GEN 39	100.00	3900.00
110663	STIM GEN 40	100.00	4000.00
110664	STIM GEN 41	100.00	4100.00
110665	STIM GEN 42	100.00	4200.00
110666	STIM GEN 43	100.00	4300.00
110667	STIM GEN 44	100.00	4400.00
110668	STIM GEN 45	100.00	4500.00
110669	STIM GEN 46	100.00	4600.00
110670	STIM GEN 47	100.00	4700.00
110671	STIM GEN 48	100.00	4800.00
110672	STIM GEN 49	100.00	4900.00
110673	STIM GEN 50	100.00	5000.00
110674	STIM GEN 51	100.00	5100.00
110675	STIM GEN 52	100.00	5200.00
110676	STIM GEN 53	100.00	5300.00
110677	STIM GEN 54	100.00	5400.00
110678	STIM GEN 55	100.00	5500.00
110679	STIM GEN 56	100.00	5600.00
110680	STIM GEN 57	100.00	5700.00
110681	STIM GEN 58	100.00	5800.00
110682	STIM GEN 59	100.00	5900.00
110683	STIM GEN 60	100.00	6000.00
110684	STIM GEN 61	100.00	6100.00
110685	STIM GEN 62	100.00	6200.00
110686	STIM GEN 63	100.00	6300.00
110687	STIM GEN 64	100.00	6400.00
110688	STIM GEN 65	100.00	6500.00
110689	STIM GEN 66	100.00	6600.00
110690	STIM GEN 67	100.00	6700.00
110691	STIM GEN 68	100.00	6800.00
110692	STIM GEN 69	100.00	6900.00
110693	STIM GEN 70	100.00	7000.00
110694	STIM GEN 71	100.00	7100.00
110695	STIM GEN 72	100.00	7200.00
110696	STIM GEN 73	100.00	7300.00
110697	STIM GEN 74	100.00	7400.00
110698	STIM GEN 75	100.00	7500.00
110699	STIM GEN 76	100.00	7600.00
110700	STIM GEN 77	100.00	7700.00
110701	STIM GEN 78	100.00	7800.00
110702	STIM GEN 79	100.00	7900.00
110703	STIM GEN 80	100.00	8000.00
110704	STIM GEN 81	100.00	8100.00
110705	STIM GEN 82	100.00	8200.00
110706	STIM GEN 83	100.00	8300.00
110707	STIM GEN 84	100.00	8400.00
110708	STIM GEN 85	100.00	8500.00
110709	STIM GEN 86	100.00	8600.00
110710	STIM GEN 87	100.00	8700.00
110711	STIM GEN 88	100.00	8800.00
110712	STIM GEN 89	100.00	8900.00
110713	STIM GEN 90	100.00	9000.00
110714	STIM GEN 91	100.00	9100.00
110715	STIM GEN 92	100.00	9200.00
110716	STIM GEN 93	100.00	9300.00
110717	STIM GEN 94	100.00	9400.00
110718	STIM GEN 95	100.00	9500.00
110719	STIM GEN 96	100.00	9600.00
110720	STIM GEN 97	100.00	9700.00
110721	STIM GEN 98	100.00	9800.00
110722	STIM GEN 99	100.00	9900.00
110723	STIM GEN 100	100.00	10000.00

1017
 21-112
 21-113
 21-114
 21-115
 21-116
 21-117
 21-118
 21-119
 21-120
 21-121
 21-122
 21-123
 21-124
 21-125
 21-126
 21-127
 21-128
 21-129
 21-130
 21-131
 21-132
 21-133
 21-134
 21-135
 21-136
 21-137
 21-138
 21-139
 21-140
 21-141
 21-142
 21-143
 21-144
 21-145
 21-146
 21-147
 21-148
 21-149
 21-150
 21-151
 21-152
 21-153
 21-154
 21-155
 21-156
 21-157
 21-158
 21-159
 21-160
 21-161
 21-162
 21-163
 21-164
 21-165
 21-166
 21-167
 21-168
 21-169
 21-170
 21-171
 21-172
 21-173
 21-174
 21-175
 21-176
 21-177
 21-178
 21-179
 21-180
 21-181
 21-182
 21-183
 21-184
 21-185
 21-186
 21-187
 21-188
 21-189
 21-190
 21-191
 21-192
 21-193
 21-194
 21-195
 21-196
 21-197
 21-198
 21-199
 21-200

2017
 2018
 2019
 2020
 2021
 2022
 2023
 2024
 2025
 2026
 2027
 2028
 2029
 2030
 2031
 2032
 2033
 2034
 2035
 2036
 2037
 2038
 2039
 2040
 2041
 2042
 2043
 2044
 2045
 2046
 2047
 2048
 2049
 2050
 2051
 2052
 2053
 2054
 2055
 2056
 2057
 2058
 2059
 2060
 2061
 2062
 2063
 2064
 2065
 2066
 2067
 2068
 2069
 2070
 2071
 2072
 2073
 2074
 2075
 2076
 2077
 2078
 2079
 2080
 2081
 2082
 2083
 2084
 2085
 2086
 2087
 2088
 2089
 2090
 2091
 2092
 2093
 2094
 2095
 2096
 2097
 2098
 2099
 2100

2101
 2102
 2103
 2104
 2105
 2106
 2107
 2108
 2109
 2110
 2111
 2112
 2113
 2114
 2115
 2116
 2117
 2118
 2119
 2120
 2121
 2122
 2123
 2124
 2125
 2126
 2127
 2128
 2129
 2130
 2131
 2132
 2133
 2134
 2135
 2136
 2137
 2138
 2139
 2140
 2141
 2142
 2143
 2144
 2145
 2146
 2147
 2148
 2149
 2150
 2151
 2152
 2153
 2154
 2155
 2156
 2157
 2158
 2159
 2160
 2161
 2162
 2163
 2164
 2165
 2166
 2167
 2168
 2169
 2170
 2171
 2172
 2173
 2174
 2175
 2176
 2177
 2178
 2179
 2180
 2181
 2182
 2183
 2184
 2185
 2186
 2187
 2188
 2189
 2190
 2191
 2192
 2193
 2194
 2195
 2196
 2197
 2198
 2199
 2200

Code	Description	Unit	Start Date	End Date	Notes
1045					
1046					
1047					
1048					
1049					
1050					
1051					
1052					
1053					
1054					
1055					
1056					
1057					
1058					
1059					
1060					
1061					
1062					
1063					
1064					
1065					
1066					
1067					
1068					
1069					
1070					
1071					
1072					
1073					
1074					
1075					
1076					
1077					
1078					
1079					
1080					
1081					
1082					
1083					
1084					
1085					
1086					
1087					
1088					
1089					
1090					
1091					
1092					
1093					
1094					
1095					
1096					
1097					
1098					
1099					
1100					
1101					
1102					
1103					
1104					
1105					
1106					
1107					
1108					
1109					
1110					
1111					
1112					
1113					
1114					
1115					
1116					
1117					
1118					
1119					
1120					
1121					
1122					
1123					
1124					
1125					
1126					
1127					
1128					
1129					
1130					
1131					
1132					
1133					
1134					
1135					
1136					
1137					
1138					
1139					
1140					
1141					
1142					
1143					
1144					
1145					
1146					
1147					
1148					
1149					
1150					
1151					
1152					
1153					
1154					
1155					
1156					
1157					
1158					
1159					
1160					
1161					
1162					
1163					
1164					
1165					
1166					
1167					
1168					
1169					
1170					
1171					
1172					
1173					
1174					
1175					
1176					
1177					
1178					
1179					
1180					
1181					
1182					
1183					
1184					
1185					
1186					
1187					
1188					
1189					
1190					
1191					
1192					
1193					
1194					
1195					
1196					
1197					
1198					
1199					
1200					

2 00000000 LO ALERT
 3 00000000 LO ALERT
 4 00000000 LO ALERT
 5 00000000 LO ALERT
 6 00000000 LO ALERT
 7 00000000 LO ALERT
 8 00000000 LO ALERT
 9 00000000 LO ALERT
 10 00000000 LO ALERT
 11 00000000 LO ALERT
 12 00000000 LO ALERT
 13 00000000 LO ALERT
 14 00000000 LO ALERT
 15 00000000 LO ALERT
 16 00000000 LO ALERT
 17 00000000 LO ALERT
 18 00000000 LO ALERT
 19 00000000 LO ALERT
 20 00000000 LO ALERT
 21 00000000 LO ALERT
 22 00000000 LO ALERT
 23 00000000 LO ALERT
 24 00000000 LO ALERT
 25 00000000 LO ALERT
 26 00000000 LO ALERT
 27 00000000 LO ALERT
 28 00000000 LO ALERT
 29 00000000 LO ALERT
 30 00000000 LO ALERT
 31 00000000 LO ALERT
 32 00000000 LO ALERT
 33 00000000 LO ALERT
 34 00000000 LO ALERT
 35 00000000 LO ALERT
 36 00000000 LO ALERT
 37 00000000 LO ALERT
 38 00000000 LO ALERT
 39 00000000 LO ALERT
 40 00000000 LO ALERT
 41 00000000 LO ALERT
 42 00000000 LO ALERT
 43 00000000 LO ALERT
 44 00000000 LO ALERT
 45 00000000 LO ALERT
 46 00000000 LO ALERT
 47 00000000 LO ALERT
 48 00000000 LO ALERT
 49 00000000 LO ALERT
 50 00000000 LO ALERT
 51 00000000 LO ALERT
 52 00000000 LO ALERT
 53 00000000 LO ALERT
 54 00000000 LO ALERT
 55 00000000 LO ALERT
 56 00000000 LO ALERT
 57 00000000 LO ALERT
 58 00000000 LO ALERT
 59 00000000 LO ALERT
 60 00000000 LO ALERT
 61 00000000 LO ALERT
 62 00000000 LO ALERT
 63 00000000 LO ALERT
 64 00000000 LO ALERT
 65 00000000 LO ALERT
 66 00000000 LO ALERT
 67 00000000 LO ALERT
 68 00000000 LO ALERT
 69 00000000 LO ALERT
 70 00000000 LO ALERT
 71 00000000 LO ALERT
 72 00000000 LO ALERT
 73 00000000 LO ALERT
 74 00000000 LO ALERT
 75 00000000 LO ALERT
 76 00000000 LO ALERT
 77 00000000 LO ALERT
 78 00000000 LO ALERT
 79 00000000 LO ALERT
 80 00000000 LO ALERT
 81 00000000 LO ALERT
 82 00000000 LO ALERT
 83 00000000 LO ALERT
 84 00000000 LO ALERT
 85 00000000 LO ALERT
 86 00000000 LO ALERT
 87 00000000 LO ALERT
 88 00000000 LO ALERT
 89 00000000 LO ALERT
 90 00000000 LO ALERT
 91 00000000 LO ALERT
 92 00000000 LO ALERT
 93 00000000 LO ALERT
 94 00000000 LO ALERT
 95 00000000 LO ALERT
 96 00000000 LO ALERT
 97 00000000 LO ALERT
 98 00000000 LO ALERT
 99 00000000 LO ALERT
 100 00000000 LO ALERT

DATE: 12-28-67
 TIME: 11:00 AM
 TO: Mr. J. B. ...
 FROM: Mr. ...
 SUBJECT: ...

Mr. J. B. ...
 Mr. ...
 Mr. ...

Item No.	Description	Quantity	Unit Price	Total
1000
1001
1002
1003
1004
1005
1006
1007
1008
1009
1010
1011
1012
1013
1014
1015
1016
1017
1018
1019
1020
1021
1022
1023
1024
1025
1026
1027
1028
1029
1030
1031
1032
1033
1034
1035
1036
1037
1038
1039
1040
1041
1042
1043
1044
1045
1046
1047
1048
1049
1050
1051
1052
1053
1054
1055
1056
1057
1058
1059
1060
1061
1062
1063
1064
1065
1066
1067
1068
1069
1070
1071
1072
1073
1074
1075
1076
1077
1078
1079
1080
1081
1082
1083
1084
1085
1086
1087
1088
1089
1090
1091
1092
1093
1094
1095
1096
1097
1098
1099
1100

Total
 ...
 ...
 ...

70452	TRN	TRN	
70453	TRN	TRN	
70454	TRN	TRN	
70455	TRN	TRN	
70456	TRN	TRN	
70457	TRN	TRN	
70458	TRN	TRN	
70459	TRN	TRN	
70460	TRN	TRN	
70461	TRN	TRN	
70462	TRN	TRN	
70463	TRN	TRN	
70464	TRN	TRN	
70465	TRN	TRN	
70466	TRN	TRN	
70467	TRN	TRN	
70468	TRN	TRN	
70469	TRN	TRN	
70470	TRN	TRN	
70471	TRN	TRN	
70472	TRN	TRN	
70473	TRN	TRN	
70474	TRN	TRN	
70475	TRN	TRN	
70476	TRN	TRN	
70477	TRN	TRN	
70478	TRN	TRN	
70479	TRN	TRN	
70480	TRN	TRN	
70481	TRN	TRN	
70482	TRN	TRN	
70483	TRN	TRN	
70484	TRN	TRN	
70485	TRN	TRN	
70486	TRN	TRN	
70487	TRN	TRN	
70488	TRN	TRN	
70489	TRN	TRN	
70490	TRN	TRN	
70491	TRN	TRN	
70492	TRN	TRN	
70493	TRN	TRN	
70494	TRN	TRN	
70495	TRN	TRN	
70496	TRN	TRN	
70497	TRN	TRN	
70498	TRN	TRN	
70499	TRN	TRN	
70500	TRN	TRN	
70501	TRN	TRN	
70502	TRN	TRN	
70503	TRN	TRN	
70504	TRN	TRN	
70505	TRN	TRN	
70506	TRN	TRN	
70507	TRN	TRN	
70508	TRN	TRN	
70509	TRN	TRN	
70510	TRN	TRN	
70511	TRN	TRN	
70512	TRN	TRN	
70513	TRN	TRN	
70514	TRN	TRN	
70515	TRN	TRN	
70516	TRN	TRN	
70517	TRN	TRN	
70518	TRN	TRN	
70519	TRN	TRN	
70520	TRN	TRN	
70521	TRN	TRN	
70522	TRN	TRN	
70523	TRN	TRN	
70524	TRN	TRN	
70525	TRN	TRN	
70526	TRN	TRN	
70527	TRN	TRN	
70528	TRN	TRN	
70529	TRN	TRN	
70530	TRN	TRN	
70531	TRN	TRN	
70532	TRN	TRN	
70533	TRN	TRN	
70534	TRN	TRN	
70535	TRN	TRN	
70536	TRN	TRN	
70537	TRN	TRN	
70538	TRN	TRN	
70539	TRN	TRN	
70540	TRN	TRN	
70541	TRN	TRN	
70542	TRN	TRN	
70543	TRN	TRN	
70544	TRN	TRN	
70545	TRN	TRN	
70546	TRN	TRN	
70547	TRN	TRN	
70548	TRN	TRN	
70549	TRN	TRN	
70550	TRN	TRN	
70551	TRN	TRN	
70552	TRN	TRN	
70553	TRN	TRN	
70554	TRN	TRN	
70555	TRN	TRN	
70556	TRN	TRN	
70557	TRN	TRN	
70558	TRN	TRN	
70559	TRN	TRN	
70560	TRN	TRN	
70561	TRN	TRN	
70562	TRN	TRN	
70563	TRN	TRN	
70564	TRN	TRN	
70565	TRN	TRN	
70566	TRN	TRN	
70567	TRN	TRN	
70568	TRN	TRN	
70569	TRN	TRN	
70570	TRN	TRN	
70571	TRN	TRN	
70572	TRN	TRN	
70573	TRN	TRN	
70574	TRN	TRN	
70575	TRN	TRN	
70576	TRN	TRN	
70577	TRN	TRN	
70578	TRN	TRN	
70579	TRN	TRN	
70580	TRN	TRN	
70581	TRN	TRN	
70582	TRN	TRN	
70583	TRN	TRN	
70584	TRN	TRN	
70585	TRN	TRN	
70586	TRN	TRN	
70587	TRN	TRN	
70588	TRN	TRN	
70589	TRN	TRN	
70590	TRN	TRN	
70591	TRN	TRN	
70592	TRN	TRN	
70593	TRN	TRN	
70594	TRN	TRN	
70595	TRN	TRN	
70596	TRN	TRN	
70597	TRN	TRN	
70598	TRN	TRN	
70599	TRN	TRN	
70600	TRN	TRN	

12345
6789
1011
1213
1415
1617
1819
2021
2223
2425
2627
2829
3031
3233
3435
3637
3839
4041
4243
4445
4647
4849
5051
5253
5455
5657
5859
6061
6263
6465
6667
6869
7071
7273
7475
7677
7879
8081
8283
8485
8687
8889
9091
9293
9495
9697
9899
10000

10101
10202
10303
10404
10505
10606
10707
10808
10909
11010
11111
11212
11313
11414
11515
11616
11717
11818
11919
12020
12121
12222
12323
12424
12525
12626
12727
12828
12929
13030
13131
13232
13333
13434
13535
13636
13737
13838
13939
14040
14141
14242
14343
14444
14545
14646
14747
14848
14949
15050
15151
15252
15353
15454
15555
15656
15757
15858
15959
16060
16161
16262
16363
16464
16565
16666
16767
16868
16969
17070
17171
17272
17373
17474
17575
17676
17777
17878
17979
18080
18181
18282
18383
18484
18585
18686
18787
18888
18989
19090
19191
19292
19393
19494
19595
19696
19797
19898
19999
20000

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

10/1/71

08:41:13	LO ALERT RETURN	T3057	MIN GEN STATOR SLOTT NO 57	
08:41:14	LO ALERT RETURN	T3059	MIN GEN STATOR SLOTT NO 59	
08:41:14	LO ALERT RETURN	T3061	MIN GEN STATOR SLOTT NO 61	
08:41:15	LO ALERT RETURN	T3065	MIN GEN STATOR SLOTT NO 65	
08:41:15	LO ALERT RETURN	T3071	MIN GEN STATOR SLOTT NO 71	
08:41:16	LO ALERT RETURN	L0042	SIM GEN 2 LO-LO CH IV LI-0527	NOT TR
08:41:18	LO ALERT RETURN	L0042	SIM GEN 2 LO-LO LEVEL TRIP	NOT TR
08:41:24	LO ALERT RETURN	L0040	SIM GEN 1 LO-LO CH IV LI-0519	NOT TR
08:41:30	LO ALERT RETURN	L0042	SIM GEN 2 LO-LO CH III LI-0528	NOT TR
08:41:40	LO ALERT RETURN	L0441	SIM GEN 3 NR LI-0552 LVL	25.6
08:41:42	LO ALERT RETURN	F0442	SIM GEN 2 NR LI-0538 LVL	25.6
08:41:44	LO ALERT RETURN	L0443	RCL3 CH III FT-0426 FLOW	10.3
08:41:44	LO ALERT RETURN	L0443	SIM GEN 3 NR LI-0537 LVL	25.6
08:41:53	LO ALERT RETURN	L0441	SIM GEN 2 NR LI-0552 LVL	25.6
08:42	ALARM		FUNCTION SELECTED = 2	
08:42:05	ALARM	ZD208	SAFETY SYS BY-PASSED TRAIN C	
08:42:06	ALARM	L0040	SIM GEN 1 LO-LO CH I LI-0551	NOT TR
08:42:06	ALARM	L0042	SIM GEN 1 LO-LO CH I LI-0551	NOT TR
08:42:06	ALARM	L0042	SIM GEN 1 LO-LO CH II LI-0518	NOT TR
08:42:11	ALARM	L0443	SIM GEN 1 LO-LO CH III LI-0517	NOT TR
08:42:11	ALARM	L0442	SIM GEN 2 NR LI-0539 LVL	25.6
08:42:17	ALARM	L00509	RMP 02 RCL 4 F	
08:42:21	ALARM	T3119	MIN GEN STATOR CLO WTR OUT BAR 19	ALARM
08:42:21	ALARM	L00717	RPSM 17 PWR RNG HI FLUX RATE TR	NOT TR
08:42:21	ALARM	T3126	MIN GEN STATOR CLO WTR OUT BAR 24	ALARM
08:42:21	ALARM	F0442	RCL3 CH III FT-0436 FLOW	10.3
08:42:21	ALARM	L00209	RMP 02 RCL 4 F	ALARM
08:42:21	ALARM	T3602	MIN GEN STATOR SLOTT NO 2	
08:42:21	ALARM	L00717	RPSM 17 PWR RNG HI FLUX RATE TR	NOT TR
08:42:21	ALARM	L0402	SIM GEN 1 NR LI-0517 LVL	25.6
08:42:21	ALARM	L0402	SIM GEN 1 NR LI-0517 LVL	25.6
08:42:21	ALARM	T3170	MIN GEN STATOR CLO WTR OUT BAR 70	ALARM
08:42:21	ALARM	L0402	SIM GEN 1 NR LI-0511 LVL	25.6
08:42:21	ALARM	L0400	SIM GEN 1 NR LI-0519 LVL	25.6
08:42:21	ALARM	L0401	SIM GEN 1 NR LI-0519 LVL	25.6
08:42:21	ALARM	F0442	RCL3 CH III FT-0426 FLOW	10.3
08:42:27	ALARM	L0422	SIM GEN 2 NR LI-0522 LVL	25.6
08:42:27	ALARM	L0402	SIM GEN 1 NR LI-0519 LVL	25.6
08:42:27	ALARM	L0401	SIM GEN 1 NR LI-0519 LVL	25.6
08:42:27	ALARM	L00364	SIM GEN 4 LO-LO CH II LI-0549	NOT TR
08:42:27	ALARM	L0400	SIM GEN 1 NR LI-0519 LVL	25.6
08:42:27	ALARM	T3041	MIN GEN STATOR SLOTT NO 41	
08:42:27	ALARM	T3105	MIN GEN STATOR CLO WTR OUT BAR 3	
08:42:27	ALARM	L00463	SIM GEN 3 LO-LO CH I LI-0554	NOT TR
08:42:27	ALARM	L00463	SIM GEN 4 LO-LO CH III LI-0548	NOT TR
08:42:27	ALARM	L00467	SIM GEN 4 LO-LO LEVEL TRIP	NOT TR
08:42:27	ALARM	F0442	RCL3 CH III FT-0426 FLOW	10.3
08:42:27	ALARM	T0127	REGEN HX LEIDOWN OUT TEMP	
08:42:27	ALARM	T0127	REGEN HX LEIDOWN OUT TEMP	
08:42:27	ALARM	L00466	SIM GEN 4 LO-LO CH IV LI-0547	NOT TR
08:42:27	ALARM	L00712	RPSM 19 LO-LO SC WATER L	ALARM
08:42:27	ALARM	T3058	MIN GEN STATOR SLOTT NO 58	
08:42:27	ALARM	T3029	MIN GEN STATOR SLOTT NO 29	
08:42:27	ALARM	L0441	SIM GEN 2 NR LI-0552 LVL	25.6
08:42:27	ALARM	L04508	DISP AY 3 REGEN HT	ALARM
08:42:27	ALARM	L0422	SIM GEN 2 NR LI-0522 LVL	25.6
08:42:27	ALARM	L00412	SIM GEN 1 BAR RNG LVL 1707066	
08:42:27	ALARM	F0442	RCL3 CH III FT-0426 FLOW	10.3
08:46:19	LO ALARM		COND STIM TO SPRC	
08:46:19	LO ALARM		DEBRIZER SPRAY WTR RESING TEMP	

Time	Event	Code	Description	Value	Unit	Alarm Status
08:46:17	SENSOR RETURN	F2153	REHEATING STM TO MSR B			
08:46:18	LO ALARM		PRESSURIZER SPRAY WTR A INL TEMP	541.0		ALARM
08:46:25	HI ALERT RETURN	T0127	REGEN HX LETDOWN OUT TEMP	507.4		NORMAL
08:46:26	RETURN		DISPLAY - REGEN HX			
08:46:31	LO ALERT RETURN	T3108	MN GEN STATOR CLO WTR OUT BAR 7			
08:46:32	LO ALERT RETURN	T3117	MN GEN STATOR CLO WTR OUT BAR 17			
08:46:52	SENSOR LO ALARM	F2153	REHEATING STM TO MSR C			
08:47:12	HI ALERT RETURN	T2284	HTR 3A SHELL DUMP TO COND A			
08:47:23	LO ALERT RETURN	T3024	MN GEN STATOR SLOT NO 34			
08:48:07	LO RETURN	L0461	STM GEN 4 NR LT-0542 LVL			
08:48:09	LO RETURN	L0462	STM GEN 4 NR LT-0544 LVL			
08:48:16	ALARM	LA0513	RMP 13 RCL DT			ALARM
08:48:24	LO RETURN	L0460	STM GEN 4 NR LT-0548 LVL			
08:48:30	LO ALERT RETURN	L0461	STM GEN 4 NR LT-0549 LVL			
08:48:37	LO ALERT RETURN	T3118	MN GEN STATOR CLO WTR OUT BAR 18			
08:48:55	LO RETURN	L0463	STM GEN 4 NR LT-0547 LVL			
08:49:58	LO ALERT RETURN	L0462	STM GEN 4 NR LT-0544 LVL			
08:49:08	LO ALERT RETURN	L0460	STM GEN 4 NR LT-0548 LVL			
08:49:38	LO ALERT RETURN	L0463	STM GEN 4 NR LT-0547 LVL			
08:49:50	HI ALERT RETURN	F0484	PRESSURIZER SPRAY CNTL 2 DEMAND			
08:50:05	LO ALERT RETURN	T2212	GEN COLD H2 FROM CLR EXCITED END			
08:50:18	RETURN	LA0513	RMP 13 RCL DT			NORMAL
08:50:30	RETURN	Z0232	AUX FW PMP 1 DISCH SG 1 TRAIN C			OPEN
08:50:31	RETURN	Z0233	AUX FW PMP 1 DISCH SG 2 TRAIN C			OPEN
08:50:41	HI ALERT	F0484	PRESSURIZER SPRAY CNTL 2 DEMAND			ALARM
08:50:43	SENSOR RETURN	F2328	AFW PMP TURB DIFF MS TO FW DISCH			
08:50:44	RETURN	Z0232	AUX FW PMP 1 DISCH SG 3 TRAIN C			OPEN
08:50:54	LO ALERT RETURN	U0475	STM GEN 4 NAR RNG LVL 1/2/3/4 AV			
08:50:54	RETURN	Z0233	AUX FW PMP 1 DISCH SG 4 TRAIN C			OPEN
08:51:15	SENSOR LO ALARM	F2151	REHEATING STM TO MSR A			
08:51:15	ALARM	Z0232	TR LG FOR BRK 2NA0418			OPEN
08:51:15	ALARM	Z0231	CE LG FOR BRK 2NA0417			OPEN
08:51:15	ALARM	Z0232	STM GEN 2 NR LT-0522 LVL			
08:51:15	LO ALERT RETURN	L0461	PRESSURIZER SPRAY CNTL 2 DEMAND			
08:51:15	LO ALERT RETURN	F0484	PRESSURIZER RELIEF TANK PRESSURE			
08:51:15	ALARM	P0485	CE LG FOR BRK 2NA0105			ALARM
08:51:15	RETURN	Z0232	MN GEN STATOR CLO WTR OUT BAR 22			
08:51:31	HI ALERT RETURN	T3125	MN GEN STATOR CLO WTR OUT BAR 32			
08:52:40	HI RETURN	T3122	STM GEN 2 NR LT-0527 LVL			
08:52:41	LO RETURN	L0423	TAVG DEVIATION FROM MEAS TREE			
08:54:04	LO ALERT RETURN	U0689	RMP 10 RCL TAVG			ALARM
08:54:16	ALARM	LA0510	RMP 13 RCL DT			ALARM
08:54:16	ALARM	LA0513	PRESSURIZER SPRAY CNTL 2 DEMAND	100.0		ALARM
08:54:16	HI ALERT	F0484	RMP 09 RCL 4 F	541.0		ALARM
08:54:16	HI ALERT	T0484	PRESSURIZER SPRAY WTR B INL TEMP	541.0		ALARM
08:54:16	HI ALERT	LA0509	RMP 09 RCL 4 F	24.5		ALARM
08:54:16	HI ALERT	L0420	STM GEN 2 NR LT-0528 LVL	70.0		ALARM
08:54:16	HI ALERT	L0403	STM GEN 1 NR LT-0517 LVL	7.0		ALARM
08:54:16	HI ALERT	P0485	PRESSURIZER RELIEF TANK PRESSURE	7.0		ALARM
08:54:16	HI ALERT	F0484	PRESSURIZER SPRAY CNTL 2 DEMAND	7.0		ALARM
08:54:16	HI ALERT	L0403	STM GEN 1 NR LT-0517 LVL	24.5		ALARM
08:54:16	HI ALERT	L0403	STM GEN 2 NAR RNG LVL 1/2/3/4 AV	24.5		ALARM
08:54:16	HI ALERT	XE FRED/BOR CALC	XE FRED/BOR CALC			ALARM
08:54:16	HI ALERT	XE FRED/BOR CALC	XE FRED/BOR CALC			ALARM
08:54:16	HI ALERT	STM GEN 2 NR LT-0528 LVL	STM GEN 2 NR LT-0528 LVL	24.5		ALARM
08:54:16	HI ALERT	RPSM 17 PWR RNG HI FLUX RATE TR	RPSM 17 PWR RNG HI FLUX RATE TR			ALARM
08:54:16	HI ALERT	RPSM 17 PWR RNG HI FLUX RATE TR	RPSM 17 PWR RNG HI FLUX RATE TR			NORMAL
08:54:16	HI ALERT	STM GEN 1 NR LT-0528 LVL	STM GEN 1 NR LT-0528 LVL	24.5		ALARM
08:54:16	HI ALERT	STM GEN 2 NR LT-0527 LVL	STM GEN 2 NR LT-0527 LVL	24.5		ALARM
08:54:16	HI ALERT	STM GEN 2 NR LT-0528 LVL	STM GEN 2 NR LT-0528 LVL	24.5		ALARM

#4 RCL off - spray

NO.	DESCRIPTION	UNIT	STATUS	PC
00001
00002
00003
00004
00005
00006
00007
00008
00009
00010
00011
00012
00013
00014
00015
00016
00017
00018
00019
00020
00021
00022
00023
00024
00025
00026
00027
00028
00029
00030
00031
00032
00033
00034
00035
00036
00037
00038
00039
00040
00041
00042
00043
00044
00045
00046
00047
00048
00049
00050
00051
00052
00053
00054
00055
00056
00057
00058
00059
00060
00061
00062
00063
00064
00065
00066
00067
00068
00069
00070
00071
00072
00073
00074
00075
00076
00077
00078
00079
00080
00081
00082
00083
00084
00085
00086
00087
00088
00089
00090
00091
00092
00093
00094
00095
00096
00097
00098
00099
00100
00101
00102
00103
00104
00105
00106
00107
00108
00109
00110
00111
00112
00113
00114
00115
00116
00117
00118
00119
00120
00121
00122
00123
00124
00125
00126
00127
00128
00129
00130
00131
00132
00133
00134
00135
00136
00137
00138
00139
00140
00141
00142
00143
00144
00145
00146
00147
00148
00149
00150
00151
00152
00153
00154
00155
00156
00157
00158
00159
00160
00161
00162
00163
00164
00165
00166
00167
00168
00169
00170
00171
00172
00173
00174
00175
00176
00177
00178
00179
00180
00181
00182
00183
00184
00185
00186
00187
00188
00189
00190
00191
00192
00193
00194
00195
00196
00197
00198
00199
00200

Code	Description	Value	Unit	Alarm	Control
1001	1001	1001			
1002	1002	1002			
1003	1003	1003			
1004	1004	1004			
1005	1005	1005			
1006	1006	1006			
1007	1007	1007			
1008	1008	1008			
1009	1009	1009			
1010	1010	1010			
1011	1011	1011			
1012	1012	1012			
1013	1013	1013			
1014	1014	1014			
1015	1015	1015			
1016	1016	1016			
1017	1017	1017			
1018	1018	1018			
1019	1019	1019			
1020	1020	1020			
1021	1021	1021			
1022	1022	1022			
1023	1023	1023			
1024	1024	1024			
1025	1025	1025			
1026	1026	1026			
1027	1027	1027			
1028	1028	1028			
1029	1029	1029			
1030	1030	1030			
1031	1031	1031			
1032	1032	1032			
1033	1033	1033			
1034	1034	1034			
1035	1035	1035			
1036	1036	1036			
1037	1037	1037			
1038	1038	1038			
1039	1039	1039			
1040	1040	1040			
1041	1041	1041			
1042	1042	1042			
1043	1043	1043			
1044	1044	1044			
1045	1045	1045			
1046	1046	1046			
1047	1047	1047			
1048	1048	1048			
1049	1049	1049			
1050	1050	1050			
1051	1051	1051			
1052	1052	1052			
1053	1053	1053			
1054	1054	1054			
1055	1055	1055			
1056	1056	1056			
1057	1057	1057			
1058	1058	1058			
1059	1059	1059			
1060	1060	1060			
1061	1061	1061			
1062	1062	1062			
1063	1063	1063			
1064	1064	1064			
1065	1065	1065			
1066	1066	1066			
1067	1067	1067			
1068	1068	1068			
1069	1069	1069			
1070	1070	1070			
1071	1071	1071			
1072	1072	1072			
1073	1073	1073			
1074	1074	1074			
1075	1075	1075			
1076	1076	1076			
1077	1077	1077			
1078	1078	1078			
1079	1079	1079			
1080	1080	1080			
1081	1081	1081			
1082	1082	1082			
1083	1083	1083			
1084	1084	1084			
1085	1085	1085			
1086	1086	1086			
1087	1087	1087			
1088	1088	1088			
1089	1089	1089			
1090	1090	1090			
1091	1091	1091			
1092	1092	1092			
1093	1093	1093			
1094	1094	1094			
1095	1095	1095			
1096	1096	1096			
1097	1097	1097			
1098	1098	1098			
1099	1099	1099			
1100	1100	1100			
1101	1101	1101			
1102	1102	1102			
1103	1103	1103			
1104	1104	1104			
1105	1105	1105			
1106	1106	1106			
1107	1107	1107			
1108	1108	1108			
1109	1109	1109			
1110	1110	1110			
1111	1111	1111			
1112	1112	1112			
1113	1113	1113			
1114	1114	1114			
1115	1115	1115			
1116	1116	1116			
1117	1117	1117			
1118	1118	1118			
1119	1119	1119			
1120	1120	1120			
1121	1121	1121			
1122	1122	1122			
1123	1123	1123			
1124	1124	1124			
1125	1125	1125			
1126	1126	1126			
1127	1127	1127			
1128	1128	1128			
1129	1129	1129			
1130	1130	1130			
1131	1131	1131			
1132	1132	1132			
1133	1133	1133			
1134	1134	1134			
1135	1135	1135			
1136	1136	1136			
1137	1137	1137			
1138	1138	1138			
1139	1139	1139			
1140	1140	1140			
1141	1141	1141			
1142	1142	1142			
1143	1143	1143			
1144	1144	1144			
1145	1145	1145			
1146	1146	1146			
1147	1147	1147			
1148	1148	1148			
1149	1149	1149			
1150	1150	1150			
1151	1151	1151			
1152	1152	1152			
1153	1153	1153			
1154	1154	1154			
1155	1155	1155			
1156	1156	1156			
1157	1157	1157			
1158	1158	1158			
1159	1159	1159			
1160	1160	1160			
1161	1161	1161			
1162	1162	1162			
1163	1163	1163			
1164	1164	1164			
1165	1165	1165			
1166	1166	1166			
1167	1167	1167			
1168	1168	1168			
1169	1169	1169			
1170	1170	1170			
1171	1171	1171			
1172	1172	1172			
1173	1173	1173			
1174	1174	1174			
1175	1175	1175			
1176	1176	1176			
1177	1177	1177			
1178	1178	1178			
1179	1179	1179			
1180	1180	1180			
1181	1181	1181			
1182	1182	1182			
1183	1183	1183			
1184	1184	1184			
1185	1185	1185			
1186	1186	1186			
1187	1187	1187			
1188	1188	1188			
1189	1189	1189			
1190	1190	1190			
1191	1191	1191			
1192	1192	1192			
1193	1193	1193			
1194	1194	1194			
1195	1195	1195			
1196	1196	1196			
1197	1197	1197			
1198	1198	1198			
1199	1199	1199			
1200	1200	1200			

1111

1111

1111

1111

Account No.	Account Name	Address	City	State	Zip	Service Class	Rate Plan	Start Date	End Date	Usage	Charges	Balance
100001	GA
100002	GA
100003	GA
100004	GA
100005	GA
100006	GA
100007	GA
100008	GA
100009	GA
100010	GA
100011	GA
100012	GA
100013	GA
100014	GA
100015	GA
100016	GA
100017	GA
100018	GA
100019	GA
100020	GA
100021	GA
100022	GA
100023	GA
100024	GA
100025	GA
100026	GA
100027	GA
100028	GA
100029	GA
100030	GA
100031	GA
100032	GA
100033	GA
100034	GA
100035	GA
100036	GA
100037	GA
100038	GA
100039	GA
100040	GA
100041	GA
100042	GA
100043	GA
100044	GA
100045	GA
100046	GA
100047	GA
100048	GA
100049	GA
100050	GA

10 10 00

QUARANTINED EQUIPMENT LIST

REV. 2

ATTENTION

N26 3-29-90

OS-34-90

At all times, the licensee is responsible for quarantined equipment and can take action involving this equipment it deems necessary to:

- Achieve or maintain safe plant conditions,
- Prevent further equipment degradation, or
- Test or inspect, as required by the plant's Technical Specifications.

To the maximum degree possible, these actions should be coordinated with the Team Leader in advance, or notification made as soon as possible.

Effective Time: 241000MAR90

The Licensee is maintaining the following Items Quarantined:

1. POL Truck (Allowable to use for normal deliveries)
2. 230 KV Insulator to Reserve Auxiliary Transformer 1A (Broken on 20 MAR 90)
3. All replaced CALCON Switches for 1A & 1B Diesel Generators
4. ERF recorded Trip Package - Unit 1 (NOTE: Database memory tape maintained by J. P. Cash.)

The following restrictions concerning Diesel generator troubleshooting, repair, and testing are agree to: (This applies to DG A & DG B except as noted)

1. Any component replacements will be concurred with by the Team Leader prior to performing the work. All replaced components will be retained until released by the Team Leader.
2. The following test procedures will be reviewed by the team prior to performance:
 - a. 1B UV Test
 - b. 1A UV Test (#1)
 - c. 1A UV Test (#2)
3. The following tests will be announced to the team leader, or a designated representative, 4 hours prior to initiation. It will not be performed until approved by the Team Leader.
 - a. 1B Sequencer Test
 - b. 1B UV Test
 - c. 1A UV Test (#1)
 - d. 1A UV Test (#2)

QUARANTINED EQUIPMENT LIST

The following personnel will not take vacation until approved by the Team Leader (normal off days are not restricted):

- a. All Operations Department Management
- b. All operators (licensed and non-licensed) in the Operations Department who were on duty during the 20 Mar 90 event
- c. All Event Critique Team members

SUBMITTED BY: Herbert L. Beacher
HERBERT BEACHER
DATE: March 29, 1990
EXTENSION: 3769 BEEPER: 138