

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 809-654-2211



LWP-95-082

September 8, 1995

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 95-005, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(D). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to mitigate the consequences of an accident.

There are no commitments being made by this letter.

If there are any questions or comments concerning this letter, please refer them to Nick Chrissotimos, Regulatory Assurance Administrator at 309-654-2241, ext. 3100.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION

L. W. Pearce
Station Manager

LWP/NC/plm
Enclosure

cc: J. Schrage
C. Miller
INPO Records Center
NRC Region III

9509190100 950908
PDR ADOCK 05000254
S PDR

STEMGR08295.LWP
Common Company

JE 2/1

**Licensee Event Report
Reviewer Assignment Form**

Revised 12/01/94

LER # 2541809500500

Date: August 12, 1995

Subject: B CR HVAC Inoperable Due To Refrigerant Leak Preventing Operation
of the Compressor.

Signatures of reviewers indicating review and approval of item:

Systems Eng. Supv:	<u><i>David Chaddick</i></u>	<u>9/8/95</u>	<u>/</u>
	Date	Date	Date
Operating Eng.:	<u><i>Alex L. Misch</i></u>	<u>9/8/95</u>	<u>/</u>
	Date	Date	Date
	<u>/</u>	<u>/</u>	<u>/</u>
	Date	Date	Date
	<u>/</u>	<u>/</u>	<u>/</u>
	Date	Date	Date

Approved: *[Signature]* 9/11/95
Station Manager/PORC Chairman Date