

ROBERT E. DENTON
Vice President
Nuclear Energy

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 586-2200 Ext. 4455 Local
410 260-4455 Baltimore



September 14, 1995

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Completion of Final Action Associated with NRC Generic Letter 88-17, "Loss of
Decay Heat Removal" (TAC No. 69731)

- REFERENCES:
- (a) Letter from Mr. R. E. Denton (BGE) to NRC Document Control Desk, dated June 7, 1993, Generic Letter 88-17, "Loss of Decay Heat Removal" Change to Completion Date for Narrow Range Level Instrument Modification (TAC No. 69731)
 - (b) Letter from Mr. D. G. McDonald (NRC) to Mr. R. E. Denton (BGE), dated December 8, 1992, Summary of Licensing Actions During the 1992 Refueling Outage and Implementation of Actions Associated with TAC Nos. M69730, M81522, M82363, M79911, Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2

The purpose of this letter is to inform you that we have completed the Unit 2 Reactor Coolant System (RCS) narrow-range level indication modification. In Reference (a), we described that circuit noise problems were encountered during the RCS narrow-range level indication acceptance testing. We committed to complete the acceptance test during the next outage of sufficient duration that involves entry into mid-loop operations, but no later than the Unit 2 Cycle 10 Refueling Outage. The Unit 2 RCS narrow-range level indication modification was tested and found acceptable on April 4, 1995 during the Unit 2 Cycle 10 Refueling Outage. It operated satisfactorily during mid-loop operations. This completes all actions associated with NRC Generic Letter 88-17 for Calvert Cliffs Unit 2. Recall that Reference (b) indicated that all actions associated with NRC Generic Letter 88-17 for Calvert Cliffs Unit 1 have been completed. Accordingly, all actions associated with NRC Generic Letter 88-17 for Calvert Cliffs are complete.

100027


2024934082

9509190155 950914
PDR ADOCK 05000317
P PDR

A001
110

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

A handwritten signature in black ink, appearing to read "J. H. Walter". The signature is written in a cursive style with a large, sweeping initial "J" and "H".

RED/TWG/dlm

cc: D. A. Brune, Esquire
J. E. Silberg, Esquire
L. B. Marsh, NRC
D. G. McDonald, Jr., NRC
T. T. Martin, NRC
P. R. Wilson, NRC
R. I. McLean, DNR
J. H. Walter, PSC