



ENTERGY

Entergy Operations, Inc.
River Bend Station
5485 U.S. Highway 61
P.O. Box 220
St. Francisville, LA 70775
Tel 504 336 6225
Fax 504 635 5068

James J. Fisicaro
Director
Nuclear Safety

September 13, 1995

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
M/S P1-37
Washington, DC 20555

Subject: River Bend Station - Unit 1
Docket No. 50-458
Monthly Operating Report

File No.: G9.5, G4.25

RBG-41965
RBF1-95-0221

Gentlemen:

In accordance with River Bend Station (RBS) Technical Specification 6.9.1.6, enclosed is the August, 1995 Monthly Operating Report for RBS - Unit 1.

Sincerely,

James J. Fisicaro
JJF/JS/kvm
enclosure

100120

9509190243 950831
PDR ADOCK 05000458
R PDR

JE24

August 1995 Monthly Operating Report
September 13, 1995
RBG-41965
RBF1-95-0221
Page 2 of 2

cc: U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Senior Resident Inspector
P.O. Box 1051
St. Francisville, LA 70775

INPO Records Center
1100 Circle 75 Parkway
Atlanta, GA 30339

Chester R. Oberg
PUCT
7800 Shoal Creek Blvd., Suite 400N
Austin, TX 78757

Dottie Sherman
American Nuclear Insurers
29 South Main Street
West Hartford, CN 06107

Cajun Electric Power Co-op, Inc.

DOCKET NO. 50/458

RIVER BEND STATION UNIT 1

REPORT NO. R-95-08

DATE September 12, 1995

COMPLETED BY T. J. Bolke

TITLE Engineer III

TELEPHONE 504-346-8651 ext. 2940

MONTH August, 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	<u>917.1</u>
2.	<u>916.3</u>
3.	<u>917.2</u>
4.	<u>870.9</u>
5.	<u>575.6</u>
6.	<u>918.5</u>
7.	<u>921.6</u>
8.	<u>920.6</u>
9.	<u>920.6</u>
10.	<u>921.7</u>
11.	<u>893.8</u>
12.	<u>891.0</u>
13.	<u>921.8</u>
14.	<u>921.2</u>
15.	<u>919.2</u>
16.	<u>917.3</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17.	<u>917.1</u>
18.	<u>918.4</u>
19.	<u>920.3</u>
20.	<u>919.1</u>
21.	<u>920.6</u>
22.	<u>920.5</u>
23.	<u>920.2</u>
24.	<u>918.6</u>
25.	<u>919.7</u>
26.	<u>920.5</u>
27.	<u>920.2</u>
28.	<u>920.2</u>
29.	<u>919.1</u>
30.	<u>921.0</u>
31.	<u>918.3</u>

DOCKET NO. 50/458

RIVER BEND STATION UNIT 1

REPORT NO. R-95-08

DATE September 12, 1995

COMPLETED BY T. J. Bolke

TITLE Engineer III

TELEPHONE 504-346-8651 ext. 2940

PAGE 1 OF 2

OPERATING STATUS

1. REPORTING PERIOD: August, 1995 GROSS HOURS IN REPORTING PERIOD: 744

2. CURRENTLY AUTHORIZED POWER LEVEL (Mwt): 2894

MAX. DEPEND CAPACITY (MWe-Net): 936

DESIGN ELECTRICAL RATING (MWe-Net): 936

3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): N/A

4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMU- LATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL	<u>744.0</u>	<u>5831.0</u>	<u>62327.2</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>744.0</u>	<u>5831.0</u>	<u>59270.1</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>2,123,882</u>	<u>16,794,264</u>	<u>159,867,277</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>720,533</u>	<u>5,757,582</u>	<u>54,139,637</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>673,396</u>	<u>5,394,614</u>	<u>50,670,346</u>

DOCKET NO. 50/458

RIVER BEND STATION UNIT 1

REPORT NO. R-95-08

DATE September 12, 1995

COMPLETED BY T. J. Bolke

TITLE Engineer III

TELEPHONE 504-346-8651 ext. 2940

PAGE 2 OF 2

OPERATING STATUS

	THIS MONTH	YR TO DATE	CUMU- LATIVE
12. REACTOR SERVICE FACTOR	<u>100.0</u>	<u>100.0</u>	<u>72.9</u>
13 REACTOR AVAILABILITY FACTOR	<u>100.0</u>	<u>100.0</u>	<u>72.9</u>
14. UNIT SERVICE FACTOR	<u>100.0</u>	<u>100.0</u>	<u>70.7</u>
15. UNIT AVAILABILITY FACTOR	<u>100.0</u>	<u>100.0</u>	<u>70.7</u>
16. UNIT CAPACITY FACTOR (USING MDC)	<u>96.7</u>	<u>98.8</u>	<u>65.8</u>
17. UNIT CAPACITY FACTOR (USING DESIGN MWe)	<u>96.7</u>	<u>98.8</u>	<u>65.8</u>
18. UNIT FORCED OUTAGE RATE	<u>0.0</u>	<u>0.0</u>	<u>12.9</u>
19. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, AND DURATION OF EACH):			
Refueling, 1/6/96, 60 days			
20. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):			
N/A			

UNIT SHUTDOWNS AND POWER REDUCTIONS

NO.	DATE	TIME START OF OCCURRENCE	TIME RECOVER FROM OCCURRENCE	DURATION (HOURS)	TYPE	REASON	METHOD	CORRECTIVE ACTION/ COMMENTS
						NOTE (1)	NOTE (2)	NOTE (3)

None

SUMMARY:

NOTE (1) TYPE OF OCCURRENCE: ENTER CODE DOCKET NO. 50/458
 F: FORCED RIVER BEND STATION UNIT 1
 S: SCHEDULED

NOTE (2) REASON FOR OCCURRENCE: ENTER CODE REPORT NO. R-95-08
 A: EQUIPMENT FAILURE (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS) REPORT MONTH August, 1995
 B: MAINTENANCE OR TEST
 C: REFUELING
 D: REGULATORY RESTRICTION
 E: OPERATOR TRAINING AND LICENSE EXAMINATION DATE September 12, 1995
 F: ADMINISTRATIVE
 G: OPERATIONAL ERROR (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS) T. J. Bolke
 H: OTHER (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS) COMPLETED BY

NOTE (3) METHOD OF SHUTTING DOWN REACTOR OR REDUCING POWER: ENTER ONE Thomas J. Bolke
 1. MANUAL SIGNATURE
 2. MANUAL SCRAM Engineer III
 3. AUTOMATIC SCRAM TITLE
 4. OTHER (EXPLAIN IN CORRECTIVE ACTION/COMMENTS)

TELEPHONE: 504-346-8651 ext. 2940