



Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609

September 15, 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:


In the Matter of)	Docket Nos. 50-259
Tennessee Valley Authority)	50-260
		50-296

**BROWNS FERRY NUCLEAR PLANT (BFN) - MONTHLY OPERATING REPORT
FOR THE MONTH OF AUGUST 1995**

In accordance with the requirements of BFN Units 1, 2, and 3 Technical Specifications, Section 6.9.1.3, TVA is submitting the Monthly Operating Report for the month of August 1995 in the enclosure.

If you have any questions, please call me at (205) 729-2636.

Sincerely


Pedro Salas
Manager of Site Licensing

Enclosure
cc: See page 2

100114

9509190257 950831
PDR ADOCK 05000259
R PDR

JE24.1

U.S. Nuclear Regulatory Commission
Page 2
September 15, 1995

Enclosure

cc (Enclosure):

Mr. Mark S. Lesser, Acting Branch Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Frederick J. Hebdon, Director
Project Directorate II-4
Division of Reactor Projects I-II
Office of Nuclear Reactor
Regulation, Mail 13 H3
Washington, D.C. 20555

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5957

Mr. Jim Lang
Director of Engineering and Operations
Electric Power Research Institute
P. O. Box 10412
Palo Alto, California 94304

NRC Resident Inspector
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, Alabama 35611

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Fred Yost, Director of Research
Utility Data Institute
1200 G Street, NW
Washington, D.C. 20005-3802

ENCLOSURE

TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN)
UNITS 1, 2, AND 3

MONTHLY OPERATING REPORT
AUGUST 1995

SEE ATTACHED

OPERATIONAL SUMMARY
AUGUST 1995

BROWNS FERRY 1

Unit 1 remains shutdown on administrative hold to resolve various TVA and NRC concerns. Unit 1 has been on administrative hold since June 1, 1985. As a result, TVA considers that accrual of reporting hours is suspended since the unit has a maximum dependable capacity of 0 MWe. Accordingly, TVA does not consider cumulative reporting period hours for the period beginning June 1, 1985, when calculating the operating status variables.

BROWNS FERRY 2

During the month Unit 2 operated at a capacity factor of 93.2 percent and generated 757,600 megawatt hours gross electrical power. As of August 31, 1995, Unit 2 has operated continuously for 11 days.

BROWNS FERRY 3

Unit 3 remains shutdown on administrative hold to resolve various TVA and NRC concerns. Unit 3 has been on administrative hold since June 1, 1985. As a result, TVA considers that accrual of reporting hours is suspended since the unit has a maximum dependable capacity of 0 MWe. Accordingly, TVA does not consider cumulative reporting period hours for the period beginning June 1, 1985, when calculating the operating status variables.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-259
UNIT: BROWNS FERRY 1
PREPARED BY: T. R. Smith
TELEPHONE: (205) 729-2955

MONTH AUGUST 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>	16	<u>0</u>
2	<u>0</u>	17	<u>0</u>
3	<u>0</u>	18	<u>0</u>
4	<u>0</u>	19	<u>0</u>
5	<u>0</u>	20	<u>0</u>
6	<u>0</u>	21	<u>0</u>
7	<u>0</u>	22	<u>0</u>
8	<u>0</u>	23	<u>0</u>
9	<u>0</u>	24	<u>0</u>
10	<u>0</u>	25	<u>0</u>
11	<u>0</u>	26	<u>0</u>
12	<u>0</u>	27	<u>0</u>
13	<u>0</u>	28	<u>0</u>
14	<u>0</u>	29	<u>0</u>
15	<u>0</u>	30	<u>0</u>
		31	<u>0</u>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-296
 UNIT: BROWNS FERRY 3
 PREPARED BY: T. R. Smith
 TELEPHONE: (205) 729-2955

MONTH AUGUST 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>	16	<u>0</u>
2	<u>0</u>	17	<u>0</u>
3	<u>0</u>	18	<u>0</u>
4	<u>0</u>	19	<u>0</u>
5	<u>0</u>	20	<u>0</u>
6	<u>0</u>	21	<u>0</u>
7	<u>0</u>	22	<u>0</u>
8	<u>0</u>	23	<u>0</u>
9	<u>0</u>	24	<u>0</u>
10	<u>0</u>	25	<u>0</u>
11	<u>0</u>	26	<u>0</u>
12	<u>0</u>	27	<u>0</u>
13	<u>0</u>	28	<u>0</u>
14	<u>0</u>	29	<u>0</u>
15	<u>0</u>	30	<u>0</u>
		31	<u>0</u>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-260
 UNIT: BROWNS FERRY 2
 PREPARED BY: T. R. Smith
 TELEPHONE: (205) 729-2955

MONTH AUGUST 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1053</u>	16	<u>1029</u>
2	<u>1052</u>	17	<u>1044</u>
3	<u>1052</u>	18	<u>1053</u>
4	<u>1059</u>	19	<u>70</u>
5	<u>1061</u>	20	<u>253</u>
6	<u>1062</u>	21	<u>963</u>
7	<u>1064</u>	22	<u>1047</u>
8	<u>1063</u>	23	<u>1053</u>
9	<u>1062</u>	24	<u>1059</u>
10	<u>1059</u>	25	<u>1052</u>
11	<u>1059</u>	26	<u>1047</u>
12	<u>1045</u>	27	<u>1056</u>
13	<u>1043</u>	28	<u>1070</u>
14	<u>1058</u>	29	<u>1047</u>
15	<u>1037</u>	30	<u>1057</u>
		31	<u>1050</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS
 REPORT MONTH: AUGUST 1995

DOCKET NO: 50-259
 UNIT: BROWNS FERRY 1
 PREPARED BY: T. R. Smith
 TELEPHONE: (205) 729-2955

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report No.	System Code ⁴	Component Code ⁴	Cause and Corrective Action to Prevent Recurrence
1	06/01/85	S	744	F					Administrative hold to resolve various TVA and NRC concerns.

¹F-Forced
 S-Scheduled

²A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continuation of Existing Outage
 5-Reduction
 9-Other

⁴Instructions for Preparation of Licensee Event Reports (NUREG-1022)

UNIT SHUTDOWNS AND POWER REDUCTIONS
 REPORT MONTH: AUGUST 1995

DOCKET NO: 50-260
 UNIT: BROWNS FERRY 2
 PREPARED BY: T. R. Smith
 TELEPHONE: (205) 729-2955

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report No.	System Code ⁴	Component Code ⁴	Cause and Corrective Action to Prevent Recurrence
3	8/19/95	F	32	A	3	260/95007	WF	JX	Turbine tripped on low condenser vacuum caused by a failed power supply to both level control loops for the Offgas condenser drain valves. Replaced failed electrolytic capacitor in the power supply for the Offgas condenser drain valves.

¹F-Forced
 S-Scheduled

²A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continuation of Existing Outage
 5-Reduction
 9-Other

⁴Instructions for Preparation of Licensee Event Reports (NUREG-1022)

UNIT SHUTDOWNS AND POWER REDUCTIONS
 REPORT MONTH: AUGUST 1995

DOCKET NO: 50-296
 UNIT: BROWNS FERRY 3
 PREPARED BY: T. R. Smith
 TELEPHONE: (205) 729-2955

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report No.	System Code ⁴	Component Code ⁴	Cause and Corrective Action to Prevent Recurrence
1	06/01/85	S	744	F	4				Administrative hold to resolve various TVA and NRC concerns.

¹F-Forced
 S-Scheduled

²A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continuation of Existing Outage
 5-Reduction
 9-Other

⁴Instructions for Preparation of Licensee Event Reports (NUREG-1022)

OPERATING DATA REPORT

DOCKET: 50-259
 UNIT: BROWNS FERRY 1
 PREPARED BY: T. R. SMITH
 TELEPHONE: (205) 729-2955

OPERATING STATUS

1. Unit Name: BROWNS FERRY UNIT 1
2. Reporting Period: August 1995
3. Licensed Thermal Power (MWt): 3293
4. Nameplate Rating (Gross MWe): 1152
5. Design Electrical Rating (Net MWe): 1065
6. Maximum Dependable Capacity (Gross MWe): 0
7. Maximum Dependable Capacity (Net MWe): 0
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reason: N/A
9. Power Level To Which Restricted, If Any (Net MWe): 0
10. Reason For Restrictions, If Any: Administrative Hold

THIS MONTH YEAR TO DATE CUMULATIVE*

11. Hours in Reporting Period	0	0	95743
12. Hours Reactor Was Critical	0	0	59521
13. Reactor Reserve Shutdown Hours	0	0	6997
14. Hours Generator On Line	0	0	58267
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Generation (MWh)	0	0	168066787
17. Gross Electrical Generation (MWh)	0	0	55398130
18. Net Electrical Generation (MWh)	0	0	53796427
19. Unit Service Factor	0	0	60.9
20. Unit Availability Factor	0	0	60.9
21. Unit Capacity Factor (MDC Net)	0	0	52.8
22. Unit Capacity Factor (DER net)	0	0	52.8
23. Unit Forced Outage Rate	0	0	25.6
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): N/A			
25. If Shut Down At End Of Reporting Period, Estimated Date of Startup: To be determined			

* Excludes hours under administrative hold
(June 1, 1985 to present)

OPERATING DATA REPORT

DOCKET: 50-260
 UNIT: BROWNS FERRY 2
 PREPARED BY: T. R. SMITH
 TELEPHONE: (205) 729-2955

OPERATING STATUS

1. Unit Name: BROWNS FERRY UNIT 2
2. Reporting Period: August 1995
3. Licensed Thermal Power (Mwt): 3293
4. Nameplate Rating (Gross MWe): 1152
5. Design Electrical Rating (Net MWe): 1065
6. Maximum Dependable Capacity (Gross MWe): 1098.4
7. Maximum Dependable Capacity (Net MWe): 1065
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reason: N/A
9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reason For Restrictions, If Any: N/A

	THIS MONTH	YEAR TO DATE	CUMULATIVE*
11. Hours in Reporting Period	744	5831	127902
12. Hours Reactor Was Critical	717	5723	87850
13. Reactor Reserve Shutdown Hours	0	0	14200
14. Hours Generator On Line	712	5699	85559
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Generation (MWh)	2360758	18614193	249783108
17. Gross Electrical Generation (MWh)	757600	6218920	82962098
18. Net Electrical Generation (MWh)	738718	6069097	80658933
19. Unit Service Factor	95.7	97.7	66.9
20. Unit Availability Factor	95.7	97.7	66.9
21. Unit Capacity Factor (MDC Net)	93.2	97.7	59.2
22. Unit Capacity Factor (DER net)	93.2	97.7	59.2
23. Unit Forced Outage Rate	4.3	2.3	16.4
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	None		
25. If Shut Down At End Of Reporting Period, Estimated Date of Startup:	N/A		

* Excludes hours under administrative hold
 (June 1, 1985 to May 24, 1991)

OPERATING DATA REPORT

DOCKET: 50-296
 UNIT: BROWNS FERRY 3
 PREPARED BY: T. R. SMITH
 TELEPHONE: (205) 729-2955

OPERATING STATUS

1. Unit Name: BROWNS FERRY UNIT 3
2. Reporting Period: August 1995
3. Licensed Thermal Power (Mwt): 3293
4. Nameplate Rating (Gross MWe): 1152
5. Design Electrical Rating (Net MWe): 1065
6. Maximum Dependable Capacity (Gross MWe): 0
7. Maximum Dependable Capacity (Net MWe): 0
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reason: N/A
9. Power Level To Which Restricted, If Any (Net MWe): 0
10. Reason For Restrictions, If Any: Administrative Hold

THIS MONTH YEAR TO DATE CUMULATIVE*

11. Hours in Reporting Period	0	0	73055
12. Hours Reactor Was Critical	0	0	45306
13. Reactor Reserve Shutdown Hours	0	0	5150
14. Hours Generator On Line	0	0	44195
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Generation (MWh)	0	0	131868267
17. Gross Electrical Generation (MWh)	0	0	43473760
18. Net Electrical Generation (MWh)	0	0	42114009
19. Unit Service Factor	0	0	60.5
20. Unit Availability Factor	0	0	60.5
21. Unit Capacity Factor (MDC Net)	0	0	54.2
22. Unit Capacity Factor (DER net)	0	0	54.2
23. Unit Forced Outage Rate	0	0	21.6

24. Shutdowns Scheduled Over Next 6 Months
(Type, Date, and Duration of Each): N/A
25. If Shut Down At End Of Reporting Period,
Estimated Date of Startup: To be determined

* Excludes hours under administrative hold
(June 1, 1985 to present)