

APPENDIX A

NOTICE OF VIOLATION

TU Electric
Comanche Peak Steam Electric Station

Docket No. 50-446
Construction Permit No. CPPR-127

During an NRC inspection conducted on December 9-13, 1991, and January 6-9, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1991), the violation is listed below:

Criterion V of Appendix B to 10 CFR Part 50 requires that activities affecting quality be accomplished in accordance with procedures appropriate to the circumstance.

Contrary to the above, eight Unit 2 preoperational test procedures were found to contain numerous format and content errors and were determined to be inadequate and not appropriate to the circumstance for which they were written.

This is a Severity Level IV violation (Supplement II) (446/9167-01).

Pursuant to the provisions of 10 CFR Part 2.201, TU Electric is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region IV, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas,
this 10th day of February 1992