



231 W Michigan, PO Box 2046, Milwaukee, WI 53201

(414) 221-2345

VPNPD-92-075
NRC-92-021

February 14, 1992

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, D.C. 20555

Attention: Mr. Robert Samworth, Senior Project Manager
Project Directorate III-3

Gentlemen:

DOCKETS 50-266 AND 50-301
COMPLETION OF ACTIONS IN RESPONSE TO NRC GENERIC LETTER 89-06
CERTIFICATION OF FULL IMPLEMENTATION OF THE SAFETY PARAMETER
DISPLAY SYSTEM (TAG NOS. 73693 AND 73694)
POINT BEACH NUCLEAR PLANT UNITS 1 AND 2

By letters dated July 12, 1989, and March 5, 1991, we advised you of those tasks and their associated schedule necessary to certify the full implementation of the safety parameter display system (SPDS) at Point Beach Nuclear Plant Units 1 and 2. We received concurrence with these plans by NRC letters dated January 8, 1991, and March 22, 1991. The tasks that were incomplete as of our March 5, 1991, submittal (namely to document a basis for the SPDS setpoints and to compare parameter labels and abbreviations used in the SPDS with those used in the Standard Usage Manual) have now been completed. At this time, we can certify that our SPDS fully satisfies the requirements of NUREG-0737, Supplement 1, taking into account the information in NUREG-1342. This letter satisfies a request in your March 22, 1991, letter that we provide written notification upon full implementation of the SPDS.

Should you have any questions concerning this letter, please feel free to contact us.

Sincerely,

A handwritten signature in cursive script that reads "James J. Zach".

James J. Zach
Vice President
Nuclear Power

Copies to NRC Regional Administrator, Region III
NRC Resident Inspector

9202200181 920214
PDR ADDCK 05000266
P PDR

ADDCK
1/10