June 13, 1984

Docket No. 50-293

Mr. William D. Harrington Senior Vice President, Nuclear Boston Edison Company 800 Boylston Street Boston, Massachusetts 02199

Dear Mr. Harrington:

SUBJECT: PLANT SPECIFIC ANALYSIS TO DETERMINE GAS AND WATER CLEARING THRUST LOADS ASSOCIATED WITH SECOND SRV ACTUATIONS IN RELIEF VALVE DISCHARGE LINES

Re: Pilgrim Nuclear Power Station, Unit 1

One of the issues to be resolved related to the Mark I Containment Long Term Program (LTP) was whether following the initial safety relief valve (SRV) actuation, sufficient time for the water leg to stabilize exists prior to a second actuation. To satisfy the acceptance criteria in NUREG-0661 "Mark I Containment Long Term Program" related to water clearing thrust loads in the relief valve discharge lines, associated with second SRV actuations, some licensees have made system logic changes to reduce these loads. The logic changes used include variors combinations of lower SRV opening and closing setpoints and lower reactor vessel water level prior to main steam isolation valve (MSIV) closure.

We have recently become aware that at least one licensee has determined that these logic changes to reduce thrust loads, that it had previously intended to make, were no longer needed. A revised analysis performed by General Electric utilizing z methodology not approved in NUREG-0661 provided the basis for the licensee's decision. Since the methodology utilized appears to deviate from the methodology found acceptable by the staff, this letter is being sent to all BWR licensees that have Mark I containments that have not made setpoint logic changes to reduce water clearing thrust loads associated with second SRV actuations.

Within 45 days of receipt of this letter it is requested that you notify us if any analyses were performed utilizing methodology not previously approved in NUREG-0661 in determining if setpoint logic changes were needed to reduce water clearing thrust loads associated with second SRV actuations. In addition identify if any credit for operator action is required to prevent or reduce the thrust loads associated with second actuations of SRVs and if so, the kind of action and how long after event initiation the action is required.

8406250165 840513 PDR ADOCK 05000293 PDR Mr. William D. Harrington

This request for information was approved by the Office of Management and Budget under clearance number 3150-0091 which expires October 31, 1985.

- 2 -

Sincerely,

Original signed by/

Domenic B. Vassallo, Chief Operating Reactors Branch #2 Division of Licensing

cc: See next page

DISTRIBUTION Docket File NRC PDR Local PDR ORB#2 Reading DEisenhut OELD SNorris PLeech BSiegel ELJordan JNGrace ACRS (10) Gray File FEltawila

 DL:ORB#2
 DL:ORB#2
 DL:ORB#2
 DL:ORB#2
 DL:ORB#2

 SNorris:ajs
 PLeech
 BSiegel
 DVassallo

 06/11/84
 06/11/84
 06/13/84

Mr. William D. Harrington Boston Edison Company Pilgrim Nuclear Power Station

## cc:

Mr. Charles J. Mathis, Station Mgr. Boston Edison Company RFD #1, Rocky Hill Road Plymouth, Massachusetts 02360

Resident Inspector's Office U. S. Nuclear Regulatory Commission Post Office Box 867 Plymouth, Massachusetts 02360

Mr. David F. Tarantino Chairman, Board of Selectman 11 Lincoln Street Plymouth, Massachusetts 02360

Water Quality and Environmental Commissioner Department of Environmental Quality Engineering 100 Cambridge Street Boston, Massachusetts 02202

Office of the Attorney General 1 Ashburton Place 19th Floor Boston, Massachusetts 02108

U. S. Environmental Protection Agency Region I Office Regional Radiation Representative JFK Federal Building Boston, Massachusetts 02203

Mr. Robert M. Hallisey, Director Radiation Control Progam Massachusetts Department of Public Health 600 Washington Street, Room 770 Boston, Massachusetts 02111 Thomas A. Murley Regional Administrator Region I Office U. S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, Pennsylvania 19406

Mr. A. Victor Morisi Boston Edison Company 25 Braintree Hill Park Rockdale Street Braintree, Massachusetts 02184