

GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

June 15, 1984

5211-84-2134


Office of Nuclear Reactor Regulation
J. F. Stolz, Chief
Operating Reactors Branch No. 4
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Stolz:

Three Mile Island Nuclear Station, Unit I (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Asymmetric LOCA Loads (ALL)

As discussed with Mr. Owen Thompson of your staff, we are transmitting a copy of the back-up calculations showing that the TMI-1 hot leg restraint is adequate under ALL conditions. This information should resolve items 2.4.1, 2.4.4, 2.4.8, 3.3.1 and 3.3.2 of your letter dated March 27, 1984. The attached information also supplements GPUN letter dated June 25, 1982 (5211-82-151), B&W 1621 and its supplement. The attached information provides the appropriate calculations demonstrating the acceptability of the existing TMI-1 hot leg restraints without additional modification.

Sincerely,


H. D. Hukill,
Director, TMI-1

HDH/PGD/CWS/mle

Attachment: B&W Letter, B. J. Short to D. G. Slear
dated July 29, 1982 (ESC-393)

cc: R. Conte
J. Van Vliet

8406250211 840615
PDR ADOCK 05000289
P PDR

Aool
11

4C
4D

AUG 04 1982

PGD

~~AS-C~~
~~ESC-C~~
Nuclear Power Generation Division

Babcock & Wilcox

a McDermott company

July 29, 1982
ESC-393
582-7086/T1.2

3315 Old Forest Road
P.O. Box 1260
Lynchburg, Virginia 24505-1260
(804) 385-2000

TMI - 1

AUG 2 1982

RESTART

9.30.114

Mr. D. G. Slear, TMI-1 Engineering Project Manager
GPU Nuclear Corporation
100 Interpace Parkway
Parsippany, New Jersey 07054

Attention: Mr. J. A. Mahn

Subject: GPU Nuclear Corporation (TMI-1)
Master Services Contract, Effective date: June 1, 1977
Reference Nos.: B&W 582-7105, GPU M77120
Task 202 - Analysis of Hot Leg Support for Asymmetric LOCA Loads

Attachment: GPU Nuclear Vendor Transmittal Form, P.O. No. M77120,
transmitting B&W Document Number 32-1135359-00 (5 copies)


Dear Mr. Slear:

The results from evaluating the Asymmetric LOCA Loads for TMI-1 (Task 86) showed that the hot leg restraint was overstressed. Many discussions between your Mr. Steve Leshnoff and several engineers at B&W concluded that a less conservative calculation could be performed and a positive margin could be calculated.

The attached document shows a calculated safety factor of 1.002 and completes the subject Task 202.

If you need any further assistance, or have any questions, please call me at 804-385-2083.

Very truly yours,



B. J. Short, Senior Product Manager
Engineering Product Management

BJS/bgd

cc: S. Leshnoff - GPUN
W. D. Maxham - B&W
L. J. Stanek - B&W

To: D. G. SLEAR P.O. No. M77120
 Address: 100 Interpace Parkway WO/SO 5520/60270 B/A 412095
Parsippany, NJ 07054 Spec. No. NA Base 5522
 Subject: Analysis of Hot Leg Support for Engr. J. A. Mahn
Asymmetric LOCA Loads

From: Babcock + Wilcox
 Address: P.O. Box 1260
Lynchburg, Va. 24505
 Sub. By: B. J. Short
 Title: Sr. Product Manager
 No. Reprod. _____ No. Prints 5

- Submitted For:
- Waiver
 - Review
 - Dist.
 - Info

Sub. No. _____

Action Codes			
A	Drawing Reviewed	Without comments	1
		With comments as noted	2
		Not required	3
		No comments and no print returned	4
B	Vendor Action	No further reproducible is required	5
		Resubmit revised reproducible	6
		Resubmit certified mylar reproducible	7
		Do not proceed with fabrication resubmit revised reproducible	8

GPUN No.	Vendor Doc. No.	Rev.	Title	Act.
	<u>32-1135359-00</u>		<u>Review of GPUN Calculation for TMI Restraint Bracket Design</u>	

Waiver/Comment

Instruction/Comment

Approval _____
 Supervisor _____ Date _____

CALCULATION DATA/TRANSMITTAL SHEET

DOCUMENT IDENTIFIER CALC. 32 - 1135359 - 00
 TRANS. 86 - _____ - _____

TYPE: RESEARCH & DEVELOPMENT SAFETY ANALYSIS REPORT MUC. SERV. INPUT DESIGN RQMT. DESIGN VERIF. OTHER

TITLE Review of GPUN Calculation For TMI Restraint Bracket Design

PREPARED BY C. C. Lin *CC Lin* REVIEWED BY William D. Maxham

TITLE Principal Engineer DATE 7/28/82 TITLE Manager SSU DATE 29 July 82

PURPOSE:

To review GPUN design calculation for TMI Hot Leg Restraint Bracket

SUMMARY OF RESULTS (INCLUDE DOC. ID'S OF PREVIOUS TRANSMITTALS & SOURCE CALCULATIONAL PACKAGES FOR THIS TRANSMITTAL)

See summary of this document.

DISTRIBUTION

I. INTRODUCTION

This report presents our view on GPUN calculation No. 1101X-322C-A41¹, design qualification for TMI Hot Leg Restraint Bracket attachment. It is not intended to qualify the use of the results.

II. DESIGN REQUIREMENT

References 2 and 3 are used as the guideline for this review. Bracket design should meet the following requirements:

$$\text{II-a. } \phi \cdot F \geq \gamma \cdot L \quad \text{-----(1)}$$

Where F = Shear strength of the bracket

$$F = 1.4 \cdot (L - D_1/2) \cdot t \cdot \sigma_u^P \quad \text{... (2)}$$

L = Design Load

ϕ = Strength Reduction Factor

γ = Load Factor

$$\text{II-b. } l/D \geq 1.7 \cdot \frac{\sigma_b}{\sigma_u^P} \quad \text{-----(3)}$$

Where l = Length of Bracket Free-End Zone

D = Diameter of Pin

$\sigma_b = \gamma \cdot L / \text{Projected Area of Pin}$

$\sigma_u^P = 1.05 \cdot \sigma_u$ (σ_u = Ultimate Strength of bracket material)

The bracket has structural parameters as follows:

$$L = 7 \text{ in.}$$

$$D = 4 \text{ in.}$$

$$t = 3 \text{ in.}$$

$$\sigma_u = 58 \text{ ksi}$$

$$D_1 = 4.03125 \text{ in.}$$

III. REVIEW OF GPUN CALCULATION

Design load, L, of 1271.7 Kips is obtained from BAW-1621, the asymmetric LOCA loads analysis. Shear strength of the bracket, F, calculated from EQ.(2), is 1274.9 Kips.

III-1 To meet EQ.(1)

EQ. (1) Can be rewritten as

$$F/L \geq \frac{1}{\phi} \text{-----(4)}$$

It should be noted that F/L is also termed as safety factor (SF).

Therefore, the bracket is designed with $SF = F/L = \frac{1274.9}{1271.7} = 1.002$ --- (5)

If $\phi = .85$ is applied to the design, then EQ.(1) can be met only with using a load factor of .852 (<1.).

Hence, it can be concluded that the design has a SF of 1.002, and a load factor of .852 if strength reduction factor of .85 is used in design calculation. In case a load factor of 1, is to be used, this design provides no margin for strength reduction.

III-2 To meet EQ.(3)

EQ.(3) is derived with a safety factor of 2. To provide a SF of 1.002, EQ.(3) can be modified into

$$L/D \geq .852 \cdot \frac{V_b}{V_u} P \text{---(6)}$$

$$\text{with } L/D = \frac{7}{4} = 1.75 \text{ and}$$

$$.852 \cdot \frac{V_b}{V_u} P = .852 \cdot \frac{1271.7}{\frac{3 \cdot 4}{60.9}} = 1.5$$

Therefore, EQ.(6) is met if SF of 1.002 is used in design.

IV. SUMMARY

The design of TMI Hot Leg Restraint Bracket has a safety factor of 1.002, and allows no margin for strength reduction if a LOAD factor of 1. is used.

V. REFERENCES

1. GPUN calculation no. 1101X-322C-A41 (Attached)
2. AISC Code, 1978
3. Fisher, J.W., and Struk, J.H.A., "Guide to Design Criteria For Bolted and Rivets Joints," Wiley, 1974.

SUBJECT EVALUATION OF TMI-1 HOT LEG RESTRAINT AFTER

DATE 7/28/81

POSTULATED GUILLOTINE BREAK AT ELBOW

COMP. BY/DATE E 7/27/81

CHK'D. BY/DATE P.S. 7/31

32-1135359-001.0 STATEMENT OF THE PROBLEM

The asymmetric LOCA loads (ALL) analysis (BAW-1621) identified the bracket attachment to the primary wall embedment portion of the hot leg restraint as a possible point of failure subsequent to a guillotine break at the elbow. This is, in fact, not an asymmetric LOCA load but was considered as part of the ALL evaluation.

Due to a maximum load of 1271.7 KIPS, the bracket attachment is said to fail by a shear-out failure due to high bearing loads. If true, a reportable situation exists due to a structural deficiency from a loading that is part of the plant design basis.

2.0 KEY RESULTS

A technical logic exists which can be used to demonstrate that the hot leg restraint bracket attachment will not fail at the postulated load. The technical logic employs:

1. NRC Standard Review Plan (SRP) 3.6.2 to incorporate strain rate effects (10% increase on yield strength and a permissible strain of one-half the uniform ultimate strain).
2. AISC Sec. 1.5.2.2 to incorporate a 35% increase in yield when considering bearing stress.
3. A B & W Owners Group position on material property variability to increase both yield strength and ultimate strength by 5%.
4. Design guidelines from the experimental work of, Fisher, J. W., and Striuk, J. H. A., Guide to Design Criteria for Bolted and Riveted Joints, Wiley, 1974.

The results below are supported by calculation

1. The maximum overload to be taken in bearing is 1271.7 KIPS. It can be shown that the maximum allowable load is 1274.9 KIPS.
2. The net section tension stress is 42.53 KSI while the maximum net section tension strength is found to be 42.77 KSI.

Attached Reference

SUBJECT EVALUATION OF TM2-1 HOT LEG RESTRAINT AFTER

DATE 7/28/81

COMP. BY/DATE E 7/28/81

POSTULATED GUILLOTINE BREAK AT ELBOW.

CHK'D. BY/DATE J. D. S. 7/1

These results are conservative because the following load reduction mechanisms are not invoked:

1. A plastic hinge develops in the hot leg piping between the restraint and the OTSG inlet which will permit the large rotation required for the pipe to contact more than the 4 U-bars of the 7 that are impacted.
2. These results ignore the energy absorbing circumferential deformation of the hot leg pipe as it bears against the U-bars. The pipe is treated as infinitely stiff with respect to local deformations.

3.0 CONCLUSIONS

A reportable situation does not exist. There is margin in the present structure, without modification, to withstand a maximum load of 1271.7 KIPS as a result of a guillotine break at the hot leg elbow. Structural integrity is demonstrated using NRC SRP 3.6.2, AISC code, and the technical literature.

4.0 REFERENCES

1. BAW-1621, BW 177-FA OWNERS GROUP, EFFECTS OF ASYMMETRIC LOCA LOADS, PHASE 2 ANALYSIS, JULY '80.
2. FISHER, J.W., & STRUIK, J.H.A., GUIDE TO DESIGN CRITERIA FOR BOLTED AND RIVETED JOINTS, WILEY, 1978.
3. AISC MANUAL OF STEEL CONSTRUCTION, SEVENTH EDITION.
4. NRC STANDARD REVIEW PLAN (SRP) 3.6.2.

5.0 ASSUMPTIONS AND BASIC DATA.

1. LOADS

THE ELBOW BREAK LOADS ARE IDENTIFIED ON THE FOLLOWING TABLE (TABLE 1). ONLY THE PEAK LOAD AT BAR #1 IS CONSIDERED.

2. GEOMETRY

APP B. CONTAINS A SKETCH OF THE AREA.

SUBJECT EVALUATION OF TMI-1 HOT LEG RESTRAINT AFTER

DATE 7/27/81

POSTULATED WILLOWTIME BREAK AT 6

COMP. BY/DATE E 7/28/81

CHK'D. BY/DATE J.P. Sh... 7/31

Summary of Pipe Whip Restraint Loads for TMI-1 - As-Built(a)

<u>Break type</u>	<u>Restraint (see Figure B-2)</u>	<u>Peak load, lb</u>	<u>Load description</u>
Hot leg guill. at RV	No. 1, bar 1	2,533,810	Tension
	bar 2	2,513,110	Tension
	bar 3	2,275,870	Tension
	bar 4	868,406	Tension
	bar 5	NI	--
	bar 6	NI	--
	bar 7	NI	--
	Sum	8,161,230	Tension
	Collar	NI	--
	No. 2	NI	--
Hot leg guill. at elbow	No. 1, bar 1	2,543,340 *	Tension
	bar 2	2,519,150	Tension
	bar 3	2,261,450	Tension
	bar 4	544,007	Tension
	bar 5	NI	--
	bar 6	NI	--
	bar 7	NI	--
	Sum	7,718,890	Tension
	Collar	NI	--
	No. 2	NI	--

* DESIGN LOAD

Note: NI: not impacted.

TABLE 1
PEAK DESIGN LOAD FOR ELBOW BREAK

1 2 7 1 6
2 5 4 3 0 1

SUBJECT TM2-1 HOT LEG RESTRAINT, BRACKET ATTACHMENT

EVALUATION AFTER ELBOW BREAK.


6.0 CALCULATIONS.

BRACKET STRESSES

MAX AXIAL LOAD: 1271.7 KIPS.

6.1 TENSION

$$\sigma_t = \frac{1271.7 \text{ KIPS}}{4.984 \text{ in}^2} = 42.53 \text{ KSI.}$$



THIS STRESS IS ACCEPTABLE USING EITHER OF TWO CRITERIA.

1. USING NRC SRP 3.6.2, THE MAX. STRAIN FOR RESTRAINTS SHOULD NOT EXCEED ONE-HALF THE UNIFORM ULTIMATE STRAIN, $\frac{1}{2} \epsilon_{uN}$. THE STRESS ASSOCIATED WITH THIS STRAIN IS $S_u = 51.15 \text{ KSI. (FIG. 1)}$

$$\sigma_t < S_u.$$

2. IN FISHER & STRUIK, REF. ABOVE IT IS NOTED THAT IT IS USUALLY CONSIDERED DESIRABLE FOR A PINNED JOINT TO HAVE THE CAPACITY FOR DISTORTION OR GEOMETRICAL ADJUSTMENT BEFORE FAILURE BY FRACTURE. THIS MEANS THAT THE CONNECTION SHOULD PERMIT YIELDING TO OCCUR IN THE GROSS CROSS-SECTION MEMBER BEFORE THE JOINT FAILS THROUGH THE NET SECTION. THIS REQUIREMENT IS SATISFIED IF:

$$\frac{A_n}{A_g} \geq \frac{\sigma_y}{\sigma_u}$$

EQ. 5:10 IN FISHER & STRUIK.

Attached Reference

SUBJECT A.L.L. HOT LEG RESTRAINT BRACKET

DATE 7/16/81

COMP. BY/DATE S 7/28/81

CHK'D. BY/DATE P. Shen 7/31

ATTACHMENT EVALUATION AFTER ELBOW BREAK




FIG. 1

STRESS-STRAIN CURVE FOR STRUCTURAL STEEL.

SUBJECT TH3-1 HOT LEG RESTRAINT, BRACKET ATTACHMENT

DATE 7/28/81

COMP. BY DATE E 7/28/81

EVALUATION AFTER ELBOW BREAK

CHK'D. BY DATE P. Sim 7/31

BY REARRANGEMENT,

$$A_n \sigma_u \geq A_g \sigma_y$$

SOLVING FOR THE NET SECTION ALLOWABLE, REMEMBERING THAT σ_u PERTAINS TO THE NET SECTION AND σ_y TO THE GROSS SECTION,

$$A_n (\sigma_n)_{ALLOW.} = A_g (\sigma_y)_{ALLOW.}$$

$$(\sigma_n)_{ALLOW.} = \frac{A_g}{A_n} (\sigma_y)_{ALLOW.} = \frac{(\sigma_y)_{ALLOW.}}{A_n/A_g}$$

NOW,

$$\frac{A_n}{A_g} = \frac{2 \times 4.984 \times 3}{2 \times 7.00 \times 3} = 0.712$$

$$\phi (\sigma_y)_{ALLOW.} = .5 \sigma_u \quad (\text{AISC SECT. I.5.1.1})$$

SUBSTITUTING,

$$(\sigma_n)_{ALLOW.} = \frac{30.45}{.712} = 42.77 \text{ KSI} > \sigma_c$$

IT IS USEFUL TO NOTE THAT:

$$\begin{aligned} A_n \sigma_u &\geq A_g \sigma_y \\ (2 \times 4.984 \times 3) (1.85 \times 58) &\geq (2 \times 7.00 \times 3) (1.1 \times 1.05 \times 36) \\ (29.904) (60.9) &\geq (42) (41.58) \\ 1821.2 &\geq 1746.4 \end{aligned}$$

THE GROSS SECTION REACHES YIELD BEFORE THE NET SECTION FRACTURES.

FISHER AND STRUIK RECOMMEND A FACTOR, ϕ , EQUAL TO 0.85.

$$\frac{A_n}{A_g} \geq \frac{\sigma_y}{\phi \sigma_u}$$

IN THIS APPLICATION, THE FACTOR IS .96 AND IS JUSTIFIED BY VIRTUE OF INFREQUENT LOADING.

Attached Reference

SUBJECT TH3-1 HOT LEG RESTRAINT, BRACKET ATTACHMENT

DATE 7/28/81

EVALUATION AFTER ELBOW BREAK.

COMP. BY/DATE S. 7/28/81

CHK'D. BY/DATE P.S. 7/28/81

BRACKET STRESSES

MAX AXIAL LOAD : 1271.7 KIPS.

6.2 BEARING

USE OF G_u FOR BEARING ALLOWABLE

AISC 1.5.2.2 MAT'L PROP. VARIABILITY ϕ (SRP 3.6.2) AISC 1.5.6 FOR INFREQUENT LOAD

$$F_p = 1.35 F_y \times 1.05 \times 1.10 \times 1.33$$

$$= 2.07 R_y = 74.66 \text{ KSI} > G_u$$

USE G_u .

FROM FISHER & STRUIK, USING LOAD FACTOR DESIGN,

$$F = (2t) \left(L - \frac{d}{2} \right) (0.7 G_u^P) \quad \text{EQ. 5.35 IN FISHER & STRUIK.}$$

$$F = (1.4) \left(7 - \frac{4.03125}{2} \right) (3) (60.9)$$

$$F = 1274.9 \text{ KIPS.}$$

$$F > F_{APPLIED} ; F_{APPLIED} = 1271.7 \text{ KIPS.}$$

THE LIMITING LOAD CAPACITY IS GREATER THAN THE APPLIED LOAD


THE ULTIMATE TENSILE STRENGTH IS

$$G_u = 1.05 \text{ (FOR MAT'L PROP. VARIABILITY)} \times (\sigma_u)_{MIN}$$

$$= (1.05 \times 58) = 60.9 \text{ KSI.}$$

32-1135359-00
JUL 07 1981

1 of 4



Page 11

Attached Reference

ENC. ADJUSTMENT
ABOVE

APP " 2 of 4
E

SURGE LINE
CONN. TO
HOT LEG
SEE GA1 DWG
E-015-03B

EL 317'-2 3/4"

FOR LUG
SEE DET 'A'

4" φ
VERT
PIN

2'-8 1/2"


3 1/2" 1'-0"
(TYP)

2'-6 1/2"

7 1/2" 7 1/2"

4" φ
VERT
PIN


2'-0 1/2"
WIDE R (TY



9'-0 1/2"
FLAT SURFACE

36" φ PIPE

4'-9"



DET 'A'
3" THK R


PLATFORM
EL 306'-9"

32-1135359-00

Page 12
SECT A

Attached
Reference
SH 2 OF 4

APP A
2/4
E



(EL 318'-1")

FLAT SURFACE
EL 317'-0"

φ 3" φ PIPE
(INSUL)

φ 4" φ
VERT
PIN

3" CL
(TYP)

φ 36" φ PIPE

2 φ 4" φ VERT
PIN


EL 314'-0"

32-1135859-00

			PLATFORM (EL 306'-9")	Attached Reference

IC

APP A
4 of 6



SEE DET
'B'

8 1/8"

1/4"
3"
1/8"

DET B
1"=1'-0"

SADDLE
R

36" φ PIPE

EL 314.0

4'-4"

PRIMARY
WALL

DECAY HEAT SYSTEM
NOZZLE SEE GAT
DWG E 304-642

32-1135359-00

Page 14

PLATFORM
EL 303.9"

Attached
Reference

SH 4 OF 6