

~~05-69-90~~

67-1A

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: U. S. NUCLEAR REGULATORY COMMISSISON

Title: INTERVIEW OF GREGORY LEE, JOHN AUFDENKAMPE, WILLIAM F. KITCHENS, WILLIAM BURMEISTER AND DEAN WEST

Docket No.

LOCATION: Waynesboro, Georgia

DATE: March 28, 1990

PAGES: 1-122

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

9202200347 920116
PDR ADDCK 05000424
S PDR

Page	Line	Correction and Reason for Correction
45	2d3	delete "the greatest period ... ago." since it is not necessary + is more clearly explained by the following sentence.
47	24	add "already" before "received" for clarity.
50	2	change "9-C" to "I+C" (accuracy)
63	1b	change "include" to "conclude" (accuracy)
74	8	delete "in" (for clarity)
74	1b	change "from" to "for" (accuracy)
75	2	change to "have is to have in excess of the Tech Spec minimum" (clarity)
75	25	change "a commulator" to "an accumulator" (accuracy)
76	b	change "control monitor" to "control room monitors" (accuracy)
82	2	change "rent" to "mid"
82	19	change "onto" to "into"
83	15	"these drain" to "these drains" plural
88	5	change "operable" to "inoperable"
97	14	change "pressurize" to "depressurize"
99	7	change "and" to "at"
104	23	change "the" to "they"
105	2	use colon after "are"

ADDENDUM TO INTERVIEW OF

Dean West
(Print Identity of Interviewee)

Page

Line

Correction and Reason for Correction

No Comments

Page

_____ Date 4-3-90

Signature

Dean West

U. S. NUCLEAR REGULATORY COMMISSION

INTERVIEW OF:

GREGORY LEE)
 JOHN AUFDENKAMPE)
 WILLIAM F. KITCHENS)
 WILLIAM BURMEISTER)
 DEAN WEST)

Main Conference Room
 Administration Building
 Vogtle Electric Generating Plant
 Waynesboro, Georgia

Wednesday, March 28, 1990

The interview commenced at 1:43 p.m.

APPEARANCES:

On behalf of the Nuclear Regulatory Commission:

WILLIAM LAZARUS
 WARREN LYON
 AL CHAFFEE
 BILL JONES
 RICK KENDALL
 GENE TRAGER

On behalf of INPO:

PAUL DIETZ

On behalf of CP&L:

MIKE JONES

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J
O
7
0
0
2

F
C
R
M

F
E
D

PROCEEDINGS

1
2 MR. LAZARUS: The date is March 28, 1990, 1:44 p.m.
3 We're at Vogtle Station conducting an interview with --
4 Whereupon,

5 DEAN WEST
6 WILLIAM BURMEISTER
7 WILLIAM F. KITCHENS
8 JOHN AUFDENKAMPE
9 GREGORY LEE

10 appeared as witnesses herein and were examined and testified
11 as follows:

12 EXAMINATION

13 WITNESS WEST: Dean West, Operations Department,
14 Procedures Group.

15 WITNESS BURMEISTER: Bill Burmeister, Unit
16 Superintendent.

17 WITNESS KITCHENS: Skip Kitchens, Assistant General
18 Manager.

19 MR. AUFDENKAMPE: John Aufdenkampe, Manager,
20 Technical Support.

21 WITNESS LEE: Greg Lee, Engineering Supervisor.

22 MR. LAZARUS: Okay, thank you.

23 The purpose of the interview is to develop
24 background on your responses to Information Notice 8817.

25 MR. LYON: Could each of you in turn perhaps in two
26 or three sentences kind of thing just give us a feedback of
27 your involvement in the 8817 process between the time you

R
E
N
G
A
D
C
O
B
A
Y
O
N
N
E
N
J
0
7
0
0
P
F
O
R
M
F
E
E
D

1 essentially received that letter and say today?

2 WITNESS WEST: What I essentially -- this is Dean
3 West -- what I essentially did was coordinate with Greg Lee
4 in Engineering and took all the action items and worked them
5 into the operations procedures and also we did some liaison
6 work with Mechanical Maintenance and I&C Department for some
7 of their procedures for instrumentation enhancements. That
8 was my role, making sure they got in the procedures.

9 MR. LYON: You said I&C and what was the other?

10 WITNESS WEST: Mechanical Maintenance.

11 MR. LYON: Okay.

12 WITNESS BURMEISTER: Bill Burmeister -- I've been
13 involved in a couple of different ways, primarily as an
14 operations person, I've seen all the changes that were made
15 to the procedures since the early generic letter came out on
16 the subject and the updated 8817 letter came out, and how it
17 affected our procedures and I've reviewed the resulting
18 changes. I've also been involved in reviewing changes,
19 physical changes that were made to the plant as far as
20 instrumentation and permanent site glass that we're putting
21 in and have been involved in another way through the owners'
22 group, Westinghouse owners' group. They have developed a
23 guideline on loss of RHR at mid-loop conditions and I've
24 been involved in reviewing and developing that as part of
25 the Westinghouse owners' group.

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
S

N
J
0
7
0
0
C

F
O
R
M

P
E
D

1 MR. LYON: Has that guideline been issued?

2 WITNESS BURMEISTER: No, it's very close. I was
3 told two weeks ago that it would be issued in two weeks and
4 so I would say its issue is imminent.

5 MR. LYON: Okay.

6 WITNESS KITCHENS: I've been involved in
7 implementation and the review of the 8817 and the overall
8 issue on mid-loop as a part of the Plant Vogtle management
9 team.

10 Let me say maybe an overview of the thing here.
11 When we first got the generic letter and the issues that
12 were involved, we did have a task force here and I believe
13 that's what Dean West alluded to as to the inter-
14 departmental group that worked on what should our response
15 be and how can we respond to this item.

16 Also we have currently in the corporate office in
17 the SONOPCO project -- this is one of the projects that has
18 a project manager assigned to it and we're statused each
19 month as to the status of it. So although the people that
20 are here, with the possible exception of John, will mostly
21 just talk about operational aspects and the procedures, we
22 can also talk to you about training. There is an overall
23 project leader in our company from the point of view of
24 ensuring not only operations and maintenance activities are
25 done right but design changes and analyses that we've done

P
E
N
G
A
D
C
O
B
A
Y
O
N
N
E
N
J
C
T
D
O
G
2
F
O
R
M
F
E
D

1 were all coordinated in a way, so we did have a project and
2 a schedule for all that.

3 I'd like to say one other thing and I don't mean
4 this to be a paid political announcement, but to start with,
5 I believe that some of the changes that we made to our plant
6 and some of the changes we made to our procedures did help
7 us to come through the event the other day, the site area
8 emergency. So I think that we learned some lessons because
9 of the generic letter and also because of the case study
10 from Diablo Canyon that our people were trained on.

11 MR. LYON: Okay.

12 MR. AUFDENKAMPE: I'm John Aufdenkampe. I was
13 involved early when it came out as 8712 from an engineering
14 standpoint. I was in the Engineering Support Department as
15 an engineering supervisor for NSSS systems at the time.

16 Most of my focus has been on the hardware side of it
17 up until I guess about six months ago when I changed
18 departments. But I was involved in the early development of
19 the hardware side. I worked closely with Jim Mintz who is
20 the project manager that Skip referred to in the corporate
21 office and also was involved in reviewing our submittals to
22 the Commission associated -- the 60-day submittal, the 90-
23 day submittal associated with generic letter 8817.

24 MR. LYON: That was Jim -- would you spell the last
25 name?

1 MR. AUFDENKAMPE: M-i-n-t-z. He is available via
2 telephone if we need to talk to him, as is our licensing
3 engineer associated with this project, Jack Stringfellow in
4 Birmingham.

5 MR. LYON: Okay.

6 WITNESS LEE: I'm Greg Lee and I was an operations
7 supervisor when I started -- was introduced to generic
8 letter 8712 -- and I say introduced to it, I noted the
9 significance of the whole event. Anyway, I was involved
10 with the response to the generic letter and looking at --
11 giving input to Engineering what I felt like we needed as
12 far as instrumentation and all to meet the generic letter.
13 We were about to go into a mid-loop situation and I had to
14 get the AOP, abnormal operating procedure 18019 ready for
15 that event, deciding, you know, what we needed to do as far
16 as vent path, what kind of vent path to use and that sort of
17 thing. I've been to some workshops, a workshop that you
18 were at, Warren, on operation. I went to that one and got
19 all the information on that and I took the WCAP and used the
20 generic information and wrote a plant specific AOP from
21 that, and you know, decided based on that which way we
22 needed to go. Like can we close containment in two hours or
23 not, that was one of the things I found to be real
24 significant at your workshop and we wrote that as a
25 cautionary procedure.

1 But anyway, I was involved with that procedure and
2 later on I became involved with making sure that the rest of
3 the operations procedures like the UOPs, the drain down
4 procedure and all, had the correct kind of correlation
5 between the different procedures and the controls necessary
6 to set up for draining down, making sure instrumentation was
7 installed when it needs to be installed, relying on other
8 departments to make sure to install the instrumentation,
9 that sort of thing, so I was pretty well involved with
10 generic letter 8712 and 8817. I always consider it 8712
11 because that was the beginning of it all.

12 MR. LYON: Do you recall the number of that WCAP?

13 WITNESS LEE: No, I didn't, because I used --

14 WITNESS BURMEISTER: 11916.

15 WITNESS LEE: I think that's what it is. I got a
16 copy from Eric Franze from Westinghouse in the beginning and
17 it was the same information. I was just going to use that.

18 MR. LYON: I understand.

19 WITNESS LEE: Had all the curves, heat up curves and
20 vent sizes.

21 MR. LYON: And which workshop did you attend?

22 WITNESS LEE: Okay, I attended one in D.C. and it
23 was more relative to the inspection teams on EOPs.

24 MR. LYON: That was the Dulles Airport workshop?

25 WITNESS LEE: Yes.

1 MR. LYON: That was held last summer I believe.

2 WITNESS LEE: That's right.

3 MR. LYON: Okay.

4 WITNESS LEE: The one that you held was in Atlanta.

5 MR. LYON: There was a panel discussion in Atlanta.

6 There was one in Denver immediately after the Dulles one.

7 WITNESS LEE: I went to the Denver.

8 MR. LYON: You went to the Denver one, not the
9 Dulles?

10 WITNESS LEE: That's right.

11 MR. LYON: Okay. Were you also involved in the
12 workshop that Westinghouse sponsored in oh, I think it was
13 September of '88?

14 WITNESS LEE: No, I was not.

15 MR. LYON: Okay.

16 WITNESS LEE: But I was -- I have been a participant
17 in a Westinghouse owners' group and I was involved in early
18 development of that generic --

19 MR. LYON: Is this the operations subcommittee side?

20 WITNESS LEE: Operations subcommittee.

21 MR. LYON: Okay. And you essentially were the
22 channel to provide this information back to Vogtle?

23 WITNESS LEE: That's right. I've been involved with
24 the shutdown LOCA issues and that sort of thing too and I've
25 recently dropped out of being a participant and Bill

W
A
D
C
O
S
A
Y
O
N
N
E
N
C
O
S
E
S
2
F
O
R
M
I
D

1 Burmeister has picked up the Georgia Power representative
2 for Vogtle.

3 MR. LYON: Let me kind of go back and let's follow
4 just a little bit of history of the process. The first
5 communication that came out on this as I recall was an
6 information notice shortly after Diablo Canyon?

7 WITNESS LEE: Yes.

8 MR. LYON: Could you tell us your response to that?

9 WITNESS LEE: I don't remember the response to it.
10 I considered it very similar in events, that the information
11 notice was very similar type of situation to the generic
12 letter.

13 MR. LYON: Now this was before -- this was
14 immediately following the Diablo Canyon event, one of the
15 first pieces of information that came out as I recall was an
16 information notice. I forget the number. Would that have
17 come to you eventually?

18 WITNESS LEE: Yes, it would have.

19 MR. LYON: Do you recall any Plant Vogtle response
20 to that?

21 WITNESS LEE: Not really. It became a NUREG -- the
22 Diablo Canyon became a NUREG.

23 MR. LYON: Yes.

24 WITNESS LEE: I think it was 11 --

25 WITNESS BURMEISTER: 1269.

1 WITNESS LEE: I don't remember the number. That's
2 when -- I considered that more detailed and more useful.
3 The other event just seemed like another event, it just kind
4 of was redundant I thought to the generic letter.

5 MR. AUFDENKAMPE: If it was issued as an information
6 notice, we would have, I'm 99 percent sure, put together a
7 package on it and would have reviewed it and we can pull
8 that up and find out what our initial response -- at least
9 our evaluation of the condition was.

10 MR. LYON: I'm going to be much more interested in
11 recent history than past history, as you will -- I'm just
12 going to try to lay a path and a foundation and see how we
13 go.

14 WITNESS LEE: I'm sure there is, you know, response
15 like John said, on every information notice and bulletin.

16 MR. LYON: I understand. Now the NUREG you referred
17 to came out in June following the Diablo Canyon event that
18 previous April.

19 WITNESS LEE: Yes.

20 MR. LYON: And 88 -- I'm sorry, 8712, the generic
21 letter, came out very shortly thereafter. I would guess you
22 got them both at about the same time.

23 WITNESS LEE: Right, I didn't even remember which
24 one occurred -- they were very similar in nature.

25 MR. LYON: Could you folks briefly describe the

P
E
N
G
A
D
C
O
B
A
Y
O
N
N
E
N
D
I
T
O
O
2
F
O
R
M
F
E
E
D

1 Vogtle response to those?

2 WITNESS LEE: Well --

3 WITNESS KITCHENS: Without going back and looking,
4 we're not going to be able to tell you the Vogtle response
5 to specific I&E notices without looking back into our files.

6 MR. LYON: Okay. That's a fair feedback.

7 WITNESS KITCHENS: I want to be sure that when we
8 answer you, that --

9 MR. LYON: This was two years ago. I'll tell you
10 what, why don't we for the time being -- did you initiate
11 actions at the plant in response to those two documents?

12 WITNESS LEE: Yes.

13 MR. AUFDENKAMPE: In response to 8712, definitely.
14 We definitely took action because we were preparing to go
15 into an outage at that time.

16 WITNESS LEE: Right and I took it very seriously
17 because I knew that we were going into that situation and it
18 had special precautions that had to be taken into
19 consideration.

20 MR. LYON: Okay, so you did address them then.

21 WITNESS LEE: I felt like we addressed it in the
22 procedures for generic letter 8712, before we went into the
23 outage.

24 MR. LYON: And you beat me to it, you took my
25 question away from me.

P
E
N
G
A
D

C
O
S
A
V
I
O
N
N
E

N
O
7
0
0
2

F
O
R
M

F
E
D

1 WITNESS LEE: Good, that's the way we wanted it.

2 MR. LYON: Okay. And did you have preliminary
3 notification of the content of generic letter 8817 -- yeah,
4 preliminary information.

5 WITNESS LEE: Yes, I did. I believe your workshop
6 was even preliminary. You know, you said it wasn't issued
7 yet. I got a copy of that before I went to the workshop, a
8 preliminary version of it, realizing that it changed.

9 WITNESS KITCHENS: 8817, I don't remember the exact
10 details but we did get some preliminary information on it,
11 which we acted on for our first refueling outage.

12 MR. LYON: Okay, this came by way of Larry Walsh and
13 the owners' group?

14 WITNESS LEE: Yes.

15 MR. LYON: And you did then initiate activities in
16 response to that?

17 WITNESS LEE: Yes, we did.

18 MR. LYON: Was that information consistent with what
19 you later received as 8817?

20 WITNESS LEE: It was more detailed.

21 MR. LYON: In which?

22 WITNESS LEE: Especially on the containment closure
23 issue.

24 MR. LYON: 8817 was more detailed?

25 WITNESS LEE: 8817 seemed to me to be more detailed

P
E
N
G
A
D
C
O
B
A
Y
O
N
N
E
N
T
O
O
2
F
O
R
M
F
E
D

1 in that area.

2 MR. LYON: Okay. Were there any inconsistencies? I
3 recognize the more detail in the published document, were
4 there any inconsistencies that caused you extra work between
5 what you had gotten by way of the owners' group operations
6 subcommittee and 8817 when it came in?

7 WITNESS LEE: It was just a different emphasis. We
8 had to look at it a little more differently, especially in
9 the area of containment. After reading 8712, we may not
10 have noticed that we had -- we thought that containment, you
11 know, if you had steam in the area, we didn't know what
12 degree of containment closure, and especially after going to
13 the workshop, made it clear that, you know, we practically
14 have to establish containment integrity, that we couldn't
15 just put a plastic liner up and that would be sufficient.
16 We had to close the hatch with at least so many bolts on the
17 inside.

18 MR. LYON: What is your impression of the need for
19 closure? What is it that we are trying to protect against?

20 WITNESS LEE: The fact that you would have a release
21 of steam. You may have fuel damage -- if it got so hot that
22 you had fuel damage, core uncovered, you would have gases
23 that would --

24 WITNESS KITCHENS: Radioactive release from
25 containment.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

WITNESS LEE: Out to the -- straight to the --

MR. LYON: Are we trying to protect against a release or do we anticipate a real pressurization of containment?

WITNESS LEE: Well there wasn't an exact amount of pressurization involved, but you know, most people felt that it was going to be a very minimal amount of pressurization to -- you know, because of the volume in the -- of RCS and decay heat, it would not pressurize containment that much.

MR. LYON: Did you ever -- do you recall having ever received any kind of message or feedback that our real concern was the -- being able to contain a core melt at least for some reasonable period of time and to protect against the pressurization that would result from a hydrogen burn which would be expected following a core melt?

WITNESS LEE: Yes, we heard that and, you know, as far as there being a hydrogen burn, so that would be -- that was another concern of the workshop. There would have to be a certain number of containment coolers running.

MR. LYON: Did that get factored into the degree of closure that you folks had to provide?

WITNESS LEE: Since we had to go to containment closure -- establish containment integrity, then yes, it would have been, you know, sufficient for the pressurization and containment cooling measures were taken too.

P
E
N
S
I
D
C
O
B
A
Y
O
N
N
E
N
7
0
0
2
F
O
R
M
F
E
E
D

1 MR. LYON: Would you hazard a guess as to order of
2 magnitude pressure you might be protecting against?

3 WITNESS LEE: That was never determined. There was
4 a lot of speculation about what that pressure might be, you
5 know. After attending the workshop and everything, I
6 gathered some people thought it was not that -- the amount
7 of pressurization would be minimal. I didn't know -- all I
8 know is I established containment integrity because I didn't
9 know what value that we could expect.

10 MR. LYON: Okay.

11 WITNESS LEE: This is what we provided in the
12 abnormal procedure, was if you lose RHR, establish
13 containment integrity.

14 WITNESS KITCHENS: Yeah, but what you're really
15 establishing is refueling containment integrity.

16 WITNESS LEE: Yes, all the bolts would not be
17 completely established. We did track containment
18 penetrations by information LCO's. We knew -- we had a way
19 of identifying them and --

20 WITNESS KITCHENS: I just wanted to be sure you
21 didn't -- containment integrity, Modes 1 through 4,
22 refueling integrity, what we have in our procedures is to
23 establish a Mode 6 refueling level, basically, we go out and
24 do the surveillances.

25 MR. LYON: Do you recall the generic letter 8817

1 guidance as to the degree of closure needed on the equipment
2 hatch?

3 WITNESS LEE: There had to be like four bolts, if it
4 was an inside sealing patch.

5 MR. LYON: It was four bolts.

6 WITNESS LEE: Four bolts.

7 MR. LYON: I don't believe you'll find that
8 criterion in 8817.

9 WITNESS LEE: I'm not sure where --

10 WITNESS KITCHENS: If you'll hold on just a second
11 I'll look it up and read it, Greg.

12 MR. LYON: If you can find it, I would be delighted
13 to hear you read it to me because it isn't there.

14 WITNESS LEE: This was voiced time and time again at
15 the workshop that it was four bolts as long as it was sealed
16 on the inside. It might have been the preliminary 8817, I'm
17 not sure.

18 MR. DIETZ: Is that the criteria you established
19 then, was four bolts --

20 WITNESS LEE: Yes.

21 MR. DIETZ: How many did you get on during this
22 event?

23 MR. AUFDENKAMPE: I think he's getting four bolts
24 from our Tech Specs. Our Tech Specs say four bolts.

25 WITNESS KITCHENS: That's what I'm trying to tell

1 you, for what we do, we maintain -- we get the containment
2 in similar configuration as we would for the refueling mode
3 Tech Spec requirement, which requires four bolts.

4 MR. LYON: But 8817 did not reference anything of
5 that nature.

6 WITNESS KITCHENS: Right.

7 MR. LYON: 8817 requests -- excuse me, recommended
8 that you have a no-gaps criterion, which kind of leads me
9 into my next question. Did you ever check to see if you did
10 have indeed a no-gaps criterion with four bolts, or have you
11 ever tested your equipment hatch such as for example
12 pressurizing between the two seals with the four bolts and
13 seeing if you would hold pressure?

14 WITNESS LEE: Not to my knowledge.

15 WITNESS KITCHENS: The no-gaps is the same as
16 refueling Tech Spec requirement. You can't have a direct
17 access between the inside and the outside of containment.
18 Basically if you can see between the inside and outside
19 containment, then you would not have it. But we have not
20 done any pressurization type tests that I'm aware of. We
21 don't do a local leak rate test which is four bolts.

22 MR. LYON: Do your Tech Specs state that the four
23 bolts is the requirement or that they give you a no-gaps
24 situation? I'm a little confused.

25 WITNESS KITCHENS: Okay. In Mode 6 while we're

P
E
N
G
A
R
D

C
O

B
A
Y
O
N
N
E

N
J
C
T
O
O
V

F
O
R
M

E
D

1 doing refueling core alterations, part of the Technical
2 Specification requirements -- and it's pretty much a generic
3 Tech Spec requirement -- is that you have the containment in
4 a certain condition. You can't have any access, direct
5 access between the inside and outside of containment, and it
6 specifically has some -- I don't have it with me but if you
7 read them it would be easier, but it specifically has you
8 during that time not having any direct access between the
9 inside and outside containment. One of the specific things
10 that's on the list there is equipment hatch closed and
11 retained by a minimum of four bolts.

12 MR. LYON: I understand.

13 WITNESS KITCHENS: Also we have other surveillances
14 where we go out and ensure valves are closed. Containment
15 integrity implies a whole different word -- whole different
16 meaning. That implies integrated leak rate testing, local
17 leak rate has been done before refueling containment
18 conditions, it's basically that you can't see between the
19 inside and outside. You want to have it mechanically closed
20 up.

21 MR. LYON: That's why we coined the word containment
22 closure in that generic letter, we wanted to differentiate
23 between that and the licensing Mode 1, if you will,
24 containment isolation.

25 WITNESS KITCHENS: One thing that you asked about

1 MR. LYON: Such as your emergency personnel hatch?

2 WITNESS KITCHENS: I don't recall if there's
3 anything specific on emergency personnel.

4 MR. LYON: Okay.

5 WITNESS KITCHENS: If there were any other
6 penetration that's not specifically called out in
7 containment, then you probably would be able to get by with
8 that for refueling.

9 MR. LYON: I see. The closure time, I understand
10 you folks have come up with a 59 -- or is it 57 minute
11 closure time requirement?

12 WITNESS KITCHENS: 57.

13 WITNESS LEE: Yes, that's the new, very conservative
14 value. I say very conservative, that's based on 48 hours
15 after shutdown.

16 WITNESS KITCHENS: It's based on us being at mid-
17 loop condition 48 hours after shutdown on extended run at
18 full power.

19 WITNESS LEE: Which is very conservative.

20 MR. LYON: What is the basis for the conservative
21 statement?

22 WITNESS LEE: There was an REA written for Southern
23 Company to evaluate Vogtle's meeting the generic letter and
24 that's one of the things that they were to determine, was
25 you know, what type of containment closure should we have to

P
A
R
T
I
C
I
P
A
N
T
S
O
F
T
W
A
R
E
C
O
M
P
A
N
Y
O
F
T
E
C
H
N
O
L
O
G
Y
I
N
C
O
R
P
O
R
A
T
E
D
I
N
T
H
E
U
N
I
T
E
D
S
T
A
T
E
S
O
F
A
M
E
R
I
C
A

1 preclude core uncovering.

2 MR. LYON: What does REA mean?

3 WITNESS LEE: Request for Engineering, it's like a
4 request for engineering support.

5 MR. AUFDENKAMPE: It's request for engineering
6 assistance, the way we communicate with our off-site
7 engineering agencies.

8 MR. LYON: I see, do you have an identifying number?

9 WITNESS KITCHENS: I pulled you a copy. You asked
10 me at my last interview for a copy of this and I brought it
11 today, but I see a note to pass this to Herb Beacher, but
12 you're welcome to have this. This is the calculations and
13 all, it shows the assumptions.

14 MR. LYON: If you would give that to Herb, so that
15 he can give it to us and process it through, I would
16 appreciate it.

17 WITNESS KITCHENS: It's REA number was VG-9011.

18 MR. LYON: Okay.

19 WITNESS KITCHENS: I believe what he meant by
20 conservative was the assumptions that were used in doing
21 this were conservative assumptions.

22 MR. LYON: Are you familiar with all of those?

23 WITNESS KITCHENS: I can read them to you.

24 MR. LYON: No, no, I don't want them read, I just
25 want to know --

P
E
N
G
A
D
D

C
O
D

B
A
Y
O
N
N
E

N

O
F
O
O
?

F
O
R
M

F
E
L
D

1 WITNESS KITCHENS: I'm familiar with some of them.
2 They did do assumptions with how much water we had when we
3 were at mid-loop, but actually used mid-loop at 187, we
4 normally don't go that far down. They did the assumption of
5 -- that we were there at the time a loss of RHR, we had been
6 shutdown for only 48 hours, which would be a world's record
7 if we were able to get to mid-loop in 48 hours. That's what
8 he meant by conservative, they erred on the conservative
9 side toward making the time small for those things. The
10 heat sinks of the metal in the vessel were assumed to not
11 exist, those kinds of things. We assumed a larger power
12 that we're authorized by our Tech Specs now. The initial
13 core power would be five percent more than really allowed.

14 WITNESS BURMEISTER: Also minimum RWST level
15 required by Tech Spec.

16 MR. LYON: How does the RWST level factor into that
17 number?

18 WITNESS BURMEISTER: Provides pressure head to
19 provide flow to the RCS.

20 WITNESS KITCHENS: I believe that one --

21 MR. LYON: You're calculating this time in which you
22 have to have the equipment hatch closed assuming that you
23 have gravity flow?

24 WITNESS KITCHENS: No, no. The assumption he just
25 referred to, there's another part of this that does a

1 calculation to show gravity flow and in that particular
2 calculation they assume minimum. I believe, Bill, the one
3 for time to expose core doesn't assume any mid-loop.

4 MR. LYON: Okay. Do you know off-hand your heat up
5 rate while at mid-loop 48 hours after shutdown?

6 WITNESS KITCHENS: 8.3 degrees a minute, I believe.

7 MR. LYON: Is that in any documentation that's
8 readily available?

9 WITNESS KITCHENS: Uh-huh, it's also in our
10 procedure that Greg referred to.

11 MR. LYON: For the record would you state what
12 procedure you're referring to?

13 WITNESS LEE: 18000?

14 WITNESS KITCHENS: 18000, 19-C.

15 MR. LYON: And that is figure --

16 WITNESS KITCHENS: This heat up rate is Figure 4.

17 MR. LYON: And that's of the order of eight degrees
18 a minute?

19 WITNESS KITCHENS: Well it gives the heat up rate
20 versus time after reactor shutdown and if you assume 48
21 hours, then it turns out to be 3.3

22 MR. LYON: Does it also give a time to boiling?

23 WITNESS KITCHENS: Yes.

24 MR. LYON: And that's what figure?

25 WITNESS KITCHENS: That's Figure 2.

P
E
N
G
A
D

C
O

S
A
Y
O
N
N
E

N
J

C
I
T
O
O
S
Z

F
O
R
M

F
E
D

1 MR. LYON: And what is the time to boiling?

2 WITNESS KITCHENS: At 48 hours?

3 MR. LYON: Yes, sir.

4 WITNESS KITCHENS: Time to boiling is 48 hours, I'd
5 say approximately 500 seconds.

6 MR. LYON: 500 seconds, so of the order of ten
7 minutes, say?

8 WITNESS KITCHENS: Yes.

9 MR. LYON: From the time of the loss of RHR, you
10 would be boiling at mid-loop.

11 WITNESS KITCHENS: Yes, 48 hours after shutdown.

12 MR. LYON: I understand. If we were to have some
13 steam generator manways open under those circumstances,
14 where would the steam go from the boiling?

15 WITNESS KITCHENS: What other configuration would
16 you have us have? I assume you would not have any nozzle
17 dams or anything.

18 MR. LYON: No nozzle dams in, the steam generating
19 manways are off.

20 WITNESS KITCHENS: What about the manway?

21 MR. LYON: If you want to take the pressurizer
22 manway off, that's okay too. So the steam goes out the
23 manway. Do you have a feel for the volume of steam that
24 would go out through that manway?

25 MR. DIETZ: That's a trick question.

P
E
R
G
A
D
C
O
B
A
Y
O
N
N
E
N
J
O
D
D
Z
F
O
R
M
F
E
D

1 WITNESS KITCHENS: There was an incident where that
2 actually happened a long time ago, I don't recall.

3 MR. LYON: It's big.

4 WITNESS LEE: More than you can make up. That is
5 also addressed in the REA.

6 MR. LYON: They calculated that steam flow rate? Do
7 you recall off-hand what that is?

8 MR. AUFDENKAMPE: Not right off-hand, but looking at
9 it, I think there are over 277.93 cubic feet per second.

10 MR. LYON: Call it say roughly 300 cubic feet per
11 second? So if I multiply that by 60, I've got 18,000, so
12 say of the order of magnitude of 15,000 cubic feet per
13 minute. Would you be able to stay in containment with that
14 kind of steam volume coming out through one of those
15 manways?

16 (No response.)

17 MR. LYON: In other words, where I'm headed is, if
18 you were in that situation, could your people remain at the
19 equipment hatch trying to get it off?

20 MR. AUFDENKAMPE: The answer is yes, and again this
21 is all in this REA and I'm somewhat at a disadvantage,
22 because I read it right before I came here.

23 MR. LYON: That's all covered in the REA?

24 MR. AUFDENKAMPE: That's where the 57 minutes comes
25 into.

1 MR. LYON: Okay.

2 MR. AUFDENKAMPE: 26 minutes to reach the maximum
3 principal concentration and --

4 MR. LYON: Excuse me, we're missing each other. I'm
5 not concerned about concentrations.

6 MR. AUFDENKAMPE: I understand.

7 MR. LYON: Go ahead, I'm sorry.

8 MR. AUFDENKAMPE: 26 minutes but to read the maximum
9 radiation, maximum permissible concentration with respect to
10 radiation then we come back in with respirators and finish
11 the job before we reach the maximum temperature that we can
12 withstand. That's where the 57 minutes comes from.

13 MR. LYON: So you are taking into account the steam
14 and you're condensing that steam?

15 MR. AUFDENKAMPE: There's no credit for condensing.

16 MR. LYON: There is no credit. You're right, I'm
17 going to be very interested in reading that because I have
18 never seen one of these analyses.

19 Okay. In response to 8817, did you look at other
20 penetrations in your containment?

21 WITNESS LEE: Other than the hatch, equipment hatch?

22 MR. LYON: Yes.

23 WITNESS LEE: Well we were keeping track of it, we
24 have an administrative control to identify them and as the
25 note says, to initiate containment closure per this

P
E
N
G
A
D
C
G
B
A
Y
O
N
N
L
N
J
D
D
D
E
F
O
R
M
F
E
E
D

1 procedure.

2 MR. LYON: And since you're keeping track of them,
3 that means the operators have a record of what is open and
4 what is closed?

5 WITNESS LEE: (Nodding head affirmatively.)

6 MR. LYON: And the procedure specifically references
7 that record so they could do a cross check to make sure
8 everything was closed up?

9 WITNESS LEE: That is set up by the procedure
10 itself, that when you go into mid-loop you're to establish
11 this list and identify -- keep track of these penetrations
12 that are open.

13 MR. LYON: Okay.

14 WITNESS LEE: Here, it's just general guidance that
15 you need to initiate containment closure. That implies to
16 the operator he's supposed to close them if they're --

17 WITNESS KITCHENS: Let me answer it a little more
18 direct. In our cool down procedure and shutdown procedure,
19 which is Unit Operating Procedure 12006-C, Greg has put into
20 it as one of the steps, it says when required to initiate
21 RCS draining by performing the following -- there's a whole
22 list of things to do. One of them is determine the closure
23 status of the equipment hatch and ensure the hatch is
24 capable of being closed within 57 minutes, or ensure the
25 hatch is closed prior to reducing RCS level below three feet

P
E
N
D
A
D

C
O

B
A
Y
O
N
N
E

N

O
Y
O
O
?

F
O
R
M

F
E
D

1 below the reactor flange. The one he's talking about is the
2 second requirement. A review of all containment
3 penetrations addressed in procedure number 14210 containment
4 building penetrations, refueling, should be accomplished to
5 determine those which have been opened by manual means and
6 an information LCO generated for those identified.

7 To answer your question, we have an information LCO
8 manual that the shift supervisor keeps at his work station
9 and he could easily identify for that if there was any
10 penetration that had been opened by manual valve or
11 something.

12 MR. LYON: Okay. Now in many plants that I have
13 been in I see cabling dragged through the equipment hatch.
14 I see tubing, pipes, walkways, similar kinds of things going
15 through the personnel hatch, stuff such as one would use for
16 steam generator lancing operations. Do you folks do that
17 kind of a process at this plant?

18 WITNESS KITCHENS: No, sir.

19 MR. LYON: How do you handle it?

20 WITNESS KITCHENS: We do during eddy current
21 testing, but during this particular outage, we actually
22 installed in a spare penetration a penetration for that very
23 thing, for sludge lancing and for putting temporary cables
24 through. It's a spare penetration that allows us to run the
25 cables through there, through a sealed penetration.

1 MR. LYON: You indicated that for eddy current
2 testing you might bring your cables through another path?

3 WITNESS KITCHENS: This was also for that.

4 MR. AUFDENKAMPE: For eddy current testing and
5 sludge lancing, we have a dedicated containment penetration
6 that has a special flange adaptor to accept the Westinghouse
7 sludge lance and eddy current hoses and cables. They run
8 through the penetration and they do not communicate with the
9 outside atmosphere.

10 WITNESS KITCHENS: This also allows us to perform
11 refueling without having the direct access between the
12 inside and the outside, we in essence built a penetration
13 for that.

14 MR. LYON: So you enhanced your operating capability
15 at the same time that you enhanced safety;.

16 WITNESS KITCHENS: Yes, sir.

17 MR. LYON: Are any other kinds of cables, welding
18 hoses, anything of this nature, typically snaked through
19 into containment during an outage?

20 WITNESS KITCHENS: Through equipment or personnel
21 hatch, is that --

22 MR. LYON: That kind of a thing, yes.

23 MR. AUFDENKAMPE: Generally not. As far as power
24 goes, we -- the last outage and this outage, we provided
25 extra temporary power and in this outage we installed

1 permanent I guess an extra 900 amp service or 600 amp
2 service in containment so we don't have to bring electrical
3 cables in and demin water supply, I think the penetration is
4 sufficiently sized to satisfy all our demin water needs.

5 MR. LYON: Okay. Let me leave containment and go to
6 a different area. You've mentioned some analyses in this
7 REA. Does that contain essentially all of the important
8 analyses that you have conducted to support your operations
9 for this generic letter response?

10 WITNESS LEE: Yes.

11 MR. LYON: There's nothing else that I really should
12 ask for that would provide some additional insight into the
13 preparation for these conditions?

14 MR. AUFDENKAMPE: Not with respect to analyses.
15 That's not dodging the question --

16 (Laughter.)

17 MR. AUFDENKAMPE: This is only analysis, this is
18 only the engineering analysis associated with the response
19 to generic letter 8817.

20 MR. LYON: Uh-huh.

21 MR. AUFDENKAMPE: Where you asked us to do the
22 analysis or the Commission has asked us to do that analysis.

23 WITNESS KITCHENS: We use pretty much generic
24 information from the owners' group and others prior to that
25 but you asked the question are there other things you should

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J

T
O
D
D

F
O
R
M

E
D

1 ask for -- you know, one of the things you haven't asked
2 about, I assumed that you would, would have been training.
3 We have a lot of --

4 MR. LYON: That's on my list.

5 WITNESS KITCHENS: -- a lot of -- we have performed
6 a lot of training associated with this primarily with our
7 licensed operators.

8 MR. LYON: Okay.

9 WITNESS KITCHENS: Both from the point of view of a
10 case study for the specific events in Diablo Canyon and for
11 the 8712 and 8817. You know, we've done a pretty good bit
12 of training for mid-loop ops and that's one thing you had
13 not asked about yet.

14 MR. LYON: Well since you've identified that issue,
15 let me ask about it. What training do you provide to your
16 maintenance and instrument tech kinds of people as related
17 to 8817?

18 WITNESS KITCHENS: I'm not sure. I will find out
19 for you.

20 MR. LYON: Does anyone know?

21 WITNESS KITCHENS: The closest person to know in
22 this group would be me because none of them are responsible
23 for --

24 MR. LYON: Okay.

25 WITNESS KITCHENS: I honestly don't know. I'm not

1 avoiding your question.

2 MR. LYON: I understand. I find a no to be the
3 easiest response to a question, as opposed to if you know
4 something then you have to go into it a bit.

5 Would you look into that a little bit?

6 WITNESS KITCHENS: Yes. You want to know about
7 training that maintenance or I&C types may have had
8 associated with mid-loop ops and particularly the generic
9 letters we've been talking about, those issues?

10 MR. LYON: Yes. Generic letter 8817 and both the
11 expeditious responses and the program enhancements addressed
12 the avoidance of perturbations through those kinds of
13 operations and we would like to have an understanding of how
14 you have dealt with that issue.

15 WITNESS KITCHENS: Okay.

16 WITNESS BURMEISTER: We do have a note in the UOP,
17 you know where Jnit shift supervisor controls the activities
18 along those lines as far as allowing maintenance activities.
19 He has a note in the unit operating procedures that says
20 don't allow any type of activity that would cause
21 perturbations during mid-loop operations.

22 MR. LYON: Uh-huh.

23 WITNESS BURMEISTER: We do have that kind of note.

24 MR. LYON: But that's a little different than having
25 your people that are out there in the field having a

P
E
N
S
I
O
N
S
I
N
G
C
O
M
M
U
N
I
T
Y
S
E
C
T
O
R
I
A
N
S

1 sensitivity to those kinds of things.

2 WITNESS KITCHENS: He specifically was talking about
3 training and briefings to the other people other than
4 operations, I believe, were you not -- not just procedure
5 requirements.

6 MR. LYON: I'm not going to explore all aspects of
7 your training, but let me explore one aspect. When -- and
8 the one I'd like to look into a little bit you did not reach
9 during this event but I think it's appropriate because if
10 you had not gotten electric power back for an extended time
11 you probably would have -- and that is the behavior of the
12 system once boiling initiates.

13 You were, as I understand it, in a situation with
14 all manways on, you had closed up all penetrations with the
15 exception of the cono-seal openings. And let's postulate
16 that boiling initiated at that point. My first question is
17 -- let me back up just a little bit -- as we approached
18 boiling, what would your training have told the operators
19 that they should be doing?

20 WITNESS KITCHENS: For the configuration that --

21 MR. LYON: Let's make it simple. Forget the cono-
22 seals. The reactor coolant system is closed, you're coming
23 up on boiling. What does the operator expect and would you
24 have been providing training and guidance as to what to
25 expect and what should be done?

1 WITNESS KITCHENS: I'm trying to remember. Both
2 Bill and I would have received that training. The training
3 I remember was specifically associated with the different
4 things that would happen were you to have a cold leg open
5 with the dams in, manways on or not. We received training
6 as to what pressurization of the reactor vessel head would
7 do under certain conditions, how having manways in in
8 certain conditions would allow you to actually uncover the
9 core quicker that way, just for having the RCS -- no
10 blockages, no manways, no isolation valves, loop isolation
11 valves closed. I don't recall --

12 MR. LYON: Excuse me -- loop isolation valves? Do
13 you have those beasts?

14 WITNESS KITCHENS: No.

15 MR. LYON: Oh, okay.

16 WITNESS KITCHENS: The only training I recall is to
17 try to recover -- get some flow going, some cooling flow
18 going to the reactor.

19 WITNESS BURMEISTER: It's kind of hard to say you
20 can take the training that was received and extrapolate from
21 that. Like I was thinking of alternative actions before we
22 got to that point. We were at 120 degrees, maybe 20 or 30
23 minutes into the event, and before we got RHR cooling back,
24 it had increased to 135 degrees, somewhere around there.
25 And I was already formulating a plan in my mind as to what I

P
E
N
S
I
O
N
S
C
O
R
E
S
B
A
Y
O
N
N
E
S
J
U
R
Y
C
O
U
R
T
R
E
C
O
R
D
S
F
O
R
M
E
R
O

1 would do and at what point I would do it. And it was based
2 on my training and my knowledge of the events and that may
3 not be the same as someone else was thinking, but I would
4 have at 150 -- somewhere between 150 and 160 degrees, have
5 asked for the pressurizer manway to be removed and to
6 initiate gravity feed. That's personally what I would have
7 done.

8 But you're not in the situation necessarily where
9 you're relying on one person's judgment. At this time we
10 already had the TSC established and our engineering people
11 were involved in pursuing alternative paths for getting
12 water to the vessel and cooling the core.

13 MR. DIETZ: Does the term reflux boiling mean
14 anything to you?

15 WITNESS BURMEISTER: We were on the phone with the
16 NRC and they were suggesting at the time to go ahead and
17 just fill as much as you can and then use the steam
18 generators to remove heat. We recognized the fact that we
19 had not swept the U-tubes and that we would not be able to
20 fill the U-tubes with very much water, just gravity fill the
21 RCS to the point where you got some pressurization. You
22 would have some heat transfer in the steam generators and
23 reflux would be the method of heat transfer.

24 MR. DIETZ: What's reflux boiling?

25 WITNESS BURMEISTER: Steam entering into the steam

1 generators and condensing and running back down in the tubes
2 into the core -- I guess you don't necessarily have to fill
3 up to -- fill w? the loops in order to use that type of heat
4 transfer. You have a lot of non-condensables in the RCS
5 which will impede that process but still the steam that does
6 carry with the non-condensables can condense on the tubes
7 and you do have --

8 MR. DIETZ: So the steam would rise into the tubes.

9 WITNESS BURMEISTER: Yeah, I guess I was mixing two
10 subjects here, the people at the NRC that were on the phone
11 were talking about fill it up, just fill it up, and we said
12 well we're very close to getting electrical power supply
13 back and we don't believe that's necessary at this time, you
14 know, considering their input. But what you're suggesting,
15 the reflux boiling, I don't know if that particular
16 recommendation came up. But that's after the fact, waiting
17 until the point you've got 212 degrees. What I'm looking at
18 is what are you going to do before you get there. I think -
19 - I was getting ready to take actions before we got to the
20 point of boiling. I didn't want to wait until we got to
21 that point and then figure out what to do with it, but
22 that's just my own personal opinion.

23 MR. LYON: So you would have attempted to restore a
24 single phase natural circulation by filling it with the
25 manways off?

1 WITNESS BURMEISTER: Right, with the pressurizer
2 manway off. They had put it on in a very short period of
3 time, I think it was like 15-20 minutes. It didn't take
4 very long at all and the bolts were just snugged down by
5 hand, so they could have been easily removed.

6 MR. LYON: Okay.

7 MR. AUFDENKAMPE: A hammer wrench.

8 WITNESS BURMEISTER: Oh, they were tightened down?

9 MR. AUFDENKAMPE: They were hammer wrenched, they
10 weren't torqued.

11 WITNESS BURMEISTER: I heard they were not torqued,
12 so I presumed that we could remove the manway in an
13 expeditious manner.

14 MR. LYON: Do you know what his question was about
15 reflux boiling, what that process is?

16 WITNESS BURMEISTER: Yes.

17 MR. LYON: Could you tell us in maybe one sentence?

18 WITNESS BURMEISTER: In one sentence? Steam from
19 the core exit travels through the hot legs to the steam
20 generators and is condensed in the steam generator tubes and
21 travels back down as condensate into the top of the core
22 again and is displaced by steam again and that process is in
23 continuous motion.

24 MR. LYON: All right, and is that an effective
25 technique for core cooling?

1 I agree, you went into Mode 4. Will it prevent any
2 damage whatsoever to the fuel? Does Diablo Canyon give us
3 any help there?

4 WITNESS BURMEISTER: I don't know how long Diablo
5 Canyon existed in a state where reflux boiling was used for
6 removing heat.

7 MR. LYON: Okay.

8 WITNESS BURMEISTER: Is it something you can use for
9 an indefinite period of time? I can't answer that question.

10 MR. LYON: Okay.

11 WITNESS BURMEISTER: It seems like it will buy you
12 time to take other actions.

13 MR. LYON: Let me go to the technique that you
14 suggested where you said that you would have removed the
15 pressurizer manway, initiated gravity feed and just started
16 filling it up. How full would you take it and what flow
17 path would you have used to do that?

18 WITNESS BURMEISTER: There's -- in our RHR procedure
19 there is a means of establishing gravity feed.

20 MR. LYON: That's on the last page, isn't it?

21 WITNESS BURMEISTER: It's in the procedure, there's
22 another way of doing it too. Actually there's a third
23 option to cooling the core and we basically have --

24 WITNESS KITCHENS: It's not on the last page.

25 MR. LYON: Well the figures are on the last page.

1 WITNESS KITCHENS: I think you're -- he's talking
2 about a whole other procedure.

3 MR. LYON: You're not in your loss of RHR procedure?

4 WITNESS KITCHENS: No, system procedure 13011-1,
5 section 4.7 gives you a way to gravity fill. It gives you t
6 he option to either turn RHR pump on and not to fill from
7 the RWST, to fill the reactor --

8 MR. LYON: But my specific question was what mode of
9 fill would you have used once you've gotten the pressurizer
10 manway off in this event, if you had to do that.

11 WITNESS BURMEISTER: The mode of fill? Gravity
12 fill.

13 MR. LYON: Through what flow path?

14 WITNESS BURMEISTER: The flow path there is from the
15 RWST through the RHR pump flow path through the discharge
16 into the vessel.

17 MR. LYON: Okay.

18 WITNESS KITCHENS: You would have had to open some
19 MOV's?

20 WITNESS BURMEISTER: Right.

21 WITNESS KITCHENS: Manually. We would have had to
22 take the operators and manually open an MOV and close it.

23 MR. LYON: Once you started filling, would your
24 level instrumentation give you an accurate indication of
25 what was going on?

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J

C
I
T
Y
O
F
F
I
C
E

F
O
R
M

F
E
E
D

1 WITNESS BURMEISTER: If you experienced
2 pressurization in the RCS, it would not immediately give you
3 a good indication of actual level in the RCS.

4 MR. LYON: How am I going to pressurize if I took
5 off the manway?

6 WITNESS BURMEISTER: If pressurization did occur.

7 MR. LYON: Okay, well I've taken the manway off,
8 that is my situation and I'm flowing in at several thousand
9 GPM, as an order of magnitude, maybe 1000, somewhere in that
10 ball park, through that flow path. What is my indicated
11 level going to be doing in the RCS?

12 WITNESS BURMEISTER: The RCS is at 100 degrees and
13 you're putting in 70 degree water, it's going to give you an
14 indicated level that's a little bit higher.

15 MR. LYON: But probably not much more.

16 WITNESS BURMEISTER: Not very -- yeah, right.

17 MR. LYON: Did any of the training that was set up
18 cover any potential impact of RCS level on level indication
19 and did anyone look into that in working up the response to
20 8817?

21 WITNESS BURMEISTER: The training covered changes in
22 RCS level and if you were to change level rapidly or even at
23 a fairly constant but -- anything other than a slow rate,
24 you could experience an inaccuracy indication due to
25 differences in pressure that occur between the RCS and the

P
E
N
S
I
O
N
S
C
O
R
E
S
F
O
R
M
E
D

1 sensing lines. You have a large volume of air that has to
2 travel through the RCS and the sensing lines to balance out
3 in the level glass, you have to wait for that balance to
4 occur. If you're changing level rapidly, that balance will
5 take some time to occur and therefore your level will not be
6 immediately accurate.

7 MR. LYON: Let's suppose that you fill the RCS up a
8 ways and despite your best efforts the steam generators
9 don't turn out to be an effective heat transfer or heat
10 rejection technique and it starts boiling and the steam is
11 going out through this open manway. Would you expect that
12 would have a big influence on your level indication?

13 WITNESS BURMEISTER: Yes.

14 MR. LYON: Why?

15 WITNESS BURMEISTER: You're saying that the RCS
16 would begin to pressurize, in other words?

17 MR. LYON: Yes, basically. I mean I've got a head
18 of water up there in the pressurizer, yes.

19 WITNESS BURMEISTER: Depends on the rate of
20 pressurization but --

21 MR. LYON: Let's suppose it's at a pseudo-steady
22 state so that I'm pushing steam into the pressurizer and
23 that steam is going out through that open manway and perhaps
24 I'm holding up some water up in the pressurizer as well.
25 Will my level indication be accurate?

1 WITNESS BURMEISTER: There are other things that can
2 happen. Steam can enter the reference column of the tygon
3 tube --

4 MR. LYON: Let's assume that doesn't happen.

5 WITNESS BURMEISTER: At a very slow pressurization
6 rate or --

7 MR. LYON: Okay, let me leave that topic.

8 WITNESS LEE: We did use the hot legs, the same hot
9 legs that -- you know, that RHR takes suction off of, to
10 provide a level tap for the temporary and the permanent
11 level instrumentation.

12 MR. LYON: Is that a drain line up there that you're
13 connected to? Maybe the manifold for your hot leg RTD's? I
14 never did determine what you used for an actual tap there.

15 WITNESS LEE: It was a -- it was the lower RVLIS
16 tap.

17 MR. LYON: Okay, someone told me that -- I recall
18 now.

19 WITNESS LEE: And we felt like it would be -- as far
20 as getting at what you were talking about just now about the
21 DP's across the driving head and all, we felt like that was
22 the level that was chosen because it was more of an
23 indication of the true level at the suction, in case you
24 needed to restore level to the RHR -- we wanted to make sure
25 you could have a level at the RHR suction before you

1 attempted to start a pump, that you had true level at that
2 suction point.

3 MR. LYON: Uh-huh.

4 WITNESS LEE: And as far as having to factor in all
5 the velocity heads and static heads and all because of the
6 flow, I know that would be if RHR were running, you know --
7 in a running situation, but as far as the situation you're
8 talking about, that's on a different leg in the pressurizer.

9 WITNESS BURMEISTER: It's like if you had a
10 pressurization in the RCS possibly that's higher than the
11 tygon tube is seeing, then the level is going to indicate
12 higher than the tygon tube, so you'll have an erroneous
13 indication.

14 MR. LYON: But I have a reference leg that ties back
15 into the RCS to avoid that.

16 WITNESS BURMEISTER: The reference leg for like the
17 tygon tube is in the top of the pressurizer.

18 MR. LYON: Yes.

19 WITNESS BURMEISTER: And --

20 MR. LYON: And one is on the control board.

21 WITNESS BURMEISTER: That would have worked fine.
22 The ones on the control board are off the RVLIS.

23 MR. LYON: And where do their reference sites go?

24 WITNESS BURMEISTER: They're --

25 WITNESS LEE: The upper one.

1 WITNESS BURMEISTER: The upper on the wide range
2 RVLIS?

3 WITNESS LEE: Yes.

4 VOICE: I don't think the wide range RVLIS was
5 connected yet.

6 WITNESS KITCHENS: Y'all are all talking about
7 different things. There's a wide range on the control board
8 that was connected.

9 MR. LYON: Anybody want a break? Let's take about a
10 -- it's 2:47 according to my watch. Can we start again at
11 2:57, we'll take ten minutes even.

12 (A short recess was taken.)

13 MR. LYON: We've returned from a ten minute break.
14 We're still in the general topic of draining and how that
15 interacted and we just finished covering level.

16 Could you tell me anything about draining aspects of
17 thermocouple responses covering such things as the ex core
18 thermocouples, the hot and the cold leg narrow range
19 temperature indications, the hot and the cold leg wide range
20 indications and RHR temperature in a situation in which you
21 have lost RHR?

22 WITNESS BURMEISTER: The most recent tape I just
23 viewed before I came here is the 22 minute tape that we
24 showed to all the operators on shift before the refueling
25 outage started and it discusses the use of two thermocouples

1 during the period of time when we're at mid-loop operations,
2 the greatest period of time that we can have the two
3 thermocouples hooked up. There's obviously a period of time
4 where the reactor vessel head is in the process of being
5 lifted and set and in that period of time we would not have
6 the two core exit thermocouples available.

7 The procedures does say if you do not have those
8 available and you are experiencing problems with RHR, the
9 AOP on RHR directs you to fill the hot legs to the point
10 where you would have good communication with the hot leg
11 RTD's and be able to use those, although not as good of a
12 temperature indication from what's going on in the core,
13 they would provide you information -- you know, indication
14 of temperature at the hot leg.

15 MR. LYON: Does the training or do the procedures
16 discuss the differences that one might see between the ex-
17 cores and those hot leg wide range RTD's?

18 WITNESS BURMEISTER: Doesn't give you any concrete
19 values, it does indicate that there's going to be a
20 difference.

21 MR. LYON: Which, the procedures, the training or
22 both?

23 WITNESS BURMEISTER: The training tape I viewed.

24 MR. LYON: Covers that. Do the procedures flag
25 that?

1 WITNESS BURMEISTER: I'd have to look at the AOP. I
2 didn't look at that particular aspect.

3 MR. LYON: Does anyone know off the top of their
4 head?

5 WITNESS KITCHENS: What was the question again?

6 MR. LYON: Whether the procedures flag that there
7 may be a difference between the wide range hot leg RTD's and
8 the ex core thermocouples.

9 (No response.)

10 MR. LYON: If you don't know immediately, I can
11 look. We have the procedure.

12 WITNESS BURMEISTER: It doesn't really say that, it
13 just says to do it.

14 MR. LYON: I understand.

15 WITNESS LEE: It's a secondary -- it's an
16 alternative. You use the core exit TC's. If that's
17 unavailable, then you use the core exit TC's. So it was
18 structured as an alternative.

19 MR. DIETZ: What kind of differences would you
20 expect at mid-loop on the RTD's?

21 WITNESS LEE: I don't know exactly.

22 MR. DIETZ: Are they from the top of the pipes, side
23 of the pipe, bottom of the pipe?

24 WITNESS LEE: Ours are kind of up on the side near
25 the top, so we have a thing here that says operating at mid-

R
E
N
O
A
S
C
O
B
A
Y
J
O
N
N
E
N
J
I
T
D
O
S
F
O
R
M
E
D

1 loop, core exit TC's indication is lost, then raise RCS
2 level to top of hot leg.

3 MR. DIETZ: So if you were at mid-loop you would
4 expect to not be able to read them.

5 WITNESS LEE: Right.

6 MR. DIETZ: Except maybe if it starts steaming.

7 WITNESS LEE: That's true. It's only a backup to
8 the core exit.

9 MR. LYON: Now that step only occurs in your loss of
10 RHR procedure, is that correct? You would not do that in a
11 normal operation.

12 WITNESS LEE: That's right.

13 MR. TRAGER: Is it possible to get a copy of that
14 tape?

15 WITNESS KITCHENS: What was this tape? I'm writing
16 down things to get them.

17 MR. TRAGER: I think it's the same tape that Rob
18 Dorman -- is that the same tape that he referred to? Is
19 there a training in mid-loop operations?

20 WITNESS BURMEISTER: Right, it's a tape that we made
21 available to the shift crews prior to the refueling outage
22 for them to view, it's a 22-minute tape. It discusses the
23 Diablo Canyon event -- kind of a refresher because we had
24 received training on mid-loop operations between this
25 current refueling outage and the last refueling outage and

1 also prior to the last refueling outage.

2 WITNESS KITCHENS: We had a tape too where someone
3 had made a model of reactor coolant systems that you could
4 see through and they showed how cavitation works and
5 vortexing -- that's a different tape, I just want to make
6 sure I get the right tape that you want. We've got several
7 tapes on this subject, several lesson plans and every few
8 months we train on this.

9 MR. LYON: The answer --

10 WITNESS KITCHENS: What we have on our simulator now
11 simulates mid-loop operations over at the training center.

12 MR. DIETZ: Have they done any training on the
13 simulator with mid-loop scenarios?

14 WITNESS KITCHENS: Yes.

15 MR. DIETZ: With the crews?

16 WITNESS KITCHENS: Yes.

17 MR. DIETZ: The crew that was on that morning, had
18 they had that in the simulator?

19 WITNESS KITCHENS: Which training?

20 MR. DIETZ: Any scenarios on mid-loop.

21 WITNESS KITCHENS: I don't know.

22 MR. DIETZ: I just wondered.

23 WITNESS BURMEISTER: I believe so. It's covered
24 every week.

25 WITNESS KITCHENS: Had they already been to the

P
E
N
I
D
C
D
B
A
Y
O
N
H
E
N
J
T
O
O
2
F
O
H
M
P
S
E

1 be used when you are in a reduced inventory condition?

2 WITNESS KITCHENS: I think there's a 9-C procedure.

3 WITNESS LEE: I was looking for a reference in here
4 that discusses that.

5 MR. LYON: Will you get us a copy of the procedure
6 that specifies which thermocouples?

7 And what criteria did you use in selecting those
8 thermocouples?

9 WITNESS WEST: We just trigger I&C to go to enable
10 thermocouples for us and set the alarms on the ERF. So the
11 process they use -- you'll have to ask the I&C for the
12 process.

13 WITNESS KITCHENS: I'll find out for you. None of
14 us here know the answer to your last question. You just
15 asked how did we pick them? I don't believe anyone knows.

16 MR. LYON: But you are the people that put together
17 all of this 8817 response.

18 WITNESS KITCHENS: No, sir, what I tried to tell you
19 at the first, this is only the operations part of it.
20 There's also, as he said, a project manager in Birmingham,
21 Mr. Mintz --

22 MR. LYON: Okay, now I understand.

23 WITNESS KITCHENS: There's I&C people that was on
24 the task force Dean was on. All you have assembled here
25 today are operations folks and John Aufdenkampe.

P
E
N
G
A
D

C
O
L
L
A
Y
O
N
N
E

N
J

7
0
0
2

F
O
R
M

P
E
D

1 MR. LYON: And you allow him to sit with you?

2 WITNESS KITCHENS: We love him. He's the only
3 person that's just about as short as me on our management
4 staff and me and him like to stand next to one another.

5 I'll find that out for you and if we have a
6 procedure or a specific I&C information on that, I'll get
7 that for you too. I think we probably have an I&C procedure
8 for doing that. If not I'll find out how we decided which
9 ones to do.

10 MR. LYON: I appreciate it.

11 MR. DIETZ: Would they indicate different?

12 WITNESS KITCHENS: Sure.

13 MR. DIETZ: Why?

14 WITNESS KITCHENS: Well depends on where it is in
15 the core, which RHR train you have in. It also depends
16 whether it's above one in an assembly that you just changed
17 out or not or if it was one that had a lot of decay heat on
18 it. I think it would indicate different because of the
19 actual temperature in that area where the one was, is one
20 reason.

21 MR. DIETZ: Where would you prefer to have it?

22 WITNESS KITCHENS: I'd probably prefer to have it
23 near the center of the reactor, personally. I don't know
24 without thinking about it.

25 Did you understand my last comment?

P
E
N
S
I
O
N
C
O
R
D
E
N
J
T
O
O
Z
E
F
O
R
M
E
D

1 MR. LYON: Yes, I was asking the wrong people.

2 WITNESS KITCHENS: But you have operations and one
3 engineering and now licensing rep and the manager of the
4 operation folks. But there are engineering, I&C, other
5 licensing folks, project folks, A&E folks that worked on all
6 this. You just have a small group of the people that worked
7 with the operations procedures and what-not. The reason I'm
8 taking the notes on the training is we should have had our
9 training superintendent here to help talk with you too.
10 There are people that could answer these questions, but I'll
11 get the answers to them on the training

12 MR. DIETZ: We'll also get ahold of him too.

13 WITNESS KITCHENS: You've not talked with Rob
14 Dorman?

15 MR. B. JONES: His interview was conducted at --
16 there was a scheduling that his interview was conducted at
17 the same time as this one, so it's somewhat fragmented, but
18 that's just the way it turned out.

19 WITNESS KITCHENS: I'm going to follow up and get
20 this anyway, I'll touch base with him and make sure we get
21 you this.

22 MR. LYON: You had mentioned RHR pump amps and that
23 was one of the suggestions for monitoring the RHR behavior
24 in 8817. What led you to select pump motor current as
25 opposed to perhaps some other parameters?

P
E
N
G
A
D
C
O
S
A
Y
O
N
N
E
W
J
O
D
L
D
Z
F
O
R
M
E
E
D

1 MR. AUFDENKAMPE: We did an engineering study and
2 that was the best one available.

3 MR. LYON: And that engineering study -- could we
4 have a copy of that?

5 MR. AUFDENKAMPE: Yeah.

6 MR. LYON: Would you identify that for the record
7 please?

8 MR. AUFDENKAMPE: BG-0 -- BG-9010.

9 MR. LYON: Okay. You know you are retaliating
10 because you're going to load me down on the way back and I'm
11 going to dislike you for it.

12 WITNESS KITCHENS: We'll copy on both sides.

13 MR. LYON: That's not necessary. Does anyone want
14 to say just very briefly your feel for the behavior of that
15 and why that was selected? Anyone have any feel for why
16 that one was picked?

17 WITNESS LEE: We were about the only plant that
18 didn't have it, for one thing.

19 WITNESS KITCHENS: We don't have pump amps in our
20 control room except for reactor coolant pump.

21 MR. LYON: I think you're the only one I have ever
22 been in that didn't have an analog pump motor current
23 indicated somewhere in the control room.

24 WITNESS LEE: We had some parameters prior to this,
25 you know, which we used but of course we didn't have amps.

P
E
N
S
I
V
E
C
O
R
P
O
R
A
T
I
O
N
S
E
N
J
E
R
Y
S
E
R
I
E
S
F
O
R
M
E
D

1 We added it to the indication cavitation.

2 MR. LYON: How is the pump motor current displayed
3 in the control room?

4 WITNESS KITCHENS: RHR pump motor?

5 MR. LYON: Yes.

6 WITNESS KITCHENS: Now it's input to the ERF
7 computer and it's displayed on the CRT screen as a trend of
8 -- well you could display it many different ways but the way
9 we generally display it is a trend of the value of amps over
10 time.

11 MR. LYON: How long is --

12 WITNESS KITCHENS: It's also input to our critical
13 safety function trees for Mode 5 and Mode 6 such that if
14 there's a certain fluctuation in amps, it also provides an
15 alarm on the computer and the critical safety function tree
16 changes color on there. So it alerts the operator by alarm
17 and change of color on the SPDS.

18 MR. LYON: That is an audible alarm?

19 WITNESS KITCHENS: Yes.

20 MR. LYON: It's loud enough that somebody is going
21 to pick it up.

22 WITNESS KITCHENS: Sir?

23 MR. LYON: It's loud enough that someone is going to
24 pick it up.

25 WITNESS KITCHENS: Yes, sir, it's a very irritating

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J

0
7
0
0
2

F
O
R
M

F
E
D

1 sound. When that alarm goes off, you would definitely hear
2 it in the control room.

3 MR. LYON: Now that is a computer processed signal.
4 Is that sampled at any particular time interval?

5 WITNESS BURMEISTER: That's variable, depending upon
6 the selection on the screen.

7 MR. LYON: Between what and what.

8 WITNESS KITCHENS: I think you're answering a
9 different --

10 MR. AUFDENKAMPE: I'd say two seconds but it might
11 be one second. I might have Proteus and ERF confused.

12 WITNESS KITCHENS: He's talking about how often does
13 the computer give the amps.

14 MR. LYON: Of the order of two seconds. That would
15 be a minimum, but that is an operator selectable value?

16 WITNESS KITCHENS No, sir, it is not. What Bill
17 was referring to is that the operator can select the trend,
18 whether he wants to see amps for the last two hours or 20
19 minutes or five minutes.

20 MR. LYON: Okay, I understand.

21 What consideration went into the selection of that
22 two second sample interval and whether it was sufficient to
23 meet the objectives?

24 WITNESS KITCHENS: The two second sample interval, I
25 believe was the computer itself, it's built into it.

1 MR. LYON: Okay.

2 MR. AUFDENKAMPE: Once we got to generic letter 8817
3 and we decided to display pump amps into the ERF, it was
4 already built into the machine.

5 MR. LYON: I understand.

6 MR. AUFDENKAMPE: When they spec'd out the machine,
7 two seconds was something that they evaluated and determined
8 that that would be adequate for our needs.

9 MR. LYON: Is your judgment that a two second sample
10 time is sufficient to show noise on the pump motor current
11 if you're hitting an intermittent vortex situation?

12 MR. AUFDENKAMPE: I've never really thought of it.

13 WITNESS KITCHENS: My answer is yes, based on
14 experience both in the plant and observing --

15 MR. LYON: Was that considered as to determination
16 of adequacy when you selected this method of showing the
17 motor current?

18 MR. AUFDENKAMPE: I don't know.

19 WITNESS KITCHENS: You have the wrong people to get
20 that. That's the design group.

21 MR. LYON: Okay, that's good feedback, I appreciate
22 that.

23 WITNESS LEE: It takes a sample, it has to have too
24 many perturbations -- two perturbations in five seconds,
25 something like that, for it to --

P
E
N
G
A
D
C
O
B
A
Y
C
I
N
E
N
J
U
7
0
0
2
F
O
R
M
F
E
E
D

1 MR. AUFDENKAMPE: For the alarm, but to record the
2 data it doesn't.

3 WITNESS LEE: On, all the time.

4 MR. DIETZ: You mentioned about some experience in
5 the plant. Since you've had it in there, have you gotten
6 down to where you were starting to see a little bit of air
7 being pulled into the RHR pump?

8 WITNESS KITCHENS: No, not that I'm aware of. The
9 settings that we had put in originally for the -- I told you
10 that this was put in as an alarm function is one of the
11 critical safety function trees, the initial settings were
12 apparently too tight because we did get some spurious
13 alarms. In other words, it sees the fluctuations very well
14 on the ERF computer and when you change flow rates on the
15 pump you can see it very well, the amps changing.

16 WITNESS BURMEISTER: We had the fortune of being
17 able to do a test on Unit 2 before we actually went critical
18 with RHR in service, and we lowered the level in the RCS and
19 determined exactly under what conditions flow rate versus
20 number of pumps in service, versus reactor vessel level --
21 at what time -- at what position the onset of air
22 entrainment and air binding had occurred. So we have some
23 good information on that and our procedures pick a margin
24 for operating at mid-loop which is substantially above the
25 level where we get onset of vortexing.

1 MR. DIETZ: Did you have the amp indication at the
2 time?

3 WITNESS BURMEISTER: What I was going to ask -- we
4 may have observed motor current and I was just wondering,
5 John, if you knew that.

6 MR. AUFDENKAMPE: When we did the cavitation time?

7 WITNESS BURMEISTER: Right. Do you recall -- we may
8 have an individual that is aware of how much cycle or
9 frequency -- what the frequency of cycling was on motor
10 current, who might have information on that, when vortexing
11 actually occurred.

12 WITNESS KITCHENS: Again if you want to know about
13 that test, you have the wrong people in here, but we can get
14 the right person in here probably -- possibly the one who
15 conducted it. We did do a pre-operational test for this
16 reason of determining when we would get vortexing and the
17 stability of our pumps at mid-loop on Unit 2.

18 MR. LYON: One thing that I forgot to ask, do you
19 folks have information on the behavior of cold leg
20 temperature indications and say RHR temperature indications
21 when the RHR pumps are not running and is this factored into
22 training?

23 WITNESS KITCHENS: I need to be excused at least for
24 a few minutes.

25 WITNESS BURMEISTER: Would you ask that question

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

again?

MR. LYON: Sure. Do you folks have information on your behavior of your cold leg temperature indications and the RHR temperature indications when you have no RHR flow, how those would be expected to behave and has that been factored into training?

WITNESS BURMEISTER: I'm not probably the best person to answer that, again Rob Dorman may be, but to my knowledge we have not looked at or discussed how cold leg temperature indication would compare to RHR temperature indication while RHR is in service and out of service during training sessions.

MR. LYON: I'm really only interested in the out of service. Do you have a personal judgment on how that would behave if you had loss of RHR, anybody?

WITNESS LEE: It would rise.

MR. LYON: Okay, so the RHR -- am I hearing that the cold leg temperatures and the RHR temperature would track the core exit?

MR. AUFDENKAMPE: They would trail.

MR. LYON: Would what?

MR. AUFDENKAMPE: Trail core exit --

MR. LYON: Trail, but you would expect them to come up slowly, perhaps at a slower rate than the core exits?

MR. AUFDENKAMPE: Yeah, never getting to the core

P
E
N
D
A
D
C
O
B
A
T
C
O
N
N
E
N
J
O
Y
O
O
Z
F
O
R
M
P
E
D

1 exits.

2 MR. LYON: Understand. You're saying they're going
3 to hang behind a ways. Okay, that was the part I had
4 forgotten to cover.

5 Let me go over to the steam generator for a little
6 bit. Have you addressed steam generator condition in the
7 response to 8817? And if so, how?

8 WITNESS BURMEISTER: From an inventory standpoint?

9 MR. LYON: Sure, from anything. Is there anything
10 you do with respect to your steam generators that impacts
11 either positively or negatively on the plant and that's
12 related to the 8817 topics?

13 WITNESS BURMEISTER: I can tell you what conditions
14 do exist in the plant but I can't tell you how they compare
15 to what our response was in 8817.

16 MR. LYON: Okay, I'm really not trying to contrast
17 your response in writing, if you will, if that's what you
18 mean. What I'm trying to do is establish a picture of the
19 things that you have in the plant -- yes, tied to 8817
20 perhaps, but more importantly the actual condition that the
21 plant would be expected to be in to deal with the 8817
22 topics.

23 WITNESS BURMEISTER: The steam generators are
24 normally kept in wet lay up at 95 percent level indication
25 on the wide range scale. The only time we drain them down

P
E
N
G
A
D

C
O

B
A
Y
C
K
N
E

N
J
0
7
0
0
6

F
O
R
M

F
E
D

1 is to improve the chemistry situation in the generators and
2 to perform sludge lancing and in particular this outage, we
3 drained them down for -- we drained one steam generator down
4 for one other reason and that was to install another steam
5 generator level tap for a modification that we are making to
6 our level control system. So the bulk of the time during
7 the outage, the steam generators are at 95 percent wide
8 range level.

9 MR. LYON: Is there a control or procedure that
10 deals with those kinds of operations while you're at mid-
11 loop?

12 WITNESS BURMEISTER: The unit operating procedure
13 has -- as we cool down and enter Mode 5 on the way down, has
14 you place the steam generators in wet lay up which is a
15 condition where you have 95 percent wide range level.

16 MR. LYON: If you were at mid-loop, would you drain
17 one or more steam generators if you needed to do something
18 with that steam generator such as eddy current testing?

19 WITNESS BURMEISTER: In light of everything that's
20 happened, it wouldn't be prudent but we --

21 MR. LYON: But that wasn't my question.

22 WITNESS BURMEISTER: We don't have procedural
23 controls which would prevent you from draining the steam
24 generator, if that's what you're asking.

25 MR. DIETZ: During this outage when you went down

P
E
N
G
A
D

C
J

B
A
Y
O
N
N
E

N
J

D
7
0
0
2

F
O
R
M

F
I
L
E

1 the first time, you did some steam generator sludge lancing?

2 WITNESS BURMEISTER: Right, but that occurred after
3 we had refilled the RCS.

4 MR. DIETZ: It did not occur at mid-loops?

5 WITNESS BURMEISTER: The steam generators were only
6 drained during the period of time the cavity was filled with
7 water, to my best recollection.

8 MR. LYON: Is anything done with respect to steam
9 generator operability so that these are going to serve
10 potentially as a place that will remove heat from the RCS,
11 such as being able to dump steam.

12 WITNESS BURMEISTER: Not procedurally to my
13 knowledge; however, they were available. I mean all four of
14 the steam generators were available to remove steam, the
15 atmospheric relief valves could have been manually opened
16 without power.

17 MR. LYON: Is that in procedures anywhere?

18 WITNESS BURMEISTER: Yes.

19 MR. LYON: Which procedure?

20 WITNESS BURMEISTER: 18038, is that the right
21 procedure, Greg?

22 WITNESS LEE: Yes, that's the procedure on how to
23 manually open the ARV's without any power.

24 MR. LYON: Is that referred to in the loss of RHR
25 procedure?

P
E
N
S
A
D

C
O

B
A
Y
C
O
L
N
E

N
I

O
7
D
S
2

P
O
R
T
M

F
E
D

1 WITNESS BURMEISTER: There's also a system
2 operating procedure that covers the same evolution, but I
3 don't believe either of those procedures are referenced by
4 the loss of RHR procedure.

5 MR. LYON: Is that kind of thing covered by
6 training? Would you believe it was general knowledge that
7 people would respond to?

8 WITNESS BURMEISTER: In connection with the loss of
9 RHR incident?

10 MR. LYON: Yes. If the temperature were climbing in
11 the RCS and you were boiling and steam generator pressure
12 were beginning to rise.

13 WITNESS BURMEISTER: I can't tell you that that's
14 explicitly stated in training. I think you would have to
15 draw together your total -- your integrated knowledge of the
16 plant and overall training to include that.

17 MR. LYON: Okay.

18 WITNESS LEE: It has a step in here that says in
19 Mode 4 and the steam generators are available for RCS
20 cooling, then maintain TAUG below 350 by maintaining at
21 least one steam generator field in the narrow range and by
22 dumping steam using the steam dumps or the steam generator
23 atmospheric relief valves. So that's the guidance given in
24 the AOP. It doesn't reference 18038, but that's common
25 knowledge, they know to go to that.

1 MR. LYON: I understand. One of the areas that 8817
2 covered was systems that support the RHR system. Could you
3 discuss for us the way in which supporting systems were
4 incorporated into your processes for conducting mid-loop
5 operations and in the training?

6 WITNESS BURMEISTER: I can give you a perspective
7 from the outage standpoint, outage planning standpoint. We
8 scheduled support systems to be available for RHR, both
9 trains of RHR, during mid loop operations. They include
10 NSCW and CCW cooling. Both systems were available for both
11 trains of RHR and both 1-E busses were energized to support
12 operation of the RHR pumps, unfortunately from the same
13 source, but -- as you well know, but all the support systems
14 were available.

15 MR. LYON: Is there a procedure or process that
16 reasonably assures that kind of consideration or is this a
17 team judgment, if you will, on the part of the people
18 planning the outage?

19 WITNESS BURMEISTER: More than anything, I think it
20 is our philosophy or interpretation with respect to
21 complying with Technical Specifications. I'll try to avoid
22 using acronyms.

23 MR. LYON: Do you believe that compliance with
24 Technical Specifications is going to mean that you also
25 comply with the recommendations of 8817?

P
E
N
G
A
D

C
O

B
A
T
U
N
N
E

N
J

O
7
U
O
2

F
O
R
M

F
E
O

1 WITNESS BURMEISTER: I think it's our intent to
2 comply with both, the recommendations in 8817 and Technical
3 Specifications.

4 MR. LYON: Understand.

5 WITNESS BURMEISTER: I'm not sure I understand.

6 MR. LYON: All right, let me try it again. I have a
7 set of Technical Specifications, I have a set of
8 recommendations in generic letter 8817. Do you believe that
9 complying with your Technical Specifications would also
10 satisfy the 8817 recommendations?

11 MR. CHAFFEE: Or would they ensure that --

12 WITNESS BURMEISTER: No, there are many more
13 recommendations and requirements addressed in the generic
14 letter that go above and beyond what is called for in the
15 Technical Specifications.

16 MR. AUFDENKAMPE: The way we take care of that,
17 Warren, is all our commitments associated with generic
18 letters or any other NRC correspondence goes through our
19 commitment tracking program. We generate action items which
20 go to Greg, who puts them into the procedures and then we
21 follow our procedures. So all of those commitments are
22 incorporated into procedures.

23 MR. LYON: Can you describe how the commitment --
24 I'll put it in quote -- well first of all, what is your
25 commitment to supply supporting systems for the RHR in mid-

1 loop operation and can you describe how that is processed
2 through the procedure you just described? What assures that
3 it is going to happen?

4 WITNESS BURMEISTER: That's a big question.

5 WITNESS LEE: You have to have two loops of RHR and,
6 you know, our RCS loops, that's a Tech Spec, and to have
7 support systems -- for RHR to be operable, that means you
8 have a support system. Sometimes though -- there was some
9 guidance to have a backup for things like SIP's which is in
10 conflict with the Tech Specs.

11 MR. LYON: Yes. And that's a piece of it.

12 WITNESS LEE: I know that's not exactly the support
13 systems that you're referring to, you're talking about
14 support systems to ensure --

15 MR. LYON: Okay, but that's a support system, if you
16 will, for RCS cooling and that's fair game, if you will, in
17 the scope of my question.

18 WITNESS BURMEISTER: As well as containment air
19 coolers?

20 MR. LYON: Yes, we did not mention containment air
21 coolers in 8817 but that's fine too.

22 WITNESS BURMEISTER: We put that in our procedures
23 too and they're tracked by commitments as John mentioned
24 earlier.

25 MR. LYON: And the SI pump?

1 WITNESS LEE: Having it available even though it's,
2 you know, racked out, but available for use. That's in the
3 procedures, which is really like a -- we're complying with
4 Tech Specs but you know, we have it available should we need
5 it as a last resort, since we don't have hot leg injection
6 any other way but by the SIP.

7 MR. CHAFFEE: So you make sure they're available
8 when you're in mid-loop operations, is that what you're
9 saying, or just when you're shut down or at all times?

10 WITNESS LEE: For mid-loop operations.

11 MR. CHAFFEE: That's required by one of your
12 procedures?

13 WITNESS LEE: Yes.

14 MR. CHAFFEE: But was that an enhancement as a
15 result of generic letter 8817 or an offshoot from that?

16 WITNESS LEE: Yes. In the way that the
17 Westinghouse owners' group was going with their procedure
18 and recommendations when I was --

19 MR. CHAFFEE: Did the Westinghouse owners' group
20 publish their guidance for their procedures?

21 WITNESS BURMEISTER: It has not been distributed
22 yet, should be within a week or two.

23 MR. CHAFFEE: Do you know what's going to be in it?

24 WITNESS BURMEISTER: Yes.

25 MR. CHAFFEE: Have you implemented what's in it?

P
E
N
G
A
D

C
O

B
A
Y
O
N
H
E

N
J
O
R
D
O
O
R

F
O
R
W

F
E
D

1 WITNESS BURMEISTER: A lot of what's in it, we have
2 currently covered in our abnormal operating procedure.

3 MR. AUFDENKAMPE: You know, we haven't implemented
4 all the corrective actions associated with generic letter
5 8817. Those are the hardware things committed to be done by
6 the end of this outage -- we're close but the hardware stuff
7 is committed to be done by the end of this outage with the
8 analysis and procedure changes by May 3, that's on Unit 1,
9 and Unit 2 is the end of the upcoming Unit 2 outage.

10 MR. CHAFFEE: You've probably gone over this before,
11 but let me ask a question, can you summarize for me the
12 things that you've done as a result of 8817 in hardware
13 changes, procedure changes?

14 WITNESS LEE: There have been a lot of procedure
15 changes. I can go through the procedures --

16 MR. CHAFFEE: I don't mean -- like what have you
17 done to assure that you have redundant sources of water
18 available to make up the RCs?

19 WITNESS LEE: We have a statement about maintaining
20 RWST level.

21 MR. AUFDENKAMPE: We have RWST level, we have a
22 charging pump available that we have to have available at
23 all times. We have a safety injection pump that although
24 Tech Specs require us to have it inoperable, all we do is
25 take out the pump breaker and the hand switch, the entire

P
E
N
G
A
D
C
O
B
A
Y
O
N
N
E
N
J
O
Z
B
O
O
2
F
O
R
M
F
E
E
D

1 system beside that is ready to come to service.

2 MR. CHAFFEE: Oh, the Tech Specs require the safety
3 injection pump to be inoperable?

4 MR. AUFDENKAMPE: Yes. What we've done is if we
5 would have to use that, then we would use 1054-X for an
6 emergency condition.

7 MR. CHAFFEE: I see. So in this case, the Tech
8 Specs are set up so they work against being able to deal
9 with the problem of loss of RHR.

10 WITNESS LEE: But we're proceeding to request --

11 WITNESS BURMEISTER: I can briefly go through about
12 a dozen changes to our procedures if you want me to.

13 MR. CHAFFEE: Okay.

14 WITNESS BURMEISTER: These are all additions that we
15 didn't have say two years ago. We've made changes over the
16 last two years and we've made changes as recently as 3/8/90.
17 We're continuing to add more information as we get it.

18 MR. CHAFFEE: And the thing that triggered you to
19 start making changes two years ago was what?

20 WITNESS BURMEISTER: Probably --

21 WITNESS LEE: Probably 8712, the Diablo Canyon
22 event.

23 WITNESS BURMEISTER: Containment closure status to
24 ensure it is capable of being closed within 57 minutes is
25 our current time based on the latest analysis or ensure the

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J
0
7
0
0
2

F
O
R
M

E
E
D

1 hatch --

2 MR. CHAFFEE: I have a question on that. On this
3 particular event on Tuesday, I think it took an hour and 20
4 minutes to close the hatch. Is there a reason why it took
5 longer or do you have any idea?

6 MR. AUFDENKAMPE: I think the answer to that is once
7 the order was given to close the hatch, it took like 42
8 minutes.

9 MR. CHAFFEE: Oh, is that right?

10 MR. AUFDENKAMPE: But there was a delay in giving
11 the direction to go close the hatch, in evaluating the
12 condition that we were in and taking the appropriate
13 corrective actions.

14 WITNESS BURMEISTER: Right. We initiated action to
15 close it and we got it into condition to where it could
16 readily be closed and then we told them to wait because I
17 think at that time we had established RHR cooling.

18 MR. CHAFFEE: Does the 57 minutes include the time
19 it takes to recognize you need to do it or is it from a
20 certain point in the event or do you know?

21 WITNESS BURMEISTER: That information should be in
22 that --






23 MR. AUFDENKAMPE: That 57 minutes is from time zero
24 when you do shutdown cooling.

25 MR. CHAFFEE: So in this case --

P
E
N
G
A
D
C
O
B
A
Y
O
N
N
E
N
J
O
7
D
D
2
F
O
R
M
E
D






1

IMAGE EVALUATION TEST TARGET (MT-3)








1

IMAGE EVALUATION TEST TARGET (MT-3)



1

IMAGE EVALUATION TEST TARGET (MT-3)



1 MR. AUFDENKAMPE: But the 57 minutes is also with
2 respect to the worst case condition, which is 48 hours after
3 shutdown.

4 MR. CHAFFEE: So the follow on question would be, in
5 this case it took an hour and 20 minutes to do it -- granted
6 it wasn't the worst case. Is there some reason to believe
7 that if it was a worst case you would have been able to do
8 it in 57 minutes instead of an hour and 20 minutes? Is
9 there something about what happened here that -- just the
10 fact that it was not as much of an anxiety -- can you think
11 of any reason why you could do it faster in the worst case
12 scenario than in this case? It must have taken some time to
13 recognize you needed to do it?

14 MR. AUFDENKAMPE: I wasn't in the control room but
15 my perspective from the TSC, although power was back by the
16 time I got to the TSC, is that they had started preparations
17 for it but they were concentrating on restoring power and
18 had restored power and in fact the order was actually given
19 after power was restored, to go ahead and shut it.

20 WITNESS BURMEISTER: While I was in the TSC, that
21 happened. I went to the TSC after electrical power had been
22 restored and I requested that maintenance not continue
23 attempting to put the equipment hatch in place because we
24 had RHR cooling in place and RCS had been cooled down to 90
25 some degrees and conditions were stable and they were in the

1 process -- they had already energized one RAT -- reserve
2 auxiliary transformers -- to one of the emergency busses and
3 were in the process of energizing the other bus from the
4 reserve auxiliary transformer. And I at that time told them
5 not to continue trying to close the hatch and to just stay
6 on standby and keep people there ready to close it if we
7 need them, but not to continue. And that's why I think
8 there was a pretty substantial delay in closing the
9 equipment hatch. It's not that we were not capable of
10 closing it sooner, we had pulled them back from doing it.

11 MR. LYON: What was the position of the hatch and
12 the condition of the polar crane with respect to the hatch
13 when you told them to hold?

14 WITNESS BURMEISTER: I was told that the hatch was
15 lowered, they had begun lowering the hatch over the opening.

16 MR. LYON: That's close enough.

17 WITNESS BURMEISTER: I don't have a very good
18 description other than that.

19 MR. LYON: That's close enough.

20 WITNESS BURMEISTER: To me it sounded like it was
21 imminent, you know. If I asked them to do it, they could
22 get it done in 15 minutes. That's the impression I got
23 talking to the maintenance manager in the TSC.

24 MR. AUFDENKAMPE: From the point he slowed down, not
25 from the beginning.

1 WITNESS BURMEISTER: Right.

2 MR. CHAFFEE: The 57 minutes to shut the hatch, is
3 that something that -- that's what you have to meet in worst
4 case conditions?

5 WITNESS BURMEISTER: Yes.

6 MR. CHAFFEE: And what in fact can you do, best
7 case, is it a lot -- can you do it in 30 minutes or --

8 WITNESS BURMEISTER: I don't think we have conducted
9 a time test, that would be something interesting to try.

10 MR. CHAFFEE: Yeah, I agree, that's a good idea.

11 MR. DIETZ: How long did they delay from the time
12 you asked them to stop until you then requested them to
13 restart -- what time delay are we talking about?

14 WITNESS BURMEISTER: I don't know because I left the
15 TSC sometime after that and apparently Skip or somebody else
16 there, Jimmy Paul Cash possibly, asked them -- requested
17 them to continue placing equipment hatch, for whatever the
18 reason was.

19 MR. CHAFFEE: You were taking us through --

20 WITNESS BURMEISTER: Okay, I'm sorry. The next item
21 we have, a review of all containment penetrations addressed
22 in a procedure or surveillance procedure, we have should be
23 accomplished to determine those which have been opened by
24 manual means and an info LCO generated for those identified.
25 Basically review all the penetrations and make sure they are

P
E
N
D
A
D

C
O

B
A
Y
O
N
N
E

N
J
0
7
0
0
2

F
O
R
M

F
E
D

1 secured.

2 MR. CHAFFEE: So you do that before you go out to
3 mid-loop, is that the idea?

4 WITNESS BURMEISTER: Right. And they're either
5 secured or we initiate a piece of paper that says this
6 penetration is not in a condition that constitutes
7 containment integrity for Mode 6 or Mode 5 and therefore, we
8 could look at these pieces of paper. They're in what we
9 call information LCO's -- and determine which penetrations
10 we need to go out and manually secure. I think that was
11 talked about a little bit earlier today.

12 The next item is with respect to installing cold leg
13 dams and what we need for vent paths. Basically the vent
14 paths that we can use are the pressurizer manway or steam
15 generator manway on the hot leg side that is not dammed, or
16 removing three pressurizer code safeties from vent paths.

17 If it is intended to operate at one foot above mid
18 nozzle level, the preferred RHR configuration is one train
19 in operation with a flow of 3000 gallons per minute.

20 MR. CHAFFEE: Is that a change from previous?

21 WITNESS WEST: It was to reinforce the fact not to
22 have excessive flow. The pump is capable of much more than
23 3000 gallons a minute.

24 MR. CHAFFEE: So previously you had no guidance for
25 mid-loop and this became the guidance?

F
E
N
G
A
D
C
O
B
A
Y
O
N
N
E
N
J
O
7
O
O
2
F
O
R
M
F
E
E
D

1 WITNESS WEST: The standing order that the troops
2 have is to have an excessive Tech Spec minimum and the Tech
3 Spec minimum we decreed is 3000 gallons a minute and that's
4 the only guidance that they had.

5 MR. CHAFFEE: So the tendency would be to have 3500
6 or 4000 to make sure you don't drop below the Tech Spec
7 limit, but in this case --

8 WITNESS WEST: In this case here we want them to
9 keep it as low as possible.

10 WITNESS BURMEISTER: If it is intended to operate
11 below 191 foot elevation -- this is four feet above mid-loop
12 or three feet below the flange -- a minimum of two in-core
13 thermocouples shall be available during periods where the
14 reactor head is installed and to request I&C to set an in-
15 core thermocouple alarm set point to 10 degrees above the
16 desired temperature per a procedure they follow.

17 MR. CHAFFEE: Where are the thermocouples read out
18 when they're installed?

19 WITNESS BURMEISTER: On the ERF computer.

20 MR. CHAFFEE: Is that the only place?

21 WITNESS BURMEISTER: Or also the Proteus.

22 I&C should be notified to install temporary remote
23 level monitoring in the control room, this is the RVLIS
24 tap, the instrumentation that comes off the RVLIS taps and
25 it's available on a cumulator level indicator on the main

1 control board.

2 Tygon tube watch is required any time the RCS level
3 is being changed while the RCS level is below 17 percent.
4 Periodic comparison checks should be made every four hours
5 between the control room and temporary level monitors in the
6 tygon tube. Control monitor should agree within seven
7 percent of scale with the tygon tube.

8 MR. CHAFFEE: Is there any standard in there in
9 terms of how close the reading should be between the
10 thermocouples? Between the thermocouple reading out on the
11 ERF as opposed to the Proteus?

12 WITNESS BURMEISTER: No, we don't have any
13 procedural guidance.

14 MR. CHAFFEE: Have you had any problem with the two
15 disagreeing?

16 WITNESS BURMEISTER: It's the same information, they
17 should read out the same, but I can't tell you without
18 checking myself, I haven't verified that.

19 Two out of three level monitors must agree before
20 draining the RCS below the top of the hot leg. If neither
21 control room RCS monitor is available, a continuous tygon
22 tube watch should be established while the RCS level is
23 below 17 percent in the pressurizer.

24 While operating with steam generator nozzle dams
25 installed --

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J

D
I
S
S
E

F
U
R
M

F
E
E
D

1 MR. CHAFFEE: The word you used was "should" or was
2 it --

3 WITNESS BURMEISTER: Our "shoulds" are like
4 "shalls".

5 MR. CHAFFEE: Okay.

6 WITNESS BURMEISTER: According to our guidance in
7 the procedures. That's different than most places, but --
8 I think the definitions are like if we have a "shall" in a
9 procedure, that's like a regulatory commitment or an ANSI
10 document or some other type of commitment. If it's a
11 "should" we follow it anyway, but it's not necessarily
12 required by some other document. Is that right, Greg?

13 WITNESS LEE: Yeah, that's right. "May" is the only
14 thing is optional and even at that you have to have
15 management okay to perform a "may" -- not to perform a
16 "may".

17 WITNESS BURMEISTER: If neither control -- excuse
18 me, the next one -- while operating with the steam generator
19 nozzle dams installed ensure one safety injection pump is
20 capable of being racked in and operated in the hot leg
21 injection mode if needed. This is what we talked about
22 earlier.

23 While level is in the region of the RCS hot leg,
24 trend RHR pump parameters on the ERF for early detection of
25 possible RHR pump degradation due to vortexing. This would

F
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J
0
7
0
0
2

F
O
R
M

F
E
E
D

1 include the current indication of RCS RHR flow --

2 WITNESS WEST: RCS pressure also.

3 WITNESS BURMEISTER: RCS pressure, temperature --
4 also have an interesting parameter that I used to monitor
5 when I was on shift and that's RHR pump discharge pressure
6 and I used to monitor that on the shutdown train because
7 it's an indication of water level.

8 MR. CHAFFEE: Oh, is that right?

9 WITNESS BURMEISTER: A very good one in fact. We
10 can set limits on our trended parameters to alarm if they're
11 exceeded and in one particular instance, we had a suction
12 valve on one of the RHR trains go closed and got -- we were
13 trending the RHR pump discharge pressure on the shutdown
14 pump and the trend parameter went off scale and changed just
15 from that perturbation and the operators caught it and
16 within 30 second they were able to shut down the RHR pump,
17 so that's a good indication of water level that we don't
18 take credit for.

19 MR. CHAFFEE: This is a side question. If we wanted
20 to find out what the data collection capabilities are of
21 your ERDS --

22 WITNESS BURMEISTER: ERF computer?

23 MR. CHAFFEE: Proteus. Who do we ask to get a half
24 hour tutorial on its ability to collect data?

25 MR. AUFDENKAMPE: Those are two different people.

1 The ERF computer is John Ealick and the Proteus computer is
2 Larry Smith.

3 MR. CHAFFEE: Do you happen to know from those two
4 systems if they collected all the data up from this
5 particular event?

6 WITNESS BURMEISTER: That should be part of the
7 event critique package. I don't know if you've had the
8 opportunity to look at that yet.

9 MR. CHAFFEE: It's actually included as part of the
10 package?

11 MR. AUFDENKAMPE: Everything that printed would be
12 in that package.

13 MR. CHAFFEE: Is it typically a fairly voluminous
14 amount of material or --

15 MR. AUFDENKAMPE: Proteus generally is, although in
16 this kind of condition you may not get much. It's really
17 when you get a trip from power that it starts going berserk.

18 MR. LYON: But that system only puts out what is
19 printed?

20 MR. AUFDENKAMPE: Both of them just generally put
21 out -- well for the conditions that we're looking at,
22 generally just print out the alarm status changes.

23 MR. LYON: And in this instance was any of that
24 material being printed out or provided or was it disabled
25 because of the power situation, do you know?

F
R
E
E
D
O
M
R
E
C
O
R
D
S

1 MR. AUFDENKAMPE: No, the computer worked, we had a
2 -- let's talk about the ERF computer because that's going to
3 give you better data associated with this event.

4 MR. LYON: Okay.

5 MR. AUFDENKAMPE: The ERF computer has a hard disk.
6 It always keeps two hours of plant history and when you have
7 a -- what I'll call a mode change, computer mode change,
8 when it goes to mode zero, it saves that two hours of data
9 on hard disk and then it starts accumulating data, it starts
10 out at two second frequencies and then as time goes on it
11 goes to five seconds and keeps getting longer and longer and
12 I think at about 14 hours it runs out of storage space. And
13 in this event, we -- about an hour and a half into it, we
14 took it from whatever mode it was in, probably mode 6, to
15 mode zero and saved all that data so we can replay the
16 entire event on the simulator.

17 MR. CHAFFEE: Oh, is that right? You've got that
18 all saved?

19 MR. AUFDENKAMPE: Yes.

20 MR. CHAFFEE: In the simulator, you could reproduce
21 the entire thing?

22 MR. AUFDENKAMPE: (Nodding head affirmatively.)

23 MR. CHAFFEE: Well how about that.

24 WITNESS BURMEISTER: Can it actually run the
25 simulator?

1 MR. AUFDENKAMPE: Yes.

2 MR. CHAFFEE: And that would include -- would that
3 by chance include the data on the thermocouples?

4 MR. AUFDENKAMPE: It includes the thermocouple data,
5 unfortunately at some time into the event, the thermocouple
6 data on the ERF computer went screwball.

7 MR. CHAFFEE: Figures. I thought that was too good
8 to be true. Okay. Maybe we ought to -- who do we talk to
9 to have it run on the simulator?

10 MR. AUFDENKAMPE: Probably Ken Holmes. There may be
11 some bugs in it, it's designed to do that, I don't know if
12 we've ever done it before.

13 MR. CHAFFEE: Okay, that's great.

14 WITNESS BURMEISTER: There's a couple more
15 statements in the procedures.

16 A minimum of four containment cooling units will be
17 operable and capable of being started if required while the
18 RCS level is below 191 feet.

19 MR. CHAFFEE: Say that one more time.

20 WITNESS BURMEISTER: A minimum of four containment
21 cooling units will be operable and capable of being started
22 if required while the RCS level is below 191 feet, which is
23 three feet below the flange. We also give some explicit
24 guidance on controlling level. Minimum RCS level is one
25 foot above mid-nozzle except for steam generator burping

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J
O
D
O
O
P

F
O
R
M

F
E
E
D

1 during the initial drain down, and there you can reduce
2 level to six inches above vent loop to facilitate burping
3 the steam generators.

4 MR. LYON: While you're doing that draining
5 operation, are there pauses to allow the system to
6 stabilize?

7 WITNESS BURMEISTER: Actually this particular
8 requirement existed quite a bit earlier, two or three years
9 ago and maybe even longer than that. We currently drain the
10 steam generator U-tubes in a different fashion. We
11 introduce nitrogen to the channel heads and actually force
12 the water -- or displace the water in the U-tubes with
13 nitrogen, and this can be done at a higher level than mid-
14 loop.

15 MR. LYON: And when you say you introduce it, how is
16 it brought in?

17 WITNESS BURMEISTER: The nitrogen?

18 MR. LYON: Yes.

19 WITNESS BURMEISTER: Through a regulator onto
20 channel head drains off the steam generators, there's a one
21 inch flow path that's just right at the bottom of the steam
22 generator, the nitrogen comes in and flows up into the U-
23 tubes displacing the water and allows them to drain.

24 MR. LYON: You're very unique in that, few people
25 can do that.

1 WITNESS BURMEISTER: There are a few other plants
2 that use it.

3 MR. LYON: It was one of the suggestions, few people
4 have figured out a way to do that well. There are a few
5 that have installed pipes. I didn't know that you were one.

6 WITNESS BURMEISTER: We just did that just prior to
7 the last refueling outage.

8 MR. CHAFFEE: What's this pipe again?

9 WITNESS BURMEISTER: It's a channel head drain
10 that's part of the Westinghouse design on the steam
11 generators. We didn't ask for anything to be added, that's
12 just -- if you were to drain the channel head, for example,
13 to do eddy current inspect' g, you have to put your
14 equipment inside the steam generator channel heads. Before
15 you do that, you can open these drain -- the one inch drain
16 valves and drain that area so that it's a lot easier than
17 having to go in there and suction it out or mop it out or
18 otherwise take it out.

19 MR. CHAFFEE: I'm missing the significance of having
20 it there.

21 MR. LYON: The significance is that most people
22 drain down and they have to allow nitrogen to pass from
23 either the vessel head or the pressurizer by way of the
24 surge line, or both, up into the steam generators so that
25 the water can drain out of the tubes and it usually comes

1 sloshing down and it's a very erratic kind of an operation,
2 difficult to control and it introduces a lot of uncertainty.
3 By introducing the nitrogen directly below the -- shoot,
4 what's the word I want -- the tube sheet, directly below the
5 tube sheet, it allows the tubes to drain smoothly and you
6 don't get into a lot of this difficulty and you can progress
7 with your draining more rapidly without all that erratic
8 nonsense. It's a good technique.

9 MR. CHAFFEE: What they do is they actually have a
10 pipe that --

11 MR. LYON: It injects nitrogen, if you will, right
12 down below the ends of the tubes and it goes right up into
13 the tubes and allows them to drain.

14 MR. CHAFFEE: And that was standard design in the
15 steam generators, is that --

16 WITNESS BURMEISTER: Yes.

17 MR. AUPDENKAMPE: It's not designed --

18 WITNESS KITCHENS: No, but I mean we didn't ask for
19 it for this reason in our steam generators. There are some
20 plants that don't have that and originally we were going to
21 inject the nitrogen by disassembling one of the RCS flow
22 scoops, which is what I believe Plant Farley does. Some
23 other plants do that. But because we have the channel head
24 drains, it's easier, we just hook up a nitrogen supply, a
25 nitrogen bottle, to the channel head drain and blow the

1 water out of the tubes that way.

2 MR. AUFDENKAMPE: Here's a diagram of it, this is
3 the tube sheet here and you have a baffle between the hot
4 leg and the cold leg and then we've got a little drain valve
5 in here and we send nitrogen up in there, it bubbles up into
6 here and then it helps the water come down and provides a
7 gas to displace the water. And then it also drains out this
8 section. There's a little hole between the baffle pipes so
9 it communicates with both sides.

10 MR. LYON: Now what is the reason you come down with
11 this six inches at mid-loop to do that?

12 WITNESS BURMEISTER: No, we don't.

13 MR. LYON: I misunderstood, would you say again at
14 what level --

15 WITNESS BURMEISTER: If we were not to use the
16 nitrogen bottles, we would drain down to six inches above
17 mid-loop to facilitate natural draining of the U-tubes. But
18 because we introduce the nitrogen into the channel heads, we
19 can do that at some level above the top of the hot legs.

20 MR. LYON: Okay, I misunderstood then.

21 WITNESS KITCHENS: He read you the procedure, it
22 tells you to only go to 188 foot unless you're going to burp
23 the steam generators. We haven't used that.

24 MR. LYON: And you cannot do that?

25 WITNESS BURMEISTER: The provision exists in the

P
E
N
D
A
D
C
O
B
A
Y
O
N
N
E
N
J
U
Y
O
O
R
2
F
O
R
M
P
E
D

1 procedure, but we don't use that right now.

2 MR. LYON: Okay, so one real benefit is they don't
3 have to go to mid-loop to drain their steam generators and a
4 plant without this capability has to do that and it's a very
5 erratic kind of a mid-loop to boot.

6 MR. CHAFFEE: You don't have to go to mid-loop to
7 drain the steam generators.

8 MR. LYON: As defined in the generic letter.

9 MR. CHAFFEE: Oh, I see, but other plants have to go
10 to mid-loops just to get the water out of the U-tubes?

11 MR. LYON: Yes. To put the dams in, yes, you still
12 have to go to mid-loop, but that's a more stable condition
13 then.

14 You indicated -- I'm sorry, are you finished?

15 WITNESS BURMEISTER: Yes.

16 MR. LYON: Okay --

17 WITNESS BURMEISTER: There's one other important
18 change that I think you might already be familiar with, but
19 the interlocks on the suction valves for RHR are disabled
20 when we drain to mid-loop.

21 MR. CHAFFEE: Required by procedures?

22 WITNESS BURMEISTER: Right.

23 MR. LYON: When you put an SI pump onto what you've
24 termed an available basis, what assures that that SI pump is
25 lined up and that the various valves that are needed are

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J

O
7
0
0
7

F
O
R
M

F
E
E
D

1 indeed either lined up or can be operated so that you can
2 pump water into the RCS -- what procedure covers that?

3 WITNESS LEE: This procedure here does.

4 MR. LYON: Which procedure is that?

5 WITNESS BURMEISTER: The procedure requires that
6 condition to exist and you're asking how do we go about
7 implementing that?

8 MR. LYON: No, what I'm asking is if I need that
9 pump, how do I know that I can get it into an operating
10 status quickly? How do I know that somebody didn't go out
11 and start working on a valve associated with that pump that
12 I am going to depend upon?

13 WITNESS BURMEISTER: We have a work control process
14 where myself or another individual reviews all the work
15 that's authorized prior to the shift supervisor seeing it
16 and --

17 MR. CHAFFEE: But doesn't that process depend upon -
18 - doesn't it anchor itself to Tech Specs in terms of what
19 you do and don't tag out?

20 WITNESS BURMEISTER: No, actually the Tech Specs
21 require us to have it tagged out. We tag it out to ensure
22 that it's still available with the nozzle dams in should we
23 need it. We keep it semi-operable. We keep it such -- the
24 way it's worded in the procedure is ensure one safety
25 injection pump is capable of being racked in and operated in

F
E
H
G
A
D

C
O

B
A
Y
O
N
N
E

N
J

0
7
0
0
2

F
O
R
M

F
E
D

1 the hot leg injection mode, if needed. That's a step in
2 the procedure. What we do is -- in the clearance that we
3 have for complying with Tech Specs -- see, there's a
4 conflict here, the Tech Spec says this has to be rendered
5 operable. The generic letter and the real good practice is
6 to have one available should you need it for cooling, is
7 something different.

8 You're asking how do we maintain the control, we
9 have work controls -- we have people that know that they
10 have to do this, it's in this procedure. Also in our outage
11 schedule, we know what equipment we have to have or not
12 have, so we don't schedule to do maintenance on equipment
13 that we have to have in certain modes. So we treat it sort
14 of like a Tech Spec item in that we don't -- we ensure at
15 least one safety injection pump is available should we need
16 it.

17 MR. LYON: So it is tracked by the same tracking
18 system that you use for tracking your Tech Specs, is that
19 what I'm hearing?

20 MR. DIETZ: Do you also have a chart in the control
21 room that you keep up to date with the flow paths and that?

22 WITNESS BURMEISTER: The safety injection pump
23 system window was placed on the outage schedule and no work
24 was scheduled to occur at the same time we wanted to keep a
25 safety injection pump available.

1 MR. LYON: Okay, now that would make this work, but
2 what would assure that that was indeed the condition during
3 your planning?

4 WITNESS BURMEISTER: I personally reviewed all
5 outstanding clearances and work associated with the system
6 and we had just run the system for a surveillance test,
7 check valve flow test, just prior to draining down.

8 MR. LYON: Let me try something a little different.

9 MR. CHAFFEE: Oh, I see, you don't have to have the
10 safety injection pump operable the full time you're at mid-
11 loop in this outage?

12 MR. AUFDENKAMPE: Available.

13 MR. LYON: Available, big difference. Let me
14 suppose that you've gone through this whole process of
15 planning and everything and you have specified an SI pump
16 and it is available and everything is all lined up and one
17 of the maintenance people is walking along and he sees that
18 a valve in this particular system is leaking and needs to be
19 repaired. Now of course that's all dutifully reported back
20 up and someone schedules rip that valve apart and fix it.
21 What in your process would keep that from happening until
22 you made a different line up or set up your other SI pump to
23 meet this situation?

24 WITNESS BURMEISTER: Well in order to do that work,
25 it would require a clearance.

1 MR. LYON: Yes.

2 WITNESS BURMEISTER: And I personally review every
3 single clearance before it's issued to the field.

4 MR. LYON: If you got run over by a truck and --

5 WITNESS BURMEISTER: My counterpart is Bob Brinkley.

6 MR. LYON: But is there a procedure or a check in
7 the written process of things that would make that happen?

8 WITNESS KITCHENS: There's no check other than the
9 normal work controls we have for ensuring configuration
10 control for compliance with our procedures and our --

11 MR. CHAFFEE: What would be the problem of having a
12 mid-loop procedure that addressed it?

13 WITNESS KITCHENS: That's what this is. The whole
14 section here that he was reading out is all about mid-loop
15 and requirements thereof.

16 MR. CHAFFEE: So that procedure addresses only mid-
17 loop operations?

18 WITNESS KITCHENS: No, this procedure addresses unit
19 cool down to cold shutdown. One section of it that we're
20 talking about right here is for mid-loop operations and
21 gives the configuration requirements.

22 MR. CHAFFEE: Is there a problem with having a
23 procedure that's sole purpose is mid-loop operations that
24 could have precautions, limitations, that you would have to
25 meet before you go into that configuration?

1 WITNESS LEE: This one does.

2 WITNESS KITCHENS: It's a preference item of do you
3 have many small procedures or fewer larger procedures, but
4 this section here could be taken out. When you get to this
5 point you could say refer to mid-loop operations procedure
6 number whatever and all this could be put in there if you so
7 wanted to do that.

8 WITNESS LEE: But reducing RCS level needs to be
9 addressed in your plant administrative type of procedure
10 which is our unit operating procedure. If you don't address
11 it in there, you wouldn't know to go to the other procedure.
12 So you either have to put it in here or have it refer
13 in this procedure, one way or another.

14 WITNESS BURMEISTER: To give you a little background
15 on it, what we call unit operating procedures direct the use
16 of all the other system operating procedures and appropriate
17 surveillances and alarm response procedures, et cetera. We
18 are always in a unit operating procedure upon receipt of a
19 license.

20 MR. CHAPFEE: And you're required to meet the
21 limits, precautions that apply for that procedure at the
22 time.

23 WITNESS BURMEISTER: Right.

24 MR. CHAPFEE: Okay. Do operators, when they get
25 clearances or stuff, do they check whether or not -- what

P
E
N
C
I
L
S
A
R
E
N
O
T
T
O
B
E
U
S
E
D
I
N
C
O
N
N
E
C
T
E
D
F
O
R
M
E
D

1 the work that's involved -- violates the current procedure
2 that they're in?

3 WITNESS BURMEISTER: That's kind of a hard question
4 to ask -- to answer, I'm sorry. I mean, I would say yes,
5 they should be familiar with the procedures that they're
6 required to follow in the current plant condition, the
7 status of the plant and the impact of the work that they
8 authorized should be considered when they authorize the work
9 to be performed.

10 MR. CHAFFEE: Who authorizes the work in the control
11 room, the PRO, the SRO?

12 WITNESS BURMEISTER: Work is authorized by the shift
13 supervisor.

14 MR. CHAFFEE: Once he signs off then it goes ahead
15 and gets implemented?

16 WITNESS BURMEISTER: Yes, and in some cases a
17 clearance is required and would have to be --

18 MR. CHAFFEE: But he doesn't see these clearances
19 until they come through some -- I forgot the -- like the
20 equipment control group that screens the stuff first or does
21 the --

22 WITNESS BURMEISTER: Our work planning group
23 prepares the clearance initially. I have individuals that
24 work for me that review the clearances and also prepare a
25 sheet of clearances to be installed by the shift for each

1 night. I review that list also and I go to a daily meeting
2 that reviews clearance activities and specific work orders
3 that are to be performed during the next 24 hours. And so
4 this list is brought down to what we call the SSS, support
5 shift supervisor, and has a list of all the clearances that
6 are to be hung during the next 24 hours and we put the time
7 that we expect it to be hung by and so if somehow he gets a
8 clearance that's not on this list, he generally will not
9 hang it unless it's an urgent thing that came up that was
10 needed to support continuing operations.

11 MR. CHAFFEE: Then you screen them so that no
12 clearance goes out that's going to be in conflict with the
13 mode.

14 WITNESS BURMEISTER: That's right. I think most of
15 them understand fairly well that if they authorize a
16 clearance that's not on that list, they're sticking their
17 neck out a little bit further. In other words, you know,
18 they should do a closer review before they authorize it.

19 MR. CHAFFEE: Okay, I understand.

20 WITNESS KITCHENS: For the SI system during this
21 outage, we did not come up with a board for the flow path,
22 we did for boric acid flow path and a special standing order
23 because during the outage schedule the work that was
24 scheduled on the CVCS system was such that we wanted to
25 absolutely maintain control of that during -- because there

1 was a lot more work going on and there's I don't know how
2 many, four or five possible flow paths. For the SI pump
3 here, there's really just the two.

4 MR. DIETZ: That was for the gravity drain
5 capability?

6 WITNESS KITCHENS: No, sir, that was for our boric
7 acid flow path, to maintain at least one boric acid flow
8 path. We did come up with some special things for the
9 outage because of the nature of the schedule. We didn't do
10 that for SI probably because the schedule was such that you
11 do A-train and you do B-train and it's a lot easier to
12 maintain control.

13 MR. LYON: A couple of quick areas because I
14 promised that I would allow ten minutes for Paul.

15 Why do you use hot leg injection for your SI pump?

16 WITNESS LEE: That's the only system that can give
17 us hot leg injection.

18 MR. LYON: Yes, but why do you want hot leg
19 injection?

20 WITNESS LEE: I know we don't need to because we're
21 not in the situation where you have the hot leg dams
22 installed. I know you can get in a configuration where
23 that's the only way to put water into the top of the core,
24 is through the hot leg.

25 MR. LYON: Is that need for hot leg injection

1 limited to only when you have the nozzle dam line up that
2 you're referring to? Suppose I didn't have any nozzle dams
3 in place, would I still have a potential place where I would
4 need hot leg injection?

5 WITNESS LEE: If you had a cold leg opening -- you
6 know, it's always better -- if you had a cold leg opening,
7 it would be better to use hot leg injection. You know, there
8 is -- if you had a bubble in the head for some reason, which
9 usually occurs because you have a dam, then you would need
10 hot leg injection.

11 MR. LYON: Okay.

12 WITNESS LEE: But that is just a contingency, you
13 could probably do away with that step.

14 MR. LYON: Do your procedures include an accumulator
15 dump as one way of injecting water into the system?

16 WITNESS BURMEISTER: Yes, that's in the Mode 4, Mode
17 5 procedure.

18 MR. LYON: Where does that appear in the line up
19 versus gravity feed? I think it's toward the very end of
20 the loss of RHR procedure.

21 WITNESS KITCHENS: Is your question where does it
22 come in the sequence of performing this procedure?

23 MR. LYON: Yes, is it before or after the guidance
24 to the operator for using gravity as a means of adding water
25 to the system?

1 WITNESS LEE: It's at step A-12 as far as the SI
2 accumulators.

3 MR. LYON: And where is the --

4 WITNESS LEE: And 27.

5 MR. LYON: So dumping the accumulators is
6 significantly before you would try gravity feed?

7 WITNESS LEE: Depends on RCS temperature. You know,
8 if you're at a point where RCS temperature is greater than
9 200 degrees, you don't want to rely on gravity feed because
10 you're approaching boiling and you might have a pressure
11 build up in RCS and gravity drain may not be available,
12 depending on the RCS pressure.

13 MR. LYON: Okay.

14 WITNESS LEE: It was put as a contingency early,
15 depending on RCS temperature being greater --

16 MR. LYON: I understand. Did anyone assess -- let
17 me ask a different question. Do you assure that the
18 accumulators will be available, do you maintain pressure in
19 the accumulators for this purpose and a water volume?

20 WITNESS KITCHENS: No -- the answer is no. In the
21 same was as we maintain an SI pump?

22 MR. LYON: Yes.

23 WITNESS KITCHENS: No, we don't administratively
24 require the accumulators to be full and pressurized with
25 nitrogen while we're at mid-loop.

P
E
N
G
A
D

C
O

R
A
Y
O
N
M
E

N
J

C
7
0
0
R

F
O
R
M

E
E
D

1 MR. CHAFFEE: Do you have any water in them at all?

2 WITNESS KITCHENS: I don't know of any procedural
3 requirement that we have aux feed water in them at all. If
4 you were to have them, you could use this procedure --

5 MR. LYON: I understand, but it is a specific step
6 in the procedure that is designed to cover a particular
7 situation and yet what I'm hearing is they very well may not
8 be available at all.

9 WITNESS KITCHENS: May not.

10 MR. LYON: Would they be likely to be available?

11 WITNESS BURMEISTER: Yes, in Mode 4 and 5 because
12 that procedural requirement to use accumulators if they're
13 available appears in the Mode 4 and 5 procedure and
14 typically we do not pressurize the accumulators and drain
15 them until well after Mode 5 activities have started.

16 MR. CHAFFEE: Don't you have them drained at the
17 time you go to mid-loop?

18 WITNESS BURMEISTER: Pardon?

19 MR. CHAFFEE: Don't you drain them at the time you
20 go in mid-loop?

21 WITNESS BURMEISTER: If not drained, at least
22 depressurized before you go to mid-loop, yes.

23 MR. CHAFFEE: You wouldn't keep them pressurized
24 with the steam generator manways removed with people in the
25 proximity doing work, would you?

P
E
N
D
A
D

C
O

B
A
Y
D
N
N
E

W
J
O
7
O
B
E

F
O
R
M

F
E
E
D

1 WITNESS BURMEISTER: But while the RCS -- typically
2 while the RCS is pressurized, in other words, you're above
3 200 degrees, in the early parts of the cool down into Mode
4 5, accumulators are still pressurized.

5 MR. CHAFFEE: Right, but I think all this discussion
6 is focusing on mid-loop, right?

7 WITNESS KITCHENS: You're either talking about in
8 Mode 5 during mid-loop, we probably would never use that
9 response not obtained part. If you did, it would be to
10 drain the accumulators and not to inject them with nitrogen.

11 MR. LYON: One of the steps in the loss of RHR
12 procedure is a use of the accumulators.

13 WITNESS BURMEISTER: I understand, step A-12.

14 MR. LYON: Yeah.

15 WITNESS BURMEISTER: And you may not be at mid-loop
16 when you're in this procedure.

17 MR. LYON: That is correct.

18 WITNESS KITCHENS: You could be at 349 degrees in
19 this procedure.

20 MR. LYON: Yes.

21 WITNESS KITCHENS: And pressurized.

22 MR. LYON: Right. Now let's suppose I am a little
23 cooler than that and perhaps I'm at 50 psi and I initiate
24 this injection step. Will I inject nitrogen into the RCS?
25 Has anyone evaluated that, and if so, has anyone looked at

1 the implications of that nitrogen injection, perhaps with
2 respect to efforts to restart RHR?

3 WITNESS KITCHENS: Probably not.

4 MR. LYON: Okay.

5 WITNESS BURMEISTER: That particular thing, to my
6 knowledge, has only been addressed for an accident situation
7 and hot condition.

8 MR. LYON: With a large break.

9 WITNESS BURMEISTER: A large break LOCA --

10 MR. LYON: Yes, I understand, in which case we know
11 it's not a problem.

12 WITNESS BURMEISTER: Not a problem, but not while
13 we're in mid-loop conditions.

14 MR. LYON: Okay, I've only got one more thing that I
15 want to touch base on here. Do you have a procedure for RHR
16 venting?

17 WITNESS BURMEISTER: Yes.

18 MR. LYON: And what does that involve?

19 WITNESS KITCHENS: First off, I think we're having
20 trouble with some of the questions and we're answering you
21 probably in a different sense than what you're asking. We
22 have a system operating procedure for RCS filling and
23 venting.

24 MR. LYON: I'm sorry, let me --

25 WITNESS KITCHENS: Are you referring to the AOP?

1 MR. LYON: Let me set the perspective then. You're
2 in mid-loop, something happened and for whatever reason, you
3 know you have sucked a lot of air into an RHR pump and you
4 have lost that pump.

5 WITNESS KITCHENS: But it was previously running?

6 MR. LYON: It was the pump that was running. And
7 now you wish to try to get that pump back. What would you
8 do, is there a procedure that covers that? I'm hearing the
9 answer is yes.

10 WITNESS LEE: Yes. We stop the pump and we open the
11 vent valves.

12 MR. LYON: Which ones?

13 WITNESS LEE: Okay, they're the solenoids --

14 MR. LYON: Okay, those are the ones that are up in
15 the top --

16 WITNESS LEE: In the very high point.

17 MR. LYON: Yeah, the high point immediately outside
18 of containment.

19 WITNESS LEE: Yes.

20 MR. LYON: And that is what size pipe?

21 WITNESS LEE: About a one inch.

22 MR. LYON: And does the operator know whether that
23 vent is being effective, that indeed it is venting air?

24 WITNESS LEE: We don't have --

25 MR. AUFDENKAMPE: We do know when it's completed

1 venting air and it's blowing water.

2 MR. LYON: How would you know that?

3 MR. AUFDENKAMPE: Because you have a sump in it to
4 give you a high level --

5 MR. LYON: But you wouldn't have an indication that
6 it was blowing air, although once the sump started filling,
7 you'd know you had reached that point.

8 MR. CHAFFEE: That valve in question, you'd have to
9 operate it locally or is it a remote manual?

10 MR. AUFDENKAMPE: Remote.

11 MR. LYON: Do you have any other vents that you
12 would operate?

13 WITNESS LEE: No. I talked to the RHR engineer and
14 supposedly our system has very -- as far as the arrangement
15 of the RHR piping, it has a good gradual slope to the hot
16 leg and --

17 MR. LYON: Okay, I will agree that that vent will
18 vent most of the RHR hot leg between the containment wall
19 and the lowest point in the RHR system. From that lowest
20 point, the RHR pipe turns and goes up several feet into your
21 RHR pump. Is there a vent --

22 MR. AUFDENKAMPE: Not several feet.

23 WITNESS LEE: It'd be a foot or two, it's just right
24 at the bottom.

25 MR. LYON: Yes, agreed. I would have guessed that

1 it was about at my waist level, so maybe it's a foot and a
2 half, two feet -- okay. Now I don't see how the vent you
3 have just operated would take care of venting the pump
4 casing if it had become either steam or air bound. Do you
5 have any experience that this is effective so that you could
6 do that?

7 WITNESS LEE: We have quite a head of water there.
8 If you stop the pump, it should collect a bubble.

9 MR. LYON: Is there another vent and is it called
10 out in the procedure?

11 WITNESS LEE: Just this one vent, there's only one.

12 WITNESS KITCHENS: In the abnormal operating
13 procedures, we spell it out.

14 MR. LYON: Okay, it's all yours, Paul.

15 MR. LIETZ: I guess I'd like to shift a little bit
16 away from the direct things dealing with RHR and talk to you
17 a little bit about what procedures you have available to
18 cover various emergencies in a shutdown condition. Being
19 not only loss of RHR, cavitation of RHR at mid-loop, but LCA
20 at mid-loop -- LOCA, period. This would be a loss of
21 inventory. A criticality or a loss of AC power, loss of
22 instrument air. Do you have -- loss of maybe
23 instrumentation power. Do you have procedures that govern
24 those that deal with mid-loop -- or with shutdowns?

25 WITNESS BURMEISTER: Yes.

P
E
N
D
A
D

C
O

B
A
Y
O
N
N
E

N
J

D
E
C
E
M
B
E
R

F
O
R
M

I
D

1 WITNESS LEE: We have a procedure for a loss of 125
2 volt AC to 1-E. It'll address, you know, any mode you might
3 be in. It could be Mode 1 or several modes. Usually the
4 procedures are divided up into sections by mode.

5 WITNESS KITCHENS: To be more specific to answer
6 your question, I think some of the ones you just mentioned
7 actually cover all the modes of operation or the major ones.
8 some of them probably are written where they only cover
9 power operations. Greg is telling you about the one
10 procedure there, it probably would cover all modes of
11 operation, instrument air abnormal operating procedures is
12 divided into whether or not you're on RHR, whether you're in
13 Mode 4 or 5, power, whatever. We actually cover that and
14 that would be covered in loss of instrument air.

15 We do have a loss of coolant -- also reactor coolant
16 abnormal operating procedures for when we're shutdown. We
17 do have a shutdown in Modes 3, 4, 5 and 6 I guess.

18 WITNESS LEE: Yes, divided up into various modes.

19 MR. DIETZ: Does it help you diagnose that you've
20 actually for -- for instance if the RHR suction relief opens
21 and sticks open, would it help you get that isolated?

22 WITNESS LEE: Well that would just be an RCS leak
23 type of situation there and that would be -- could be in the
24 RCS leak procedure, 18004.

25 MR. DIETZ: How big a hole is that?

P
E
N
D
A
D

C
O

B
A
Y
O
N
N
E

N
J

H
I
T
C
H
C
O

V
O
R
M

F
E
E
D

1 WITNESS LEE: A big one. It addresses it to that
2 extent. For instance cavitation --

3 WITNESS KITCHENS: To answer your specific question,
4 that is addressed in this procedures, it's one of the
5 symptoms to go look for if you lost it, is RHR lifting of
6 relief valves, (reading) as indicated by rising PRT level
7 pressure or temperature. That's one of the symptoms they go
8 to to try to determine where the leak is while you're on
9 RHR.

10 MR. DIETZ: How about criticality as well, shutdown,
11 loss of something that causes a dilution, inadvertent
12 dilution?

13 WITNESS KITCHENS: We don't have specific abnormal
14 or emergency procedures I don't think for inadvertent
15 criticality or dilution accident. We do have a high flux at
16 shutdown alarm and we have an alarm response procedure that
17 addresses if you were to get to a point where you would get
18 the high flux at shutdown alarm. There are specific steps
19 that are similar to one of these, but it's only in the case
20 where you would get that alarm.

21 MR. DIETZ: Is the owners' group working on any kind
22 of a shutdown emergency type procedures?

23 WITNESS BURMEISTER: They're working on what the
24 call Mode 4 LOCA guidance. They did an analysis and there
25 are four potential options for plants to take to ensure that

1 they will not have a problem in the event the Mode 4 LOCA
2 occurs and they are to use, for example, a single train cool
3 down on RHR. To give you the background and the scenario,
4 say you had two trains of RHR in service at 350 degrees on
5 recirc with the RCS and you had a LOCA. The risk of the
6 potential exposure is that you could have steam binding and
7 take out both RHR pumps. So one of the recommendations is
8 that you only use single train cool down and leave the other
9 one lined up for injection. Until you get down to 275
10 degrees -- that's a plant specific number dependent upon
11 elevation head in RWST.

12 Another option is to have the ability to purge the
13 RHR pump suction piping with cold water to -- you know, in
14 the event that you have steam binding from a small break
15 LOCA and it takes out one of your RHR pumps, you need to be
16 able to restore it and this is one means of doing it. Some
17 plants don't have that capability.

18 Another option to deal with the problem is to
19 demonstrate somehow that you have -- you can maintain RHR
20 pump operability. That would require further analysis and
21 more testing, I'm sure.

22 A fourth option was to make high head pumps
23 available, which are currently not available by Tech Specs.

24 Another plant suggested just don't put RHR in
25 service until you get down to a certain temperature, use

1 your atmospherics or your steam dumps to cool down to 275
2 degrees. The drawback with that option is that it would be
3 a much slower cool down.

4 MR. DIETZ: Those are setting yourself up with the
5 right condition so that if you have the events --

6 WITNESS BURMEISTER: You'll be able to deal with
7 them. But that's all this particular analysis took a look
8 at.

9 MR. DIETZ: I'm looking for procedures for dealing
10 with -- detecting the event and mitigating it.

11 WITNESS BURMEISTER: To my knowledge, the owners'
12 group is not working on anything in that area.

13 MR. DIETZ: You also have safety function status
14 trees that you use while at power.

15 WITNESS KITCHENS: We also have safety function
16 status trees that we use in every mode. We have actually
17 gone through and programmed ours such that they are
18 functional in Modes 4 and 5 and I believe 6.

19 MR. DIETZ: The trees, do you have copies of those,
20 are those hard copy available also?

21 WITNESS KITCHENS: We can get those, I can print
22 them off the computer if nothing else.

23 What we did there, there's no owners' group that I
24 know of -- there's no Westinghouse owners' group
25 requirements for those or recommendations for those, but we

P
E
N
D
A
D

C
O

S
A
Y
O
N
N
E

N
J
O
7
U
D
P

F
C
R
M

F
E
D

1 at Vogtle did make us some and they're based in large part
2 on Tech Spec parameters and on other -- just other good
3 parameters that we thought we would need to know while we
4 were shut down.

5 MR. DIETZ: Each one of the status trees for coming
6 down or an accident at power has a bubble at the end that
7 has a procedure associated with it. Do you have a procedure
8 associated with the shutdown one too?

9 WITNESS KITCHENS: On some of them.

10 MR. DIETZ: Is it possible to get a copy of the
11 emergency type procedures that would deal with the shutdown
12 type events we've been talking about, the ones that you do
13 have?

14 WITNESS KITCHENS: Yes.

15 WITNESS BURMEISTER: We brought them here, but I
16 guess we're not supposed to give them to you directly.

17 MR. DIETZ: You know who to give them to.

18 WITNESS KITCHENS: We'll give them to Herb.

19 WITNESS KITCHENS: Do you want any of the abnormal
20 or emergency procedures -- actually we call them abnormal
21 procedures that deal with the plant in a shutdown mode?

22 MR. DIETZ: Right.

23 WITNESS KITCHENS: Also you'd like to see what we've
24 got set up for our critical safety function trees for other
25 than the Modes 1, 2 and 3 that the owners' group had.

1 MR. DIETZ: Right.

2 WITNESS KITCHENS: Okay, I'll get you those.

3 MR. DIETZ: That'll help a lot.

4 MR. CHAFFEE: I guess -- I'm sorry I came in here
5 late, but John --

6 MR. AUFDENKAMPE: Aufdenkampe.

7 MR. CHAFFEE: Okay. Can you tell me how you fit in
8 the organization, what's your position title?

9 MR. AUFDENKAMPE: Presently my position is Manager
10 of Technical Support. The sections that report to me are
11 quality control, reactor engineering, NSAC which is the
12 group Herb works for, plant procedures group and the plant
13 performance group. The reason I was requested to come to
14 the interview is associated with generic letter 8817.

15 MR. CHAFFEE: I understand.

16 MR. AUFDENKAMPE: At the time of 8817, I was in
17 engineering and was the supervisor of the NSSS group, which
18 is -- so I was involved in the engineering aspects of
19 generic letter 8817.

20 MR. CHAFFEE: Great.

21 MR. AUFDENKAMPE: Also was the engineering
22 supervisor in the TSC at the time of the event.

23 MR. CHAFFEE: Okay. Now I've got a lot of
24 questions.

25 MR. AUFDENKAMPE: I get off at four.

P
E
N
D
A
D
C
D
B
A
Y
O
N
N
E
H
J
O
O
D
Z
F
O
R
M
F
E
D

1 MR. CHAFFEE: You had the engineers on your staff
2 that were in the TSC, that were monitoring RCS temperature
3 and did some sort of a plot?

4 MR. AUFDENKAMPE: Yes.

5 MR. CHAFFEE: How come that plot I understand showed
6 maximum temperature of 118 degrees whereas I understand the
7 operators kept saying it was 136 degrees?

8 MR. AUFDENKAMPE: Because that plot is based on
9 historical data maintained by the ERF computer and at some
10 point into the event, the computer decided it didn't want to
11 keep that historical data any more.

12 MR. CHAFFEE: Oh, so you recognized that 118 degrees
13 as --

14 MR. AUFDENKAMPE: I did not recognize that at the
15 time.

16 MR. CHAFFEE: No, but I mean now.

17 MR. AUFDENKAMPE: That is my understanding now.

18 MR. CHAFFEE: But you haven't actually --

19 MR. AUFDENKAMPE: I talked to John Ealick who is our
20 guru of the ERF computer and that is what he told me.

21 WITNESS KITCHENS: What I believe the real case is,
22 is that 136 degrees is probably closer to the maximum
23 temperature. We do have a plot for RHR suction now that
24 show it going to 130 degrees. The 136 degrees was reading
25 from the thermocouples that an SRO was taking during that

1 time in the control room. One thing to remember on the time
2 frame, by the time these engineers you're talking about got
3 to the TSC, we were already back on RHR so they didn't see
4 the real time information. They did go and get historical
5 data for the plot.

6 MR. CHAFFEE: The reason I asked is I'm trying to
7 figure out what was the maximum temperature.

8 MR. AUFDENKAMPE: Let me add with respect to the
9 plot, the plot was done approximately two hours into the
10 event and was done to provide our corporate people something
11 to make the press release that was scheduled I think for
12 2:00 that afternoon. The information that we were working
13 on or using in our assumptions and actions in the TSC was
14 assuming 136 degrees because that's what we had gotten from
15 -- I don't remember --

16 WITNESS KITCHENS: From the control room.

17 MR. AUFDENKAMPE: We were assume about a four to six
18 degree rise in 36 minutes, is what we were operating on.

19 MR. CHAFFEE: So the initial temperature was what?

20 MR. AUFDENKAMPE: Ninety approximately.

21 MR. CHAFFEE: Okay, one more question. In your role
22 as it relates to 8837, did the engineering department do any
23 kind of calculations or have any calculations done that
24 looked at worst case scenarios or is this a question that
25 Warren has already asked?

1 MR. AUPDENKAMPE: We just completed that, design
2 engineering completed that. We talked to Warren about it,
3 we're going to make that available to him. It was completed
4 on February 16 of this year in response to the generic
5 letter. Our commitment was to have every -- just about
6 everything done by the end of this outage. So it was in
7 preparation for that.

8 WITNESS KITCHENS: We have incorporated that into
9 our --

10 MR. AUPDENKAMPE: We've incorporated the majority of
11 what's in there into our procedures.

12 MR. CHAFFEE: What is that calculation?

13 MR. AUPDENKAMPE: That's where the 57 minutes comes
14 from, maximum steaming rate in the core, all sorts of
15 different things. As Warren has --

16 WITNESS KITCHENS: We also gave a calculation for
17 gravity fill of the RCS through several flow paths,
18 including RHR and CVCS, SI.

19 MR. CHAFFEE: Can we get that today?

20 MR. AUPDENKAMPE: Yes.

21 WITNESS KITCHENS: I brought you a copy because you
22 had asked me for it the other day and I gave it through Herb
23 Beacher and I think you may have it by now.

24 MR. CHAFFEE: Great.

25 WITNESS KITCHENS: I also have two other copies.

1 I'd give them right to you except you might not want them.
2 But we have that here and I brought you one because it's the
3 same thing you had asked me for the other day.

4 MR. CHAFFEE: Thanks.

5 MR. LYON: Would you folks put together a list of
6 what you consider all the procedures that are applicable to
7 the generic letter 8817 response and provide that to us and
8 that should identify the administrative kinds of controls as
9 well as your normal and abnormal whatever you want to call
10 them, emergency -- in other words, everything --

11 WITNESS KITCHENS: May I make a suggestion on that?

12 MR. LYON: Sure.

13 WITNESS KITCHENS: I think the best thing to do,
14 maybe I'll ask Greg to do this, is to make that list but
15 also for us to mark you up a copy because as we pointed out
16 the unit operating procedure, one section of it, covers mid-
17 loop. Why don't we mark it for you so you won't have to
18 read through all -- it'll be like this --

19 MR. LYON: That would be great.

20 WITNESS KITCHENS: We'll give you a list but we'll
21 also -- if we can get the right procedures and get them to
22 you in the proper way, to mark those sections that we think
23 are applicable to the generic letter.

24 MR. LYON: That's be great. I'll take all the help
25 I can get.

1 WITNESS KITCHENS: We'll highlight them or mark them
2 so it'll make it easier for you to see all these procedures
3 we've been telling you about.

4 MR. LYON: Okay. Anything further anybody?

5 MR. KENDALL: John, I've got some questions --

6 MR. LYON: May I interrupt for a second? Do we need
7 to hold anyone else?

8 MR. LAZARUS: I have some questions.

9 MR. LYON: Okay, go ahead.

10 WITNESS KITCHENS: May I ask if we could ask Bill
11 questions first, he's supposed to be at simulator class.

12 MR. LAZARUS: Mine I think will be very short.

13 WITNESS KITCHENS: If you could ask him the
14 questions first, then he --

15 MR. LAZARUS: I'm Bill Lazarus, the question I have
16 shifts back to the classification of the event, so it's a
17 totally different hat here.

18 Basically I was locking through the emergency
19 classification procedure and we discussed a little bit, the
20 procedure says for site area emergency, loss of all off-site
21 and all on-site AC power for more than 15 minutes or loss of
22 all vital DC power for more than 15 minutes. In this case
23 you lost the two vital busses and I got some indication that
24 your training has been that the loss of the vital busses is
25 what you use as a definition for this site area emergency

P
E
N
D
A
D

C
O

B
A
Y
O
N
N
E

N
I
C
7
0
0
2

F
O
R
M

F
E
E
D

1 loss of all on-site power and off-site power.

2 WITNESS BURMEISTER: When we look at the word "off-
3 site power" we have a surveillance procedure that we perform
4 to determine whether or not we have off-site sources
5 available, and it's typically as it pertains to energizing
6 the RATs and because we didn't have two RATs available, we
7 didn't have any means of off-site power, is the way I looked
8 at it. And therefore, that combined with not having the on-
9 site power led us conservatively, but in any event we stayed
10 -- I believe it to be a site area emergency because we did
11 have non-1-E power available through station backfeed, but
12 that was not immediately available to power any RHR pumps or
13 anything to cool the core and it would have taken some
14 modifications and some either movement of piping or hoses or
15 pumps or whatever to get flow going to the core.

16 MR. LAZARUS: Was that specifically part of your
17 training or previous understanding that loss of just the
18 vital busses, loss of essentially safeguards, load
19 capability, would qualify for this site area emergency?

20 WITNESS BURMEISTER: I should say yes, but I can't
21 really say that. I don't recall at the time.

22 MR. LAZARUS: Basically what I'm saying, I think
23 that NUREG 0654, which is almost identical to the words you
24 use, is ambiguous and your decision is probably the right
25 one, but I was just trying to find out if that was something

P
E
N
G
A
D
C
O
P
A
Y
O
N
N
E
N
J
C
7
0
0
7
F
O
R
M
F
E
D

1 that had been pre-determined or you determined at the time
2 to be applicable.

3 WITNESS L. JRMEISTER: Skip may be able to provide
4 more input on it, but to my knowledge it was not pre-
5 determined.

6 WITNESS KITCHENS: The thing that I told you the
7 other day, we have a loss of all AC power emergency
8 procedure and the symptoms for entry into that are loss of
9 both emergency AC busses -- both emergency AC busses are de-
10 energized. It doesn't say all power, both AC busses being
11 de-energized, emergency AC busses, gets you directly into
12 this loss of AC -- all AC. Now this really assumes you're
13 at power or probably Mode 3, but we made a conscious effort
14 and changed that recently. It used to say loss of all AC
15 power. We changed it -- you can see a rev bar here -- May
16 of '89, we changed it to say both safety related busses.
17 Loss of all AC power is the name of the procedure.

18 MR. LAZARUS: Is that something in the package of
19 things that have already been submitted or will be
20 submitted to us?

21 WITNESS KITCHENS: I'll be glad to submit it. I do
22 not know the answer to your question. I can put it in with
23 the procedures that you asked for on the shutdown. Even
24 though this one isn't really specifically for shutdown
25 condition.

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J
0
7
0
0
2

F
O
R
M

F
E
D

1 MR. LAZARUS: I appreciate that. The other
2 question, just a quick one on accountability. I've had a
3 couple of I think conflicting views from people on their
4 understanding of assembly areas. Some have indicated that
5 they believe there are still two assembly areas which will
6 be announced by the shift supervisor or whoever is making
7 the announcement in the control room at the time of a site
8 area emergency being declared, depending on wind direction.
9 Others have indicated there's only one assembly area and
10 that's the admin building parking lot. What is your view on
11 what the current situation is with assembly areas?

12 WITNESS BURMEISTER: Non-essential personnel not
13 involved in the emergency?

14 MR. LAZARUS: Yes.

15 WITNESS BURMEISTER: The assembly area is the admin
16 parking lot. The evacuation centers are the visitors'
17 center -- not the visitors' center but the rec area and
18 Plant Wilson.

19 MR. LAZARUS: So there are really three different
20 assembly areas; one -- is this by procedure, this admin
21 building parking lot?

22 WITNESS KITCHENS: The admin building parking lot
23 is an accountability place, it's an assembly area we call
24 it. And I know we're using words, but the relocation center
25 is what I believe by procedure we call -- when we evacuate

1 the site, we have site evacuation, we have to say, depending
2 on which way the wind is blowing, whether we go to the
3 recreation center or Plant Wilson. One is that way and one
4 is that way. But I do not believe we ever called them
5 accountability centers.

6 For an alert, procedurally and I think by training
7 and generally for an alert, we would send people to the
8 admin building for accountability.

9 For a site area and general emergency, there's no
10 pre-determined accountability area.

11 MR. LAZARUS: Is there a pre-determined message for
12 an alert that would say go to the admin building or admin
13 building parking lot?

14 WITNESS BURMEISTER: It says go to your assembly
15 area.

16 WITNESS KITCHENS: I'd have to look in the procedure
17 and see what it says.

18 MR. LAZARUS: It says report to your assembly area?

19 WITNESS BURMEISTER: Yes. I think the confusion is
20 that for a site area and a general emergency the procedure
21 says that you assembly -- for non-essential personnel, you
22 assemble at either the Plant Wilson or the rec area at the
23 direction of the Emergency Director. The Emergency Director
24 in this particular case, knowing the circumstances involved,
25 elected not to follow that procedural requirement. This has

1 already been discussed.

2 MR. LAZARUS: Yeah, I understand that.

3 WITNESS BURMEISTER: You have all that information.

4 MR. LAZARUS: Yes.

5 WITNESS BURMEISTER: And that's where I think some
6 of the confusion came in because security people were -- or
7 other personnel were used to going to those two areas for
8 site area emergency or a general and when the Emergency
9 Director elected to send the people to the normal assembly
10 area for an alert, it created a little bit of confusion.

11 WITNESS KITCHENS: Even during this conversation I
12 can see the confusion in that there are relocation centers
13 for evacuation and there's an accountability area, which the
14 only one I know of, as accountability area, is the admin
15 building.

16 MR. LAZARUS: You used two terms and neither one of
17 them was assembly area, which is the one that I've heard.

18 WITNESS KITCHENS: Assembly area may also be a term
19 they use for here, for the admin building parking lot. That
20 as not intended for a case where you evacuate and I believe
21 Bill is right, the procedure pretty much says to -- that you
22 evacuate and the decision is with the Emergency Director as
23 to which of the two relocation centers you go to. Do you
24 see what I'm getting at? There's all these terms.

25 I heard a page announcement after I arrived at the

P
E
N
G
A
D

C
O

B
A
Y
O
N
N
E

N
J
E
T
D
D
E

F
O
R
M

T
E
D

1 TSC that said all personnel report to your accountability
2 area and most people looked around and we said what's an
3 accountability area. So we contacted the control room
4 again and said gee, you'd better tell them where to go, we
5 don't know what accountability area means. They made
6 another announcement that said all non-essential personnel
7 go to the administration building parking lot. But even we
8 in the TSC were confused when that announcement was made, to
9 go to your accountability area, we did not know what that
10 meant.

11 MR. CHAFFEE: Did that announcement come from the
12 control room?

13 WITNESS KITCHENS: Yes, all the page announcements
14 come from the control room.

15 MR. LAZARUS: Almost.

16 WITNESS KITCHENS: Well anybody can pick up the page
17 -- we don't normally make pages from anywhere except the
18 control room that I know of. We have a procedure on that.
19 That's where we make them from.

20 MR. LAZARUS: That's all I have. I understand why
21 I'm confused now.

22 WITNESS BURMEISTER: Sorry.

23 MR. CHAFFEE: Any other questions? Okay, let's go
24 off the record.

25 (Brief pause.)

1 MR. CHAFFEE: Go ahead.

2 MR. LYON: We were discussing the RHR system a
3 little while ago and discussing the vents and you had
4 discussed that you have a vent that I understand is operable
5 from the control board that you could use. If that were to
6 be ineffective, what other vents do you have on the RHR
7 system that might permit you to get the pump back into
8 operation?

9 WITNESS KITCHENS: For the pump itself we have a
10 pump casing vent.

11 MR. LYON: Would you describe the size of that,
12 where it is located and what would be necessary to operate
13 it?

14 WITNESS KITCHENS: I don't know the size of it
15 without looking at a P&ID but it's probably a one inch or
16 half inch valve. To vent it, what you would do is you'd go
17 and probably direct a hose to the floor drain so it wouldn't
18 come out on you. It's right at the pump casing and you
19 would open the valve and vent it until air quit issuing from
20 it and water issued from it.

21 MR. LYON: Do you know if that is a single valve, a
22 double valve or whether it has a cap or anything like that
23 on it?

24 WITNESS KITCHENS: Not off-hand, I don't know, sir.

25 MR. AUFDENKAMPE: The standard design for that

1 pressure system would be a single valve with either a cap or
2 a flange.

3 WITNESS KITCHENS: That particular one would
4 probably have a cap on it, it probably would be a single
5 valve.

6 MR. LYON: Would whoever went to vent it know that
7 and take whatever wrench was needed?

8 MR. AUFDENKAMPE: They would check the P&IDs and
9 that would tell them what it had on it and they would take
10 the appropriate equipment.

11 MR. LYON: But that's not something you would flag
12 in the procedures normally?

13 WITNESS KITCHENS: It's in the procedures.

14 MR. LYON: Is it, that you need that wrench? We can
15 find that out. Why don't we drop that because we can look
16 in the procedure. Unless anyone has anything else to to
17 add, I think we have everything we need. Thank you very
18 much.

19 (Whereupon, the interview was concluded at

20 3:50 p.m.)

C E R T I F I C A T E

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

This is to certify that the attached proceedings before the U. S. Nuclear Regulatory Commission in the matter of:
Name: Interview of DEAN WEST, SKIP KITCHENS, JOHN AUFDENKAMPE AND GREGORY LEE

Docket Number:

Place: Vogtle Nuclear Generating Plant, Waynesboro, GA

Date: March 28, 19990

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken stenographically by me and, thereafter reduced to typewriting by me or under my direction, and that the transcript is a true and accurate record of the foregoing proceedings.

William L. Warren
WILLIAM L. WARREN
Official Reporter

Ann Riley & Associates

P
E
N
D
A
D

C
O
B
A
Y
O
N
N
E

N
J
C
T
D
D
Z

F
O
R
M

F
E
D

05-48-90
3/30/90

DIESEL GENERATOR FAILURE ANALYSIS

SENSOR LINE LEAKAGE

2/23 ~1/2 AIR LINE LEAKS
3/29 E23H VIBRATION (2 LOCATIONS)
E92 TURBO CHARGER LO PRESSURE
E18 HIGH TEMP LUBE OIL (2 LOG.)
E168 HI TEMP JACKET WATER LINES
E14 LO JACKET WATER PRESSURE
E68 HI CRANKCASE PRESSURE

(P3 TRIPS AT 45# AND RESETS AT 49#; checked GRI PRESSURE AT 61#)

OK 3/23 CALIB. SENSOR
186°/200° ± 4°
-READJUSTED
-OTHER 2 TESTED NOW

TROUBLE SHOOTING REQ'D
CALIB.
BUBBLER TESTING

140° ALARM (KYLE)
SPURIOUS? (JOHN'S)
(IN CR)

(ACTION PACKS)
AFTER HI TEMP
-BOTH CLEARED
AFTER RESET

TESTING SHOWED "A"
SENSOR WOULD

NOT RESET 3/23

3/30 SLUGGISH REPLACING SENSOR

JACKET WATER PRESSURE LO (1/1 NORMAL TRIP)
JACKET WATER TEMP HI (2/3 EMERGENCY TRIP)

TURBO CHARGER LO PRESSURE (1/2 TAKEN TWICE)

LUBE OIL HI TEMP (190° ALARM OFF THERMOCOUPLE)

LUBE OIL LO PRESSURE SENIOR MALFUNCTION
(EMER. TRIP) (OBSERVED IN CR FOR > 1 MIN.)

LUBE OIL LO LEVEL
(ALARM NOTED AFTER 3rd START ADDED OIL)

HI LUBE OIL TEMP TRIP (1/1 NORMAL)