

Arizona Public Service Company

RECEIVED
NRC

1984 JUN 15 PM 1:05

June 12, 1984
ANPP-29724-TDS/TRB

REGISTRATION

U. S. Nuclear Regulatory Commission
Region V
Creekside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs


Subject: Interim Report - DER 84-37
A 50.55(e) Potentially Reportable Deficiency Relating to
Unauthorized/Unqualified Duct Sealant
File: 84-019-026; D.4.33.2

Reference: Telephone Conversation between P. Narbut and T. Bradish on May
17, 1984.

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the
referenced telephone conversation. At that time, it was estimated that a
determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim
Report is attached. It is now expected that this information will be
finalized by August 30, 1984, at which time a complete report will be
submitted.

Very truly yours,


E. E. Van Brunt, Jr.
APS Vice President
Nuclear Production
ANPP Project Director

EEVB/TRB:db
Attachment

cc: See Page Two

8406250235 840612
PDR ADOCK 05000528
S PDR

IE-27

Mr. T. W. Bishop
DER 84-37
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
D. B. Karner
W. E. Ide
D. B. Fasnacht
A. C. Rogers
L. A. Souza
D. E. Fowler
T. D. Shriver
C. N. Russo
J. Vorees
J. R. Bynum
J. M. Allen
J. A. Brand
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
H. D. Foster
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
S. R. Frost
J. Self
D. Canady

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

INTERIM REPORT - DER 84-37
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA PUBLIC SERVICE COMPANY (APS)
PVNGS UNIT 1, 2, 3

I. Potential Problem

Unauthorized and/or unqualified sealant material has been used in HVAC Ductwork in Containment/Auxiliary/Control/Fuel Buildings.

II. Approach To and Status of Proposed Resolution

Bechtel engineering is currently studying this problem to determine reportability and technical justification for corrective action. The subcontractor is investigating the extent of this problem, and his report is scheduled to be ready by July 1, 1984.

III. Projected Completion of Corrective Action and Submittal of the Final Report

Evaluation of this condition and submittal of the Final Report is Forecast to be completed by August 30, 1984.