

13 *K. 1/4*

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by IE staff on this date.

FACILITY: Southern California Edison Co.
San Onofre Nuclear Generating Station
Unit 2
San Clemente, CA
Docket No. 50-361

Licensee Emergency Classification
___ Notification of Unusual Event
___ Alert
___ Site Area Emergency
___ General Emergency
XX Not Applicable

SUBJECT: SHUT DOWN FOR STEAM GENERATOR TUBE LEAK REPAIR

The leakage rate in steam generator E088 reached 300 gallons per day on 6/19/84. Unit 2 was shut down at 6:00 a.m. PDT on 6/20/84 to locate and repair the leak. As noted earlier, equipment is onsite and preparations for the repair have been completed. The licensee expects an outage of approximately 25 days.

No further supplements to this PN are anticipated. This information is current as of 8:00 a.m. PDT 6/20/84.

CONTACT: *PJA* P. Johnson
FTS 463-3745

A. Chaffee
FTS 796-4015

DISTRIBUTION

H St. <u>9:51</u>	MNBB <u>9:57</u>	Phillips <u>10:10</u>	E/W <u>10:12</u>	Willste <u>9:14</u>	Air Rights <u>10:17</u>	Mail:
Chairman Palladino	EDO	NRR	IE	NMSS		ADM:DMB
Comm. Gilinsky	PA		OIA	RES		DOT:Trans
Comm. Bernthal	MPA		AEOD			Only
Comm. Roberts	ELD					
Comm. Asselstine						
SECY						
ACRS						
CA						
PDR						

Regions: I - 10:36, II - 10:25, III - 10:35, IV - 10:31
 INPO 10:38 NSAC 10:40
 Licensee: 10:15
 (Reactor Licensees)
 Resident Inspector 9:57

REGION V: FORM 211
(Revised 3/14/83)

8406250334 840620
PDR I&E
PNO-V-84-035B PDR

10/24
di