

APPENDIX A

NOTICE OF VIOLATION

Omaha Public Power District

Docket: 50-285/82-30

Based on the results of an NRC inspection conducted during the period of November 29-December 3, 1982, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 47 FR 9987, dated March 9, 1982, the following violation was identified:

Procedural Compliance

Technical Specification 5.11, "Radiation Protection Program," states: "Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be . . . maintained and adhered to"

Radiation procedures are also addressed in your Standing Order T-1, "Radiation Protection Manual," which states: "All station personnel, . . . will abide to every provision of the Radiation Protection Manual"

In addition, Section IV.I.1, "Weekly Review of Standing R.W.P.'s," of Radiation Protection Procedure (RPP)-20, "Radiation Work Permit," which is part of the Radiation Protection manual states: "All R.W.P.'s written for a period greater than five working days will be reviewed by a designated individual within the Radiation Protection Group . . . the R.W.P. will be dated and initialed in the space provided."

Contrary to the above, on November 30, 1982, the NRC inspector determined that the licensee had not performed the proper weekly review of 18 Standing RWP's between November 12-November 30, 1982.

This is a Severity Level V violation. (Supplement (IV))

Pursuant to the provisions of 10 CFR 2.201, Omaha Public Power District is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including:

- (1) the corrective steps which have been taken and the results achieved;
- (2) corrective steps which will be taken to avoid further violations; and
- (3) the date when full compliance will be achieved.

Consideration may be given to extending your response time for good cause shown.

Dated: MAR 17 1983