# Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION

Title:

Georgia Power Company: Vogtle Electric

Generating Plant: Unit 1 and Unit 2

Docket Number:

50-424-OLA-3; 50-425-OLA-3

ASLBP No.: 93-671-01-OLA-3

Location:

Rockville, Maryland

Date:

Tuesday, September 19, 1995

Work Order No.:

NRC-322

Pages 14236-14456

# ORIGINAL

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

200036

9509200323 950919 PDR ADDCK 05000424 T PDR (RO10)

# UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

+ + + + +

#### ATOMIC SAFETY AND LICENSING BOARD

#### HEARING

----X

In the matter of: : 50-424-OLA-3

GEORGIA POWER COMPANY, et al. : 50-425-OLA-3

: Re: License Amendment

(Vogtle Electric Generating : (transfer to

Plant, Unit 1 and Unit 2) : Southern Nuclear)

: ASLBP No.

13 93-671-01-OLA-3

Tuesday, September 19, 1995

Hearing Room T 3B45

Two White Flint North

11545 Rockville Pike

Rockville, Maryland

The above-entitled matter came on for hearing,

20 pursuant to notice, at 8:55 a.m.

#### 21 BEFORE:

22 PETER B. BLOCH Chairman

JAMES H. CARPENTER Administrative Judge

24 THOMAS D. MURPHY Administrative Judge

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVENUE, N.W.
WASHINGTON, D.C. 20005

23

4

5

6

7

9

10

11

12

14

15

16

17

18

#### APPEARANCES:

2

3

-

6

7

8

9

10

11

12

13

14

15

100

16

17

18

19

20

21

22

23

24

25

# On behalf of the NRC:

CHARLES A. BARTH, ESQ.

JOHN HULL, ESQ.

MITZI A. YOUNG, ESQ.

of: Office of the General Counsel

U.S. Nuclear Regulatory Commission

Washington, D.C. 20555

(301) 504-1589

# On behalf of the Licensee:

ERNEST L. BLAKE, JR., ESQ.

DAVID R. LEWIS, ESQ.

of: Shaw, Pittman, Potts & Trowbridge

2300 N Street, N.W.

Washington, D.C. 20037

(202) 663-8474

#### **NEAL R. GROSS**

APPEARANCES: (cont.)

2

3

4

5

8

9

10

11

12

13

14

15

16

17

18

19

20

JAMES E. JOINER, ESQ.

JOHN LAMBERSKI, ESQ.

WILLIAM WITHROW, ESQ.

of: Troutman Sanders

Nationsbank Plaza, Suite 5200

600 Peachtree Street, N.E.

Atlanta, Georgia 30308-2216

(404) 885-3360

# On behalf of the Intervenor:

MICHAEL D. KOHN, ESQ.

STEPHEN M. KOHN, ESQ.

MARY JANE WILMOTH, ESQ.

of: Kohn, Kohn & Colapinto, P.C.

517 Florida Avenue, N.W.

Washington, D.C. 20001

(202) 234-4663

21

22

23

24

25

NEAL R. GROSS

# INDEX

Howard Hill and Lewis A. Ward 14246 14445 14255  By Mr. Kohn 14253 14258  14258 14261  14258 14267  14270 14274  10 14270 14280  11 14276 14286 14292  13 14286 14298 14307  14 14351 14341  15 14360 14348  16 14382 14359  17 14379  18 14411 14401  19 By Ms. Young 14418 14410  20 14425 14421  21 14436 14425  22 By Mr. Kohn 14439 14442  23 By Ms. Young 14449 14443  25 NEAL R. GROSS	2	WITNESS	DIRECT	CROSS	REDIRECT	RECROSS	BOARD
5       By Mr. Kohn       14253       14258         6       14255       14261         7       14258       14265         8       14261       14270         9       14267       14274         10       14270       14280         11       14276       14286         12       14286       14292         13       14298       14307         14       14351       14341         15       14360       14348         16       14382       14359         17       14397       14379         18       14411       14401         19       By Ms. Young       14418       14410         20       14425       14421         21       14436       14425         22       By Mr. Kohn       14439       14427         23       By Ms. Young       14442       14436         24       By Mr. Kohn       14449       14443         25       14447	3	Howard Hill and					
6 14255 14261 7 14258 14265 8 14261 14270 9 14267 14280 11 14276 14286 12 14286 14292 13 14298 14307 14 14351 14341 15 14360 14348 16 14382 14359 17 14397 14379 18 14411 14401 19 By Ms. Young 14418 14410 20 14425 14425 21 By Mr. Kohn 14439 14427 23 By Ms. Young 14442 14436 24 By Mr. Kohn 14449 14443	4	Lewis A. Ward	14246		14445		14255
14258 14265  14261 14270  14274  10 14270 14280  11 14276 14286  12 14286 14292  13 14298 14307  14 14351 14341  15 14360 14348  16 14382 14359  17 14397 14359  18 14411 14401  19 By Ms. Young 14418 14410  20 14425 14421  21 14436 14425  22 By Mr. Kohn 14439 14425  24 By Mr. Kohn 14449 14443  25 14443	5	By Mr. Kohn		14253			14258
8 14261 14270 9 14274 10 14270 14280 11 14276 14286 12 14286 14292 13 14298 14307 14 14351 14341 15 14360 14348 16 14382 14359 17 14397 14379 18 14411 14401 19 By Ms. Young 14418 14410 20 14425 14421 21 14436 14425 22 By Mr. Kohn 14439 14425 24 By Ms. Young 14449 14443 25 14447	6			14255			14261
9 14267 14274 10 14270 14280 11 14276 14286 12 14286 14292 13 14298 14307 14 14351 14341 15 14360 14348 16 14382 14359 17 14397 14379 18 14411 14401 19 By Ms. Young 14418 14410 20 14425 14421 21 14436 14425 22 By Mr. Kohn 14439 14427 23 By Ms. Young 14449 14443 25 14447	7			14258			14265
10	8			14261			14270
11	9			14267			14274
14286 14292 13 14298 14307 14 14351 14341 15 14360 14348 16 14382 14359 17 14397 14379 18 14411 14401 19 By Ms. Young 14418 14410 20 14425 14421 21 14436 14425 22 By Mr. Kohn 14439 14425 23 By Ms. Young 14442 14436 24 By Mr. Kohn 14449 14443	10			14270			14280
13	11			14276			14286
14	12			14286			14292
15	13			14298			14307
14382 14359 17 14397 14379 18 14411 14401 19 By Ms. Young 14418 14410 20 14425 14421 21 14436 14425 22 By Mr. Kohn 14439 14427 23 By Ms. Young 14442 14436 24 By Mr. Kohn 14449 14443 25 14447	14			14351			14341
17	1.5			14360			14348
18	16			14382			14359
19 By Ms. Young 14418 14410 20 14425 14421 21 14436 14425 22 By Mr. Kohn 14439 14427 23 By Ms. Young 14442 14436 24 By Mr. Kohn 14449 14443	17			14397			14379
20 14425 14421 21 14436 14425 22 By Mr. Kohn 14439 14427 23 By Ms. Young 14442 14436 24 By Mr. Kohn 14449 14443	18			14411			14401
21 14436 14425 22 By Mr. Kohn 14439 14427 23 By Ms. Young 14442 14436 24 By Mr. Kohn 14449 14443 25 14447	19	By Ms. Young		14418			14410
22 By Mr. Kohn 14439 14427 23 By Ms. Young 14442 14436 24 By Mr. Kohn 14449 14443 25	20			14425			14421
23 By Ms. Young 14442 14436 24 By Mr. Kohn 14449 14443 25	21			14436			14425
24 By Mr. Kohn 14449 14443 25 14447	22	By Mr. Kohn		14439			14427
25 14447	23	By Ms. Young		14442			14436
	24	By Mr. Kohn		14449			14443
	25			D 0000			14447

# NEAL R. GROSS

#### EXHIBITS

2	EXHIBIT NO.	DESCRIPTION	IDENT	REC'D
3		Rebuttal, Hill and Ward		
4	BOUND FO	DLLOWING PAGE 14249		
5	GPC II-195	Hill/Ward Exhibit A (BOUND)	14250	14250
6	GPC II-196	Hill/Ward Exhibit B (BOUND)	14250	14250
7	GPC II-197	Hill/Ward Exhibit C (BOUND)	14250	14250
8	GPC II-198	Ward Exhibit H	14253	14253
9	INT II-257	3-12-90, letter Hairston	14257	14258
10	INT II-11	Quality Standard	14306	
11	INT II-258	DG-1A air receiver	14322	
12	INT II-260	01-21-90, cover Ward	14362	14365
13	INT II-261	est of Daily air leakage	14372	
14	INT II-262	amount of waterany presr.	14372	
15	INT II-263	amount of water240 psig	14372	
16	INT II-264	water formation, air supply	14372	
17	INT II-261-2	264 BOUND FOLLOWING PAGE 14372	2	
18	INT II-265	Time line sequence 3542	14415	
19				

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(9:00 a.m.)

#### P-R-O-C-E-E-D-I-N-G-S

2

3

4

5

6

7 8

LO

11

12

13

14

16

15

17

18

19

20

21

22

23

24

25

CHAIRMAN BLOCH: Good morning. The hearing

will come to order.

The Board is prepared to rule on the motion to strike testimony of Hill and Ward and conduct additional discovery. We have already ruled on the motion to strike, but what we're going to rule on this morning is the individual requests for discovery. Those requests begin on page 22 of the motion, and the response of -- Georgia Power begins responding to it on page 13.

You'll note that with respect to request number 1, some of the requested documents have been provided. We deny the remainder of the request, as there is no good cause explanation as to why the information was not requested during the lengthy discovery period.

Request number 2 is denied without prejudice to hearing this matter, if there should be a remedy phase.

Request number 3 is denied on the grounds that there is already a stipulated demonstrative aid number 4, and that, therefore, there is no need for further discovery on the basis for the stipulated exhibit.

Request number 4 is granted, based on the detailed showing of cause, company specific request.

Request number 5 is denied, although it may be

#### NEAL R. GROSS

relevant to the relief phase.

Request number 6 is also denied with respect to this phase of the proceeding.

Request number 7 is denied. The root cause of the failure is not an issue; and, therefore, subsequent events are not relevant to whether there were wilful misstatements.

Request number 8 is granted, with respect only to the MWOs issued during 1990 that have not already been produced. We don't know if there are such MWOs, but we consider that portion of the request should be granted.

Request number 9 is denied. Relevant dew point data are stipulated in Intervenor's demonstrative aid number 4, and anything after 1990 is not considered relevant.

Request number 10 is granted, because we consider it relevant to the possible cause of the allegedly defective dew point instruments. I'm sorry, the possible reuse, not the possible cause, the possible reuse of allegedly defective dew point instruments.

MR. BLAKE: To the end of '91, Judge?

CHAIRMAN BLOCH: The end of '91, that's

Request number 11, we're going to order as a matter of an adequate record. We ordered this discovery

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

correct.

in order to assist the Board in having a full understanding of the issue, but without determining that the 1995 incident is litigable.

Request number 12 is denied.

Request number 13 is denied. No adequate showing of cause. Root cause is not an issue. Not relevant to misrepresentation.

Request number 14 is granted. We consider it directly relevant to the testimony that was submitted. Of course, if there is discovery requested of Cooper, then a subpoena request should be submitted.

Request number 15 is denied. It is beyond the scope of this proceeding, and it also was previously discoverable.

Request number 16 we consider overly broad.

However, Georgia Power Company should produce all documents provided to, and reviewed by or relied on, by Hill and Ward, with respect to matters directly or indirectly related to the scope of the witness' testimony. So it's limited to the scope of the testimony. But to the extent that there were documents provided to them that they relied on, those should be provided.

With respect to the requests, these are requests for the Board to exercise its discretion, and we will deny all of those except the ones we commented on.

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

The first part of request number 2 concerning completion of the fax transmission that is already part of Intervenor's Exhibit II-215 is granted, subject to possible claims of privilege.

Request number 4 is granted, but it may be all documents to the present, or it may stop if the instrument was recalibrated and declared back in service. So you can stop the records on Alnor VP 2466, if it's placed back in service. Otherwise, it should be from the date to the present, just to find out what the history of that instrument is and whether or not it was considered officially to be defective. Those are all of the grants on that portion of the order.

We have Mr. Hill and Ward this morning, is that correct? Do we need to record anything on the record about the stipulations reached about the other two witnesses?

MR. MICHAEL KOHN: Your Honor, I don't think we need to put anything on the record at this time. I think counsel, during a break, can reduce things to writing, or at some point put it on the record in the final form.

CHAIRMAN BLOCH: All right.

MR. BLAKE: The outcome, from the Board's standpoint, was that there is not going to be a need to

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

call either of the two witnesses. 1 CHAIRMAN BLOCH: Well, we just want to make 2 sure there's no further argument about what the 3 stipulation was, so --4 MR. BLAKE: While Mr. Ward and Mr. Hill are 5 coming, there are two documents today for the parties. 6 It's the rebuttal testimony for this panel of Hill and Ward, and it's the affidavit of Lewis A. Ward dated September 1. CHAIRMAN BLOCH: Good morning. Mr. Ward, 10 welcome back. Mr. Hill, welcome to our proceeding. 11 I'd like to provide you with some information 12 about your obligations before we start. 13 WHEREUPON, 14 LEWIS A. WARD 15 AND 16 HOWARD T. HILL 17 were called as witnesses by Counsel for the Licensee and, 18 having first been duly sworn, assumed the witness stand, 19 were examined and testified as follows: 20 CHAIRMAN BLOCH: And would each of you please 21 identify yourselves by name and present position, for the 22 record? 23 WITNESS WARD: I'm Lewis A. Ward, and I'm --24 my title is now Manager of Engineering and Licensing for 25 **NEAL R. GROSS** 

Vogtle.

1

2

3

4

5

10

11

12

13

14

15

16

17

18

19

21

22

23

24

251

WITNESS HILL: My name is Howard Hill. I'm a Consulting Engineer in private practice.

#### DIRECT EXAMINATION

MR. BLAKE: Mr. Hill, Mr. Ward, do you have available to you a copy of a document entitled "Rebuttal Testimony and Responses to Board Questions of Howard T. Hill and Lewis A. Ward on Diesel Generator Air Quality Issues," dated August 21, 1995?

WITNESS WARD: Yes.

WITNESS HILL: I do.

MR. BLAKE: And were each of you involved in the preparation of this document? And, if so, would you describe how?

witness ward: Yes, I was prepared -- I was involved in the preparation of part of this. Basically, I provided answers for questions that were outlined for -- by Troutman Sanders.

MR. BLAKE: And are those answers indicated in this testimony by your name appearing before the response portion?

WITNESS WARD: Yes.

MR. BLAKE: And, Mr. Hill, how about you?

WITNESS HILL: I was also involved in the preparation of a portion of this testimony. And as in the

#### **NEAL R. GROSS**

case of Mr. Ward, I provided answers to questions raised 1 by the attorneys of, in this case, Shaw Pittman. I 2 reviewed the -- and commented on the drafts that were 3 provided back to me on those answers, and reviewed and 4 approved the final version. 5 MR. BLAKE: Now, as corrected by each of you, 6 is this testimony true and accurate, to the best of your 7 knowledge and belief, or do you have any additional 8 corrections to make to it? 9 WITNESS WARD: I have some corrections to make 10 to it, on page --11 CHAIRMAN BLOCH: Could you hold for just a 12 second? I need to run to my office. 13 (Whereupon, the proceedings were off the record briefly.) 15 MR. BLAKE: Mr. Ward, you were indicating that 16 in addition to whatever corrections or modifications you 17 made in the course of developing the draft testimony, you still have some corrections to make to this testimony 19 which is distributed. Can you do those? 20 WITNESS WARD: Yes. Page 1, line 7, I'm in a 21 new job position. My title is now Engineering and 22 Licensing Manager. And the rest of them are typographical 23 errors. Page 12, line 17, the last word should be

NEAL R. GROSS

"orifice" instead of "office." Page 13, line 2, the last

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

14

word should be "orifice." 1 MR. MICHAEL KOHN: What page? 2 WITNESS WARD: 13, line 2, last word. On 3 page 18, line 1, the date should be May 3, instead of 4 May 30. And that's all. 5 MR. BLAKE: Mr. Hill, do you have any 6 additional corrections to make? 7 WITNESS HILL: I have no additional 8 corrections. To the best of my knowledge, it's true and 9 accurate testimony. 10 MR. BLAKE: Now, with those corrections, is 11 the testimony correct and accurate, to the best of your 12 knowledge and belief, both of you? 13 WITNESS WARD: Yes. 14 WITNESS HILL: It is. 15 MR. BLAKE: And do you adopt it as your 16 testimony in this proceeding? 17 WITNESS WARD: I do. 18 WITNESS HILL: I do. 19 MR. BLAKE: Judge Bloch, I would ask that this 20 testimony, the rebuttal testimony of Howard T. Hill and 21 Lewis A. Ward be accepted into evidence in this proceeding 22 and be physically incorporated into the record just as 23 though read. 24

CHAIRMAN BLOCH: Gentlemen, do you understand

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1	that when we do this, it's the same as if you had read the
2	testimony or spoken the testimony aloud in the hearing?
3	WITNESS WARD: Yes.
4	WITNESS HILL: Yes.
5	CHAIRMAN BLOCH: Both witnesses have indicated
6	that they understand. The testimony is admitted and may
7	be bc into the transcript at this point.
8	MR. BLAKE: Do you have available to you,
9	along with the testimony, a document, Mr. Hill, entitled
10	"Professional Resume, Howard T. Hill, Consulting
11	Engineer"? This document would have been attached to the
12	testimony as your Exhibit A.
13	WITNESS HILL: I have that document.
14	MR. BLAKE: And are you familiar with this and
15	prepared to answer questions about it?
16	WITNESS HILL: Yes, I am.
17	MR. BLAKE: Mr. Ward, is there attached also
18	to this testimony a document entitled "Hill/Ward Exhibit
19	B, Vogtle Experience with Calcon Sensors and Diesel
20	Generator Trip Circuits"?
21	WITNESS WARD: Yes.
22	MR. BLAKE: And are you familiar with this
23	document and prepared to answer questions about it?
24	WITNESS WARD: Yes.
25	MR. BLAKE: And is there also, Mr. Ward,
	NEAL R. GROSS

# UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

# Before the Atomic Safety and Licensing Board

In the Matter of	Docket Nos. 50-424-OLA-3 50-425-OLA-3
GEORGIA POWER COMPANY,	)
et al	) Re: License Amendment (Transfer to Southern Nuclear)
(Vogtle Electric Generating Plant	
Units 1 and 2)	) ASLBP No. 93-671-01-0LA-3

REBUTTAL TESTIMONY AND RESPONSES TO BOARD QUESTIONS OF

HOWARD T. HILL

AND

LEWIS A. WARD

ON

DIESEL GENERATOR AIR QUALITY ISSUES

# REBUTTAL TESTIMONY AND RESPONSES TO BOARD QUESTIONS OF HOWARD T. HILL AND LEWIS A. WARD

- O. PLEASE STATE YOUR NAME AND POSITION.
- 5 A. (Hill) My name is Howard T. Hill. I am a Consulting Engineer
- 6 located in Novato, CA.

2 3

- 7 (Ward) My name is Lewis A. Ward. I am the Maintenance Support
- 8 Manager for the Vogtle Project in Birmingham, Alabama.
- 9 Q. WHAT ARE YOUR PROFESSIONAL QUALIFICATIONS?
- 10 A. (Hill) My professional qualifications are summarized on my
- 11 resume, which is attached hereto as Exhibit A.
- 12 (Ward) A summary of my professional qualifications was
- 13 previously attached as Exhibit A to my prefiled testimony on air
- 14 quality issues and admitted into evidence as GPC Ex. II-59.
- 15 O. WHAT IS THE PURPOSE OF YOUR REBUTTAL TESTIMONY?
- 16 A. (Hill, Ward) The purpose of this rebuttal testimony is to
- 17 respond to several issues raised in the Pre-Filed Testimony of
- 18 Allen L. Mosbaugh concerning diesel air quality, licensing
- 19 requirements, and dew point measurements. An additional purpose of
- 20 this testimony is to respond to various questions raised by the
- 21 Atomic Safety and Licensing Board.
- 22 Q. DR. HILL, WHAT IS YOUR EXPERIENCE WITH AIR SYSTEMS?
- 23 A. (Hill) I have 29 years of varied engineering experience,
- 24 principally in the fields of testing, measurements, and failure
- 25 analysis. This includes over 15 years in the area of reactor
- 26 containment leakage rate testing. My work in containment leakage

- 1 rate testing includes determination of water vapor concentrations
- 2 in containment atmospheres, and assessment of condensation and
- 3 evaporation under various pressure and temperature conditions. I
- 4 have developed numerous schemes for improving the reliability of
- 5 measurements and interpretation of data.
- 6 Q. DR. HILL, PLEASE DESCRIBE YOUR FAMILIARITY WITH THE DIESEL AIR
- 7 START SYSTEM AT PLANT VOGTLE.

15

- 8 A. (Hill) I have personally reviewed documents, including
- 9 drawings, specifications, and design criteria for the diesel air
- 10 start system at Plant Vogtle. In addition, I visited the site and
- 11 personally inspected the diesel buildings. I interviewed several
- 12 Georgia Power personnel who are familiar with the diesel air start
- 13 system at Plant Vogtle. I also studied the control logic system
- 14 and walked down the 1A diesel air start system.

#### LICENSING REQUIREMENTS FOR VOGTLE DIESEL AIR START SYSTEM

- 16 Q. MR. WARD, ON PAGE 17 OF MR. MOSBAUGH'S RETYPED PREFILED
- 17 TESTIMONY, HE ASSERTS THAT "THE PLANT VOGTLE FSAR COMMITS TO
- 18 MEETING THE DEWPOINT REQUIREMENTS OF THE ISA STANDARD [ISA S7.3-
- 19 1975]." ON PAGE 19 OF MR. MOSBAUGH'S RETYPED PREFILED TESTIMONY,
- 20 HE CLAIMS THAT "THE ISA STANDARD REQUIRES 32°F DEWPOINT AIR OR
- 21 LOWER . . . . \* DO YOU HAVE AN OPINION ON THIS TESTIMONY?
- 22 A. (Ward) Yes. The Vogtle FSAR does not commit to apply ISA
- 23 S7.3-1975 to the diesel generator starting system. The diesel

- 1 generator starting system is addressed in Section 9.5.6 of the
- 2 FSAR, previously admitted as Board Ex. 3 and GPC Ex. II-98(B).
- 3 That section makes no mention of or reference to the ISA Standard.
- 4 Q. MR. WARD, WHAT DEW POINT COMMITMENTS ARE MADE IN SECTION 9.5.6
- 5 OF THE FSAR?
- 6 A. (Ward) FSAR Section 9.5.6.2.2, which describes the system
- 7 operation, states that the pressure dew point of the air dryers is
- 8 factory set at 35°F, which is more than 10°F below the minimum
- 9 design temperature of 50°F for the diesel generator rooms. The
- 10 FSAR Table 9.5.6-1 (Sheet 1) lists 50°F as the dew point of air
- leaving the dryer. This design was accepted in Section 9.5.6 of
- 12 the NRC Staff's Safety Evaluation Report, previously admitted as
- 13 Board Ex. 4.
- 14 Q. DR. HILL, IS THE NRC'S ACCEPTANCE OF THE VOGTLE DIESEL START
- 15 AIR SYSTEM CONSISTENT WITH NRC GUIDANCE?
- 16 A. (Hill) In my opinion, it is. The NRC's Standard Review Plan
- 17 has a specific chapter on emergency diesel engine starting systems,
- 18 Chapter 9.5.6. Section II.4 provides suggested acceptance criteria
- 19 for starting air, and provides that "starting air should be dried
- 20 to a dew point of not more that 50°F when installed in a normally
- 21 controlled 70°F environment, otherwise the starting air dew point
- 22 should be controlled to at least 10°F less than the lowest expected
- 23 ambient temperature." It is my opinion that the diesel starting
- 24 air system addresses this guidance in two ways. First, the dryer

- set point for dew point is set at 35°F, which is more than 10°F 1 2 below the minimum design temperature in the diesel generator building. Second, the heaters in the diesel generator building are 3 set at 60°F, so that the maximum allowable dew point (50°F) is 4 still at least 10°F below the minimum expected temperature. It is 5 particularly notable that the SRP chapter on the diesel starting 6
- air system makes no reference to ISA S7.3. 7
- MR. WARD, MR. MOSBAUGH'S RETYPED PREFILED TESTIMONY (PAGES 16-8
- 20) AND CROSS-EXAMINATION TESTIMONY (TR. 8504-09), OPINES 9
- EXTENSIVELY ABOUT ISA STANDARD S7.3-1975 BEING A LICENSING 10
- REQUIREMENT FOR PLANT VOGTLE. DO YOU HAVE ANY FURTHER COMMENTS ON 11
- THIS TESTIMONY? 12

17

18

19

20

21

22

23

24

25

- A. (Ward) Yes, I do. Mr. Mosbaugh's testimony appears to assert 13
- that the ISA Standard operates as a requirement for Vogtle based on 14
- two FSAR sections, namely Sections 9.5.6 and 1.9.68.4, and Georgia 15
- Power's response to Generic Letter 88-14. 16

With respect to FSAR Section 9.5.6, Mr. Mosbaugh has referred to FSAR Table 3.2.2-1, which is cited in this section, as the source for the codes and standards applicable to the diesel starting and control air system. Table 3.2.2-1, however, merely identifies construction codes. The applicable portion of that Table states that the air compressors and dryers are designed in accordance with manufacturer's recommendations, and makes no reference to the ISA Standard. The air receivers are built in accordance with ASME Boiler and Pressure Vessel Code Section III requirements. Again, there is no reference to the ISA Standard.

FSAR Section 1.9.68.4, "Regulatory Guide 1.68.3, April 1982, Preoperational Testing of Instrument and Control Air Systems," (Staff Ex. II-2) describes Georgia Power's position regarding this regulatory guide. Therein, Georgia Power indicates that it follows the ISA Standard for the Vogtle instrument air system but no such commitment is made regarding the separate and distinct diesel starting air system. Moreover, both the position in FSAR Section 1.9.68.4 and Regulatory Guide 1.68.3 are applicable to preoperational testing. These positions are not applicable to plant operations.

Finally, in its response to NRC Generic Letter 88-14 (Intervenor Ex. II-13), Georgia Power committed to the ISA standard for the <u>instrument air system</u> and not for the <u>diesel air start system</u>. Page 9 and Table 6 of the Georgia Power response identify all "active valves" in the <u>instrument air system</u>, but the Diesel Generator Air Start valves are not listed. Page 3 of the Georgia Power response provides a separate discussion of the commitment of the diesel air start system. It states that the maximum dew point acceptance criteria for the diesel air start system is established at 50°F at system pressure, with a reference to FSAR Table 9.5.6-1. Therefore, Mr. Mosbaugh's contention that Plant Vogtle is committed to the ISA standard for the diesel air start system is incorrect.

- 1 Q. MR. WARD, IS THE DIESEL AIR START SYSTEM, INCLUDING ANY
- 2 CONTROL LINES, PART OF THE VOGTLE INSTRUMENT AIR SYSTEM?
- 3 A. (Ward) No. The Vogtle Instrument Air System (or Compressed
- 4 Air System) is a separate system addressed in a different FSAR
- 5 section, Section 9.3.1. The specific components included in the
- 6 Instrument Air System are identified on the schematics that are
- 7 included in FSAR Section 9.3.1. Neither the diesel starting air
- 8 system nor any of its control lines are included in these system
- 9 drawings, nor are the systems physically connected.
- 10 Q. DR. HILL, ON PAGE 18 OF MR. MOSBAUGH'S TESTIMONY, HE SAYS THAT
- "[T] HE DEW POINT AT LINE PRESSURE SHALL BE AT LEAST -7.8 DEGREES C
- 12 (18°F) BELOW THE MINIMUM TEMPERATURE TO WHICH ANY PART OF THE
- 13 INSTRUMENT SYSTEM IS EXPOSED AT ANY SEASON OF THE YEAR." DO YOU
- 14 HAVE ANY OPINION ON THIS TESTIMONY?

21

- 15 A. (Hill) Yes. Mr. Mosbaugh's assertion is based on ISA S7.3,
- 16 which Mr. Ward stated above is inapplicable. In any event, both
- 17 Mr. Mosbaugh and the ISA standard are in error in converting
- 18 between Fahrenheit and Centigrade temperature differences. The
- 19 7.8°C differential specified in the standard corresponds to
- 20 14.04°F, not 18°F, as asserted in Mr. Mosbaugh's testimony.

# ALLEGATIONS OF MOISTURE IN THE DIESEL AIR SYSTEM

- 22 Q. DR. HILL, MR. MOSBAUGH CLAIMS THAT THE CAUSE OF THE DIESEL
- 23 FAILURES ON MARCH 20, 1990 IS THE PRESENCE OF MOISTURE IN THE
- 24 DIESEL AIR START SYSTEM. ON PAGE 18 OF MR. MOSBAUGH'S RETYPED

- 1 PREFILED TESTIMONY, HE SAYS THAT "LOCAL COLD SPOTS EXISTED AT
- 2 VOGTLE BECAUSE LARGE OUTSIDE AIR INTAKES DIRECTLY BLOW ON PORTIONS
- 3 OF THE VOGTLE DIESEL AIR SYSTEM. " DO YOU HAVE AN OPINION ON THIS
- 4 TESTIMONY?
- 5 A. (Hill) Yes. It is my opinion that Mr. Mosbaugh is incorrect.
- 6 There are several features in the diesel air system that refute his
- 7 assertion. First, the diesel building is thoroughly heated and
- 8 well insulated. Electric heaters mounted on the diesel room wall
- 9 are set to turn on when room temperature drops to 60°F. The
- 10 control cabinet in the diesel building is individually heated as
- 11 well. That heater turns off only when temperature inside the
- 12 cabinet reaches 100°F. Even when the diesel is not running it
- 13 radiates heat supplied by the jacket water and lube oil warming
- 14 systems. These systems maintain the water and oil temperature at
- 15 approximately 150°F.

25

16 Second, the ventilation system in the diesel room minimizes the possibility of any cold spots. The normal ventilation system 17 18 will draw air in through the lower level intakes, but the ventilation fan that draws in the air does not activate until the 19 room temperature reaches 85°F and turns off again when the 20 temperature is reduced to 65°P. The intake louvers close when the 21 fan shuts off. This would not result in "blasts" of cold air, as 22 23 Mr. Mosbaugh asserts on page 21 of his retyped prefiled testimony. The air streams from the lower level intakes would not flow across 24

the control air lines, because those lines are shielded by the

engine, the steel checker plate trench cover, and the control panel cabinet enclosure.

A different ventilation system operates when the diesel is running. Engineered Safety Feature ("ESF") fans start automatically when the diesel starts, and draw air in through the upper level intakes in the diesel building. This air is directed down toward the engine and discharges out of the lower level louvers. This air could flow across some control air lines running across the top of the engine. However, when the diesel operates, it generates considerable heat, which would probably prevent the control air lines from cooling to any significant extent. The ESF fans stop when the diesel shuts down. When the ESF fans stop, the louvers automatically close.

In sum, because of the redundant sources of heat in the diesel building and the configuration and specifications of the ventilation system (as discussed above), it seems virtually impossible that a significant cold blast of air would enter the room and chill hundreds of feet of stainless steel tubing.

- 19 Q. ON PAGE 21 OF MR. MOSBAUGH'S RETYPED PREFILED TESTIMONY, HE 20 SAYS THAT HIS "EXPERIENCE AT VOGTLE WAS THAT THE AIR RECEIVERS WERE
- 21 NORMALLY WARM TO THE TOUCH. \* DO YOU HAVE AN OPINION ON THIS
- 22 TESTIMONY?

- 23 A. (Hill) Yes. Air receivers are not normally warm to the touch.
- 24 The air receivers may warm up slightly when the compressors are
- 25 running to recharge them, but even then because air receivers have

- 1 large metal surface areas, they quickly return to ambient room
- 2 temperature. I have personally verified this at Plant Vogtle by
- 3 touching one or two of the receivers.
- 4 (Ward) I have the same observation after touching the
- 5 receivers on many occasions.
- 6 Q. ON PAGE 42 OF MR. MOSBAUGH'S RETYPED PREFILED TESTIMONY, HE
- 7 SAYS THAT DIESEL TRIP #134 INVOLVED A HIGH JACKET WATER PRESSURE
- 6 CIRCUIT. DO YOU HAVE AN OPINION ABOUT THIS TESTIMONY?
- 9 A. (Ward, Hill) Yes, there is no such instrument/sensor. The
- 10 trip associated with diesel start #134 did not involve a high
- 11 jacket water pressure circuit because no such sensor/circuit
- 12 exists.
- 13 Q. DR. HILL, ON PAGE 69 OF MR. MOSBAUGH'S RETYPED PROFILED
- 14 TESTIMONY, HE CLAIMS THAT DIESEL AIR SYSTEM DEW POINTS MEASURED
- 15 ABOVE 50°F AT THE AIR RECEIVER WOULD MAKE AIR QUALITY
- 16 UNSATISFACTORY AND WOULD VIOLATE THE ISA STANDARD ON INSTRUMENT AIR
- 17 QUALITY. DO YOU HAVE AN OPINION ON THIS TESTIMONY?
- 18 A. (Hill) Yes, I do. In the first place, as Mr. Ward discussed
- 19 above, the ISA standard does not govern the design of the diesel
- 20 air start system. If, however, I were going to apply this
- 21 Standard, I would apply it only to actual control elements, such as
- 22 the 60 paig portion of the system. Applying the Standard in this
- 23 manner, the dew point would only have to be kept below the Standard
- 24 after the pressure regulator in the control cabinet.

1 Q. DR. HILL, ON PAGE 84 OF MR. MOSBAUGH'S RETYPED PREFILED

2 TESTIMONY, HE SAYS THAT OUT OF SPECIFICATION HIGH DEW POINT AIR

WOULD PASS THROUGH THE FILTER UNIMPEDED AND INTO THE PNEUMATIC

LOGIC BOARD PASSAGEWAYS AND TRIP LINES WHERE, WHEN COOLED TO BELOW

5 THE DEW POINT, IT WOULD FORM WATER. DO YOU HAVE AN OPINION ABOUT

6 THIS TESTIMONY?

3

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

(Hill) Yes, I do. As I understand Mr. Mosbaugh's position, he postulates that water vapor condenses in the 60 psig control lines and that this affects the performance of the diesel air system. Mr. Mosbaugh's contention is without merit. First, in order for the quantity of condensate to be sufficient to affect system performance, there would have to be some continuous makeup flow through these lines. The amount of water vapor in a still control line cannot physically condense to a significant quantity of liquid water. Second, the continuous makeup flow passes through the 240 psig control air supply line which is alongside of and at the same temperature as the control (trip) lines. The dew point of the vapor in the 240 psig lines is on the order of 30°F above that in the 60 psig lines. If vapor condenses in the 60 psig lines, it must condense at a more rapid rate in the 240 psig line. condensate in the 240 psig line would eventually fill this line and enter the filter bowl in the diesel control panel where it would be trapped below the baffle disc. If water has never been found in the filter bowl at Plant Vogtle, it is extremely unlikely that there has ever been any condensation in the 60 psig control lines

- 1 (particularly those inside the cabinet where elevated temperature
- 2 is maintained by a heating strip).
- 3 Q. DR. HILL, ON PAGE 86 OF MR. MOSBAUGH'S RETYPED PREFILED
- 4 TESTIMONY, HE SAYS THAT "LOWERING AIR PRESSURE REDUCES THE DEW
- 5 POINT, BUT IT DOES NOT CHANGE THE AIR QUALITY COMMITMENT GPC MADE
- 6 TO THE NRC IN THE GENERIC LETTER RESPONSE. " DO YOU HAVE AN OPINION
- 7 AS TO THIS TESTIMONY?
- 8 A. (Hill) Yes, I do. As I understood Mr. Mosbaugh's testimony
- 9 during the hearing (Tr. 8563-8570), he asserts that condensation in
- 10 the 60 psig control lines causes a malfunction of the control
- 11 system which results in spurious diesel trips. On page 86 of his
- 12 retyped prefiled testimony he claims that it is not important that
- 13 the dew point in the 60 psig lines is well below that in the 240
- 14 psig line, because of Georgia Power's commitment to the NRC. The
- 15 lower dew point, however, is significant if one is evaluating the
- 16 likelihood of condensation occurring in the control lines. The
- 17 lower dew point not only makes such condensation extremely unlikely
- 18 but also provides considerable margin in the control air system
- 19 design.
- 20 Q. DR. HILL, ON PAGE 94 OF MR. MOSBAUGH'S RETYPED PREFILED
- 21 TESTIMONY, HE ASSERTS THAT THERE WAS A 16-OUNCE GLASS JAR HALF-
- 22 FILLED WITH A WATERY FLUID THAT WAS IN THE CONTROL AIR TUBING LINES
- 23 FOR EDG 1A. DO YOU HAVE AN OPINION AS TO THIS TESTIMONY?

A. (Hill) Yes, I do. This amount of water (about 8 ounces) is enough to fill 20 feet of 3/8 inch tubing. I cannot come up with any reasonable scenario that would account for the accumulation of even a small fraction of that quantity of water in the control air lines. To assess the possibility of such condensation, I considered an extreme scenario, where the dew point in the receiver is 86°F (the highest reported dew point in EDG 1A receivers), and the temperature in the vicinity of control lines is 35°F (15 degrees below the minimum design temperature of the room and 25 degrees below the heater set point). According to my calculations, to condense 8 ounces of liquid under these conditions would require cooling 2500 cubic feet of 60 psig air.

To put this volume in perspective, control air is continuously supplied to 6 groups of sensors; high pressure crankcase, low pressure turbo oil, low pressure jacket water, high vibration, high temperature engine bearings, and high temperature lube oil. Each sensor is supplied through a 0.006 inch office located in the control cabinet. Under a worst case (conservative) leakage scanario all six sensors and/or interconnecting tubing joints are postulated to leak sufficiently to induce maximum possible flow through each orifice. In reality, only two sensors (low pressure turbo lube oil and low jacket water pressure) vent with the engine shut down. Maximum, or critical, velocity of flow through an orifice is about 1130 ft./sec. at a temperature of 70°F (this varies from about 1100 ft./sec. at 40°F to 1160 ft./sec. at 100°F). The area of an individual orifice is 0.0000283 square

inches. The maximum volumetric rate of flow to all six sensor 1 lines is 6 x 1130 x 0.0000283/144 (the divisor 144 converts orfice 2 area in square inches to square feet) = 0.00133 cubic feet per 3 second. At this flow rate, 2500 cubic feet of air will leak from 4 the system in 2500/0.00133 = 1,800,000 seconds or, about 22 days, 5 during which time the tubing must be continuously exposed to 35°F air. Based on the foregoing, I consider it highly unlikely that 7 2,500 cubic feet of air (a large quantity of air) would flow 9 through the control lines to make up leaks during the brief

In addition, the high jacket water temperature and low pressure lube oil lines (the two that tripped) are not pressurized when the diesel is not operating. Therefore, condensation in those

lines would be impossible unless the diesels are running.

duration of the extreme temperature conditions postulated.

10

14

18

19

20

21

22

23

24

25

15 Q. DR. HILL, IF THE WATER THAT MR. MOSBAUGH ASSERTS WAS FOUND IN
16 THE CONTROL LINES COULD NOT HAVE CONDENSED THERE, WHERE ELSE COULD
17 IT HAVE COME FROM?

A. (Hill) The only other possible source of a significant volume of water would be from water condensed in the 240 psig supply line and somehow subsequently transmitted into the control lines. This possibility too, however, is not realistic. Assuming hypothetically that water condensed in the 3/8 inch tubing which supplies high pressure (240 +/- psig) air to the diesel air start system control cabinet during operation of the system, then this water would travel along various routes to reach the control lines.

In the process, numerous components and tubing runs inside the cabinet would be flooded.

First, the water would have to pass through the filter which is located near the bottom of the cabinet. Water would have to completely fill the filter assembly before any would pass through to the regulator. Due to the construction of the filter, it is unlikely that the water in the lower part of the collection bowl will quickly evaporate after inlet air conditions return to normal (40 +/- F dew point). This water is trapped below a baffle and is well shielded from air flow through the filter assembly. This water would be observed during filter element changeout.

Second, water exiting the filter would flood the regulator, which is at the same level as the filter, and then pass into the maze of tubing within the cabinet. Any water passing to the control system mother board would probably flood the vertical tubing between the regulator and that board. If there were any leaks, the water would pass into the sensors.

At the time of the Site Area Emergency, the Low Pressure Lube Oil and High Temperature Jacket Water trip lines were pressurized through logic elements following a diesel start signal. Once pressurized, these lines were maintained at pressure by small bleed flows through memory elements. Air for the bleed flow is supplied by the regulator and passes through various components on the logic boards. If the regulator is discharging water, the path through the various logic elements to the trip lines would eventually flood if there were any trip line or sensor leakage.

Pressurized air from the regulator is continuously applied to numerous solenoid and manually actuated valves, most of which pass this air to logic elements when actuated. If the regulator is discharging water, the tubing and logic elements downstream of these valves would flood when the valves actuate.

While the control system logic is fairly complex, it is clear that any leakage from the Low Pressure Lube Oil and High Temperature Jacket Water Temperature trip lines or sensors would result in water flowing through many of the logic elements while the diesel is running. Entry points for water are continuously pressurized ports on the mother board as well as the various valves which port pressure to different logic elements depending on mode selection (test bypass, maintenance, etc.).

The end result of water flowing through the above pathways is that many of the logic elements and much of the tubing in the control cabinet would become flooded after some period of diesel operation. It is difficult to imagine that this would not have some ongoing negative impact on control system operation which would persist until the entire system is drained and blown dry.

Q. DR. HILL, ON PAGES 97-98 OF MR. MOSBAUGH'S RETYPED PREFILED TESTIMONY, HE SAYS THAT ANOTHER INDICATION THAT VOGTLE HAD WATER IN THE DIESEL AIR SYSTEM WAS THAT THERE WAS A DESIGN CHANGE INITIATED BECAUSE WATER WAS ACCUMULATING IN THE DIESEL AIR COMPRESSOR CRANKCASE OIL. DO YOU HAVE AN OPINION AS TO THE VALIDITY OF THIS TESTIMONY?

- (Hill) Yes, I do. Finding water in the compressor crankcase A. 1 oil is not unexpected and has no bearing on the quality of air 3 leaving the dryers. The dryers are provided to extract water from the moist air discharged by the compressors. Condensation can 4 5 occur in the compressor cylinders and/or crankcase. Some air leaks 6 through the gaps in the piston rings and any water condensed in the cylinders will eventually leak through these gaps. 7 Since the compressors run intermittently, the crankcase oil never heats up to the point at which the water would boil off.
- TESTIMONY, HE IMPLIES THAT WATER HAD "POURED OUT" OF THE DIESEL
  TRIP LINES AND THAT MR. BURR WOULD HAVE REPORTED THIS TO YOU. DO
  YOU HAVE ANY COMMENT ON THIS TESTIMONY?

  A. (Ward) Yes, I do. I do not recall that Mr. Burr told me of
  any water pouring out of the diesel trip lines. I believe that I
  would have recalled such a conversation, given the potential

MR. WARD, ON PAGE 96 OF MR. MOSBAUGH'S RETYPED PREFILED

18 Site Area Emergency. Moreover, my notes taken contemporaneously

significance of such an issue in light of the events following the

- 19 with the events following the Site Area Emergency do not reflect
- 20 such a statement.

10

- 21 Q. MR. WARD, MR. MOSBAUGH CLAIMS THAT NONE OF THE JACKET WATER
- 22 SWITCHES COULD HAVE ACTUATED ON MARCH 20, 1990 BECAUSE OF
- 23 MISCALIBRATION, SINCE THE TRIP SET POINTS WERE MEASURED ON MARCH 30
- 24 AND FOUND WELL ABOVE THE ACTUAL JACKET WATER TEMPERATURES THAT

- 1 WOULD HAVE BEEN OBSERVED ON MARCH 20. DO YOU HAVE ANY COMMENT ON
- 2 THIS TESTIMONY?
- 3 A. (Ward) Yes, I do. One of the Jacket Water Temperature
- 4 Switches (1-TSH-19112) on DG 1A that was in place on the engine on
- 5 March 20, 1990, had the following history:

The switch was installed new on November 19, 1989. It was calibrated in a water bath, was found to be correctly set from the factory at 199.4°F, and was not readjusted.

On March 1, 1990, this switch was calibration checked as part of the outage overhaul of DG 1A. The as-found setpoint (average of 3 tests) was 210.4°F. The switch was reset down to 203.1°F (average of 3 more tests). Thus, it would have been maintained at elevated temperature for a period of time which should have produced an actual setpoint lower than 203.1°F.

On March 30, 1990, the switch was removed from the DG for testing. The as-found setting was 186.2°F, based on 3 tests. It was adjusted upward to 199.9°F, based on 3 tests. Again, the uncontrolled time at elevated temperature should have produced actual setpoints lower than those recorded. The switch, however, was also noted to be leaking at more than 20°F below setpoint and was replaced with a new one on March 31, 1990, and the old switch was quarantined.

On May 30, 1990, this switch was tested at Wyle Laboratories.

The as-found setpoint was 162.2°F and 162.6°F, based on 2 tests under controlled test conditions.

1

3

13

22

4 Therefore, I do not believe that the as-found or as-left data taken 5 on March 1, 1990 (before the Site Area Emergency) or on March 30, 6 1990 (after the Site Area Emergency) accurately reflected the 7 actual setpoint of the switch on March 20, 1990. Since the asfound setpoint, using inconsistent test methods on March 30, 1990, 8 9 was significantly lower than it had been only days before, and the switch was leaking more than 20°F below its setpoint, I believe 10 11 that it is very possible that it tripped during the Site Area 12 Emergency at around 165°F normal temperature.

#### RESPONSE TO BOARD QUESTIONS CONCERNING APPENDIX I TO NUREG-1410

- Q. MR. WARD, WERE YOU ASKED AT THE HEARING ON JUNE 8, 1995 ABOUT
  THE INFORMATION PROVIDED IN APPENDIX I TO NUREG-1410?
- A. (Ward) Yes. Judge Bloch asked me a series of questions about
  Appendix I to NUREG 1410. Judge Bloch asked me: "Did you notice
  that in Appendix I, there was only one of all of the reports that
  might have been made in which there was a resolution where you
  found out what happened?" I said: "Again, I'm not sure that every
  entry that was made in the NUREG is accurate." Judge Bloch asked

"But you went over the original data, how is it inaccurate? Were

- any of the MWOs resolved by a disposition that showed the reason
- 2 for the failure, do you recall?" I said: "I believe there were
- 3 some that had much more information than is portrayed in here, but
- 4 I can't say." Judge Bloch then asked "Well, I'm sure they may have
- 5 had more information, but did they have the reason for the event
- 6 occurring?" I responded that: "I can't say -- sit here and
- 7 recall." Tr. 7894-95 (June 8, 1995).
- 8 Q. DO YOU NOW HAVE ADDITIONAL INFORMATION THAT IS RESPONSIVE TO
- 9 JUDGE BLOCH'S QUESTION?
- 10 A. (Ward) Yes. Since my testimony on June 8, I supervised a
- 11 review of the underlying documents used to generate the information
- 12 presented in Appendix I to NUREG-1410, including the Maintenance
- Work Orders. Based on that review, I have determined that there is
- 14 additional information provided in the underlying documents that is
- 15 not found in Appendix I. This additional information is attached
- 16 hereto as Exhibit B. This Exhibit compares the information
- 17 presented in Appendix I and the information found in the underlying
- documents, along with my opinions regarding the cause of several of
- 19 the instrument malfunctions reported in Appendix I.
- In addition, in a recent letter from NRC Region II, the NRC
- 21 states that they did not disagree with Georgia Power's earlier
- 22 exception to NURBG-1410 regarding Calcon sensor failures. The
- 23 letter is attached hereto as Exhibit C. The letter also states
- 24 that no current violations were identified regarding these sensors,
- 25 that previous deficiencies have been corrected, and that "no

- 1 further actions are necessary and this action is considered
- 2 closed." I agree with Region II's assessment and conclusions.

attached to it -- this testimony -- Hill/Ward Exhibit C, a two-page letter from the NRC to Georgia Power Company, 2 dated August 14, 1995, on resolution of outstanding issue 3 associated with California control switched used on 4 5 emergency diesel generators? WITNESS WARD: Yes. 6 MR. BLAKE: And are you familiar with this 7 document and prepared to answer questions about it? 8 WITNESS WARD: Yes, I am. 9 MR. BLAKE: Judge Bloch, I would ask that 10 these three documents -- Ward/Hill -- Hill/Ward Exhibits 11 A, B, and C -- be marked as GPC Exhibits II-195, 196, and 12 197, and be accepted into evidence. 13 14 CHAIRMAN BLOCH: Granted. (Whereupon, the above-referred to 15 documents were marked as GPC 16 Exhibits Nos. II-195, II-196, II-197 17 for identification, and were 18 received into evidence.) 19 MR. BLAKE: They are quite small. They've 20 been distributed, along with the testimony. It might make 21 sense to have them incorporated, right along as a package, 22 with the testimony at this point. 23

CHAIRMAN BLOCH: Granted.

MR. BLAKE: Mr. Ward, do you have before you a

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

24

25

#### PROFESSIONAL RESUME Howard T. Hill, Consulting Engineer

Education:

BCE, George Washington University, 1962

PhD. Princeton University, 1966 MBA, Golden Gate University, 1987

Registration: Civil Engineer, California

Professional Affiliations:

Society for Experimental Mechanics

American Nuclear Society

Code and Standards Membe: \_hips: ASME B&PV Code, Section III, Division 2, Working

Group on Testing and Overpressure Protection

ASME B&PV Code, Section XI, Working Group on

Concrete Pressure Components

ANSI/ANS 56.8 Working Group, Containment System Leakage Testing Requirements

Publications: Various papers on testing projects

#### Experience:

1966-1967 -- Employed by Bechtel Corp., Pipeline Division. Designed marine petroleum terminal facilities including piping, tankage and offshore loading lines.

1967-1977 -- Employed by Bechtel Corp., Scientific Development Department. Prepared conceptual designs for desalination plants and radioactive waste storage facilities. Designed and carried out numerous tests to verify design assumptions and to establish root causes of failures. Testing projects included the following.

Reactor containment pressure proof tests

Evaluation of structural vibrations

Evaluation of equipment vibrations

Evaluation of water hammer and other hydraulic pressure transient phenomena

Evaluation of pump failures

Evaluation of ice loading on Arctic offshore oil loading platform

Evaluation of high capacity hydraulic jack failures

Evaluation of piping and support response to dynamic fluid forces and thermal loading

Evaluation of containment prestressing loads

Evaluation of flow control valve failures

Design of specialized testing instrumentation

SUCLEAR REGULA	TURY COMMISSION
Docket No. 50-424/425-ULA .*	EXHIBITNO. IL 195
In the matter of Georgia Power Co.	M al., Yogtle Units 1 & 2
Staff CApplicant Commence	
Identified Preceived I Pale	cted Reporter 517
Date 9/19/95 Witness L	tur Ad WARD

1977-1979 -- Employed by Bechtel Corp., Los Angeles Power Division. Developed system startup procedures for the San Onofre Nuclear Generating Station (1977). Developed startup procedures and supervised system startup activities at the Lemoniz Plant in Bilbao, Spain (1978-1979).

1980-1987 -- Employed by Bechtel Corp., San Francisco Power Division. Designed and implemented tests similar to those listed above, primarily at nuclear power facilities. Planned and implemented containment integrated leakage rate tests and isolation valve leakage testing programs. Developed specialized instruments for measuring forces in posttensioned concrete containment tendons.

1987-Present -- Consulting engineer specializing in the following activities.

Design and implementation of safety related tests at nuclear power plants
Review and evaluation of nuclear power plant testing programs
Conforming testing programs to changing Federal regulations
Codes and standards development
Conducting safety related testing training programs
Research into pressure retaining capacity of containment structures
Application of test and measurement technology to the operation of industrial facilities.

201228-01 / DOCSDC1

# 3. VOGTLE EXPERIENCE WITH CALCON SENSORS IN DIESEL GENERATOR TRIP CIRCUITS

#### 3.1 Vogtle 1 (8/14/85)

Appendix I states: "A lube oil pressure sensor (Model B4400) was discovered with a setpoint

out of calibration low and was recalibrated. The cause of the setpoint drift

was not determined."

Response:

This date appears to be in error. Refer to Line 3.4 below.

3.2 Vogtle 1 (8/17/85)

Appendix I states: "A Calcon jacket water high temperature sensor (Model A-3500-W3) was

discovered during construction acceptance testing with a setpoint out of calibration low and was recalibrated. The cause of the setpoint drift was

not determined."

Response: This appears to be a duplicate of line 3.7 below.

3.3 Vogtle 1 (8/17/85)

Appendix I states: "A Calcon lube oil low pressure sensor (Model B4400) was discovered

with a setpoint out of calibration high and was recalibrated. The cause of

the setpoint drift was not determined."

Response: This date appears to be in error. Refer to line 3.4 below

3.4 Vogtle 1 (8/19/85)

Appendix I states: "A Calcon lube oil low pressure sensor (Model B4400) was discovered

with a setpoint out of calibration high and was recalibrated. The cause of

the setpoint drift was not determined."

Response: All five of the lube oil pressure switches (1PS-4749 A, B, C, D, and E) for

DG1A received their initial calibration under Construction Acceptance Test procedure CAT 85-2204. This procedure established the correct VEGP setpoints on these new switches; thus there was no setpoint drift since there

was no previous setpoint.

	NUCL	EAR REGUI			
Docket No.	50-424/425	-OLA-3	E	XHIBIT NO	11-19
in the matte				gte Unite	142
Staff [					
		wed DR			50

#### 3.5 Vogtle 1 (8/19/85)

Appendix I states: "A Calcon jacket water low pressure sensor (Model B4400) was discovered

with a setpoint out of calibration high and was recalibrated. The cause of

the setpoint drift was not determined."

Response: This was the initial calibration of 1PSL-19114 for DG1A, under Procedure

CAT 85-2204. No setpoint drift could have occurred.

#### 3.6 Vogtle 1 (8/20/85)

Appendix I states: "A Calcon jacket water high temperature sensor (Model A-3500-W3)

during construction acceptance test was discovered with a setpoint out of calibration high and was recalibrated. The cause of the setpoint drift was

not determined."

Response: This was the initial calibration of 1TSH-19110 for DG1A, under Procedure

CAT 85-2204. No setpoint drift could have occurred.

# 3.7 Vogtle 1 (8/20/85)

Appendix I states: "A Calcon jacket water high temperature sensor (Model A-3500-W3)

during construction acceptance testing was discovered with a setpoint out of calibration high and was recalibrated. The cause of the setpoint drift was

not determined."

Response: This was the initial calibration of 1TSH-19111 for DG1A, under Procedure

CAT 85-2204. No setpoint drift could have occurred.

#### 3.8 Vogtle 1 (8/24/85)

Appendix I states: "A Calcon low turbo oil pressure sensor (Model B4400) during

construction acceptance testing was discovered with a setpoint out of calibration low and was recalibrated. The cause of the setpoint drift was

not determined."

Response: This date appears to be in error. Refer to Line 3.4 above for 1PSL-4749C.

# 3.9 Vogtle 1 (10/28/85)

Appendix I states:

"Three Calcon jacket water high temperature sensors (Model A-3500-W3) were discovered with a setpoint out of calibration low and were

recalibrated. The cause of the setpoint drift was not determined."

Response:

During construction testing of the DG, the System Engineer wrote MWO 18511662 to perform an in-place calibration of DG1B switches 1TSH-19117, 1TSH-19118, and 1TSH-19119, using the permanently installed DG air tubing instead of a bench test rig in the shop. They were found out-of-specification low (180, 185, and 176 F), when compared to the previous bench calibration setpoints. This change could have been due to the difference in calibration techniques, drift, or a combination of these factors.

#### 3.10 Vogtle 1 (11/14/85)

Appendix I states: "A Calcon jacket water high temperature sensor (Model A-3500-W3) failed

and was replaced. The cause of the failure was not determined."

Response:

MWO 18512461 was written on this date, during construction testing, and states to replace switch 1TSH-19119 on DG1B with an acceptable switch. MWO 18512094 was written on 11/5/85 and states that the switch is venting continually; a new switch was calibrated and installed on 12/12/85 to resolve both MWOs. Since the switch had been readjusted upward a few days earlier (see 3.9) but was still venting, a plausible cause was leakage due to debris in the valve, which was later determined to be a problem.

# 3.11 Vogtle 1 (12/10/85)

Appendix I states: "A Calcon jacket water high temperature sensor (Model A-3500-W3) was

discovered with a setpoint out of calibration low and was recalibrated. The

cause of the setpoint drift was not determined."

Response: The System Engineer wrote MWO 18513689 to perform an in-place

calibration of DG1A switch 1TSH-19111 during construction testing of the DG. It was found out-of specification low (185F) when compared to the previous satisfactory bench test. That change could have been due to a difference in calibration techniques, drift, or a combination of these factors.

#### 3.12 Vogtle 1 (12/11/85)

Appendix I states: "A Calcon jacket water high temperature sensor (Model A-3500-W3) was

discovered with a setpoint out of calibration low and was recalibrated. The

cause of the setpoint drift was not determined."

Response: This was the initial calibration of 1TSH-19112 for DG1A, under Procedure

CAT 85-2204. No setpoint drift could have occurred.

#### 3.13 Vogtle 1 (2/11/86)

Appendix I states: "A Calcon lube oil low pressure sensor (Model A-3500-W3) was found

with a setpoint out of calibration low and was recalibrated. The cause of

the setpoint drift was not determined."

Response: This was the initial calibration of 1TSH-19146 for DG1A under Procedure

CAT 85-2204. No setpoint drift could have occurred. This switch is a temperature sensor and not a pressure sensor, as stated in the NUREG, and

the calibration was actually performed on 1/3/86.

# 3.14 Vogtle 1 (12/22/86)

Appendix I states: "A Calcon lube oil low pressure sensor (Model B4400) would not calibrate

in specification and was replaced. The cause of the malfunction was not

determined."

Response: MWO 18624684 states to obtain a new turbocharger low pressure turbo oil

trip sensor and to replace 1PS-4749D on DG1A. The MWO does not state that the sensor "would not calibrate in specification." The source of this

statement in the NUREG could not be determined.

#### 3.15 Vogtle 2 (1/24/88)

Appendix I states: "A Calcon vibration switch sensor (Model E4600) was found defective and

replaced with new vibration switch. The cause of the malfunction was not

determined."

Response: This occurred during the construction testing period. This switch is

different than Calcon temperature sensors and was not involved in the Site

Area Emergency in 1990.

#### 3.16 Vogtle 2 (2/5/88)

Appendix I states: "A Calcon low turbo oil pressure sensor (Model B4400) was discovered

with a setpoint out of calibration high and was recalibrated. The cause of

the setpoint drift was not determined."

Response: This occurred early during the construction testing period. No further

information was found.

#### 3.17 Vogtle 2 (2/26/88)

Appendix I states: "A Calcon lube oil high temperature sensor (Model A-3500-W3) was

discovered with a setpoint out of calibration low and was recalibrated.

The cause of the setpoint drift was not determined."

Response: The System Engineer wrote MWO 28801450 to perform an in-place

calibration check of 2TSH-19153 on DG2B during construction testing. The as-found setpoint for this switch was out-of-specification low (190F). This occurred about one month after the initial calibration of the switch and, most likely, occurred due to differences in calibration techniques.

# 3.18 Vogtle 2 (4/13/88)

Appendix I states: "A Calcon vibration detector sensor (Model E4600) was replaced due to a

defective switch. The cause of the defective switch was not determined."

Response: This occurred during construction testing period. This switch is different than

Calcon temperature sensors, and was not involved in the Site Area Emergency

in 1990.

#### Vogtle 2 (4/21/88) 3.19

Appendix I states: "A Calcon jacket water high temperature sensor (Model A-3500-W3) was discovered with a setpoint out of calibration low and was recalibrated. The cause of the setpoint drift was not determined."

Response:

The System Engineer wrote MWO 28803452 to recalibrate switch 2TSH-19119 on DG2B, because it was observed to be continuously venting. This occurred about one month after initial installation of the switch. The switch had an as-found setpoint of 158.6F, which was approximately 40F lower than the initial setpoint one month earlier. This difference could have been due to drift, as assumed in the NUREG, but was more likely a result of differences in calibration techniques.

#### 3.20 Vogtle 2 (4/24/88)

Appendix I states: "Three Calcon high jacket water temperature sensors (Model A-3500-W3)

were discovered with setpoint out of specification low and were recalibrated.

The cause of the setpoint drift was not determined."

Response: MWO 28803648 reported that three JW temperature switches (2TSH-19110,

> 2TSH-19111, and 2TSH-19112) on DG2A were venting. As-found setpoints were 180.0F, 185.1F and 181.5F, respectively. This difference could have been due to drift, as assumed in the NUREG, but was more likely a result of difference in calibration techniques. This problem occurred during

construction testing.

#### Vogtle 2 (7/22/88) 3.21

Appendix I states: "Three Calcon jacket water high temperature sensors (Model A-3500-W3)

were discovered with a setpoint out of calibration low and were recalibrated.

The cause of the setpoint drift was not determined."

Response: MWO 28807390 reported that two JW temperature sensors tripped while

> running a startup test of DG2B involving the JW temperature control valve, and stated that one switch tripped at a process temperature of about 172 F; the second switch tripped at a process temperature of about 179 F. The asfound setpoints were 181.5F (2TSH-19117), 173.4F (2TSH-19118), and 189.1F (2TSH-19119). The change from previous setpoints could have been due to drift, but was more likely a result of differences in calibration

techniques. This problem occurred during construction testing.

#### 3.22 Vogtle 1 (9/30/88)

Appendix I states: "Three Calcon jacket water header outlet temperature sensors (Model A-3500-

W3) were discovered with a setpoint out of calibration (2 high, 1 low) and were recalibrated. The cause of the setpoint drifts was not determined."

Response:

MWO 18806910 performed routine calibration on several instruments on DG1B during the first refueling outage. 1TSH-19117, 1TSH-19118, and 1TSH-19119 were all found out of calibration high at 220.1F, 213F, and 221.3F, respectively, on 10/20/88. These readings were obviously obtained using a different calibration technique than normal, since a water calibration bath cannot achieve the above temperatures at atmospheric pressure. Thus, using this inappropriate technique not only yielded suspicious test results, but was used to improperly reset the switches downward.

3.23 Vogtle 1 (10/10/88)

Appendix I states: "Ten Calcon bearing high temperature sensors were found to be defective and

were replaced. The cause of the malfunction was not documented."

Response: This problem was caused by destructively testing the sensors during routine

calibration during the first refueling outage. No defective sensors nor

malfunctions were observed.

3.24 Vogtle 1 (10/18/88)

Appendix I states: "A Calcon jacket water high temperature sensor was discovered out of

calibration high and was recalibrated. The cause of the calibration drift was

not determined."

Response: MWO 18806902 performed routine calibration on several instruments on

DG1A during the first refueling outage. 1TSH-19110 and 1TSH-19111 had as-found setpoints of 226.5F and 229.5F, respectively. The high out-of specification readings were obviously obtained using a different calibration technique than normal, since a water calibration bath cannot achieve the above temperatures at atmospheric pressure. Thus, using this inappropriate technique not only yielded suspicious test results, but was used to improperly reset the

switche 3 downward.

# 3.25 Vogtle 1 (10/19/88)

Appendix I states: "A Calcon jacket water high temperature sensor (Model A-3500-W3) was not

working properly and was replaced. The reason for the switch malfunctioning

was not documented."

Response: MWO 18806902 (reference 3.24 above) determined that 1TSH-19112 on

DG1A was defective during the first refueling outage routine calibration. On 10/18/88, the switch was replaced using MWO 18805581. The

documentation does not explain what was wrong with the old switch.

#### 3.26 Vogtle 1 (10/20/88)

Appendix I states: "A Calcon low lube oil pressure sensor (Model B4400) was discovered with

a setpoint out of calibration high and was recalibrated. The cause of the

setpoint drift was not determined."

Response: MWO 18806914 was written to perform routine calibration of several

instruments on DG1A during the first refueling outage. All five of the lube oil pressure sensors (1PS-4749 A, B, C, D, and E) were found in-specification

on 10/10/88 and 10/11/88.

# 3.27 Vogtle 1 (10/20/88)

Appendix I states: "A Calcon jacket water header pressure sensor (Model B4400) was discovered

with a setpoint out of calibration high and was recalibrated. The cause of the

setpoint drift was not determined."

Response: MWO 18806831 was written to perform routine calibration of several

instruments on DG1A during the first refueling outage. Jacket water header pressure switch 1 PSL-19114 was found in-specification, but was readjusted

to the nominal setpoint on 10/18/88.

## 3.28 Vogtle 1 (10/21/88)

Appendix I states: "A Calcon low lube oil pressure sensor (Model B4400) was discovered with

setpoint out of calibration high and was recalibrated. The cause of the

setpoint drift was not determined."

Response: This appears to be a duplicate of 3.26 above. No lube oil pressure switches

were out of calibration.

# 3.29 Vogtle 1 (10/23/88)

Appendix I states: "Two Calcon normal trip pressure sensors (Model B4400) failed. One sensor

would not respond and the other failed to reset within tolerance. The cause

of the failures were not documented."

Response: MWO 18807465 was written to verify the correct setpoint for logic switch

1PSL-4903 on DG1B. The switch would not trip within tolerance and was replaced on 10/25/88. MWO 18807466 was written to verify the correct setpoint for logic switch 1PSL-4902 on DG1A. The switch would not reset within tolerance and was replaced on 11/3/88. Both of these problems

occurred during the first refueling outage.

#### 3.30 Vogtle 1 (10/26/88)

Appendix I states: "A Calcon jacket water header outlet temperature sensor (Model A-3500-W3)

switch would not calibrate. The cause of the failure was not determined."

Response:

MWO 18807637 stated that 1TSH-19119 on DG1B was leaking and should be replaced. A new switch was obtained but would not calibrate satisfactorily. Another new switch was calibrated and installed. This work was performed on 10/27/88, which was only a few weeks after the installed switch had been reset downward about 20F (see Item 3.22 above). No explanation is provided for failure of the first replacement switch to be calibrated, but in subsequent years some new switches were determined to have foreign material in the valve poppet area which prevented the switch from being set correctly. The original switch setpoint discrepancy appears to be very similar to later observations that note the importance of using consistent calibration techniques.

3.31 Vogtle 1 (10/30/88)

Appendix I states: "Two Calcon jacket water temperature sensors (Model A-3500-W3) were

found to be defective and were replaced. The cause of the failures was not

documented."

Response: MWO 18807746 stated that, during a run of DG1A on 10/30/88, an

annunciator indicated a malfunction of jacket water temperature switches. Switches 1TSH-19110, -19111, and -19112 were checked with air and found not to be leaking. Switches 1TSH-19110 and 1TSH-19111 were removed and calibration checked in the shop with as-found setpoints of 193.7F and 193.4F,

respectively, on 11/3/88, which was only slightly out of specification. They

were then reinstalled to support DG operability. On 11/19/89, three new switches were obtained, and all three JW high temperature switches were replaced. No explanation was provided for the initial DG annunciator problem in the documentation, but foreign material in one of the switches is one potential explanation, based on subsequent observations with those components. However, the NUREG statement does not appear to be an accurate representation of the actual problem.

# 3.32 Vogtle 1 (10/31/88)

Appendix I states: "Two Calcon jacket water header outlet temperature sensors (Model

A-3500-W3) were replaced. The reason was not documented."

Response:

For no documented reason, MWO 18807793 was written on 10/31/88 to replace DG1B switches 1TSH-19117 and -19118. New switches were calibrated and installed on 11/1/88. This problem occurred only a few weeks after the installed switches had been reset downward by 12-20F (see Item 3.22 above), and only a few days after the third switch was replaced on the same DG (see Item 3.30 above). The setpoint problems appear to be very similar to later observations that note the importance of using consistent calibration techniques.

#### 3.33 Vogtle 2 (12/9/88)

Appendix I states: "A Calcon vibration sensor (Model E4600A) was malfunctioning causing the

emergency diesel generator to trip. The sensor was replaced. The cause of the

malfunction was not documented."

# 3.33 (continued)

Response: This occurred during startup testing of Unit 2. This switch is different than

Calcon temperature sensors, and was not involved in the Site Area Emergency

in 1990.

#### 3.34 Vogtle 1 (11/19/89)

Appendix I states: "A Calcon high jacket water temperature sensor (Model A-3500-W3) was

discovered with a setpoint out of calibration low and was recalibrated. The

cause of the setpoint drift was not determined."

Response: This appears to be a duplicate of the problem discussed in Item 3.31 above

(final switch replacement date).

#### 3.35 Vogtle 1 (12/5/89)

Appendix I states: "A Calcon lube oil pressure sensor (Model B4400) was found defective during

a calibration check and was replaced with a new switch. The cause of failure

was not documented."

Response: No record of the above problem was found on this date.

#### 3.36 Vogtle 1 (1/3/90)

Appendix I states: "A Calcon turbo oil pressure sensor (Model B4400B) was venting and was

replaced. Cause of the failure was not determined."

Response: No record of the above problem was found on this date. Also, the switch

model number is not correct for VEGP switches.

#### 3.37 Vogtle 1 (1/25/90)

Appendix I states: "A Calcon lube oil temperature sensor (Model A-3500-W3) was discovered

with a setpoint out of calibration high and was recalibrated. The cause of the

setpoint drift was not determined."

Response: MWO 19000439 was written on 1/25/90 to perform routine outage calibration

of many instruments on DG1A. On 3/3/90, during the outage, 1TSH-19146 was found to be set at 211F and was reset to approximately 200F. Since the switch was calibrated at 200F in January, 1986, and checked at 202F in October, 1988, but three weeks later was found to be set 10F low, it appears

that a different calibration technique was used on 3/3/90.

# 3.38 Vogtle 1 (1/25/90)

Appendix I states: "Three Calcon jacket water header outlet temperature sensors (Model

A-3500-W3) were discovered with set points out of calibration high and were

recalibrated. The cause of the setpoint drifts was not determined."

Response: MWO 19000439 was written on 1/25/90 to perform routine outage calibration

of many instruments on DG1A. On 3/1/90 and 3/2/90, during the outage, jacket water temperature switches 1TSH-19110, -19111, and -19112 were found to be set at 210F, 206.2F, and 210.4F, respectively. They were reset to the correct setpoints and were reinstalled on the engine. Each of the calibration data sheets contains a note by the technician that states, "... the

values indicated above are an average taken of three cycles." These switches

were in place on DG1A and tripped the engine approximately three weeks later during the Site Area Emergency on 3/20/90. The calibration method used during this procedure would have maintained the switch at an elevated temperature while the setpoint was adjusted downward and while the new etpoint was verified three times. Subsequent evaluation has shown that thermal growth of the switch at elevated temperatures will result in an improperly suppressed final setpoint.

# 3.39 Vogtle 1 (3/3/90)

Appendix I states: "A Calcon jacket water low pressure trip sensor (Model B4400) was

discovered with a setpoint out of calibration high and was recalibrated. The

cause of the setpoint drift was not determined."

Response: MWO 19000439 performed routine outage calibration on DG1A switch 1PSL-

19114. The switch was found to be about 2 psig out of specification and was

reset.

#### 3.40 Vogtle 1 (3/4/90)

Appendix I states: "A new Calcon high temperature main bearing sensor (Model 3434) switch

was installed. The reason the new switch was needed was not documented."

Response: This sensor was destructively tested during the 1R2 outage on DG1A and was

replaced with a new switch.

# 3.41 Vogtle 1 (3/23/90)

Appendix I states: "Three Calcon jacket water header outlet temperature sensors (Model

A-3500-W3) were checked for calibration. Two switches were found out of calibration. One switch did not pass the bubble test and was replaced. The

other two were recalibrated."

Response: MWO 19001511 documents work that was performed on DG1B during its

1R2 overhaul immediately following the Site Area Emergency. All three jacket water temperature switches (1TSH-19117, -19118, and -19119) were found set about 10F low, and two of them exhibited some leakage and were replaced. Subsequent examination showed that leakage was caused by foreign

material in the switch poppet valve.

# 3.42 Vogtle 1 (3/25/90)

Appendix I states: "A Calcon lube oil high temperature sensor (Model A-3500-W3) was

discovered with a setpoint out of calibration high and was recalibrated. The

cause of the setpoint drift was not determined."

Response: MWO 19001511 states that switch 1TSH-19153 on DG1B was venting

continuously and was defective. This work occurred as part of the restoration

of DG1B following the Site Area Emergency on 3/20/90.

#### 3.43 Vogtle 1 (3/25/90)

Appendix I states: "A Calcon start logic air pressure sensor (Model B4400) was found

malfunctioning during a surveillance procedure. The defective sensor was replaced. The defective switch was subsequently tested satisfactorily. The

cause of the malfunction was not determined."

Response: MWO 19001542 replaced defective P3 switch 1PS-4903 on DG1B as part of

restoration from the routine overhaul following the Site Area Emergency. This switch was subsequently tested and tripped within specification at the same setpoint three consecutive times; therefore, the sensor was determined

to not be defective.

#### SUMMARY:

The above data review reinforces that different calibration techniques used on the temperature switches had a major impact on the switch settings. Several instances are seen where a switch would be found set too high and would be adjusted downward, then a few days later would be reported leaking and would be found set too low. This is the same exact sequence that occurred on DG1A on 3/3/90 and 3/20/90, resulting in the Site Area Emergency (see 3.38 and 3.41 above).



#### NUCLEAR REGULATORY COMMISSION REGION II 191 MARIETTA STREET, N.W., SUITE 2009 ATLANTA, GEORGIA 20089-0180

August 14, 1995

Georgia Power Company
ATTN: My. C. K. McCay
Vice President
Vogtle Electric Generating Plant
P. O. Box 1295
Birmingham, AL 35201

SUBJECT:

RESOLUTION OF OUTSTANDING ISSUE ASSOCIATED WITH CALIFORNIA CONTROLS SWITCHES USED ON EMERGENCY DIESEL GENERATORS

Door Mr. McCoy:

This refers to an outstanding issue discussed in our October 19. 1990, letter associated with your root cause analysis of the failure of the emergency diesel generator (EDE) to provide AC power as intended. This concern was precipitated by the past history of reliability of California Controls Company (Calcon) sensors. These sensors were used on the EDSs at the Vogtle facility and became a significant concern during the Site Arma Emergency (SAE) that occurred on March 20. 1980.

An enforcement conference was held at our request on September 5, 1880, to discuss numerous items identified by the MRC Incident Investigation Team (IIT) which investigated the circumstances of the SAE. The primary items discussed at the enforcement conference were the failure to make timely emergency netifications to state and local government agencies, the inability of site personnel to establish containment integrity within the required time limits, and the failure of the EDE. The internal contamination found in the Calcon jacket water temperature sensors and inconsistent calibration techniques resulting in intermittent Calcon sensor failure were identified as the most probable cause of the EDS trips. In the October 19, 1950 letter, we informed you that the NRC concerns associated with your rost cause analysis of EDE problems would be addressed separately.

The IIT report, MURES 1410, was issued in June 1980. In this report, the IIT identified that a significant number of Calcon sensor failures had occurred at vogile since 1988. The MURES identified a list of failures that had occurred between 1988 and 1990. In your letter dated July 9, 1990, decumenting your review of the MURES, you that exception to the cancilusion reached by the IIT with respect to the sensor failures. In your review you pointed out that a large percentage of the problems identified were associated with calibration setpoints being out-of-specification during construction esceptance testing. You also identified that an out-of-calibration condition is not typically counted as a failure by either decryte Power Company (SPC) or other plants in accordance with the Nuclear Plant Reliability Date System reporting critaria and, therefore, the conclusion reached by the MEC was not based on comparable date. The MRC reviewed this correspondence and did not disagree with the SPC position and a former reply was not provided.

NUCLEAR REGULATOR	Y COMMISSION
Docket No. 50-424/425-OLA-3	DIHIBITNO. IL 197
in the matter of Georgia Power Co. et al.	, Vogtle Units 1 & 2
Staff GApplicant Intervenor	
☐ Identified ☐ Rejected ☐ Rejected	d Reporter 50

.2.

GPC

Following the SAE, the NRC has inspected EDE activities and reviewed root causa/corrective action activities on a frequent basis. The most recent NRC inspection addressing Calcen sensors was conducted May 9-20, 1994. (Inspection Report 50-424.425/94-12. dated June 9. 1994.) The inspectors did not identify any violations associated with these sensors. In addition, the inspectors identified that you had corrected the deficioncies that existed in the March 1990, time frame and few failures have been experienced since that time. The NRC inspections have confirmed that your Safety Audit and Engineering Review group has conducted adequate root cause analyses and GPC has corrected similar deficiencies.

Sannd on the reviews conducted in 1990 and subsequent observations. no further actions are necessary and this action is considered closed.

Should you have any questions concerning this letter, please contact us.

Sincerely.

Ellis W. Merscheff Director, Division of Reactor Projects

Dockat Mos.: 50-424, 50-425 License Mos.: MPF-68, MPF-61

Senior Vice President-Nuclear Seargie Pewer Company P. O. Bex 1295 Birmingham, AL 35201

> J. B. Bussley Soneral Mamager, Plant Vegtle Georgia Pamer Cumpany P. O. Box 1890 Waynesbore, SA 18889

J. A. Builey Manager-Licensing Amorgia Power Company P. O. Best 1296 Sireinghom, Al. 18201

(cc cest'd - Sas page 3)

document entitled "Affidavit of Lewis A. Ward," comprised of some six and a half pages of -- six, and some portion of a page 7, pages of text, and included with it a GPC Exhibit, which is indicated to be Ward Exhibit D, a Plant Vogtle diesel generator air start cap evaluation document, which itself has appendices A and B, do you have that document? WITNESS WARD: Yes. MR. BLAKE: And was this document prepared by you or under your direction and supervisor? WITNESS WARD: Yes, it was. MR. BLAKE: And is it accurate, to the best of your knowledge and belief? WITNESS WARD: Yes. MR. BLAKE: And do you adopt it as your testimony in this proceeding? WITNESS WARD: Yes, I do. MR. BLAKE: And are you familiar with the documents which are attached to it and prepared to answer questions about those? 201 WITNESS WARD: Yes. MR. BLAKE: Judge Bloch, I'd ask that the Affidavit of Lewis A. Ward, dated September 1, 1995, be accepted into evidence, along with the attached Ward Exhibit D document, which should be marked as GPC

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

2

3

5

8

9

11

12

13

14

15

16

17

18

19

21

22

23

24

25

1	Exhibit II-198. And I'd ask that the GPC exhibit be
2	marked and that both the affidavit and the exhibit be
3	accepted into evidence.
4	MS. YOUNG: Mr. Blake, isn't there a previous
5	document that has been marked as Ward D?
6	MR. BLAKE: I don't know the answer, but I
7	appreciate looking I'll look it up and doublecheck on
8	it. I'm more confident about the
9	MS. YOUNG: I believe it's GPC II-62, if we
10	could somehow distinguish this Ward D
11	MR. BLAKE: Okay.
12	MS. YOUNG: in another way.
13	MR. BLAKE: Thank you very much.
14	MS. YOUNG: Just so it's not confusing,
15	because I believe your Ward exhibits got all of the way up
16	to G before.
17	MR. BLAKE: I will doublecheck and
18	CHAIRMAN BLOCH: Why don't we save time, and
19	counting on Ms. Young's accuracy, call this Ward
20	Exhibit H?
21	MR. BLAKE: That's fine. It's not
22	CHAIRMAN BLOCH: There needs to be a
23	correction here later.
24	MR. BLAKE: All right.
25	MR. MICHAEL KOHN: If it's referred to in the
	NEAL R. GROSS

NEAL R. GROSS

affidavit, we may need to charge to to an H, too. WITNESS WARD: Page 6, line -- paragraph 16. 2 CHAIRMAN BLOCH: Okay. Page 6, paragraph 16, 3 line 7, says "Exhibit D" that shall now read "Exhibit H." 4 And the motion is granted. 5 (Whersupon, the above-referred to 6 document was marked as GPC Exhibit 7 No. II-198 for identification, and 8 was received into evidence.) 9 MR. BLAKE: Thank you, Judge. I have no more 10 questions. These witnesses are made available for cross. MR. MICHAEL KOHN: Thank you, Your Honor. 12 CROSS EXAMINATION 13 MR. MICHAEL KOHN: I'd like to turn your 14 attention to the affidavit we've just been looking at, Mr. Ward. I understand that your affidavit deals with 16 what you would consider to be the cause of the weak air 17 rolls, is that correct? WITNESS WARD: Yes. 19 MR. MICHAEL KOHN: And the purpose is to show 20 that the problem causing the weak air rolls showed up when one bank was isolated during surveillance testimony? 22 WITNESS WARD: That's when the problem showed 23 up, yes. MR. MICHAEL KOHN: So is it your testimony, 25

NEAL R. GROSS

basically -- on page 3 of your testimony, you say -excuse me, page 3 of the affidavit, you state about a 2 third of the way up from the bottom, "In summary, 3 conditions required to produce a weak air roll include the 4 start -- the air start system alignment." Do you see 5 that? 6 7 WITNESS WARD: Yes. MR. MICHAEL KOHN: And by referring to the air 8 start system alignment, are you referring to the that there is only one air bank? WITNESS WARD: Yes, the alignment is either 11 one bank in service or two banks in service. 12 MR. MICHAEL KOHN: And as I am reading your 13 testimony, you said it's required when only one air bank 14 would be in service, is that correct? Do you see you say, 15 "The conditions required to produce a weak air roll would 16 be when only one air bank was being used"? 17 WITNESS WARD: No. No, that's a -- that 18 sentence has several other conditions with it. 19 MR. MICHAEL KOHN: That would be one of the 20 21 requirements? WITNESS WARD: That's one of the factors. 22 MR. MICHAEL KOHN: One of the factors. 23 WITNESS WARD: Right. 24

#### **NEAL R. GROSS**

MR MICHAEL KOHN: And is that a necessary

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

25

1	factor, or is this a conditional factor? How do you look
2	at it?
3	WITNESS WARD: I would call that an
4	aggravating factor.
5	BOARD EXAMINATION
6	CHAIRMAN BLOCH: In other words, it's
7	cumulative? It could happen either in combination with
8	other factors?
9	WITNESS WARD: Yes. That's what I'm trying to
10	say here. It's a combination of factors.
11	CROSS EXAMINATION (Continued)
12	MR. MICHAEL KOHN: On page the bottom of
13	page 4 and the top of page 5, you on the bottom of
14	page 4 you provide data, and on the top of page 5 you
15	state that, "Note that all of the recorded failures
16	occurred with one of the air systems isolated." Do you
17	see that?
18	WITNESS WARD: Yes.
19	MR. MICHAEL KOHN: So are you here saying that
20	weak air rolls are associated with the one air bank being
21	used to start the diesel?
22	WITNESS WARD: What I'm saying is that the
23	four recorded failures happened in conjunction with one of
24	the banks being isolated.
25	MR. MICHAEL KOHN: And the four you are

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

NEAL R. GROSS

1	
1	mentioning are set out on the bottom of page 4?
2	WITNESS WARD: That's correct.
3	MR. MICHAEL KOHN: Are there four, or are
4	there five?
5	WITNESS WARD: Well, January 24th and 25th,
6	I'm not clear how many attempts were in that period, but
7	that was I'm counting that as one event, under one
8	alignment.
9	MR. MICHAEL KOHN: All right. So it's your
10	understanding that with respect to those starts, then,
11	that the right number 1 air system was isolated?
12	WITNESS WARD: Yes.
13	MR. MICHAEL KOHN: And if I would understand
14	the thrust of your testimony, then, that the safety
15	significance is that when you're doing an air roll, you
16	use both banks, so, therefore, there would not be a real
17	let me rephrase that.
18	In an emergency condition, both banks would be
19	utilized, is that correct?
20	WITNESS WARD: That's correct.
21	MR. MICHAEL KOHN: And that would mitigate the
22	safety significance of problems associated with just one
23	air bank isolated?
24	WITNESS WARD: That would make it less likely
25	that a problem would show up, that you would have a weak
	NEAL R. GROSS

air roll if you had both air systems in service.

MR. MICHAEL KOHN: Your Honor, I would like to mark as Intervenor's II-257 a March 12, 1990, letter signed by Mr. Hairston, concerning special report about diesel generator failures, and the two-page enclosure attached to that letter.

CHAIRMAN BLOCH: Granted.

(Whereupon, the above-referred to document was marked as Intervenor's Exhibit No. II-257 for identification.)

MR. MICHAEL KOHN: Earlier, Mr. Ward, we were discussing, on page 4 and 5 of your affidavit, this April -- excuse me -- January 24 to January 25 start of the diesel generator. And would you look on the enclosure, and the number 2 under B2, and do you note that on January 25 the diesel was started and that neither air receiver was isolated when it was started? And that the diesel rolled slowly but did not start?

WITNESS WARD: You'll have to give me a minute to read this. Okay. I've read this.

MR. MICHAEL KOHN: And is it true, then, that on your affidavit testimony on the top of page 5, where it says, "All of the recorded failures occurred with one air system isolated" is false?

#### NEAL R. GROSS

WITNESS WARD: It appears that is correct. 1 The January 25th failure on 2A, according to this letter 2 here, happened with both systems in service. 3 MR. MICHAEL KOHN: Intervenor calls for the 4 admission of II-257. 5 CHAIRMAN BLOCH: Granted. 6 (Whereupon, the above-referred to 7 document, previously marked as 8 Intervenor Exhibit No. II-257 for 9 identification, was received into 10 evidence.) 11 BOARD EXAMINATION 12 CHAIRMAN BLOCH: Mr. Ward, in light of your 13 last answer, is there any reason for you to believe that 14 the information in II-257 is incorrect? 15 WITNESS WARD: No. 16 CROSS EXAMINATION (Continued) 17 MR. MICHAEL KOHN: Mr. Ward, did you know 18 about all five of these recorded start failures, weak air 19 rolls, that are identified in the bottom of page 4 of your 20 affidavit? Let me rephrase it. 21 You identified four. Did you know, when you 22 were identifying the four, that there were, in fact, five? 23 WITNESS WARD: No, I did not. 24 MR. MICHAEL KOHN: I'd like to call the 25

NEAL R. GROSS

1	witness' attention to Intervenor's II-156 that was
2	previously identified and admitted into this proceeding.
3	CHAIRMAN BLOCH: Mr. Kohn has handed a copy of
4	that exhibit to the witness, Mr. Ward.
5	MR. MICHAEL KOHN: Mr. Ward, I believe the
6	document I showed you was the document I previously showed
7	you during your testimony, which is part of the material
8	you prepared for your the enforcement conference in
9	September 1990. Is that correct?
10	WITNESS WARD: I'll have to ask I don't
11	I can't call you know, if I previously if this was
12	part of my previous, that's fine. I can't remember 156.
13	MR. MICHAEL KOHN: On the face of that
14	document, it demonstrates that do you recognize the
15	document?
16	WITNESS WARD: It looks familiar, yes.
17	MR. MICHAEL KOHN: It looks familiar as to
18	something you prepared for a presentation to the NRC?
19	WITNESS WARD: I have probably seen this in
20	the past. I prepared that presentation over five years
21	ago.
22	MR. MICHAEL KOHN: And that document lists all
23	five starts, correct?
24	WITNESS WARD: Yes, it does.
25	MR. MICHAEL KOHN: Does that refresh your
	NEAL R. GROSS

1	recollection that you were, in fact, aware that there were
2	five starts during that time period, five weak air rolls?
3	WITNESS WARD: No, it doesn't.
4	MR. MICHAEL KOHN: Are you aware that
5	Mr. Johnson (sic) testified in this proceeding well,
6	let me back up. Did you review Mr. Johnson's (sic)
7	testimony in this proceeding to prepare your affidavit?
8	CHAIRMAN BLOCH: It's Johnston.
9	MR. MICHAEL KOHN: Johnston. Thank you, Your
10	Honor.
11	WITNESS WARD: I reviewed one page of his, not
12	all of it.
13	MR. MICHAEL KOHN: Well, are you aware that
14	Mr. Johnston testified that Plant Vogtle was the only
15	nuclear plant in the world that he was aware of to have a
16	weak air roll associated with the pinching phenomena?
17	WITNESS WARD: No, I was not.
18	MR. MICHAEL KOHN: If that is, in fact, true,
19	how do you explain that you have had five weak air rolls
20	attributed to this pinching phenomena?
21	WITNESS WARD: I can't explain why we're the
22	only one. We did have the phenomena. We did show that we
23	had inadequate clearances between the cap and the piston,
24	and Cooper agreed with that, to the extent they issued a
25	Part 21 to all other owners, notifying them of that.

Now, if Mr. Johnston says we are the only one that had that, that's -- that's fine. 2 MR. MICHAEL KOHN: Are you aware of any 3 physical configuration of your plant which would make you more prone to having these weak air rolls than the other 6 plants? 7 WITNESS WARD: I'm not that familiar with the other plants, no. 8 BOARD EXAMINATION 9 CHAIRMAN BLOCH: Mr. Ward, in particular, you 10 don't know whether the clearance problem was the same at the other plants as it was at Vogtle, do you? 12 WITNESS WARD: I don't know, no, sir. 13 CROSS EXAMINATION (Continued) 14 MR. MICHAEL KOHN: Now, if I understand it, 15 your affidavit postulates that the weak air rolls --CHAIRMAN BLOCH: Before you continue, I want 17 to direct the panel that if at any time you disagree with something being said by the other person on the panel, we would expect you to speak up about that. If you don't 20 know about it, you don't have to speak up. But if you 21 disagree, I'd appreciate that. 23 Mr. Kohn? MR. MICHAEL KOHN: Mr. Hill, did you look at 24 anything associated with the weak air rolls? 25

NEAL R. GROSS

WITNESS HILL: No, I did not.

MR. MICHAEL KOHN: As I understand it, your affidavit postulates that the weak air rolls were due to initial manufacturing defects involving clearances between the caps and pistons and that this condition may have always existed within the diesel?

WITNESS WARD: Yes.

MR. MICHAEL KOHN: And I understand that you have ruled out creep as a possible mechanism for the weak air rolls?

WITNESS WARD: I believe that's -- that's my feeling.

MR. MICHAEL KOHN: My question is, how does your affidavit reasonably explain the time lapse between the first weak air roll and the five weak air rolls which then followed within a six-month period? Let me rephrase that. Between the initial time the diesel was placed in service and the five weak air rolls which followed some few years later.

WITNESS WARD: Well, the 2A diesel was placed in service in the first half of 1989, March of '89, and this happened in January of '90. So that's less than a year. It's not several years.

MR. MICHAEL KOHN: Didn't the 2A diesel have qualification testing prior to '89?

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

WITNESS WARD: Yes. I'm just answering your 1 question. You said "placed in service." 2 MR. MICHAEL KOHN: It would have really been 3 placed in service with 35 consecutive valid tests of the 4 diesel during the qualification testing, correct? 5 WITNESS WARD: I'm using the term "placed in 6 service" as when the diesel was required to be operable to 7 meet the tech. specs., which we loaded fuel around March 8 of 1989. That's when it was (quote) "placed in service." 9 MR. MICHAEL KOHN: Well, let me rephrase my 10 question. From when diesel 2A was at the site and was 11 beginning to be started, what's the time period from that 12 point until the first weak air roll? 13 WITNESS WARD: I -- I don't have the timeline 14 for when we installed it. 1511 MR. MICHAEL KOHN: As I understand it, 1B, 16 diesel 1B also had a weak air roll, correct? 17 WITNESS WARD: Yes. 18 MR. MICHAEL KOHN: And the weak air roll at 1B 19 was some four years after it was installed at Plant 20 Vogtle? 21 WITNESS WARD: It was placed in service in the 22 early part of 1987. Again, I don't -- I wasn't there 23 during the construction period, and I don't know how long 24 that went before. But it had been in service three years, 25

NEAL R. GROSS

a little over three years, when this happened.

MR. MICHAEL KOHN: And it had qualification testing prior to that, correct?

WITNESS WARD: I'm assuming that it did, but I -- I wasn't involved in that.

MR. MICHAEL KOHN: With respect to the 1B diesel, can you explain this three or more year delay? Can you give me right now what you would understand to be a reasonable explanation of this three-year delay in detecting a weak air roll?

was caused by inadequate clearances in the piston to cap.

That wasn't a fixed number that you install them, and that

-- that clearance stayed the same on every cylinder, every
time from then on. We took the engine apart a number of
times, and we took different components apart during
overhauls. They were put back together differently. We
may have installed new caps at various points during
overhauls.

The clearance problem, in conjunction with the requirement that the engine stop at a certain position in relation to a stuck cap, is what I believe produced the subsequent weak air roll. And that wasn't the same every day from when the engine was installed in '80 -- whenever it was, before '87, and when the problem occurred in 1990.

#### **NEAL R. GROSS**

#### BOARD EXAMINATION

CHAIRMAN BLOCH: Mr. Ward, did you study the maintenance history of 1A to see whether this explanation of changing of clearances could possibly account for what happened?

MR. BLAKE: Do you mean either --

WITNESS WARD: 1B?

MR. BLAKE: -- 1B or --

CHAIRMAN BLOCH: 2A or 1A, either one. Did
you study the maintenance history of either to see
whether, in fact, maintenance practices and changes could
have caused the delay or caused the failures which didn't
occur in the beginning?

maintenance history on either one of them. But 2A, when the problem occurs, we had not had a maintenance overhaul. The engine was basically newly in service, less than a year. 1B had been through -- in 1990, we had had -- I believe we had had two refueling outages by that time. And during each time, work was done on the engine. I did not go back and look at what specifically was done.

CHAIRMAN BLOCH: Do you know whether or not that work that was actually done could account for any changes in the way the pistons functioned?

WITNESS WARD: I believe it could, because

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

2

3

5

6

8

9

11

12

13

14

15

16

17

18

19

201

22

23

pistons were taken apart. But I did not specifically look 1 at which piston had been taken apart and retorqued. 2 CHAIRMAN BLOCH: There were pistons that were 3 retorqued? 4 WITNESS WARD: Well, when they're taken off, 5 they have to be retorqued when they're put back on. 6 CHAIRMAN BLOCH: The caps were retorqued? 7 WITNESS WARD: Yes. 8 CHAIRMAN BLOCH: And could the retorquing 9 increase the -- reduce the clearances? WITNESS WARD: By causing distortion due to --11 due to the base of the cap not being completely flat. So 12 when you torque down the two hold-down bolts, it distorts 13 -- basically, brings the cap in, squeezes it in. 14 CHAIRMAN BLOCH: So the retorquing could have 15 caused reduced clearances? 16 WITNESS WARD: Yes. 17 CHAIRMAN BLOCH: And is that a procedural 18 19 problem? WITNESS WARD: The procedure has a torque 20 value on the two hold-down bolts that we go to the same 21 torque value. The problem is if the cap is not completely 22 flat, and the mating -- with the mating surface, then the 23 distortion is different. It can be different each time 24 25 you bolt it down to the same torque values.

**NEAL R. GROSS** 

1	The problem was the only thing we were
2	measuring was the torque on the two hold-down bolts. We
3	were not checking flatness with clearance prior to
4	prior to retorquing.
5	CHAIRMAN BLOCH: And has that procedure now
6	changed?
7	WITNESS WARD: What we do now is we do a pop
8	test, and I believe the procedures have been changed, but
9	I can't say for a fact they have. I know the clearance
10	checks are have been changed, and we do check the
11	clearance once we have them apart, which we had not been
12	doing prior to that time.
13	CHAIRMAN BLOCH: Mr. Kohn?
14	CROSS EXAMINATION (Continued)
15	MR. MICHAEL KOHN: The speculation you have
16	about torquing the caps could have happened at any other
17	plant as well, correct?
18	WITNESS WARD: That's correct.
19	MR. MICHAEL KOHN: But there were
20	CHAIRMAN BLOCH: Counsel struck that comment.
21	MR. MICHAEL KOHN: Yes. I've learned a
22	little.
23	(Laughter.)
24	Are you testifying that the phenomena on the
25	binding is a random phenomena and not a time-delayed
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

(202) 234-4433

phenomena? WITNESS WARD: That's my belief, yes. 2 MR. MICHAEL KOHN: Initially, are you aware 3 that Georgia Power called an expert panel to explain the 4 weak air rolls and the reason given was creep? WITNESS WARD: No. 6 MR. BLAKE: May I have a reference, please? 7 MR. MICHAEL KOHN: Yes. Mr. Johnston and 8 Mr. Owyoung's prefiled testimony. MR. BLAKE: Thank you. Was there a page 10 number? Do you have it? 11 MR. MICHAEL KOHN: Not in front of me. 12 MR. BLAKE: Okay. 13 MR. MICHAEL KOHN: Based on your -- the 14 exhibit attached as Ward Exhibit H, Georgia Power's 15 Exhibit 198, do you believe Georgia Power would have had a 16 reasonable basis to submit testimony before the Board that 17 creep was the cause of the weak air rolls? 18 WITNESS WARD: Would you repeat the question, 19 please? 20 21 22

MR. MICHAEL KOHN: Do you believe an expert panel would have a reasonable basis to submit expert testimony before this Board to indicate that creep was the cause of the weak air rolls?

MR. BLAKE: Can we provide him a copy of the

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

23

24

25

1	testimony and just let him look at it, and then comment on
2	it, if that's what you want? I have a copy.
3	CHAIRMAN BLOCH: That's a reasonable
4	suggestion.
5	MR. MICHAEL KOHN: If counsel would like to
6	provide him a copy, please do.
7	MR. BLAKE: It's the question and answer that
8	begins at the bottom of page 14 of their prefiled
9	testimony and carries over to the top of 15.
10	MR. MICHAEL KOHN: Have you had an opportunity
11	to review that prefiled testimony previously?
12	WITNESS WARD: I reviewed one page of this
13	draft, when it was in the draft stage, and I this was
14	I think was the page that I looked at. It was not in
15	the same format that it is now, so I'm not sure.
16	Yes, I reviewed this page, and that's what
17	prompted this evaluation that is my Exhibit H.
18	MR. MICHAEL KOHN: And I think you indicated
19	that you reviewed the Owyoung/Johnston testimony when it
20	was in draft form, is that correct?
21	WITNESS WARD: Yes, just this one page.
22	MR. MICHAEL KOHN: And do you recall when that
23	review occurred?
24	WITNESS WARD: Late July/early August 1995.
25	MR. MICHAEL KOHN: And do you know why you
	NEAL R. GROSS

were reviewing that draft page?

witness ward: The subject of creep had been raised, and I -- I was asked to do a draft -- whether or not that was a credible explanation for the question that had been raised about the -- whether that could be the root cause of the problem not having shown up for several years.

MR. MICHAEL KOHN: So, then, in July and August, you agreed and that testimony was submitted by Mr. Owyoung and Johnston?

WITNESS WARD: I don't understand your question.

MR. MICHAEL KOHN: I think you -BOARD EXAMINATION

CHAIRMAN BLOCH: Did you, in July and August, agree with the conclusions reached by Owyoung and Johnston about creep?

WITNESS WARD: I questioned the statement that creep was the factor that was stated here, and that's why I had a study done by Southern Company Services, to give another opinion on that same subject. I did not have a -- I did not initially endorse or reject the idea of creep, but had another study done to form a second opinion.

CROSS EXAMINATION (Continued)

MR. MICHAEL KOHN: Well, if I understand it,

**NEAL R. GROSS** 

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

25

22

23

24

2

3

8

11

12

13

14

15

16

17

1	then, your initial reaction to seeing a draft of the
2	testimony was to question its accuracy?
3	WITNESS WARD: That's that's true. I
4	questioned it.
5	MR. MICHAEL KOHN: And who did you raise the
6	question to?
7	WITNESS WARD: I raised the question to
8	well, I asked our metallus ical department at Southern
9	Company Services to do this evaluation, so I could have
10	this information for use here.
11	MR. MICHAEL KOHN: Well, someone gave you a
12	portion of the Owyoung/Johnston testimony. Who was that?
13	WITNESS WARD: My attorney.
14	MR. MICHAEL KOHN: And did you question the
15	accuracy of that testimony with your the attorneys who
16	gave it to you?
17	WITNESS WARD: I don't recall what we
18	discussed. We did discuss the page, and I did talk to
19	Mr. Johnston about it.
20	MR. MICHAEL KOHN: Is there any reason the
21	document attached as Exhibit H to your testimony, your
22	affidavit, could not have been prepared earlier?
23	WITNESS WARD: Yes. The question of creep had
24	only come up that was the first time I had heard that
25	as a plausible explanation for this problem.
	NEAL R. GROSS

MR. MICHAEL KOHN: So no one wondered why the 1 weak air rolls were time delayed until the discussion 2 about creep was began? 3 WITNESS WARD: Well, I can't say that no one 4 wondered, but the --5 MR. MICHAEL KOHN: Let me rephrase it. You 6 had no -- you hadn't wondered about that? 7 WITNESS WARD: I believe the explanations that 8 we had for the problem back in 1990 when it occurred 9 adequately explained the problem, and I still believe that 10 that is the problem is manufacturing defects in the pinch 11 caused by the caps not being flat. And the -- there had 12 not been any motivation that I am aware of to come up with 13 any other explanation. 14 You know, at that point, the vendor agreed 15 with the explanation, and we had plenty of evidence that 16 it did occur. And since we resolved that problem on the engines, we have not had a weak air roll in over five 18 years now, so, you know, I'm not sure why we would need to 19 be looking for another explanation. MR. MICHAEL KOHN: So the explanation now is 21 torquing and the caps not being flat, rather than 22 differential thermal expansion? 23 WITNESS WARD: That has always been the

NEAL R. GROSS

explanation -- manufacturing defect, which includes out of

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

24

roundness, and not flat.

2

4

5

8

9

10

11

12

13

14

16

17

18

19

20

21

22

24

CHAIRMAN BLOCH: This could be a good time for the 10-minute recess.

MR. MICHAEL KOHN: That's fine, Your Honor.

Just for the record, I'd like to just note that Mr. Ward was referring, as I understand it, to the rebuttal testimony of Owyoung/Johnston, beginning at the question on line 17, on page 14.

Is that correct?

WITNESS WARD: Yes.

CHAIRMAN BLOCH: The witness said yes.

Before we break, I'd comment that I'm interested in whether this panel can comment on the Staff testimony that was filed late yesterday. And also, on whether they can comment on the document that you requested concerning oil and weak air rolls, whether they're aware of it, whether they have knowledge of a relationship between that and the possible effect of water, because that way we can avoid a recall after you get that information.

We'll take a recess for 10 minutes.

(Whereupon, the proceedings were off the

23 record from 9:55 a.m. until 10:07 a.m.)

CHAIRMAN BLOCH: The hearing will come to

25 | order

# **NEAL R. GROSS**

# NEAL R. GROSS

WITNESS WARD: Yes.

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

3

4

5

9

10

13

14

MR. MICHAEL KOHN: Your Honor, since the Owyoung/Johnston panel testified, we would like to introduce as rebuttal documentation a demonstrative aid setting forth the FSAR requirements of other plants, with TDI diesels and the jacket water temperature set points of those diesels, to demonstrate that there is no difference between Plant Vogtle and the other diesels -- other plants. And I'm prepared to distribute this information at this time.

MP. BLAKE: It's a misnomer, it sounds to me like. You referred to this item as a demonstrative aid, and to say it's going to be put in as evidence, rebuttal evidence of something or other else, seems to me to be quite internally inconsistent. And I agree with the inconsistency.

CHAIRMAN BLOCH: It is inconsistent with how we've used demonstrative aids in the past. Demonstrative aids are valid only if they refer to admitted evidence.

MR. MICHAEL KOHN: Your Honor, the raw data, which is the basis of this demonstrative aid, is attached to it. And, therefore, we seek the introduction of the raw data attached to it. And whether the parties want to stipulate to the demonstrative aid at some point, to assist the Board in a time-consuming task, we --

CHAIRMAN BLOCH: Where are the raw data from,

## NEAL R. GROSS

1	from the Government reports?
2	MR. MICHAEL KOHN: The raw data is, yes, from
3	the FSAR and NUREG 1350.
4	CHAIRMAN BLOCH: So what
5	MR. MICHAEL KOHN: From various FSARs.
6	CHAIRMAN BLOCH: Why don't you permit the
7	Licensee to review it and see if he can stipulate to the
8	accuracy of the data. Oh, and also the Staff, that's
9	correct.
10	MR. MICHAEL KOHN: I'm certain it's something
11	they can't stipulate to at this juncture, without taking
12	some time to review it. So I
13	CHAIRMAN BLOCH: Yeah, I am, too.
14	MR. MICHAEL KOHN: propose that we just
15	move on and revisit this issue.
16	CROSS EXAMINATION (Continued)
17	MR. MICHAEL KOHN: Mr. Hill, as I understand
18	your qualifications, your area of expertise is in
19	containment and structural integrity testing and leak rate
20	testing, is that correct?
21	WITNESS HILL: Those are two areas in which I
22	have extensive experience.
23	MR. MICHAEL KOHN: Are those the areas that
24	you would consider yourself an expert?
25	WITNESS HILL: They are.
	NEAL R. GROSS

1	MR. MICHAEL KOHN: And can you tell me what
2	other areas you would consider yourself to be an expert?
3	WITNESS HILL: Testing, in general.
4	MR. MICHAEL KOHN: Are you an instrument and
5	controls engineer?
6	WITNESS HILL: I am not.
7	MR. MICHAEL KOHN: And I see that you have no
8	prior training or experience with Cooper diesels and their
9	control systems, is that correct?
10	WITNESS HILL: That is correct.
11	MR. MICHAEL KOHN: Do you consider yourself to
12	have any special expertise with respect to Cooper diesels
13	and their control systems?
14	WITNESS HILL: In terms of how the control
15	system functions to regulate the performance of the
16	diesel, no. However, that really does not enter into my
1.7	testimony.
18	MR. MICHAEL KOHN: In what area of Cooper
19	diesel operation do you think you have some expertise?
20	WITNESS HILL: In this particular case, I have
21	limited my investigations to the movement of air and water
22	vapor through the tubing and through the logic elements
23	within the control panel, and out to the sensors on the
24	diesel engine.
25	MR. MICHAEL KOHN: And do you have any

NEAL R. GROSS

1	expertise in two-phase flow?
2	WITNESS HILL: In two-phase flow per se, no.
3	MR. MICHAEL KOHN: And do you have any special
4	training or experience in fluidics?
5	WITNESS HILL: I do not.
6	MR. MICHAEL KOHN: Do you have any special
7	training or experience with respect to pneumatic control
8	systems?
9	WITNESS HILL: I do not.
10	MR. MICHAEL KOHN: And you are not a member of
11	the Instrument Society of America, is that correct?
12	WITNESS HILL: That is correct.
13	MR. MICHAEL KOHN: And as an expert, I assume
14	you are receiving compensation for your testimony?
15	WITNESS HILL: I am not compensated for my
16	testimony.
17	MR. MICHAEL KOHN: You aren't receiving
18	compensation for the work you are performing here?
19	WITNESS HILL: I'm receiving compensation for
20	doing research, evaluating data, formulating opinions and
21	conclusions based on my evaluation.
22	MR. MICHAEL KOHN: And for the time you spent
23	doing these investigations?
24	WITNESS HILL: Yes.
25	MR. MICHAEL KOHN: And can you tell me what is
	NEAL R. GROSS

the amount of compensation you have received to date, or expect to receive? 2 MR. BLAKE: I object. 3 MR. MICHAEL KOHN: Your Honor? 4 MR. BLAKE: I object to the specific numbers 5 being either inquired about or put on the record. These 6 are all commercial matters between individuals and businesses. What is the need for that? And there has been no showing of a need. If it's anything other than his normal rates, that might be a matter of inquiry. CHAIRMAN BLOCH: Why don't you ask whether 11 it's -- how it compares to his normal rates. MR. MICHAEL KOHN: Your Honor, the Federal 13 Rules specifically state that the amount of compensation 14 is relevant and discoverable. And it is customarily a 15 subject that may be gotten into. I think -- I have no 16 problem with asking -- setting forth how much his rates are and what he is charging. I'm not asking anything more 18 than that. 19 CHAIRMAN BLOCH: Why do we need to know any 20 more than whether he is collecting his normal rates for 21 this work? 22 MR. MICHAEL KOHN: Are you -- let me rephrase 23 the question. 24

Are you receiving your customary rate?

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

WITNESS HILL: I am.

1

2

3

5

6

7

8

9

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. MICHAEL KOHN: And can you tell me the total amount of time you have endeavored with respect to preparing this testimony or otherwise assisting Georgia Power?

WITNESS HILL: It's on the order of 250 hours, but that -- that figure is approximate.

## BOARD EXAMINATION

CHAIRMAN BLOCH: That's related to this testimony, the 250 hours? Or was it related to other matters as well?

WITNESS HILL: It's related to everything that I have done in conjunction with this case.

# CROSS EXAMINATION (Continued)

MR. MICHAEL KOHN: On page 2 of the testimony, you state that you interviewed several GPC employees familiar with the diesel and air start system. Can you tell me who you interviewed?

WITNESS HILL: I have discussed the diesel air start system with Ken Stokes, with Ken Burr, and with a number of people in the Vogtle I&C Department. Some of the names I can remember; some I can't.

MR. MICHAEL KOHN: And what names do you

WITNESS HILL: Mike Hobbs, Mike Duncan, Dexter

# NEAL R. GROSS

COURT R'.PORTERS AND TRANSCRIBERS 132? RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

recall?

(202) 234-4433

1	Acunde, Deborah Thames. I recall no others.
2	MR. MICHAEL KOHN: And those are the ones you
3	can recall at this time?
4	WITNESS HILL: Yes.
5	MR. MICHAEL KOHN: About how many other
6	persons do you think you interviewed?
7	WITNESS HILL: Three, four, five.
8	MR. MICHAEL KOHN: Did you take interview
9	notes?
10	WITNESS HILL: I took a few notes, but nothing
11	that I would formally call interview notes.
12	MR. MICHAEL KOHN: And is there a scope of
13	documentation you've gathered, including the notations you
14	took that you relied on when preparing your testimony?
15	WITNESS HILL: There are several documents
16	which I relied on in preparing my testimony.
17	MR. MICHAEL KOHN: My question is, your
18	interview of these persons and the knowledge you gained by
19	your visits at the sites, and your the sum total of
20	your involvement, do you believe helped provide you with a
21	background and a basis for your testimony?
22	WITNESS HILL: Certainly. The sum total of my
23	involvement is the basis for my testimony.
24	MR. MICHAEL KOHN: Okay. Did you maintain the
25	documentation that would concern the subtotal of your
	NEAL R. GROSS

(202) 234-4433

experience concerning the diesel generators? WITNESS HILL: I have maintained the drawings 2 and FSAR sections, standard review plan, ISA standard, 3 diesel building ventilation system description, and the diesel engine control system description. 5 MR. MICHAEL KOHN: How about your notes of --6 the notes that you took during this 250-hour period? 7 WITNESS HILL: No. 8 MR. MICHAEL KOHN: You didn't maintain any of 9 those notes? 10 WITNESS HILL: No, I did not. 11 CHAIRMAN BLOCH: The witness has been shaking 12 his head no. I have to say that, because it's not audible 13 for the transcript. 14 WITNESS HILL: Sorry, Your Honor. 15 MR. MICHAEL KOHN: Have you ever testified as 16 an expert before? 171 WITNESS HILL: I have been deposed as an 18 expert. I have never testified before a hearing or 19 similar proceeding. 201 CHAIRMAN BLOCH: Mr. Kohn, before you 21 continue, I'd like to comment that, to a certain extent, 22 we've had expert testimony on the meaning of plant 23 documents and regulations. And, of course, those are 24 going to be matters that we'll determine based on the 25

documents themselves. So providing, you know, what the documents say and what the regulations say, the question of what the expert says is not so important on those questions. But that's what we're going to be relying on as the primary materials.

MR. MICHAEL KOHN: Thank you, Your Honor.

Do you think you have any special expertise concerning acceptance criteria of diesel general air system?

wITNESS HILL: I do not claim to have any special expertise in the acceptance criteria. However, I do feel that my engineering background is such that if I look at the criteria, I can tell whether or not they are reasonable.

MR. MICHAEL KOHN: Do you have any special expertise with respect to ISA standards?

with respect to ISA standards in general, and ISA publishes a lot of standards. I do not claim to have any special expertise. However, many ISA standards which are within my area of technical expertise I can look at and determine whether or not I feel they are reasonable from an engineering viewpoint.

MR. MICHAEL KOHN: Do you have any special expertise with respect to effect of water on the diesel

## **NEAL R. GROSS**

1	generators? The operation of the pneumatic system?
2	WITNESS HILL: Again, I would give you the
3	same answer. Certainly, to that level of detail, I do not
4	have any special expertise on how water affects diesel
5	engine pneumatic systems. But again, I can look at the
6	control systems and determine whether or not water might
7	have a negative impact on the functioning of those
8	systems.
9	MR. MICHAEL KOHN: Mr. Ward, can you tell me
10	if you have any special expertise with respect to Plant
11	Vogtle's FSAR, interpreting FSARs?
12	WITNESS WARD: I can read the FSAR and tell
13	you my opinion of what it says.
14	MR. MICHAEL KOHN: Okay. So other than
15	were you involved in the original development of the FSAR?
16	WITNESS WARD: No, I was not.
17	MR. MICHAEL KOHN: Were you involved in the
18	licensing comparison of the FSAR with other plants?
19	WITNESS WARD: No, I was not working for
20	Vogtle at that time.
21	MR. MICHAEL KOHN: And do you have any special
22	expertise with respect to the interpretation of ISA
23	standards?
24	WITNESS WARD: No.

**NEAL R. GROSS** 

MR. MICHAEL KOHN: And I'd like to turn to

your prefiled testimony on page 6, lines 10 through 20. Before I start on this questioning, I note that the format indicates that there is -- the person providing the answer -- Mr. Hill, I have a question to you. Did you review the question and answers that you did not provide that are contained in this prefiled testimony? 6 WITNESS HILL: I have read those questions and 8 answers. MR. MICHAEL KOHN: Do you have an independent basis to provide responses to those answers? Or did you review them as to whether you would also attest under oath 11 to their accuracy? 121 WITNESS HILL: I reviewed them only insofar as they were part of the overall testimony. In most of these 14 areas, I really don't have any -- any particular 15 knowledge. MR. MICHAEL KOHN: Mr. Ward, the same question with respect to Mr. Hill's responses. WITNESS WARD: I reviewed all of the 19 responses, and for the most part I determined that I agree 20 with everything that was there. There are a fet -- few points in there that I did not dig into, particularly the 22 ISA standard. 23 MR. MICHAEL KOHN: And the fact that your name

**NEAL R. GROSS** 

does not appear by the answers, does that mean you were

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

2

3

4

5

7

9

13

16

17

21

24

not testifying about those responses? WITNESS WARD: No, that does not mean that. 2 MR. MICHAEL KOHN: So you view the testimony 3 4 BOARD EXAMINATION 5 CHAIRMAN BLOCH: What does it mean, that your 6 name is on some and not on others? WITNESS WARD: Everything in here, to the best 8 of my knowledge, is accurate. That's -- that's what it means. 101 CHAIRMAN BLOCH: But I take it that where your 11 name sn't on it you don't have the same necessity to know 12 whether it's accurate or not, is that correct? 13 WITNESS WARD: That's correct. 14 CROSS EXAMINATION (Continued) 15 MR. MICHAEL KOHN: So you haven't assessed the 16 portions of the testimony with respect to an adequate 17 factual basis or technical basis, unless your name appears 18 by the testimony. Is that an accurate --19 WITNESS WARD: Not completely. If there was 20

something erroneous in a statement that it says "Hill," I did have input into getting that resolved. But I did not go back and verify every statement that's made in those type of answers.

MR. MICHAEL KOHN: Well, then, from your

## NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

21

23

24

testimony, did you resolve prior statements that Mr. Hill 11 had in his testimony that you disagreed with? 2 3 WITNESS WARD: Yes. MR. MICHAEL KOHN: Now, we were at page 6, 4 lines 10 through 20, Mr. Hill. You state on line 17 that Mr. Mosbaugh and the ISA standard are in error. As I 6 understand it, do you agree that Mr. Mosbaugh correctly 7 quoted what the ISA standard states? 8 WITNESS HILL: That is correct. 9 MR. MICHAEL KOHN: And there is an 18 degree 10 Fahrenheit that is contained in that ISA standard, 11 correct? 13 WITNESS HILL: That is correct. 13 MR. MICHAEL KOHN: And now there is also a 14 7.8 degree -- negative 7.8 degree Centigrade mentioned as 15 well, correct? 16 WITNESS HILL: That is correct. 17 MR. MICHAEL KOHN: And do you think it stands 18 to reason -- excuse me. Your testimony is that they don't relate, but you state which one you think is right. What 201 is your basis for determining that the 18 degree 21 Fahrenheit is wrong? 22 WITNESS HILL: My testimony doesn't state that 23 either one is correct or either one is wrong. I do not 24 know which one the writers of the ISA standard intended to 25

govern, but whichever one it is it doesn't relate to the other. 2 MR. MICHAEL KOHN: Well, did you make any 3 inquiry to determine the answer to that question? 4 WITNESS HILL: No, I did not. I should add, 5 though, that it's pointed out in the testimon; the ISA 6 standard is really not applicable to the diesel air start system, so it was merely an observation on my part, in 8 reading through Mr. Mosbaugh's testimony, and then later reading the ISA, that the Centigrade and Fahrenheit numbers were incompatible with one another. 11 MR. MICHAEL KOHN: Well, do you think you had 12 an obligation to find out from the persons responsible for 13 drafting the ISA standard what the correct number was? 14 CHAIRMAN BLOCH: Mr. Kohn, he already said he 15 16 didn't get it. MR. MICHAEL KOHN: And on page 9, lines 6 17 through 12 of the testimony, with respect to start 134 of 18 the diesel generator, you indicate that Mr. Mosbaugh's 19 prefiled testimony was in error, because he was referring 20 to a high jacket water pressure sensor, rather than a low 21 jacket water pressure sensor, is that correct? 22 WITNESS HILL: Are you asking the question of 23 me? 24

MR. MICHAEL KOHN: To either.

# **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

whether that was referring to a low jacket water pressure sensor or a high jacket water temperature sensor, I don't know. It seems reasonable that it would be one of those two. But whether the use of the word "pressure" is incorrect, or the use of the word "high" is incorrect, would be pure speculation on my part, too.

MR. MICHAEL KOHN: Well, did either of you gentlemen review Mr. Mosbaugh's testimony in its entirety to determine that elsewhere he specifically states when discussing this start that it was the low jacket water pressure sensor?

was the original prefiled testimony of Mr. Mosbaugh, the one that was submitted in the April/May timeframe. I have not reviewed the retyped version of that, so I don't know. But there were so many errors in that I did not know -- I did not attempt to go through and pick out all of the differences in statements in there, if that's what you're asking.

MR. MICHAEL KOHN: Well, my question is based on your prior review of a draft of Mr. Mosbaugh's testimony. Are you well aware of the fact that elsewhere in his testimony he correctly references the low jacket water pressure sensor with respect to start 134?

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

WITNESS WARD: No.

2

3

5

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MR. MICHAEL KOHN: I'd ask you to turn to page 12 of the prefiled testimony, lines 17 and 18.

Mr. Hill, I believe this is your response, and you state, "Each sensor is supplied through a 0.006 inch orifice located in the control cabinet." Which sensors are you referring to when you use the word "heat sensor"?

withigh pressure crank case, low pressure turbo oil, low pressure jacket water, high vibration, high temperature engine bearings, and high temperature lube oil.

MR. MICHAEL KOHN: And how many sensors, in total, then, would you be referring to?

WITNESS HILL: That should be six. Yes, six.

MR. MICHAEL KOHN: And then there would be an orifice with response to each one of these six?

WITNESS HILL: That is correct.

MR. MICHAEL KOHN: Do you have any knowledge of whether there is more than one low pressure turbo oil sensor?

WITNESS WARD: I'd like to answer that.

MR. MICHAEL KOHN: I'm asking Mr. Hill for his knowledge at this time.

WITNESS HILL: I am aware that there are

# **NEAL R. GROSS**

multiple sensors on the engine. However, the drawings show a single trip line coming back to the cabinet. And I presume that that trip line T's when it gets closer to the engine and runs to two or more sensors in perhaps one or two cases. MR. MICHAEL KOHN: So is there an orifice with respect to each sensor, or not? WITNESS HILL: In accordance with the drawings, there are only six orifices, and those six orifices serve trip lines which go out to these categories of sensors. How many sensors there actually are on the engine, I do not know, but the drawing shows six orifices. MR. MICHAEL KOHN: So you haven't looked at that detail? WITNESS HILL: I have not looked at the configuration on the engine itself. I was concerned with the orifices which are in the control cabinet. MR. MICHAEL KOHN: Do you know -- can you give me an estimate of how many total sensors you think would 19 be associated with the six orifices you were referring to? WITNESS HILL: Well, perhaps as many as 10, but that's pure speculation on my part. I was only concerned with the number of tubes running out of the

MR. MICHAEL KOHN: Is it possible that the

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

cabinet to the engine.

1

2

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

21

22

23

24

drawing you were looking at shows a typical arrangement 1 rather than the specific arrangement? 2 WITNESS HILL: That's highly unlikely. 3 BOARD EXAMINATION CHAIRMAN BLOCH: Would it surprise you if 5 there were 19 sensors involved, rather than the six? 6 WITNESS HILL: I would not be surprised, no. 7 CHAIRMAN BLOCH: Would it affect your 8 testimony? WITNESS HILL: It would not. The number of 10 sensors is not the concern, Your Honor. It's the number 11 of orifices in the control cabinet, and what is beyond the 12 control cabinet is -- doesn't enter into the calculation, other than it provides a leakage path for air to pass 14 continuously through the orifice. 15 CROSS EXAMINATION (Continued) 16 MR. MICHAEL KOHN: On page 7 of the prefiled 17 testimony, Mr. Hill, you mention on lines 12 and 13 about 18 radiating heat, diesel radiating heat. Is that correct? 19 WITNESS HILL: That's mentioned in the 20 testimony, yes. 21 MR. MICHAEL KOHN: And later on, on page 8, 22 lines 6 through 11, you mention that the heat from the 23 diesel would keep control air lines from cooling, even in 24

**NEAL R. GROSS** 

the presence of ventilation flow. Is that accurate?

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

WITNESS HILL: Yes, that is.

MR. MICHAEL KOHN: Well, how hot are these diesel surfaces?

CHAIRMAN BLOCH: What's the line on page 6, Mr. Kohn?

MR. MICHAEL KOHN: Lines 6 through 11. It's page 8, Your Honor.

CHAIRMAN BLOCH: Thank you.

witness Hill: With the diesel shut down, the engine surfaces are extremely warm to the touch. You can put your hand on it. It's very uncomfortable to hold it there for any length of time. With the diesel operating, it would, of course, be warmer and probably impossible to hold your hand on it without getting blistered. So I presume, based on information that I've seen on the keep warm systems, that the engine surfaces are going to be on the order of 150 degrees Fahrenheit when the engine is shut down.

MR. MICHAEL KOHN: Well, how about the lines further away from the diesel, say 10 feet away? Do you think there is going to be any effect on those?

witness HILL: There are lines alongside of and on top of the diesel which would be exposed to air that is drawn in through the louvers on the outside wall of the building. However, any lines that are any distance

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

3

4

5

6

7

8

9

12

13

15

16

18

19

201

21

22

23

1	from the diesel are inside a covered trench which runs
2	from the diesel engine location to the control panel
3	location. These lines are insulated from any air flows.
4	MR. MICHAEL KOHN: What is your I haven't
5	had the opportunity to visit the diesel room,
6	unfortunately. How far is this radiant heat from the
7	diesel spanning? I've been told if you walk by it, you
8	can feel the radiant heat. Is that true?
9	WITNESS HILL: If you walk fairly close to the
10	diesel, you know you're adjacent to something that's quite
11	warm.
12	MR. MICHAEL KOHN: And a diesel is what, 12 by
13	40 feet on one side, or something like that?
14	WITNESS HILL: It's 12 feet high, 40 feet
15	long, possibly. I don't think it's quite that long, maybe
16	30.
17	MR. MICHAEL KOHN: And have you been on the
18	back side of the diesel?
19	WITNESS HILL: Yes, I have.
20	MR. MICHAEL KOHN: Okay. And can you feel the
21	radiant heat back there?
22	WITNESS HILL: I have been completely around
23	the diesel, so one of those sides would qualify as the
24	back side. However, if you would clarify which side
25	you're referring to, I'll be able to answer the question
	NEAL R. GROSS

better.

2

3

5

6

7

8

10

11

12

13

14

15

16

17

18

201

21

23

25

CHAIRMAN BLOCH: Mr. Kohn, are you sure you have a point to make here? There is an awful lot of "I feel warmth around the diesel," which doesn't seem very helpful at all.

MR. MICHAEL KOHN: I guess back side -- is there a wall closest to the diesel?

WITNESS HILL: Yes. The east wall of the building is six, eight feet from the engine.

MR. MICHAEL KOHN: All right. And would you -- let's look at that one, then, as the back wall. How much radiant heat would be there?

WITNESS HILL: At the wall itself?

MR. MICHAEL KOHN: Yes.

WITNESS HILL: Can't tell you.

MR. MICHAEL KOHN: But would you expect there to be some?

Whether or not you would sense it in walking by, which I think is the way most people would look at it, if you were hard against the wall, I don't know. Certainly, if you were walking in the passageway, clear of the equipment on racks which is much closer to the engine, walking between that equipment and the engine you do feel the heat.

MR. MICHAEL KOHN: Do you know where the

## **NEAL R. GROSS**

1	temperature switches that control the fans are located for
2	the diesel, the normal HVAC fans?
3	WITNESS HILL: The normal HVAC fan, to the
4	best of my knowledge and I have not personally verified
5	that it's there is on the east wall of the diesel
6	building, about mid-length on the engine and approximately
7	five feet off the floor.
8	MR. MICHAEL KOHN: You're referring to the
9	wall that we were discussing earlier?
10	WITNESS HILL: Yes, I am.
11	MR. MICHAEL KOHN: Have you ever considered
12	the fact that radiant heat from the diesel could affect
13	the operation of those temperature switches based on their
14	location?
15	CHAIRMAN BLOCH: I'm sorry. Which temperature
16	switches are you talking about?
17	MR. MICHAEL KOHN: The normal HVAC temperature
18	switches controlling the fans.
19	CHAIRMAN BLOCH: Do you mean that it would
20	make it harder for the fans to come on, is that what
21	you're asking him about?
22	MR. MICHAEL KOHN: Making the I'm not
23	asking that exact question, Your Honor, no. But
24	CHAIRMAN BLOCH: Please try to make sure that
25	you understand, intellectually, the relationship between
	NEAL R. GROSS

your case and the questions you're asking. I'm not seeing it at all right now. 2 MR. MICHAEL KOHN: Okay. And do you have --3 are you aware of any -- do you think it's possible that the heat from the engine may make the switch think that it 5 needs to turn the fans on? WITNESS HILL: Well, Mr. Kohn, I -- I can say 7 with certainty that if you have any source of radiant 8 heat, there will be some effect, measurable perhaps, perhaps too small to measure, at a very large distance from that source. As to just what effect the diesel 11 engine might have on the switch, I would not even begin to 12 speculate because I've made no temperature measurements in 13 14 the diesel building. BOARD EXAMINATION 15 CHAIRMAN BLOCH: Does that mean that you can't 16 place an upper bound on it either? 1.7 WITNESS HILL: Well, I could place an upper 18 bound on it, Your Honor. 19 CHAIRMAN BLOCH: That could be helpful. What 20 is the maximum number of degrees that it could affect the 21 thermostat? 22 WITNESS HILL: That distance from the engine,

I would say that not more than five or 10 degrees.

CHAIRMAN BLOCH: And that's based on the laws

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

23

1	of thermodynamics? Is that what you're trying to do in
2	your head right now?
3	WITNESS HILL: No. That's based on a
4	judgmental gut feeling.
5	CHAIRMAN BLOCH: Well, how much reliance
6	should we place on your judgmental gut feeling about 10
7	degrees at that distance?
8	WITNESS HILL: Well, that's not a hard number.
9	That's a gut feeling number.
10	CHAIRMAN BLOCH: So it could be more than
11	that?
12	WITNESS HILL: Conceivably.
13	CROSS EXAMINATION (Continued)
14	MR. MICHAEL KOHN: And how about if the diesel
15	was running as you indicated, it got very hot, hot
16	enough to blister your hand. Let me withdraw that.
17	MR. MICHAEL KOHN: So I take it from your
18	testimony you're not aware of any temperature survey that
19	shows the actual temperature variations in the diesel
20	room?
21	THE WITNESS: That's correct.
22	BY MR. MICHAEL KOHN:
23	Q Mr. Hill, I'd like to call your attention to
24	lines 16 through 22 of the pre-filed testimony, page
25	seven. Are with respect to these group temperature
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

(202) 234-4433

(202) 234-4433

reaches 85 degrees and then turns off when it reaches 65 degrees, is that the conditions that existed in 1990? 2 The 85 degrees set point existed in 1990. The 3 65 degrees set point, I'm not sure about. That is the current set point. What the set point was actually 5 positioned to in 1990, I don't know. Well, why would you be testifying about 7 current and not 1990 set point? 8 The set point drawing that existed in 1990 9 shows 85 degrees as the temperature at which the fans come on, 85 plus or minus, I believe 2.5. 11 The lower set point is indicated as 85 minus 12 1.25 degrees plus or minus 2.5. That is incorrect. It 13 14 was corrected by a drawing change notice, which has currently been incorporated into a drawing rev. 15 However, that drawing change notice was issued 16 sometime after 1990, and I do not know what actual set 17 points were -- were set, what the actual lower limit set 18 point on the fans was in 1990. It was either 20 degrees 19 below as it should have been or 1.25 degrees below, which 201 is improbable. 21 And the drawing change you're referring to 22 occurred in 1995. Is that correct? 23 I will have to check that. I believe the 24 drawing revision was made in 1995. The drawing change 25

NEAL R. GROSS

notice which accompanied the previous revision may have 1 been in 1994, 1993, but I will have to check that later. 2 BOARD EXAMINATION 3 CHAIRMAN BLOCH: If that's all it is, you 4 don't have to bother to tell us. If it's -- after 1993, 5 that's fine. We don't know the -- we don't need the 6 7 specific times. THE WITNESS: Yes, it was certainly after 8 1990, or it was certainly after the April time frame in question in 1990. 101 BY MR. MICHAEL KOHN: 11 So your testimony then on page seven, starting 12 on line 16, has no relationship to how the diesel was 13 actually functioning in the 1990 -- the HVAC was actually functioning in the 1990 time frame. Is that correct? 15 MR. BLAKE: Objection, asked and answered. 16 He's described how he came by the numbers. He has described what the relationship could have been in 1990. 18 He has answered this. 19 BOARD EXAMINATION 20 CHAIRMAN BLOCH: I think you did state that 21 you're not aware of what the actual practice was at the 22 plant. Is that correct? 23

**NEAL R. GROSS** 

THE WITNESS: I have not checked the actual

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

practice.

24

# BY MR. MICHAEL KOHN:

	Q	A	nd wh	en you	prepa	red th	is test	cimony, v	were you
aware	of	this	1.25	degree	s set	point	in the	e diagram	n that
you me	ent	ioned	?						

A Yes, I was.

Q And can you tell me why you did not include that factorial information in your pre-filed testimony?

MR. BLAKE: Objection. Are you seriously asking him why he didn't point out that the different might have been 20 degrees lower or it might have just been 1.25 degrees lower?

MR. MICHAEL KOHN: Yes, I am specifically asking him why his testimony indicates it's 20 degrees different rather than the 1.25 degree difference.

MR. BLAKE: He's already answered the question. He said it was highly improbable that they set it 1.25 degrees below the 85.

CHAIRMAN BLOCH: He has said that, and also the 20 degrees is more conservative because it will allow the room to get colder.

MR. BLAKE: Well, I wish I had thought of that.

## BY MR. MICHAEL KOHN:

Q Mr. Hill, I'd like to call your attention to the effect of water in the control logic at page 15 of

## NEAL R. GROSS

NEAL R. GROSS

1	if the pneu	matic elements which are designed, the
2	pneumatic l	ogic elements which are designed to fill it up
3	with air we	re completely filled with water
4	Q	I understand that portion of your testimony.
5	My testimon	y is
6		CHAIRMAN BLOCH: Your question, your question,
7	yes.	
8		BY MR. MICHAEL KOHN:
9	Q	Thank you, Your Honor. My question is would
10	you agree th	hat several ounces of water could cause a
11	malfunction	sufficient enough to trip the diesel?
12		MR. BLAKE: Would you let him answer this
13	question en	tirely too, please?
14		CHAIRMAN BLOCH: I understand the frustration
15	though. You	seem to be answering something else.
16		BY MR. MICHAEL KOHN:
17	Q	You can answer that with a yes or no and give
18	me an explan	nation.
19	А	I would agree, yes.
20	Q	All right. And such a trip could occur on
21	emergency st	eart. Would you agree with that also?
22	A	Yes.
23	Q	On page 14, line 22, you mentioned the term
24	"memory eler	ments." Can you tell me how they work?
25	A	I would have to refer back to the control
		NEAL R. GROSS

system manual to give you an accurate description of how 1 the memory element works. It basically responds to a 2 setting until that setting is changed. 3 It remembers the last pulse it received and 4 5 will maintain passageway opened or closed until it receives a signal to alter that. 6 But to give you a more coherent description of 7 how the memory element works, I would have to refer back to the diesel system, the manual, the section that covers 9 the diesel controls. 10 Based on your understanding of the memory 11 12 elements -- and I assume you previously had looked at this 13 14 A Oh yes. -- document? Okay. Could water interfere 15 with the operation of a memory element? 16 Oh yes, it could. 17 On page -- let me back up for a second. Could 18 19 the effect on the memory element be such that it would restrict or eliminate the make-up air feeding the trip 20 line? 21 Yes, it would certainly slow it down. 22 Page nine, lines 22 through 24 of your pre-23 filed testimony, I believe you -- Mr. Hill, you interpret 24 ISA standard that it would apply to the dew point

**NEAL R. GROSS** 

measurements taken after the pressure dropped from 250 to

**NEAL R. GROSS** 

any part of this system, that is the only part that I

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

25

would apply it to. CHAIRMAN BLOCH: Mr. Kohn, if he answers once, 2 that's enough. 3 MR. MICHAEL KOHN: I'm going to ask the 4 witness to look at Intervenor Exhibit No. 11. 5 MS. YOUNG: Mr. Kohn, just in case that 6 exhibit that has not been marked, you might want to 7 officially mark it now. 8 MR. MICHAEL KOHN: This is one of the 9 stipulated exhibits. Your Honor, at this time, Intervenor 101 would like to mark for the record Intervenor's Exhibit 11, 11 which is a four-page document, "Quality Standard for 12 Instrument Air ISA." 13 CHAIRMAN BLOCH: What do you want to do with 14 this? 15 MR. MICHAEL KOHN: I'd like to mark it as 16 Intervenor's Exhibit II-11. 17 CHAIRMAN BLOCH: Yes, it may be marked. 18 (Whereupon, the above-identified 19 document was marked as Intervenor's 20 Exhibit No. 11 for identification.) 21 BY MR. MICHAEL KOHN: 22 Mr. Hill, is this the standard that you were 23 referring to in the portion of your testimony we're looking at on page nine, lines 22 through 24? 25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

ISA 7.3? It's a very poor copy, but I would 1 2 say that yes, it is the same. BOARD EXAMINATION 3 CHAIRMAN BLOCH: Do you know whether or not 4 this is the version that was in effect in 1990? 5 THE WITNESS: I've only seen one copy of this, 6 Your Honor, or one version. And that is the -- probably 7 the one here, 1975. 8 CHAIRMAN BLOCH: Thank you. THE WITNESS: I do not know that it's ever 10 been revised. 11 ADMINISTRATIVE JUDGE CARPENTER: Dr. Hill, if 12 I can ask on line 20 on page nine, you testify: "If, 13 however, I were going to apply this standard." Do you 14 have any expectation that you're going to apply? 15 THE WITNESS: No. 16 ADMINISTRATIVE JUDGE CARPENTER: Why are you 17 testifying about what would happen if you were to do 18 something when you don't expect to do it? 19 THE WITNESS: I'm not going to. 20 ADMINISTRATIVE JUDGE CARPENTER: Where are you 21 leading us, sir? 22 THE WITNESS: This paragraph is responding to 23 a comment in Mr. Mausbaugh's testimony that the dew points 24 in the diesel air start system do not meet the ISA 25

**NEAL R. GROSS** 

standard. Of course, the ISA standard is not committed to 1 2 in the design of the diesel air start system. And this was just a further ad lib that even 3 if one were to apply the ISA standard, it would only be 4 applied to the lower pressure portion of the system. The 5 higher pressure portion of the system is basically 6 service-type air. 7 It's designed for moving the pistons in the 8 diesel engine, working air. It's not instrument air. 9 CHAIRMAN BLOCH: Hold on just one second, 10 please. The Board has concluded that it needs a ten 11 minute break just to relax. 12 (Whereupon, the proceedings went off the 13 record at 11:04 a.m. and resumed at 11:21 a.m.) 14 CHAIRMAN BLOCH: The Board had a little 15 conference concerned about the hearing. It's not an 16 engineering concept. It's a legal concept. 17 We're convinced that the root cause of the 18 1990 incident is not a part of this proceeding. And that 19 while it may be relevant to some of the other questions, 20 for the most part we can't see why findings on what water 21 would do within the diesel is relevant to the contentions 22 that we've allowed in this proceeding. 23 Mr. Kohn, am I wrong about that? 24 MR. MICHAEL KOHN: Well, I wouldn't say you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

wrong about it, Your Honor. My problem is that Georgia 2 Power has been filing a lot of rebuttal testimony as to that effect. 3 CHAIRMAN BLOCH: Well, you can continue cross 4 examining on it, but we're going to throw away the 5 6 findings on the subject. So --7 MR. MICHAEL KOHN: I -- I would --CHAIRMAN BLOCH: Unless we're wrong, making a 8 9 ruling --MR. MICHAEL KOHN: Making a concern, raising a 10 concern that we were afraid that they were getting into 11 that in their rebuttal testimony a while down the road, 12 13 but --CHAIRMAN BLOCH: Well, I can assure that we're 14 not going to make findings on the root causes of the 1990 15 incident, except to the extent that it relates to whether 16 or not Georgia Power was misrepresenting things to the 18 NRC. So the severity of what would happen from 19 moisture is weakly, if at all, relevant to anything. MR. MICHAEL KOHN: I'll try to assess that, 21 you know, as I'm going through the questioning. It might 22 require a lunch break to better --23 CHAIRMAN BLOCH: I wasn't just speaking of 24 you. We don't expect to get findings from the Staff or 25

**NEAL R. GROSS** 

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

the Licensee that we'll be acting on on root causes of the 1990 incident either.

Somehow, we've just gone adrift and have heard a lot about that. But I don't see why it's relevant to the immediate issues.

MR. MICHAEL KOHN: Well, I would agree, Your Honor. And I think Intervenor's testimony on that was stricken. But Licensee and NRC Staff have been doing a lot of filing on that. So I thought -- myself for crawling out of a hole.

MS. YOUNG: Judge Bloch, I think we've got a situation where, if the Board is able to understand the accuracy of communications that were going on in 1990, that all the parties, to a certain extent, have felt an obligation to explain the significance of information that may or may not have been included in those communications.

And when you do that, you run the risk of coming against some of the Board's clear rulings in the motion ruling on GPC's Motion for Summary Disposition, i.e., where the root cause of the March event is an issue that's probably within the scope of this proceeding.

But to understand the concerns about was air quality acceptable in 1990, it's been important from the standpoint of the parties to explain what are the consequences of moisture problems in the machinery.

## **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

CHAIRMAN BLOCH: Okay, does the Staff take the view that it's relevant to the disclosures made to it that understanding the true perspective on moisture affects whether or not Georgia Power should have gone back to say that its instrument wasn't effective if it wasn't effective?

MS. YOUNG: I don't think the Staff is saying that. It was trying to be responsive, and I think GPC also, to Board questions that have been raised throughout the proceeding about what is the significance of the criteria for dry air, what are the consequences for moisture in the system.

CHAIRMAN BLOCH: I'm saying maybe we went too far on that also.

MS. YOUNG: That could be.

CHAIRMAN BLOCH: You may want to reflect further on whether this is relevant to admitted issues.

You're saying the Staff is afraid it might be relevant or just to things that the Board has been discussing?

MS. YOUNG: It's questions that have been raised in the testimony of many individuals on air quality in this proceeding: Mr. Ward, Mr. Bochold, Mr. Stokes. I can go down the litany if I was prepared to.

But I think throughout that testimony, questions have been repeatedly raised about what's the

## **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

significance of moisture, what's the significance of the conclusion on the acceptable air quality, and what's the need for this criteria of dry air meeting the 35 degree dew point level.

And all of this testimony has grown out of

And all of this testimony has grown out of that to try to explain the significance of Intervenor's hypothesis for the possibility that condensation of moist air inside the system could have caused problems in March of 1990.

CHAIRMAN BLOCH: All right, let's press on.

If anyone thinks they can use the comments we've made to 
later, let's do it. But let's continue.

BY MR. MICHAEL KOHN:

Mr. Hill, before the break, we left off, I believe, at page nine, lines 22 through 24 of your testimony. And I think you've had an opportunity now to review the ISA standard referred to there?

A Yes, I have.

Q Did you consider Section 3.2 found on page three of four of Intervenor's Exhibit 11 when you provided your response found on page nine?

A No, I didn't, Mr. Kohn. The intent of this paragraph was not really to suggest that the ISA standard should be applied to any portion of the diesel air start system.

## NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

The intent was merely to show that the ISA standard does require a margin between the dew point of the air in the system and the surrounding ambient temperature. And that margin is maintained in the low pressure portion of the system and would prevent any condensation from occurring in that portion of the system.

The reference to the ISA standard in the testimony is perhaps unfortunate. But it was really intended to apply only to the fact that the ISA requires the maintenance of that margin, and that margin is easily

Q Well, then would you agree your interpretation of the ISA standard, as stated in your testimony, conflicts with Section 3.2?

A I was not attempting to interpret the ISA standard. I was merely --

maintained within the 60 psi portion.

#### BOARD EXAMINATION

CHAIRMAN BLOCH: You know, I think, as I read the testimony, you were, in line 19. And then you were also on line 21. In line 19, you say, "The ISA standard does not govern," and in line 21, you said, "It would apply only to actual control elements." Are those interpretations?

THE WITNESS: Well yes, Your Honor. I said

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

3

4

5

6

7

8

12

13

15

161

18

19

20

21

22

23

24

the the wording there is unfortunate. But my intent on
writing this paragraph was only to point out, perhaps I
didn't do that very well, that the margin between dew
point temperature and ambient temperature is maintained in
the that's required by the ISA standard is maintained
in the lower pressure portion of the system.
Now I realize that
CHAIRMAN BLOCH: You seem to say more. Would
you like to tell us how you would like us to modify it so
that it doesn't say more than that?
THE WITNESS: Yes sir. I would say that the
temperature margin if I were going to apply the
temperature margins required by the ISA standard, I would
apply those only to the low pressure portion of the
system. That was really the intent.
CHAIRMAN BLOCH: Mr. Kohn?
BY MR. MICHAEL KOHN:
Q Mr. Hill, the standard, the ISA standard,
assumes the margin associated with the pressure reduction,
doesn't it, when it gives the dew point measurement?
CHAIRMAN BLOCH: Could we go right to the
section?
MR. MICHAEL KOHN: Yes, Section 3.2. The dew
point measurements to be taken, according to the ISA
standard, are to occur before pressure reduction. Is that

**NEAL R. GROSS** 

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

correct? At line pressure, they're supposed to be taken. THE WITNESS: Well again, Mr. Kohn, the intent 2 of this paragraph -- and I tried to convey that by saying 3 that I'm not considering applying the ISA standard to the diesel air start system. 5 But if I were going to consider applying the 6 pressure or the temperature margin requirements, which are given in the ISA standard, I would apply those only to the 9 60 psi air. And if one does apply those pressure for 10 temperature requirements to the 60 psi air, they are 11 easily met. 12 BY MR. MICHAEL KOHN: But that's not what it says, and that's not the definition applied to the ISA -- in the ISA standard 15 with respect to dew point measurements, is it? 16 I realize that. And as I say, the wording of 17 this paragraph is unfortunate, but it was never intended to mean that I would apply the ISA standard in its entirety to any portion of the diesel air start system. 201

Well, is the methodology in which you applied this ISA standard similar to how you would go about applying other standards and codes?

MR. BLAKE: Again, I object. I don't understand what that question can conceivably mean.

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

13

14

21

22

23

24

Haven't we heard enough about this? The witness's position on this, I think, is 2 pretty clear. At this point, we're becoming argumentative 3 and repetitious. 4 CHAIRMAN BLOCH: Do you want to strike the 5 sections dealing with interpretation of the codes? 6 MR. BLAKE: I am prepared to -- on that. CHAIRMAN BLOCH: Mike, do you want to be heard on that? MR. BLAKE: I think the second and third 10 sentences in there are what have led to the confusion, "If 11 you were going to apply it, " et cetera. But I don't think 12 that the first sentence is appropriately stricken. 13 MR. MICHAEL KOHN: Your Honor? 14 MR. BLAKE: In view of whether or not it 15 applies, I think it's perfectly appropriate. 16 MR. MICHAEL KOHN: We --17 CHAIRMAN BLOCH: My problem is you can't apply 18 the standard as it says in Section 2. If you applied the 19 standard, you would have to apply it at the dryer and not in the line. 21 MR. BLAKE: I understand that that's the 22 position that you apparently have, and that's the position 23

NEAL R. GROSS

the Intervenor has. But it's not the position that the

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

witness has.

He says because of the rest of the system doesn't have anything to do at all with anything called instrument air. Even if you wanted to call a portion of this diesel air system "instrument air," it would only be the 60 pound portion of it.

And that's where you've started, compressor or no compressor. It's all kind of silly. And I'm willing to eliminate the last couple of sentences if you want to, but not the first sentence where he says, "It doesn't apply." And that's his view.

MR. MICHAEL KOHN: Well, we don't want to -CHAIRMAN BLOCH: How do you feel about that?

MR. MICHAEL KOHN: That we would not want any
portion stricken. It's either all testimony --

CHAIRMAN BLOCH: That's fine. Let's continue.
BY MR. MICHAEL KOHN:

Q My question is you state, "If I were going to apply the standard," and then you go on to apply it. Is this indicative of how you would normally interpret and apply standards with respect to nuclear installations?

A No, this is not. And again, I did amend my statement there to say that if I were going to apply the temperature margin requirements of the standard, I would apply that only to the air supplied to the control elements.

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1	Q I'd like to call your attention, Mr. Hill, to
2	page nine, lines one through three, of the testimony. You
3	mention that the receiver was not warm to the touch. Is
4	that correct?
5	A That is correct.
6	Q And did you have an opportunity to touch the
7	air receiver in the 1990 time frame?
8	A I did not.
9	Q And so your observations are based in what
10	time frame?
11	A It was June of 1995.
12	Q And how other than one was this one
13	observation in June of '95?
14	A It was one observation on two separate
15	receivers at the same time.
16	Q Two separate receivers in the same
17	A Yes, two receivers in the 1-A diesel room
18	within a few minutes of each other.
19	Q And you state on line that same portion,
20	that the air receivers quickly returned to ambient room
21	temperature. In terms of minutes, what do you mean by
22	"quickly?"
23	A Ten, 15, 20 minutes.
24	Q Your Honor, I would like to mark as
25	Intervenor's II-258, a three-page document consisting of a
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

(202) 234-4433

1	chart headed, "DG-1A Air Receiver VO-2 Temperaturized Air
2	Compressor Cycle," and pages two and three consisting of a
3	headed, "Unit 1-A Train."
4	CHAIRMAN BLOCH: So what's the source of the
5	data in this?
6	MR. MICHAEL KOHN: Of the pages two and three
7	of the exhibit?
8	CHAIRMAN BLOCH: No, all of the pages. If two
9	and three are from the Licensee, what's page one from?
10	MR. MICHAEL KOHN: That has been prepared
11	it's a plot of the data that we believe we can
12	demonstrate.
13	CHAIRMAN BLOCH: Well, I just asked where the
14	data is from, and you said it's a plot of the data
15	MR. MICHAEL KOHN: I'm sorry. The data points
16	are approximately 12 and four minutes excuse me, all
17	three data points, the are contained in the
18	documentation attached.
19	CHAIRMAN BLOCH: These are all the values
20	given by the Licensee?
21	MR. MICHAEL KOHN: That is correct. And I
22	don't believe
23	CHAIRMAN BLOCH: This may be marked as
24	Intervenor II-258.
25	(Whereupon, the above-identified

NEAL R. GROSS

21

22

23

25

document was marked as Intervenor Exhibit No. II-258 for identification.)

#### BY MR. MICHAEL KOHN:

Q Mr. Hill, based on the data that I presented, do you have any way to figure out how much time it would take for the temperature rise, in terms of minutes, to return to the ambient temperature?

A In looking at this plot, Mr. Kohn, the temperature rise shown here from the estimated time that the compressor started until 12 minutes after the compressor stopped is only about 1.2 degrees.

And what I'm referring to in the testimony is sensations from touching the receiver. And you know, frankly, I don't think I would get any sensation from a one or two degree temperature change.

Q And according to the only data available that we're aware of, the temperature is still rising after a period of 18 minutes from when the compressor started. Do you have any way of knowing how much longer this rise in temperature is going to occur?

A No, I do not.

Q Have you done any calculation or have your observations allowed you to monitor the actual rise in temperature from the time the diesel started until it was

## NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

**NEAL R. GROSS** 

a reading taken seven minutes after first reading. It's 1 on the left-hand side. 2 ADMINISTRATIVE JUDGE CARPENTER: Thank you for 3 helping me. 4 MR. BLAKE: I need some time to take a look at 5 what he has -- this first page is some graph in which we 6 need an opportunity to check on before I think this exhibit should be admitted since there's no sponsor for 9 it. CHAIRMAN BLOCH: Motion to defer the ruling is 10 accepted -- is granted. 11 MR. MICHAEL KOHN: You have any estimate or 12 any -- when you would be able to give us an answer? 13 MR. BLAKE: No. I suspect we could probably 14 look at it over the lunch hour and be prepared after which 15 to cross examine him. 16 CHAIRMAN BLOCH: It could be admitted on the 17 understanding that this is just a placing of the three 18! points, and that the line itself has no proven 19 significance in this proceeding. 20 MR. BLAKE: I just need an opportunity, Judge, 21 to take a look at it. 22 BY MR. MICHAEL KOHN: 23 Mr. Ward, when is the first time you recall 24 touching the air receivers? 25

**NEAL R. GROSS** 

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

I don't have a specific date, but I have been 1 involved -- I was involved in the Farley diesel start-up 2 since '75. And then I moved to Vogtle. 3 And I -- my practice, when I go through the 4 plant, is to lay hands on things to feel temperature and 5 vibrations and stuff like that. So I've been feeling diesel air receivers since about 1975. 7 (Laughter) 8 9 BY MR. MICHAEL KOHN: And is it your estimation that these air 10 receivers are usually in the 90 degree temperature range 11 for Vogtle, Plant Vogtle? 12 They're not normally warm to the touch. 13 They're normally about air temperature. 14 Well, does that mean you've touched them when 15 they have been warm to the touch? 16 If the receiver -- if the air compressor is 17 running, sure, they're -- they're a little warm. But it's 18 not easy to -- I mean, it's not something that would burn 19 20 your hand. And would the temperature of the air receivers be determined how frequently the air compressor was run? 22 No. It's the other way. The frequency of the 23 24 air compressor running determines the temperature. 25 And do you have any knowledge of how

1	frequently the air receivers were running in 1990
2	excuse me, the compressors were running in 1990?
3	A On a particular day or
4	Q In general during the March 1990 time frame.
5	A Well, I know we did an overhaul on each of the
6	engines in 1990. And as part of that, we completely
7	depressurized the air system and opened it to atmosphere.
8	When we repressurized it, it would run
9	probably several hours to bring the pressure back up to
10	normal temperature. But once it got the system recharged
11	and we weren't using it, then they would not cycle very
12	often, a period of hours between times in the cycle.
13	If we were testing a running engine, then they
14	would start often.
15	Q Your Honor, the next subject I'd like to cover
16	would probably take a little more than 15 minutes to noon.
17	I'd like to start I'd like to accomplish it now, but it
18	would require going a few minutes after 12:00.
19	CHAIRMAN BLOCH: Okay. Let's hope that your
20	estimate is fairly accurate.
21	BY MR. MICHAEL KOHN:
22	Q Mr. Ward, I'd like to call your attention to
23	page 18 of your testimony, of the pre-filed testimony.
24	A Okay.
25	Q And starting at line 13, you are discussing

1	Appendix I to NUREG 1410. It's my understanding that you
2	worked on Response Appendix I in preparation for the
3	September 1990 NRC Enforcement Conference. Is that
4	correct?
5	A Yes, I worked on a presentation.
6	Q And at that time, you challenged the NRC's
7	list in Appendix I?
8	A Yes.
9	Q And if I understand it, you will not admit
10	that any of these Calcon sensor failures were precursors
11	to the site area emergency identified in Appendix I?
12	A I did not say that, no.
13	Q Well then, are some of the failures, in your
14	estimation, precursors of the site area emergency?
15	A Yes.
16	Q And which ones, turning to Appendix I, do you
17	believe would be precursors to the site area emergency?
18	A In my Exhibit B, I gave what I believe was the
19	best explanation that could be developed on each of the
20	line items that was in Appendix I. And some of them
21	and I could go through and pick out specific examples or
22	we could go through every page.
23	But some of the calibration problems that we
24	had experienced in earlier outages or in between cutages,
25	I believe if we had picked up on the calibration

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

techniques and the criticality of doing the calibration properly on the switches, and also the importance of -for the problem of getting foreign debris in the switches and causing them to leak and trip prematurely, I believe if we had picked up on that problem in earlier outages, in my mind, they were precursors to the problems we had in '90.

And we could have corrected them earlier if we had picked up on them.

- Q So when -- are you saying then there was a failure to identify and report what appears to be precursors to the site area emergency failure?
  - A I don't understand your question.
- Q Would you -- was there a failure on the part of Georgia Power to identify and report Calcon sensor failures -- let me rephrase it. Was there a failure by Georgia Power Company to identify, report, and take corrective action with respect to Calcon sensor failures prior to the site area emergency?

A No. I believe the -- we did take some -- we did make an attempt at resolving the problem, and we got a new revised calibration technique from Calcon sometime in late '89, early '90 time frame that did incorporate that into the calibration practices.

Unfortunately, that was not enough. But I

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND A /ENUE, N.W. WASHINGTON, D.C. 20005

1

2

3

4

5

6

8

9

10

11

13

14

16

17

18

19

20

21

22

23

24

it in great detail and have provided a response, correct? 1 2 That's correct. It's my understanding you supervised in the 3 creation of preparing Exhibit B. Can you tell me what you 4 mean by "supervised?" 5 I started off having an employee go through --6 7 Can you identify the name, please? Jonathan Waltrip, to go through the two 8 A notebooks of MWO information that had all of the work orders that were used to generate the Appendix I list, and to extract some information from them to -- Appendix I 11 does not give work order numbers. It does not give switch 12 numbers. 13 It just gives a generic description of a 14 diesel generator and a date and a -- and a switch type. 15 And as I pointed out before, there are a lot of errors in 16 there. And it's -- you can't take a particular item in 17 Appendix I and go pin it down to something specific. 18 So I had Mr. Waltrip go through and look at 19 each of the items in Appendix I and try to correlate it as best he could to an MWO and a switch number. And then I 21 went back, I took that initial list and went back and did 22 all of the technical review of the data and what he had 23 done to make sure it was accurate. 24

BOARD EXAMINATION

## **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

CHAIRMAN BLOCH: Mr. Ward, let me re-ask the question that I asked before in light of Appendix B, your Appendix B. Did you notice in Appendix B there was only one of all the reports that might have been made in which there was a resolution where you found out what happened? Could you tell me how you would answer that question? THE WITNESS: Could I ask which one that is? CHAIRMAN BLOCH: Well, I'm not sure. But if there's more than one -- you mean, you think there's none? From Appendix B, I thought there was one, but I'm not sure I still know what it is. THE WITNESS: I think -- I'm still not sure I understand the question. But I think for many of the problems reported in Appendix I, if you go back and look at the history of that switch and what had been done to it previously, if anything, you can develop a sense or a -some appreciation of the repetitive nature of the switch problems that we were having. For the temperature switches, it was apparent to me, looking at all of the data points, that there was a -- that there was a pattern.

CHAIRMAN BLOCH: Okay. But what I was -- what I was talking about was the root cause determinations

# **NEAL R. GROSS**

prior to the site area emergency. And I was commenting

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

that if you looked at the paper, no one had figured out anything about root cause prior to the site area emergency. You're saying you can find the root cause now.

Am I correct that no one had found it prior to

Am I correct that no one had found it prior to the site area emergency?

engineer and someone at INC, I'm not sure who, had concluded that there was a problem in calibrating the temperature switches back in the latter part of 1989, and had requested Calcon to develop some guidance for how to better calibrate them.

And what I saw in doing my review is that that

-- that suspicion was founded because we would -- as an

example, in the first refueling outage on unit one, which

was the fall of 1988, the switches had been installed in

the engine and everything had functioned fine.

We -- we took the engine out for overall, took the switches off and did a calibration. And then a very short period of time afterwards, a week or two, something in that time frame, there was another work order reporting problems with the switches that we had just calibrated.

And if you look at the trend on them, one time they would be found out of calibration in one direction, either high or low. And in the next problem, they would

## **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

2

3

5

7

11

12

13

14

15

16

17

18

19

21

22

23

be in the opposite direction. 2 3 4 5 6 resolve it, but --7 the work orders? 8 9 10 11 12 13 14 15 appreciation for --16 17 plant document? 18 19 20

So there was a pattern of up and down trying to adjust the switches in to get it to the right set point. And I believe in general, the system engineer appreciated that there was a problem and was trying to

CHAIRMAN BLOCH: Was this reflected in any of

THE WITNESS: Yes. The --

CHAIRMAN BLOCH: Which ones? That is the appreciation for the trend.

THE WITNESS: I don't believe -- I don't believe the appreciation is in there. The specific problem is there, but I don't think there is a general

CHAIRMAN BLOCH: And was the system engineer's request for a new calibration procedure reflected in any

THE WITNESS: I believe there's a memorandum. Kenny Stokes was involved in it, but I don't know if it was a telephone call or a --

> CHAIRMAN BLOCH: But no deficiency paper? THE WITNESS: Not that I recall.

CHAIRMAN BLOCH: Shouldn't there have been?

THE WITNESS: Probably would have -- should

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

21

22

23

24

have been.

2

3

4

5

9

10

11

12

13

14

15

16

17

1.8

19

20

21

22

23

24

25

CHAIRMAN BLOCH: And why is it that the new calibration procedure was still defective and that the engineers at the plant didn't know that?

THE WITNESS: Well, the new one was only implemented -- the revised part of it was only implemented immediately before the March 1990 outage. So the first application of that procedure was on diesel 1A during the outage.

CHAIRMAN BLOCH: Well, I assume that an engineering review of a new calibration procedure would take place before it was implemented, not after.

THE WITNESS: It was. It was put into effect in the January time frame.

CHAIRMAN BLOCH: Was there an engineering review of that procedure before it was put into effect?

THE WITNESS: I believe the system engineer instigated the revision. So yes, there was an engineering review.

CHAIRMAN BLOCH: So the change in the plan procedure would have had to have been signed off by the system engineer?

THE WITNESS: No, the change -- the change itself would have been solved -- signed off by the -- either the INC superintendent or the maintenance manager

## NEAL R. GROSS

with prior reviews.

And INC procedure writer would initiate the procedure revision, you know, with a memo or an evaluation from the system engineer for what to change. And then it would go through a review process of at least two independent, or different, reviewers.

Adn probably the system engineer would see it at some phase of there. But he participated in the instigation of the procedure change.

CHAIRMAN BLOCH: But should it have been caught that the new procedure wasn't adequate? Was it a slippery matter that you couldn't easily --

THE WITNESS: No, it was -- basically, we took the information that was provided from the vendor, Calcon, on how to upgrade the procedure. So --

CHAIRMAN BLOCH: But that's not adequate without an independent review. You said there were two independent reviews.

THE WITNESS: The independent one would have been the writer of the procedure and an independent reviewer. And then the third person would have been the approver, either a superintendent or a manager.

CHAIRMAN BLOCH: Was it a tough thing to catch that the procedure still didn't correct the problem?

THE WITNESS: Well, I think so because, you

# **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

know, we had a deficiency and we had gotten information from a vendor on how to correct this procedure involving his component. And that's what we did with the procedure, 3 and that was still deficient. And I'm not sure anybody at our site or the 5 vendor, at that time, had an appreciation on the importance of stabilizing the switch at calibration 7 temperatures or for checking for cleanliness. 8 And those were the two areas where we actually 9 had problems after -- or during the March '90 problem and 10 subsequent to that. 11 CHAIRMAN BLOCH: Well, it says some problem about the spacer tube. Isn't that correct? 13 THE WITNESS: There was a question about the tightness of the spacer tube, but we did not find that, in my recollection, on any of the switches. 16 There was a question that if it was loose, it would affect it. 18 CHAIRMAN BLOCH: How would you have found it 19 if you didn't check for it? 201 THE WITNESS: We would not have. CHAIRMAN BLOCH: But you changed the procedure because it could have been a problem, right? 23 THE WITNESS: Right.

**NEAL R. GROSS** 

CHAIRMAN BLOCH: It just concerns me when

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

2

6

12

14

15

17

21

22

24

procedures are changed without someone thinking through 1 whether the new change is adequate; someone from your 2 plant, not just someone from the vendor. 3 THE WITNESS: Right. I agree. 4 CHAIRMAN BLOCH: Mr. Kohn? 5 BY MR. MICHAEL KOHN: 6 Isn't it true at the time of the site area 7 emergency, the plant was still using the generic 8 procedure, not the one prepared by Calcon? 9 There was an attached instruction sheet 10 specifically related to these switches that had been added 11 at the time of the site area emergency. 12 BOARD EXAMINATION 13 ADMINISTRATIVE JUDGE MURPHY: I don't 14 understand that answer. 15 THE WITNESS: The procedure itself was a 16 generic procedure for temperature switches. The procedure 17 revision, and I -- what we had -- what we added for these 18 specific switches was a -- I guess 1 would call it a 19 supplemental instruction sheet on what to do, on how to 20 use that procedure for Calcon temperature switches. 21 And that was attached, you know, with the 22 procedure to the work order for doing the calibrations. 23 So it was not a rigorous, formal procedure at 24 that time, just for those switches, like it subsequently 25

NEAL R. GROSS

was and should have been at that time probably. 1 34 MR. MICHAEL KOHN: 2 So if this supplemental installation 3 instruction sheet was used in that time period, we would 4 expect to see it incorporated in the NWO package? 5 Yes. 61 All right. 7 0 BOARD EXAMINATION 8 ADMINISTRATIVE JUDGE CARPENTER: Mr. Ward, 9 have you ever thought it would have been helpful if 10 somebody had looked at the Calgon -- Calcon literature, 11 which talks about a temperature sensor? And it says that 12 the devices that they sell are used as pressure 13 transducers. 14 And then somebody wouldn't apply a generic 15 calibration procedure for electrical temperature switches 16 that instruct the individual, first of all, to disconnect 17 the electrical leaves from the mechanical device. 18 And my fellow Board members fuss at me for 19 being a fuddy-duddy, but I really think there's a 20 difference between -- you must have a lot of other 21 temperature switches around the plant for there to be a 22 generic procedure. 23 But it just -- it's totally inapplicable to 24 25 this mechanical device.

NEAL R. GROSS

THE WITNESS: I think so. I think it was inapplicable.

ADMINISTRATIVE JUDGE CARPENTER: Plus the people who were trying to -- responsible for the tender loving care of this device were entirely trained in electronics and electrical background. And there was nobody looking over their shoulder, that I can see, with any background that this was a mechanical device and I'd better take it apart and figure out how it works, and why it keeps failing.

Do you get that sense at all?

THE WITNESS: Well, the --

administrative Judge Carpenter: They just drifted along, as you say. There weren't any problems for a while, so people ignored it. Then you had an outage and these people got their hands on it and did bad things to it.

And then you had troubles. And then there was a quiet period. But all the way along, no one with even a little broader perspective than an INC supervisor ever looked into the problem.

And I don't think what I'm asking about is in this hearing. But if you want to answer, you can.

THE WITNESS: Well, it's a pretty long question, but I think -- your first point about the

## NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

2

3

6

8

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

procedure, I agree with that. Using a standard, generic procedure that was -- that should be appropriate for simple electronic devices was inappropriate for this case and for a pneumatic-type instrument.

The INC technicians, they do work on pneumatic -- pneumatic equipment in other parts of the plants, for example, the air operated valves. They do all the set-ups on the positioners and controllers for the air operated valves in the plant. So they do have experience with pneumatics.

So I would have expected them, you know, if they had had any concern on how to calibrate it using an electronic-type procedure, I would have expected them to have identified that.

ADMINISTRATIVE JUDGE CARPENTER: With a deficiency on the procedure?

THE WITNESS: Either with a deficiency or more a request for a separate stand-alone procedure. I believe they felt like the device was simple enough that the -- really the generic procedure, the only thing it would -- the only really non-skilled craft information it should have would be the set point and the reset point.

I believe it's what they thought. And that applies to electronic or pneumatic or whatever other type of temperature device that they would have in-hand. And I

## **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

#### **NEAL R. GROSS**

didn't it?

2

3

4

5

6

7

9

11

12

13

15

16

17

18

19

20

21

23

24

25

A Yes.

Q Can you explain why the diesel tripped at that point after a second revision to the procedure was implemented?

A It was not a second revision. This was a new stand-alone procedure. We did not use the generic procedure at that point. We used a new procedure.

Q Well if I understand it, there was a generic procedure, and then there was some supplemental sheet attached to the generic procedure. And now there was a new specific procedure during that evolution.

Can you tell me why the diesel would trip when you were using your new, finalized procedure?

A With the new, finalized procedure, we still had not recognized the importance of temperature stabilization and repeating the heat up and cool down of the switch the same way every time when we calibrated it.

We had -- we had recognized that it was important and that temperature had a problem. But unfortunately, the way the new stand-alone procedure had been written, and I forget the exact words, but it did not require us to cool the switch back off to the normal diesel operating temperature of around 165 between each set point check or set point adjustment.

# NEAL R. GROSS

It allowed us to -- it required us to start at 165 to get the switch thermally stabilized, and then increase the temperature at a certain rate and check the switch set point.

But then if it was out of calibration, it did not require us to make an adjustment and then cool it back down and then reheat it up to recheck it. It said to make the adjustment in some other general words. I don't remember exactly what.

But the problem with that sequence was if the switch was originally out of adjustment and required adjustment, it kept the switch at an elevated temperature long enough that it then affected the set point.

Q Were you aware that in the May 1990 trip, the first time you're using your new procedures, when INC went out to test what result -- what caused the trip and diesel trip began, that the Calcon sensors were not venting?

A I'm aware of the -- I'm aware of that statement that has been made on the work order.

Q And if, in fact, the Calcon sensors were not venting, would that indicate to you that the cause of that trip may not have been the calculate -- the calibration procedures of the Calcon sensors?

A No.

BOARD EXAMINATION

**NEAL R. GROSS** 

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE IS' AND AVENUE, N.W.
WASHINGTON, D.C. 20005

CHAIRMAN BLOCH: Could you explain? 1 THE WITNESS: The -- I believe the -- that 2 note that said that the switches were not venting was made 3 the -- that check was made -- it was not made immediately 5 when the diesel tripped. It was some time period after the diesel had 6 tripped, and I'm not sure where that information came 7 from. 8 CHAIRMAN BLOCH: Where did your information 9 come from about when that observation was written? THE WITNESS: In conversations with Kenny 11 Stokes and Ken Burr. I believe there was some concern that the -- we may not have even been checking the right 13 switches. The guy who did that and wrote that may not have even been looking at the right switch. 15 BY MR. MICHAEL KOHN: 16 So are you saying that the INC personnel that 17 were checking switching during testing don't even know 18 what the right switches are that they're supposed to be 19 checking? 20 That one data point, that one entry on that 21 work order is an entry that I questioned. 22 BOARD EXAMINATION 23 CHAIRMAN BLOCH: is there a procedure for 24

NEAL R. GROSS

correcting a work order when you know that something is

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

erroneous on it?

THE WITNESS: Not that I'm aware of. I mean, we can't go back and modify the work order itself. About all we could do is, you know, write a -- write an explanation or an addendum.

And we could write a deficiency card, but that would be a stand-alone piece of paper.

CHAIRMAN BLOCH: It sounds like a stage in which you're forever bound to trip something that's not real.

THE WITNESS: Yes. Before the work order was closed out, whomever wrote it could have gone back and written on -- struck through and initialled and dated it and corrected it.

But once it goes into the records, there's really no mechanism for changing that data.

CHAIRMAN BLOCH: Since the purpose of the MWR was to figure out what's happening, does that seem appropriate to you, that you can't change something after it's closed when you've learned it's erroneous?

THE WITNESS: We can supplement it, but we can't change the records. That's --

CHAIRMAN BLOCH: Again, you can have a supplement that that record that shows that that piece of data was incorrect?

## **NEAL R. GROSS**

THE WITNESS: Yes.

2

5

6

7

8

11

12

13

15

16

17

18

19

20

22

23

25

BY MR. MICHAEL KOHN:

Q When did you and Mr. Stokes and Mr. Burr have this discussion that you were referring to?

A As recently as this summer and on any number of instances before that. You know, this goes back over five years.

But I believe I first heard about that, you know, within a week or two of the problem happening, you know?

I think at that time, it was -- we were trying to sort through what had happened on those trips. And we sent the switches off again to Wiley and got them -- you know, we went through a test program again with Wiley Labs.

And I believe I remember hearing about this discrepancy at that time. So I don't recall having seen it written down in a work order until a long time afterwards, months or years.

Q So if I understand it, the discrepancy is that the observations of the INC personnel did not jive with the Wiley report. Is that what you're saying?

A Well, the Wiley -- the Wiley report did not address the whole trip sequence.

Q Okay. Then what is it about the Wiley report

#### **NEAL R. GROSS**

that called into question the observation of the INC personnel?

A The as felt set points at Wiley under what I believe were very controlled conditions showed that the switch, the actual switch set for us, were down in the range of -- between 165 to 170, if I remember, maybe even a little lower, 162.

The date -- on the engine, they should have been leaking slightly or should have been tripped. And in particular, when they were tripping the engine, one or more of them should have been venting.

And to say that they were not venting, you know, is not --

#### BOARD EXAMINATION

CHAIRMAN BLOCH: Mr. Ward, is there any way that an INC technician would know whether or not a switch was venting during an event?

THE WITNESS: If there was an INC technician stationed on top of the diesel --

(Laughter)

THE WITNESS: I mean, that's where the switch is, is on top of the diesel or three of them actually at that time. And the only way that he could actually tell that it was venting was with the -- by either snooping or feeling air blowing out around the vent, little vent,

## **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

3

8

12

14

15

16

17

18

19

20

exit, plug. 1 That would have been his only way to tell. 2 CHAIRMAN BLOCH: Well, did that happen? There 3 was someone up there snooping the Calcon during the event? 4 5 THE WITNESS: Not during, but I believe the 6 INC techs came after the trip. 7 CHAIRMAN BLOCH: Well, it wouldn't still be 8 venting after the trip, would it? 9 THE WITNESS: No. 10 CHAIRMAN BLOCH: So how would they even dream 11 about whether it was venting after the event where it 12 mattered? 13 THE WITNESS: Well, I believe what happened on 14 the work order, somebody just wrote down something to the 15 effect, "Switch is checked and not venting." 16 CHAIRMAN BLOCH: I mean, does that show a lack 17 of intelligence? Why is it relevant that they weren't 18 19 venting after the event? THE WITNESS: I'm not sure it is relevant. I 20 think it was someone's attempt to get some data on what 21 was happening. 22

BY MR. MICHAEL KOHN:

Q Aren't you aware that the switches were tested and the snoop was applied prior to venting during a

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

23

24

1	subsequent trip to the diesel generator, that the INC
2	position technicians were pre-positioned assuming that
3	there would be a venting?
4	A That was for which start?
5	Q The
6	A I think there were about five or six
7	Q second I think the second start on May
8	23, 1990.
9	A Would you ask the question again?
10	Q Weren't you aware that INC technicians were
11	pre-positioned and applying snoop to determine when the
12	second trip of the diesel generator was occurring on May
13	23, 1990, whether those Calcon sensors were venting?
14	A I don't know if they were there on the second
15	one or not.
16	CHAIRMAN BLOCH: Do we know, Mr. Kohn is
17	there anything in the record that tells us whether or not
18	that's the event we're talking about?
19	MR. MICHAEL KOHN: Yes, Your Honor. We're
20	looking for th? + exhibit. And when we take a
21	(Pause)
22	MR. MICHAEL KOHN: Your Honor, I call the
23	witness's attention to Intervenor's Exhibit No. 37. When
24	is the first time you recall seeing this document?
25	THE WITNESS: I don't remember the first time.

## NEAL R. GROSS

#### BY MR. MICHAEL KOHN:

Q Do you have any reason to believe that this document prepared by Georgia Power Company is inaccurate?

I can rephrase the question. Do you have any reason to believe that this document accurately portrays what the persons associated with the testing of the diesel generator in the May 1990 time frame observed?

A I believe the 1312 data or the entry having to do with 1312, the note under there, I question the accuracy of that note.

## BOARD EXAMINATION

CHAIRMAN BLOCH: Mr. Ward, I noticed you said before you said something about they might have been at the wrong switch. This switch, this sensor, this appears to say that they snooped them all and that none of them vented.

Does that change your opinion as to the error?

THE WITNESS: Well, the -- there are -- there

are 20 or more sensors on the engine. And unless we had,

you know, a large number of INC technicians out there, it

would take a period of time to do it.

In some of them, like the jacket water temperature, do not -- they do not continue to -- once they trip, they don't vent air indefinitely.

So it may have been, and again I'm

## **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVENUE, N.W.
WASHINGTON, D.C. 20005

1	speculating, but it may have been that we did not check
2	all of them prior to some of them having reset.
3	I don't know, I was not there. But I
4	CHAIRMAN BLOCH: Would you have to be looking
5	at the time it happened to be able to detect the signs of
6	a of a venting on the snoop?
7	THE WITNESS: Yes.
8	CHAIRMAN BLOCH: When you see you have to
9	be there at the time it's happening? You wouldn't see
10	that later?
11	THE WITNESS: No, it would from the time it
12	tripped until the air was cut off to that switch, which is
13	there is a time delay involved in that. But
14	CHAIRMAN BLOCH: You have to have
15	THE WITNESS: it's some seconds. Once that
16	goes away, then the switch is not going to vent anymore.
17	CHAIRMAN BLOCH: And there would be no signs
18	left on the snoop?
19	THE WITNESS: Right.
20	CHAIRMAN BLOCH: Have we reached a time for
21	lunch, Mr. Kohn?
22	MR. MICHAEL KOHN: Yes, we have, Your Honor.
23	CHAIRMAN BLOCH: So, we'll return at two
24	o'clock.
25	(Whereupon, the proceedings went off the
	NEAL R. GROSS

record for a lunch break at 12:27 p.m. and resumed at 2:02 p.m.)

**NEAL R. GROSS** 

(2:02 p.m.)

2

4

5

6

10

11

12

13

14

15

16

17

18

19

21

22

23

24

25

CHAIRMAN BLOCH: Mr. Kohn?

MR. MICHAEL KOHN: Thank you, Your Honor.

CROSS EXAMINATION

MR. MICHAEL KOHN: Mr. Ward, we left off discussing the May 23, 1990 trip. Were you also aware that when the trip came in on that time there were -- no enunciators were lit?

WITNESS WARD: You're referring to the second

MR. MICHAEL KOHN: That is correct.

WITNESS WARD: No, I'm not. I'm not aware of

that.

trip?

MR. MICHAEL KOHN: You said you had some discussions with Mr. Burr about this May 23 trip, is that correct?

WITNESS WARD: Yes.

MR. MICHAEL KOHN: I'm going to show you a portion of Mr. Burr's deposition.

CHAIRMAN BLOCH: Off the record.

(Whereupon, the proceedings went off the

CROSS EXAMINATION (continued)

MR. MICHAEL KOHN: Let me back track a bit and

## NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

record briefly.)

again show you exhibit 37 with respect to page one of that 1 exhibit, the 1312 entry. And you note what alarms came 2 in. Do you see a jacket water -- high temperature jacket 3 water alarm coming in? WITNESS WARD: This sheet says alarms (a) low 5 pressure turbo lube oil, (b) low jacket water pressure. 6 MR. MICHAEL KOHN: But no high temperature 7 jacket water alarm? 8 WITNESS WARD: This sheet does not say -- it 9 says (a) and (b) as I read. 10 MR. MICHAEL KOHN: And at the same time the 11 technicians observed no venting? Isn't it true that no 1211 alarm would be consistent with no venting? 13 WITNESS WARD: Yes. 14 BOARD EXAMINATION 15 CHAIRMAN BLOCH: Mr. Ward, do you have some 16 reason to believe that the alarm was received? 17 THE WITNESS: I don't know, Judge. I have not 18 reviewed this. I did not review this as part of my 19 preparation for this hearing, and I didn't cover it in my prefiled testimony. It's been a long time since I've 21 looked at this. 22 CHAIRMAN BLOCH: Okay, but if I understand you 23 correctly in response to my question, you don't have any 24 reason to believe that an alarm was received for high 25

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

jacket water temperature, is that right? THE WITNESS: I don't have any reason to 3 believe either way. MR. MICHAEL KOHN: Your Honor, the next 4 portion would be -- show the witness Mr. Burr's deposition 5 6 on pages 141, lines 21 -- starting at line 21. CHAIRMAN BLOCH: Sorry, we don't have Mr. 7 Burr's deposition. 8 MR. MICHAEL KOHN: I understand that, Your 9 Honor. I was going to have this marked to refresh the --CHAIRMAN BLOCH: Do you have copies? 11 MR. MICHAEL KOHN: No, I don't, Your Honor. 12 CHAIRMAN BLOCH: Well, let's take a brief 13 recess while you make copies. (Whereupon, the proceedings went off the 15 record from 2:10 p.m. until 2:12 p.m.) 16 MR. MICHAEL KOHN: Your Honor, I'd like to 17 mark as Intervenor's 259 a two page document consisting of 18 a cover page of Mr. Burr's deposition of May 24, 1994 and 19 a second page which has multiple pages covered from a 20 portion of 141 to 147. CHAIRMAN BLOCH: It will be marked as 22 Intervenor's II-259. 23 (Whereupon, the above-referenced 24 document was marked as Intervenor's 25

**NEAL R. GROSS** 

## 2

## 3 4

## 5

## 6 7

## 8

## 10

## 11

## 12

## 13

## 14

## 15

## 16

## 17

## 18

## 19

## 20

#### 21

## 22

## 23

## 24

## 25

# Exhibit II-259 for identification.)

## CROSS EXAMINATION (continued)

MR. MICHAEL KOHN: Mr. Ward, I'm going to call your attention to page 141, line 21, which would be the first page portion on the top left. Do you -- and do you see line 21 begins, "Question: Now as I understand it, this is talking about the second trip is that on May 23rd, we're talking about -- " and Mr. Burr agrees that's what we're talking about.

And later on, on page 142 at lines two through seven, Mr. Burr agrees that his understanding was that there was bubble solution applied and that based on the snooping, they could not detect a vent. Now previously you testified that you had some conversations with Mr. Burr and Mr. Stokes. Do you believe this testimony of Mr. Burr correctly states his understanding of the events?

MR. BLAKE: I have an objection to that question. If he wants to ask does this refresh his recollection of the conversation or assist him to remember, I think that's quite appropriate.

CHAIRMAN BLOCH: Sustained.

MR. MICHAEL KOHN: Can you tell me if this discussion by Mr. Burr in this deposition transcript helps refresh your recollection of Mr. Burr's understanding of the events that transpired?

#### **NEAL R. GROSS**

MR. BLAKE: No, that didn't cure my problem. 1 CHAIRMAN BLOCH: Mr. Ward, does this refresh 2 your recollection of this event? 3 THE WITNESS: I need to read it all first. 4 Okay, I've read this, and this is Mr. Burr's recollection 5 of what happened four years earlier, and now my 6 recollection of what he told me what happened five years 7 earlier -- I'm not sure they agree with each other, but 8 I'm not -- I can't say for sure what happened. I was repeating earlier what I remembered having been brought up 10 in discussions with Mr. Burr and Mr. Stokes in the past. 11 But I take this for what it is, his 12 deposition. 13 MR. MICHAEL KOHN: And on page 143, it 14 indicates -- starting on 142, line 19, and then on to 143, 15 line ten, Mr. Burr indicates that he could not explain 16 that there was no enunciation for the high temperature 17 jacket water alarm. 18 CHAIRMAN BLOCH: So what's the question? 19 MR. MICHAEL KOHN: Did Mr. Burr discuss that 20 phenomena with you previously? 21 THE WITNESS: Not that I recall. 22 MR. MICHAEL KOHN: Your Honor, we call for 23 the admission of the portions of the testimony identified 24 Mr. Burr's testimony, page 141. 25

**NEAL R. GROSS** 

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

MR. BLAKE: No, I object to this. Now, this is a fairly -- and I'd like to say a little bit about this practice. And I think this is totally outside any kind of appropriate evidentiary approach to decision making. You have a witness on the stand, (a); you bring up a topic the witness doesn't remember; you confront him with a deposition of witness B, and you say to him does this help you -- he says no.

He says I'd like to now put it in for evidence of what it is B said. B's not here, B's actually been here in this proceeding and had an opportunity to talk with him but opted not to. Just this very weekend, we've gone over whether or not B would have to reappear. The answer was no. This is not an appropriate way to get in evidence of what B's thoughts were or weren't on this topic.

I oppose the admission of this document.

CHAIRMAN BLOCH: The objection is sustained.

MR. MICHAEL KOHN: Your Honor, I'd like to respond, if I may. Mr. Ward testified about his conversations with Mr. Burr. That is -- he testified what Mr. Burr's recollection was when Mr. Burr wasn't here, and he -- at this point, he said that Mr. Burr's understanding was different than what his deposition testimony is. I cannot impeach Mr. Burr's conversations with Mr. Ward

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

THE WITNESS: Let me get this out of my way.

## NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

Okay.

MR. MICHAEL KOHN: Do you have a recollection at this point about the diesel generator trips occurring in January 1990 associated with Calcon sensors? Outside of what's in Exhibit B, do you have any independent understanding about trips in January associated with -- CHAIRMAN BLOCH: You just changed the question.

MR. MICHAEL KOHN: Let me rephrase the question.

MR. MICHAEL KOHN: Do you have any independent knowledge of a trip of the diesel generator occurring in January of 1990 that is associated with a Calcon sensor failure that is not included in Exhibit B?

witness ward: I don't have any recollection,

MR. MICHAEL KOHN: I'm going to show you -- or I can read into the record I believe a portion of your testimony that should appear on June 8, 1990 at page 7976 or thereabouts.

MR. BLAKE: I'd like to see it, and I'd like to see what's around it.

CHAIRMAN BLOCH: Mr. Kohn, we all need copies.

(Whereupon, the proceedings went off the record briefly.)

#### **NEAL R. GROSS**

## CROSS EXAMINATION (continued)

MR. MICHAEL KOHN: What I would prefer doing is just read the question and answer and see if that refreshes his recollection.

MR. BLAKE: I'd prefer that you show the witness the document so he can get the setting of what it was being discussed at that point and let's -- then just ask him whatever you want.

MR. MICHAEL KOHN: Mr. Ward, if you would look at the portion of the June 8 testimony that I've given you. Can you look at the highlighted portions and read the question and answer into the record, please?

#### BOARD EXAMINATION

CHAIRMAN BLOCH: You may study the area around it before you do that. You may want to state for the record whose testimony it is, too.

THE WITNESS: Okay, the earlier questions had had to do with dryer maintenance as a precursor to the site area emergency. And then the highlighted question, the question is, --

CHAIRMAN BLOCH: I'm sorry, I couldn't hear that. The earlier questions had to do with dryer something?

THE WITNESS: Yes, this is a --

CHAIRMAN BLOCH: Dryer maintenance?

## **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1

2

3

4

6

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

20.00

1	THE WITNESS: This is Board Examination by
2	Chairman Bloch. And then the question jumps to, "Were you
3	aware of unexplained trips of the diesel generator which
4	occurred on January 3, 1990?"
5	And my answer is, "There were some in January.
6	I don't remember that that was the date."
7	CROSS EXAMINATION (continued)
8	MR. MICHAEL KOHN: Does that refresh your
9	recollection that you are aware of some unexplained trips
10	of the diesel generator in January of 1990?
11	WITNESS WARD: Yes, but that was not your
12	original question. You said due to Calcon sensors.
13	MR. MICHAEL KOHN: Well, do you have an
14	independent recollection that those trips in January 1990
15	were due to Calcon sensors?
16	WITNESS WARD: No, I do not.
17	MR. MICHAEL KOHN: Would you look at Exhibit B
18	to your testimony, the entry 3.36?
19	WITNESS WARD: Okay.
20	MR. MICHAEL KOHN: And we're looking at a
21	January 3, 1990 entry. And your response is that "no
22	records of the above problem was found on this date." Is
23	that a true statement?
24	WITNESS WARD: The response there as I know it
25	is correct. No record I cannot find a record of this
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

NEAL R. GROSS

CHAIRMAN BLOCH: -- your issues of this help

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

you with?

MR. MICHAEL KOHN: Well first, it helps with the credibility questions with respect to this witness and his testimony.

CHAIRMAN BLOCH: All right, let's continue.

MR. MICHAEL KOHN: Your Honor, Intervenor requests to mark as Intervenor's II-260 a compilation of documents, the first page being a January 29, 1990 cover letter and the attached enclosure. That's the second page. And the third page being a diesel completion sheet. The fourth page, the fifth page -- the fourth and f''th page being pages from a July 20, 1994 filing by Licensee, and the sixth and seventh pages being an attached chart to that filing.

And the last two pages, I believe, being handwritten notes of Mr. Ward. And Intervenor requests that this document be marked as Intervenor's II-260.

CHAIRMAN BLOCH: Granted.

(Whereupon, the above-referenced document was marked as Intervenor's Exhibit II-260 for identification.)

BY MR. MICHAEL WARD:

MR. MICHAEL KOHN: Mr. Ward, would you agree that this January 29, 1990 filing by Georgia Power on invalid diesel generator failures would be -- constitutes

## **NEAL R. GROSS**

1	documentation that the January 3, 1990 diesel failure is a
2	result of a Calcon sensor problem?
3	WITNESS WARD: Yes.
4	MR. MICHAEL KOHN: Was this document available
5	to you at the time you prepared your testimony?
6	WITNESS WARD: It was obviously available, but
7	I did not see it, no.
8	MR. MICHAEL KOHN: And the next document is a
9	diesel generator completion sheet. Does this document
10	indicate that the cause of the failure was associated with
11	a Calcon excuse me, the cause of the diesel trip is
12	associated with the Calcon sensor failure?
13	WITNESS WARD: Which sheet are you referring
14	to?
15	MR. MICHAEL KOHN: The third page in of the
16	document headed Completion Sheet 1. And if you'd look
17	about halfway down, it says in handwriting, "Sensor
18	failed, slowly venting."
19	WITNESS WARD: Yes.
20	MR. MICHAEL KOHN And was this document
21	available to you when you prepared Exhibit B?
22	WITNESS WARD: The document was available.
23	All documents were available. I did not see the document
24	did not locate the document.
25	MR. MICHAEL KOHN: And on July 20, 1994 in a

filing to this Board, there is a list. And if you would turn to the start contained in the listing for 1/3/90. Does that -- did those entries indicate to you that the cause of the failure was a result of a Calcon sensor failure? CHAIRMAN BLOCH: I didn't understand the question. MR. MICHAEL KOHN: Let me rephrase the question. Does the document headed Georgia Power Company's Response to the Board's Memorandum and Order, Board Questions and Concerns, dated July 9, 1994, which includes a chart of diesel starts and in particular with respect to the January 3, 1990 diesel start, does this chart indicate to you that the reason for the trip was associated with the Calcon sensor failure? WITNESS WARD: That's what the chart indicates, yes. MR. MICHAEL KOHN: And last, I'd like to call your attention to the last two pages of the document. Is this your handwriting appear on the document -- it says history of Calcon sensor problems at Vogtle? WITNESS WARD: Yes. MR. MICHAEL KOHN: And if you would look at the bottom, there's a J with a 3.36 next to it. Do you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

see that?

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	WITNESS WARD: Yes.
2	MR. MICHAEL KOHN: And what would refer to the
3	paragraph we have been looking at?
4	WITNESS WARD: Right.
5	MR. MICHAEL KOHN: And above just before
6	the line in the middle of the page, there's another J
7	turbo oil pressure sensor defective, do you see that?
8	WITNESS WARD: Yes.
9	MR. MICHAEL KOHN: And that's also referring
10	to this 3.36 paragraph, is that correct?
11	WITNESS WARD: I believe so, yes.
12	MR. MICHAEL KOHN: Does it refresh your and
13	if I understand it, this documentation was prepared to
14	help your presentation before the NRC, is that correct?
15	WITNESS WARD: Yes, it was.
16	MR. MICHAEL KOHN: Intervenor calls for the
17	admission of II-260.
1.8	CHAIRMAN BLOCH: Granted.
19	(Whereupon, the above-referenced
20	document, previously marked as
21	Intervenor's Exhibit II-260 for
22	identification, was received in
23	evidence.)
24	MR. MICHAEL KOHN: I'd like to refer you to
25	page 17 of the prefiled testimony. I'm sorry, I think I
	NEAL R. GROSS

1	need to back track a second. Let's look at the entry 3.31
2	in Exhibit B to your testimony. Were you aware that with
3	respect to the documentation associated with this Calcon
4	sensor failure that non-conforming high jacket water
5	temperature switches were installed in the diesel
6	generator?
7	WITNESS WARD: At what point in time?
8	MR. MICHAEL KOHN: To support operability.
9	WITNESS WARD: Would you repeat the question,
10	please?
11	MR. MICHAEL KOHN: Were you aware that high
12	jacket water temperature switches were taken off the
13	diesel, were tested, determined to be out of calibration
14	and were then reinstalled in the diesel to support
15	operability?
16	WITNESS WARD: Yes, that's what my response to
17	3.31 says.
18	MR. MICHAEL KOHN: And does that give you
19	cause for concern?
20	WITNESS WARD: Yes, it does.
21	MR. MICHAEL KOHN: And what action have you
22	taken?
23	WITNESS WARD: These particular switches were
24	replaced in 1989. My review on this was done in 1995. It
25	was not an operability question in 1995. The problem at

**NEAL R. GROSS** 

the plant had been resolved for more than six years. 1 MR. MICHAEL KOHN: Did you first look at this 2 documentation in the 1990 time frame? 3 WITNESS WARD: I looked at all of this 4 documentation, yes. I'm not sure that I can say I was 5 aware at that time that switches that were outside of the 6 7 MR. MICHAEL KOHN: Did you ever get to the 8 bottom of what happened as to why non-conforming --WITNESS WARD: I wasn't through with my 10 previous answer. I wasn't sure in 1990 that I knew why -11 - I wasn't aware that I can recall that the switches were out of tolerance at that time. 13 MR. MICHAEL KOHN: As of today, has anyone in 14 the company that you're aware of gotten to the bottom to determine who was responsible for installing non-16 conforming equipment in the plant? 17 WITNESS WARD: Not that I'm aware of. 18 MR. MICHAEL KOHN: Now I'd like to go back to 19 your testimony on page 17, if I may. All right, you just 20 discussed a lot of testing that occurred during this time 21 period. Did you witness this testing? 22 WITNESS WARD: I witnessed part of it. 23 MR. MICHAEL KOHN: And if you could go through 24 25 your testimony and tell me what you witnessed and what you

NEAL R. GROSS

have knowledge of? 1 WITNESS WARD: Starting where? 2 MR. MICHAEL KOHN: Start on line seven, page 3 17. Specifically, let's look at lines seven through nine 4 first. 5 WITNESS WARD: I did not witness that. 6 MR. MICHAEL KOHN: And what is the basis for 7 8 your testimony here? WITNESS WARD: The work order with supporting 9 documentation. 10 MR. MICHAEL KOHN: And I'd like to ask you to 11 look at lines 13 through 14, the statement "Thus, it would 12 have been maintained at elevated temperatures for a period 13 of time which should have produced an actual set point 14 lower than 203.1 degrees Fahrenheit." What's your basis 15 for that statement? 16 Specifically, what's your basis to indicate 17 that it would have been maintained at an elevated 18 temperature for a period of time? 19 WITNESS WARD: The time involved to do three 20 set point tests and then to readjust the switch and to do 21 three more tests of the adjusted set point is the time 22

that I'm referring to in extended -- or a period of time.

MR. MICHAEL KOHN: But you don't have any -there's no records and you don't know how long that took?

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

23

24

WITNESS WARD: No.

MR. MICHAEL KOHN: Now lines 19 through 20, you say again "The uncontrolled time and elevated temperatures should have produced actual set points lower than those recorded." What's your basis to conclude that it was uncontrolled?

WITNESS WARD: There was nothing in the procedure to say -- for example, back on page 17, the three set point checks. There was nothing to say how quickly to do that or whether to check it one time, reduce the temperature back to 65, allow the switch to regain its equilibrium at 65, heat it up again, check the set point at that time.

It just says check it three times. And you know, on a FAR basis, a guy could have checked it once and then gone to lunch and come back and check it the second and third times an hour or two later and would have met the intent of this -- or would met the statement in the procedure. That's what I mean by uncontrolled.

MR. MICHAEL KOHN: And on page 18 of your testimony, line eight, you mentioned "inconsistent test methods on March 30, 1990." What's your basis for that statement?

WITNESS WARD: Again, it has to do with the amount of uncontrolled time at elevated temperatures that

#### NEAL R. GROSS

- 11	
1	was stated on the previous page bottom of page 17.
2	MR. MICHAEL KOHN: And again, you don't have
3	any knowledge of how long this time period was, do you?
4	WITNESS WARD: No, it was uncontrolled and
5	unrecorded.
6	MR. MICHAEL KOHN: And therefore, it would
7	have been inconsistent, correct?
8	WITNESS WARD: Right. Not consistent from
9	test to test.
10	MR. MICHAEL KOHN: Okay. And then you don't
11	know which directions the errors would be made. It could
12	have been less time during this point, correct?
13	WITNESS WARD: It could have been less time
14	than the previous calibration, that's true.
15	CHAIRMAN BLOCH: Mr. Kohn, this is a really
16	gripping cross examination.
17	MR. MICHAEL KOHN: I felt the same way when I
18	was reading the prefiled testimony.
19	CHAIRMAN BLOCH: If you could step up the
20	pace, it might at least keep the mind alive.
21	MR. MICHAEL KOHN: The next area we're going
22	to look into is the calculation on the formation of water,
23	which may be of more interest.
24	CHAIRMAN BLOCH: Is there a way to break this
25	up after you start after five minutes or so?

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1	MR. MICHAEL KOHN: Yes, Your Honor.
2	CHAIRMAN BLOCH: Okay. Mr. Kohn, do you think
3	if we let the witnesses examine this they'll just change
4	their testimony and you won't need a cross?
5	MR. MICHAEL KOHN: I would think so, Your
6	Honor.
7	CHAIRMAN BLOCH: Is there a way for them to
8	familiarize themselves with the totality of what it is
9	that you are going to be asking them about?
10	MR. MICHAEL KOHN: I'm just going to go
11	through each one at a time. I can put them in a sequence
12	right now so everyone should have it in front of them.
13	The first document we'd be looking at is headed Estimate
14	of DG Daily Air Leakage.
15	CHAIRMAN BLOCH: And that will be Intervenor
16	Exhibit
17	MR. MICHAEL KOHN: II-261.
18	CHAIRMAN BLOCH: Okay.
19	MR. MICHAEL KOHN: The next one would be is
20	headed Amount of Water in Humid Air at Any Pressure, which
21	would be II-262.
22	CHAIRMAN BLOCH: Continue.
23	MR. MICHAEL KOHN: Are you with me, Mitzi?
24	Okay. The third one is Amount is headed Amount of
25	Water in Humid Air at 240 psig, (17.3 Atmosphere), marked
	NEAL R. GROSS


**NEAL R. GROSS** 

CHAIRMAN BLOCH: I'm sorry, during the break?

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

25

# Estimate of DG Daily Air Leakage



225 psig = 239.7 psia = 16.3 atm. , 250 psig = 264.7 psia = 18.0 atm.

scf = standard cubic feet (at STP)

scf per tank @ 225 psig = (16.3 atm) x 305cu. ft. x 491.6 R / 549.6 R = 4447 scf.

scf per tank @ 250 psig = (18.0 atm) x 305cu. ft.\* x 491.6R / 549.6 R = 4911 scf.

Volume added per cycle = 464 scf

Compressor capacity = 76 scfm\*

Running time per cycle = 464 scf / 76 scfm = 6.1 minutes

Assume each compressor cycles on 1 time per 8 hour shift to make up for leakage:

This is 6 additions of 464 scf of air per day = 2784 scf / day

= 116 scf / hour

= 1.93 scf / minute

= .032 scf / second

NUCLEAR REGULATORY COMMISSION

Docket No. 50-424/425-0LA-3 EXHIBIT NO. II - 2 5 1

In the matter of Georgia Power Co. et al., Vogtle Units 1 & 2


Staff Applicant Printervenor Other

Identified Prisceived Reporter SD

Date 9/19/95 Witness HILL and Carl ARD

\* Data from FSAR Table 9.5.6-1 (Board Exh. #3)

# Amount of Water in Humid Air at any Pressure



1 cubic foot of humid air

## At Any Pressure

Dewpoint Temp. F	Vapor Pressure Water (in. Hq.) *		
95	1.66		
90	1.42		
86	1.25		
80	1.03		
60	.522		
50	.362		
35	.204		

# SECTION 7:

Parts Per Million by Volume = PPM V

Partial pressure H <sub>2</sub>O vapor x 10 E6
Partial Pressure of Dry Air

\* Perry's Chemical Engineer's Hdbk. Fourth Edition

Partial pressure Water Vapor = Vapor pressure of Water at given temperature

Partial Pressure Dry Air = Total pressure - Vapor Pressure of Water at given Temp.

Parts Per Million by Weight = PPM W

PPM w PPM v Mol. Wt. Air

NUCLEAR REGULA	TORY COMMISSION
Docket No. 50-424/425-OLA-3	EXHIBITNO. 74-262
in the matter of Georgia Power Co.	et ai., Vogtle Units 1 & 2
Staff Applicant Hitterveno	or Other
☐ Identified ☐ Reju	
Desa 9/19/95 Witness	HILL and WARD

## SECTION 7

## GENERAL DEW POINT MEASUREMENT INFORMATION

# basic humidity definitions

#### DALTON'S LAW

John Dalton was the first to surmise that the total pressure, pm, exerted by a mixture of gases or vapors is the sum of the pressures of each gas if it were to occupy the same volume by itself. The pressure which each gas component of a multiple constituent gas (such as air) exerts is called its partial pressure. If px, py, and p, represent the respective partial pressures of gases X, Y, and Z in a mixture, Dalton's Law states:

Elementary as it may seem, the concept of Dalton's Law is often overlooked in considering problems in humidity, because one forgets that the "water" in a gas is actually a gas itself and must be treated in accordance with the gas laws. Air must be considered a mixture of gases - oxygen, nitrogen, and water vapor (neglecting the minor constituents). All discussions of humidity can then be reduced to discussions of water vapor pressure, and all definitions encountered in humidity can be expressed in terms of vapor pressure.

#### DEW POINT

Dew Point is that unique temperature to which the air (or any gas) must be cooled in order that it shall be saturated with respect to water.

#### FROST POINT

Frost Point is that unique temperature to which the air (or any gas) must be couled in order that it shall be saturated with respect to ice.

The dew point or frost point DEFINES the partial pressure of the water vapor in the gas, from the Smithsonian Meteorological Tables.

#### RELATIVE HUMIDITY

Relative Humidity is the ratio of the actual vapor pressure (as defined by the Tables) in the mixture to the saturation vapor pressure, with respect to water, at the prevailing dry bulb temperature.

Example 1. (Metric Units)

If dew point = 10°C and dry bulb = 25°C:

$$=\frac{12.272 \text{ mb}}{31.671 \text{ mb}} = 38.7\%$$

If frost point = - 45°C

and dry bulb = - 40°C.

(with respect to water)

Example 2. (English Units)

If dew point = 50°F and dry bulb = 90°F:

If frost point = -50°F

and dry bulb = - 40°F:

RH . Vapor Pressure at - 50°F (Actual) Vapor Pressure at - 40°F

(with respect to water)

- 1.990×10-3"Hg = 35.7%

NOTE: RH is arbitrarily defined with respect to water even though it seems that it should be with respect to ice at - 40°C (-40°F).

#### PPM BY VOLUME

Parts per million (PPM) by volume is the ratio of the partial pressure of the water vapor to the partial pressure of the dry

Example 1. (Metric Units)

If frost point = -60°C and system total pressure is 1013 mb (14.7 PSIA)

Example 2. (English Units)

If frost point \* - 70°F and system total pressure is 14.7 PSIA (29.92"Hg):

$$= \frac{4.974 \times 10^{-4}'' \text{ Hg}}{(29.92 - .004974)'' \text{Hg}} \times 10^{\circ}$$

= 17PPM(by volume)



## PPM BY WEIGHT

PPM by weight of dry gas is identical to PPM by volume except that the weight ratio changes with the molecular weight of the carrier gas.

Example 1. (Metric Units)

If frost point = -60°C, system total pressure is 1013 mb, and the carrier gas is hydrogen:

= 10.7 
$$\times \frac{18}{2}$$
 = 96.3PPM (by weight)

Example 2. (English Units)

If frost point \* - 70°F, system total pressure is 14.7 PSIA, and the carrier gas is hydrogen:

= 17 
$$\times \frac{18}{2}$$
 = 153 PPM (by weight)

## MOLECULAR WEIGHT OF COMMON GASES

Acetylene	26	Helium	4
Air	29	Hydrogen	2
Ammonia	17	Methane	16
Argon	40	Nitrogen	28
CO <sub>2</sub>	44	Oxygen	32
co	28	Sulfur Dioxide	64
Ethylene	28	Water	18

## DEW POINT/FROST POINT RELATIONSHIPS

Below 0°C (32°F), dew point hygrometers measure the frost point temperature rather than the dew point. The tables below permit conversion from dew to frost point. For a more accurate conversion, consult Table 102 of Smithsonian Meteorological Tables.

letric	Units (°C)						
F.P.	D.P.	F.P.	D.P.	F.P.	D.P.	F.P.	DP.
0	0	- 12	- 13.4	- 24	- 26.6	- 36	- 39.4
- 1	- 1.2	- 13	- 14.5	- 25	- 27.7	- 37	- 40.5
- 2	- 2.3	- 14	- 15.6	- 26	~ 28.8	- 38	-41.6
- 3	- 3.4	- 15	- 16.7	- 27	- 29.9	- 39	- 42.6
- 4	- 4.5	- 16	-17.8	28	- 30.9	- 40	- 43.7
- 5	- 5.6	- 17	- 18.9	- 29	- 32.0	-41	- 44.7
- 6	- 6.8	- 18	-20.0	- 30	- 33.0	- 42	- 45.8
- 7	- 7.9	- 19	-21.1	- 31	- 34.1	- 43	- 46.8
- 8	- 9.0	- 20	- 22.2	- 32	25.2	-44	- 47.9
- 9	- 10.1	- 21	-23.3	- 33	- 36.2	- 45	- 49.0
-10	-11.2	- 22	-24.4	- 34	- 37.3	- 46	- 50.0
- 11	-12.3	- 23	- 25.5	- 35	- 38.4		

English Units (*F)							
F.P.	D.P.	F.P.	D.P.	F.P.	D.P.	F.P.	D.P.
+ 32	+ 32	+10	+ 7.4	- 12	- 16.7	- 34	-40.3
+ 31	+ 30.8	+ 9	+ 6.3	- 13	- 17.8	- 35	-41.4
+ 30	+ 29.7	+ 8	+ 5.2	- 14	- 18.9	- 36	-42.4
+ 29	+ 28.6	+ 7	+ 4.1	- 15	- 20.0	- 37	-43.5
+ 28	+ 27.5	+ 6	+ 2.9	- 16	-21.1	- 38	-44.5
+ 27	+ 26.4	+ 5	+ 1.8	- 17	- 22.2	- 39	-45.6
+ 26	+ 25.2	+ 4	+ 0.7	- 18	- 23.3	- 40	-46.6
+ 25	+24.1	+ 3	- 0.4	- 19	- 24.3	- 41	-47.7
+ 24	+ 22.9	+ 2	- 1.5	- 20	- 25.4	- 42	-48.7
+ 23	+21.8	+ 1	- 2.6	- 21	- 26.4	- 43	-49.8
+ 22	+20.7	0	- 3.7	- 22	-27.5	- 44	-50.8
+ 21	+ 19.6	- 1	- 4.8	- 23	- 28.6	- 45	-51.9
+ 20	+ 18.5	- 2	- 5.8	-24	-29.6	- 46	-52.9
+ 19	+ 17.4	- 3	- 6.9	- 25	-30.6 .	- 47	-54.0
+ 18	+16.2	- 4	- 8.0	- 26	-31.7	- 48	-55.0
+ 17	+ 15.1	- 5	- 9.1	- 27	- 32.8	- 49	-56.1
+ 16	+14.0	- 6	-10.2	- 28	-33.9	- 50	-57.1
+ 15	+12.9	- 7	-11.3	- 29	-35.0	- 51	-58.2
+14	+11.8	- 8	-12.4	- 30	-36.1	- 52	-59.2
+ 13	+ 10.7	- 9	- 13.5	-31	-37.2	- 53	-60.3
+ 12	+ 9.6	-10	-14.6	- 32	-38.2	-	
+11	+ 8.5	-11	- 15.6	- 33	-39.3		

REFERENCE: Smithsonian Meteorological Tables, Sixth Revised Edition, List, Robert ).,
Publication No. 4014, Smithsonian Institution, Washington, D.C.

Table 15-1. Thermodynamic Properties of Moist Air (Standard Atmospheric Pressure, 29.921 in. Hg)

100	9.772 H, × 10 <sup>a</sup>	9 046	000	9 046	- 24 037	001	- 24 036	-0 05897	.00000	-0 05897	-	-0 4277	4 666 pa × 10a	-100
-95 -90 -85 -80 -75	1 489 2 242 3 342 4 930 7 196	9 (73 9 300 9 426 9 553 9 680	000 000 000 000 000	9 173 9 300 9 426 9 553 9 580	- 22 835 - 21 631 - 20 428 - 19 225 - 18 022	002 002 003 005 007	-20 425 -19 220	-0 05565 -0 05237 -0 04913 -0 04595 -0 04280	00000 00001 00001 00001 00002	-0 05565 -0 05236 -0 04912 -0 04594 -0 04278	-197 44 -195 51 -193 55	-0 4225 -0 4173 -0 4121 -0 4669 -0 4017	0 7!11 1 071 1 597 2 356 3 641	-95 -90 -85 -86 -75
-70 -65	10 40 14 91 H <sub>s</sub> × 10 <sup>a</sup>	9 806 9 932	.000	9 806 9 932	-16 820 -15 617	011	-16 809 -15 602	-0 03969 -0 03663	.00003	-0 03966 -0 03658		-0.3965 -0.3913	4 976 7 130 pe × 10 <sup>a</sup>	70 63
-60 -55 -50 -45 -40	2 118 2 982 4 163 5 766 7 925	10 059 10 186 10 313 10 440 10 566	.000 000 001 001 001	10 059 10 186 10 314 10 441 10 567	-14 416 -13 214 -12 012 -10 511 -9 609	022 031 043 060 083	-11 969	-0 03360 -0 03061 -0 02766 -0 02474 -0 02186	00006 00009 00012 00015 00021	-0 03354 -0 03052 -0 02754 -0 02459 -0 02165	-183 39 -181 29 -179 16	-0 3861 -0 3810 -0 3758 -0 3707 -0 3655	1 0127 1 4258 1 9910 2 7578 3 7906	-66 -55 -56 -45 -46
- 35	10 81 H, × 10*	10 693	002	10 695	-8 408	113	-8 295	-0 01902	00028	-0 01874	174 84	-0 3604	5 1713 Pa × 10 <sup>8</sup>	- 35
- 30 25 20 15	1 464 1 969 2 630 3 491	10 820 10 946 11 073 11 200	002 004 005 006	10 822 10 950 11 078 11 206	-7 207 -6 905 -4 804 -3 603	154 207 277 368	-5 798 -4 527	-0 01621 -0 01342 -0 01067 -0 00796	00038 00051 00068 00089	-0 01583 -0 01291 -0 00999 -0 00707	-170 42 -168 17	-0 3552 -0 3500 -0 3449 -0 3398	0 70046 94212 1 2587 1 6706	- 30 - 25 - 20 - 15
-10 -5	4 606 6 040	11 326 11 452	008	11 334 11 463	-2.402 -1.201	487 639	-1.915 -0.562	-0 00529 -0 00263	00115 00149	-0 00414 -0 00114	-163 60 -161 28	-0 3346 -0 3295	2 2035 2 8886	-10
0 5 10 15 20	H, × 10 <sup>8</sup> 0 7872 1 020 1 315 1 687 2 152	11 578 11 705 11 831 11 958 12 084	015 019 025 032 042	11 593 11 724 11 856 11 990 12 126	0 000 1 201 2 402 3 603 4 804	835 1 085 1 401 1 800 2 302	0 835 2 286 3 803 5 403 7 106	0 00000 90260 90518 90772 91923	00192 00246 00314 00399 00504	0 00192 00506 00632 01171 01527	-156.57 -154.17	-0 3244 -0 3193 -0 3141 -0 3090 -0 3039	3 7645 4 8779 6 2858 8 0565 10 272	10
25 30 32 32 34	2 733 3 454 3 788 3 788 4 107	12 211 12 338 12 388 12 388 12 438	054 068 075 075 082	12 265 12 406 12 463 12 463 12 520	6 005 7 206 7 686 7 686 8 167	2 929 3 709 4 072 4 072 4 418	8 934 10 915 11 758 11 758 12 585	01273 01519 01617 01617 01715	00635 00796 00870 00870 00940	01908 02315 02487 02487 02655	-144 36 -143 36 0 04	-0 2988 -0 2936 -0 2916 0 0000 0041	13 032 16 452 18 035 18 037 19 546	31 33 33 34
36 38 40 42 44	4 450 4 818 5 213 5 636 6 091	12 489 12 540 12 540 12 541 12 641 12 691	089 097 105 114 124	12 578 12 637 12 695 12 755 12 815	8 547 9 128 9 608 10 088 10 369	4 791 5 191 5 622 6 084 6 580	13 438 14 319 15 230 16 172 17 149	01812 01909 02005 02101 02197	01016 01097 01183 01275 01373	02828 03006 03188 03376 03570	8.09	0081 0122 0162 0202 0242	0 21 66 22904 24767 26763 28899	33 44 4
46 48 50 52 54	6 578 7 100 7 658 8 256 8 894	12.742 12.792 12.843 12.894 12.944	134 146 156 170 185	12 876 12 938 13 001 13 064 13 129	11 049 11 530 12 010 12 491 12 971	7 112 7 681 8 291 8 945 9 644	18 161 19 211 20 301 21 436 22 615	02293 02387 02481 02575 02669	01478 01591 01711 01839 01976	03771 03978 04192 04414 04645	20.11	0282 0321 0361 0400 0439	31185 33629 36240 39028 42004	4 4 5 5 5
56 56 60 62 64	9 575 10 30 11 08 11 91 13 80	12 995 13 045 13 096 13 147 13 197	200 216 233 251 271	13 195 13 261 13 329 13 398 13 468	13 452 13 932 14 413 14 893 15 374	10 39 11 19 14 05 12 96 13 94	23 84 25 12 26 46 27 85 29 31	02762 02855 02948 03040 03132	02121 02276 02441 02616 02803	04883 05131 05389 05656 05935	30.12	0478 0517 0555 0594 0632	.45176 .48558 .52159 .55994 .60073	54 54 64 64
66 68	13.74 14.75	13.247 13.298	.292 .315	13 539 13 613	15.855 16.335	14.98 16.09	30.83 32.42	.03223 .03314	03002	06225 06527	34 11 36.11	0670 0706	64411	66
70 72 74 76 78	月, × 10 <sup>p</sup> 1 582 1 697 1 819 1 948 2 086	13 348 13 190 13 449 13 499 13 550	339 364 392 422 453	13 687 13 762 13 841 13 921 14 003	16.816 17.297 17.778 18.259 18.746	17 . 27 18 . 53 19 .88 21 . 31 22 . 84	34 09 35 83 37 66 39 57 41 58	03405 03495 03585 03675 03765	03437 03675 03928 04197 04482	06842 07170 07513 07872 08247	40.11 42.10 44.10 46.10	0746 9784 9821 9859 9896	73915 79112 84624 90470 96665	7

Compiled by John A. Goff and S. Gratch. Nee also Keasan and Kaye, "Thermodynamic Properties of Air," Wiley, New York, 1945.
Enthalpy of dry air taken as zero at 0°F. Enthalpy of biquid water taken as zero at 32°F.


\* Extrapolated to represent metastable equilibrium with undercooled biquid.

nd water

Table 15-1. Thermodynamic Properties of Moist Air (Standard Atmospheric Pressure, 29.921 in. Hg)—
(Continued)

-			Volume,		n .	Enthalpy,		D	Entropy,	les sie)	Cur	densed wat	THE PERSON NAMED AND POST OFFICE ADDRESS OF THE PERSON NAMED AND POST OFFI THE PERSON NAMED A	
Temp.	Saturation humidity H. × 10 <sup>9</sup>	ru.	fs./lb. dry	şif #s	Au IS.t	Aur	À.	a.t.u.	/(*F.)(lb. d	ary air	Enthalpy B.t.u./ib.	B.t.u./ (lb.)(*F.)	Vapor press., in. Ug	Temp
80 82 84 86 88	2 233 2 389 2 555 2 731 2 919	13 601 13 651 13 702 13 752 13 803	0 486 523 560 602 645	14 087 14 174 14 262 14 354 14 448	19 221 19 702 20 183 20 663 21 144	24 47 26 20 28 94 30 90 32 99	43 69 45 90 48 22 50 66 53 23	0 03854 03943 04031 04119 04207	0 04784 05105 05446 05807 06189	0 38638 09048 09477 09926 10396	48 10 50 09 52 09 54 08 56 08	0 0933 0970 1007 1043 1080	1 0323 1 1017 1 1752 1 2529 1 3351	8 8 8 8
90 92 94 96 98	3 118 3 330 3 556 3 795 4 049	13 853 13 904 13 954 14 905 14 056	692 741 795 851 911	14 545 14 645 14 749 14 856 14 967	21 625 22 106 22 587 23 068 23 548	34 31 36 67 39 18 41 85 44 68	55 93 56 78 61 77 64 92 68 23	04295 04382 04469 04556 04643	06596 07025 07480 07963 08474	.10890 .11407 .11949 .12519 .13117	58 08 60 07 62 07 64 06 66 06	1116 1153 1188 1224 1260	1 4219 1 5135 1 6102 1 7123 1 8199	9
100 102 104	4 319 4 606 4 911	14 106 14 157 14 207	975 1 043 1 117	15 081 15 200 15 324	24 029 24 510 24 991	47 70 50 91 54 32	71.73 75.42 79.31	04729 04815 04900	09016 09591 1020	.13745 .14406 .1510	68 06 70 05 72 05	1296 1332 1367	1 9333 2 9528 2 1786	10
106 108 110 112	H <sub>4</sub> × 10 0 5234 5578 5944 6333 6746	14 258 14 368 14 359 14 469 14 460	1 194 1 278 1 365 1 460 1 560	15 452 15 586 15 724 15 869 16 020	25 472 25 953 26 434 26 915 27 397	57 95 61 80 65 91 70 27 74 91	83 42 87 76 92 34 97 18 102 31	04985 05070 05155 05239 05323	1085 1153 1226 1302 1384	1584 1660 1742 1826 1916	74 04 76 04 78 03 80 03 82 03	1403 1438 1472 1508 1543	2 3109 2 4502 2 5966 2 7505 2 9123	11
116 118 120 122 124	7185 7652 8149 8678 9242	14 510 14 561 14 611 14 662 14 712	1 668 1 782 1 905 2 034 2 174	16 178 16 343 16 516 16 696 16 885	27 878 28 359 28 841 29 322 29 804	79 85 85 10 90 70 96 66 103 9	107 73 113 46 119 54 125 98 132 8	05407 05490 05573 05656 05739	1470 1562 1659 1763 1872	2011 2111 2216 2329 2446	84 02 86 02 88 01 90 01 92 01	1577 1612 1646 1681 1715	3 0021 3 2603 3 4474 3 6436 3 8493	1 1
126 128 130 132 134	9841 1 048 1 116 1 189 1 267	14 763 14 813 14 864 14 915 14 963	2 323 2 482 2 652 2 834 3 029	17 086 17 295 17 516 17 749 17 994	30 285 30 766 31 248 31 729 32 211	109 8 117 0 124 7 133 0 141 8	140 1 147 8 155 9 164 7 174 0	05821 05903 05985 05067 06148	1989 2113 2245 2386 2536	2571 2703 2844 2993 3151	94 01 96 00 98 00 100 00 102 00	1749 1783 1817 1851 1885	4 0649 4 2907 4 5272 4 7747 5 0337	-
136 138	i 350 i 439	15 016 15 066	3 237 3 462	18 253 18 528	32 692 33 174	151 2 161 2	183 9 194 4	06229 06310	2695 2865	3318 3496	104 00 106 00	1918	5 3046 5 5878	
140 142 144 146 148	0 1534 1636 1745 1862 1989	15 117 15 167 15 218 15 268 15 319	3 702 3 961 4 239 4 539 4 862	18 819 19 128 19 457 19 807 20 181	33 .655 34 136 34 618 35 099 35 581	172 0 183 6 196 0 209 3 223 7	205 7 217 7 230 6 244 4 259 3	06390 06470 06549 06629 06708	3047 3241 3449 3672 3912	3686 3888 4104 4335 4583	107 99 109 99 111 99 113 99 115 99	1985 2018 2051 2084 2117	5 8838 6 1930 6 5160 6 8532 7 2051	
150 152 154 156 158	2125 2271 2430 2602 2788	15 369 15 420 15 470 15 521 15 571	5 211 5 587 5 996 6 439 6 922	20 580 21 007 21 466 21 960 22 493	36 063 36 545 37 026 37 508 37 990	239 2 255 9 273 9 293 5 314 7	275 3 292 4 310 9 331 0 352 7	96787 96866 96945 97923 97101		4848 5132 5438 5768 6125	117 99 119 99 121 99 123 99 125 99	2150 2183 2216 2248 2281	7 5722 7 9350 8 3541 8 7701 9 2036	
160 162 164 166 166	.2990 3211 3452 3716 4007	15 622 15 672 15 723 15 773 15 824	7 446 8 020 8 648 9 339 10 093	23 068 23 692 24 371 25 112 25 922	38 472 36 954 39 436 39 918 40 400	337 8 363 0 390 5 420 8 454 0	376.3 402.0 429.9 460.7 494.4	07179 07257 07334 07411 07488	6204 6652 7142	6511 6930 7385 7883 8429	128 00 130 00 132 00 134 00 136 01	2313 2345 2377 2409 2441	9 6556 10 125 10 614 11 123 11 652	
170 172 174 176 176	4327 4682 5078 5519 6016	15 874 15 925 15 975 16 026 16 076	10 938 11 870 13 911 14 074 15 386	26 812 27 795 28 886 30 100 31 462	40 882 41 364 41 846 42 328 42 810	490 6 531 3 576 5 627 1 684 1	531 5 572 7 618 3 669 4 726 9	07565 07641 07718 07794 07870	.8927 .9654 1.047	9030 9691 1 0426 1 125 1 216	138 01 140 01 142 02 144 02 146 03	2473 2503 2537 2568 2600	12 203 12 775 13 369 13 967 14 628	
180 182 184 186 188	6578 7218 7953 8805 9902	16 127 16 177 16 225 16 278 16 329	16 870 18 565 20 513 22 775 25 427	32 997 34 742 36 741 39 053 41 756	43 292 43 775 44 257 44 740 45 222	748 5 821 9 906 2 1004 1119	791 8 865 7 950 5 1049 1164	07946 08021 08096 08171 08245	1 490 1 645	1 319 1 437 1 571 1 727 1 907	148 03 150 04 152 04 154 05 156 06	2631 2662 2693 2724 2755	15 294 15 985 16 702 17 446 18 217	
190 192 194 196 198	1 099 1 241 1 416 1 635 1 917	16.379 16.430 16.480 16.531 16.581	28.580 32.375 37.036 42.885 50.426	44 959 48 805 53 516 59 416 67 007	45 704 46 157 46 670 47 153 47 636	1255 1418 1619 1871 2195	1301 1464 1666 1918 2243	98320 98394 98468 98542 98616	2 296 2 609 3 002	2 122 2 380 2 694 3 087 3 593	158.07 160.07 162.08 164.09 166.10	2786 2617 7848 2879 2910	19 017 19 845 20 004 21 594 22 514	
200	2.295	16.632	60 510	77 142	48 119	2629	2677	06689	4.179	4. 266	168.11	2940	23.468	1 2

# Amount of Water in Humid Air at 240 PSIG (17.3 atm.)



1 cubic foot of humid air @ 240 PSIG (17.3 atm.)
and:

# Dewpoint 86 F

Specific vol air \* (1 atm) @ 86 F = 13.75 cu. ft. / #

Density of air (1 atm) @ 86 F = 1 / 13.75 = .073 # / cu. ft.

Density of air (17.3 atm) @ 86 F = 17.3 x .073 = 1.27 # / cu. ft.

Water content = 1.27 # dry air / cu. ft. x 1488 x 10 E-6 # water / # dry air = .00189 # water / cu. ft. dry air = .030 oz. Water / cu. ft. dry air

# Dewpoint 60 F

Specific vol air \* (1 atm.) @ 60 F = 13.10 cu. ft. /#


Water Content = .522 / 1.253 x 13.75 / 13.10 x .030 oz. / cu ft dry air

= .013 oz. / cu. ft. dry air

Data from Perry's Chemical Engineers Hdbk. Fourth Edition

NUCLEAR REGULATOR	
Docket No. 50-424/425-OLA-3	EXHIBIT NO. TI . 765
In the matter of Georgia Powy Co. et al	, Vogtie Units 1 & 2
Staff Applicant Fintervenor	
Identified   GReceived   Rejecte	d Reporter SP
Date 9/19/95 Witness +	0

# Amount of Water in Humid Air at 240 PSIG (17.3 atm.), continued



1 cubic foot of humid air @ 240 PSIG ( 17.3 atm. )

Dewpoint 95 F Water content = .039 oz. / cu. ft. dry air

Dewpoint 86 F Water content = .030 oz. / cu. ft. dry air

Dewpoint 60 F Water content = .013 oz. / cu. ft. dry air

Dewpoint 50 F Water content = .009 oz. / cu ft. dry air


Water condensed in cooling from 86 F to 60 F = (.030 - .0130 ) oz. / cu. ft

= .017 oz. / cu. ft. dry air

Water condensed in cooling from 95 F to 50 F = (.039 - .009) oz. / cu. ft.

= .030 oz. / cu. ft. dry air

# Water Formation in Control Air Supply Typical Conditions (early April 1990)



Water condensed cooling 240 psig air from 86 F to 60 F = .017 oz. / cu. ft.

Volume of 240 psig air required to condense 8 oz of water = .017 oz./ cu. řt.


- = 470 cu. ft. @ 17.3 atm (240 psig) & 86 F
- = 1594 cu. ft. @ 5.1 atm (60 psig) & 86 F
- = 7326 scf.

Time to condense 8 oz. Water = 7326 scf / 2784 scfd = 2.6 days

Time available before 3-20-90 = 7 days (last run of DG1A before 3-20-90 was 3-13-90)

NUCLEAR REGULATORY Docket No. 50-424/425-OLA-3	1-11 714
in the metter of Georgia Power Co. et al., \	/ogtie Units 1 & 2
□ Identified □ Received □ Rejected Date G / G / G / Witness # 1	Reporter_SD

# Water Formation in Control Air Supply Adverse Conditions



Water condensed cooling 240 psig air from 95 F to 50 F = .03 oz. / cu. ft.

Volume of 240 psig air required to condense 8 oz of water = .03 oz./ cu. ft.

- 267 cu. ft. @ 17.3 atm
   (240 psig) & 95 F
- = 905 cu. ft. @ 5.1 atm (60 psig) & 95 F
- = 4093 scf.

Time to condense 8 oz. Water = 4093 scf / 2784 scfd = 1.5 days

Time available before 3-20-90 = 7 days (last run of DG1A before 3-20-90 was 3-13-90)

MR. MICHAEL KOHN: Lunch break.

CHAIRMAN BLOCH: Okay.

2

3

8

12

13

14

15

16

17

18

19

201

21

23

24

MR. MICHAEL KOHN: And I pointed out some figures I wanted to see if you could agree with. And if you would look near the bottom of this document, it says running time per cycle and it comes to 6.1 minutes. Were you able to agree with that calculation?

WITNESS HILL: I have two, I guess, relatively minor comments on the calculation, but under estimated air leakage, the one, two, three, four, five, six, seventh line where it says compressor capacity --

MR. MICHAEL KOHN: Yes, sir.

name plate data, - ...s is a drawing that shows the compressor name plate -- the capacity is given as 88 actual cubic feet per minute instead of 76 standard cubic feet per minute.

MR. MICHAEL KOHN: The documentation of 76 comes from Ward Exhibit 3, which you do not have in front of you, but it is from the FSAR table. Does that --

WITNESS HILL: Well, I would be more inclined to believe the actual compressor name plate data. The FSAR would typically list a lower or upper limit as applicable. In this particular case, it would be a lower limit on capacity. I only mention this because in order

# NEAL R. GROSS

to bring this in conformance with my calculations, we 1 2 would have to have the same basis. BOARD EXAMINATION 3 CHAIRMAN BLOCH: This would make running time 4 per cycle slightly less than 6.1 minutes, is that correct? 5 WITNESS HILL: Yes, sir. 6 MR. MICHAEL KOHN: Your number was actual and 7 this number would be standard, wouldn't it? WITNESS HILL: The number used here is 9 standard, but the compressor is typically rated at actual 101 because you have so many rpm, a certain displacement in 11 the cylinders, and they will draw in the same volume of 12 air regardless of the density of the air. 13 CHAIRMAN BLOCH: This changes it to about 5.5 14 or 5.6. Does this make any difference in what you're 15 doing, Mr. Kohn? 16 MR. MICHAEL KOHN: Not much, Your Honor. 17 MR. BLAKE: Can we have a proffer before we go 18 through this painful exercise any further, Judge Bloch, of 19 where we're headed? You at least have the benefit of 20 the cross examination plan. 21 CHAIRMAN BLOCH: What is the purpose of this? 22

MR. MICHAEL KOHN: Well, we're going through the testimony of Mr. Hill with respect to how long it takes to form water in the system, which was something

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

23

24

1	like 22 days, I think is in his testimony.
2	CHAIRMAN BLOCH: You think you can establish
3	it will take how many days?
4	MR. MICHAEL KOHN: One or two days.
5	CHAIRMAN BLOCH: Okay, that seems like
6	legitimate goal for cross examination. Let's take in that
7	proffer and take a break for ten minutes.
8	(Whereupon, the proceedings went off the
9	record from 2:55 p.m. until 3:07 p.m.)
10	CHAIRMAN BLOCH: On the record. Let's go!
11	CROSS EXAMINATION (continued)
12	MR. MICHAEL KOHN: Do you know the difference
13	between SCFM and ACFM?
14	WITNESS HILL: Are you asking me?
15	MR. MICHAEL KOHN: Yes, sir.
16	WITNESS HILL: A standard cubic foot of air is
17	defined at particular temperature and pressure conditions.
18	Unfortunately, those conditions are not standard
19	universally. But for most practical work, it's defined at
20	atmospheric pressure and a temperature of about 70 degrees
21	Fahrenheit.
22	MR. MICHAEL KOHN: And ACFM?
23	WITNESS HILL: An actual cubic foot is a cubic
24	foot of air at whatever density the air is at. At
25	standard temperature and pressure an actual cubic foot and
	NEAL R. GHOSS

5

6

7

8

9

11

12

13

14

15

16

1/

18

19

20

21

22

23

24

25

the standard cubic foot are the same. If you double the pressure, you cut the absolute temperature in half, the air becomes twice as dense and the actual cubic foot would contain twice as many air molecules as the standard cubic foot.

MR. MICHAEL KOHN: And do you know what STP is, standard temperature and pressure?

witness Hill: Standard temperature and pressure is temperature and pressure as defined in whatever standard you're using. Normally it's standard atmospheric pressure at a temperature of about 70 degrees Fahrenheit. In some applications, it's atmospheric pressure and a temperature of 0°C or 32°F. There are also other applications in which different standard temperatures are used.

It's not -- the term standard there
unfortunately does not apply to a universal standard for
temperature.

MR. MICHAEL KOHN: Thank you, sir. Now I'd like to call your attention to the document marked as Intervenor's II-262, and I'd like you to look down on the bottom half where it says equation from EG&G manual section seven. Can you confirm that those equations are properly set forth here?

WITNESS HILL: I have not checked those

#### **NEAL R. GROSS**

equations yet.

CH

WI

Your Honor?

CH

attorney for I

WI

how many ounce

9

10

11

12

13

14

16

17

18

19

20

22

23

24

25

CHAIRMAN BLOCH: How long will it take?

WITNESS HILL: If I might ask a question here,

CHAIRMAN BLOCH: Please do. Ask it of the attorney for Intervenor.

WITNESS HILL: If the object is to establish how many ounces of water there are per cubic foot of air, I do agree with the general order of magnitude of the numbers on the second page of Intervenor's Exhibit II-263.

MR. MICHAEL KOHN: Yes, that's fine. We can jump to there.

CHAIRMAN BLOCH: Did we just jump? Great!

MR. MICHAEL KOHN: The witness is agreeing to

get to where I wanted to go. I'm happy. And can you look

now down to the bottom of Intervenor's 263, page two,

under heading Water Condensed and Cooling From 86°F to

60°F, and the other one, Water Condensed and Cooling from

95°F to 50°F? Do you agree with those calculations?

wITNESS HILL: I agree with the order of magnitude of the numbers. I haven't checked them with a calculator, but calculating it independently with just a pencil calc, they look approximately correct.

MR. MICHAEL FOHN: Now I'd like to call your attention to Intervenor's 264. Based on your

# **NEAL R. GROSS**

calculations, if you would look down near the bottom, it says time to condense -- well, let's actually start above water condensed cooling 240 psig air from 86°F to 60°F equals 9.17 ounces per cubic foot, and then there's volume of 240 psig air required to condense eight ounces of water.

Do you agree with the end result of 73 -- of the three end results given down there of 470 cubic feet at 17.3 atmosphere, the 1594 cubic feet of 5.1 atmospheres, and the 7326 SCF?

with a calculator. They look approximately correct.

MR. MICHAEL KOHN: And then based on your general understanding, would you agree with the conclusion that the time to condense eight ounces of water at 7326 SCF at the estimate leakage rate from the first document identified as Intervenor's 261 would come to 2.6 days?

WITNESS HILL: Again, the number looks approximately correct.

MR. MICHAEL KOHN: And the next page, I'll ask you to do the same calculation to see if you can come to - the second to the bottom line, where time to condense eight ounces of water of 4093 SCF at 27 S4SCFD would come to 1.5 days?

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

#### BOARD EXAMINATION

CHAIRMAN BLOCH: If he can establish that the

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

conditions in the hypothetical exist, then you agree it could occur, is that right? 2 WITNESS HILL: Yes, sir. 3 CHAIRMAN BLOCH: Well, I don't think this 4 witness is -- has directly observed whether the conditions 5 occurred in this time period. MR. MICHAEL KOHN: Well, let's start with some 7 of them at least. You testified, I believe, that the 86° 8 dew point at 240 psi in the receiver existed? ADMINISTRATIVE JUDGE CARPENTER: Page number, 10 please? 11 MR. MICHAEL KOHN: Prefiled testimony page 12, 12 13 line seven. ADMINISTRATIVE JUDGE CARPENTER: Thank you. 14 CHAIRMAN BLOCH: What was the question again? 15 MR. MICHAEL KOHN: The witness agreed for the 16 purposes of the calculations he presented that the 86° dew 17 point at 240 psi in the receiver --18 CHAIRMAN BLOCH: Is what? 19 MR. MICHAEL KOHN: Is a condition at the 20 plant. 21 WITNESS HILL: I use that number as the basis 22 for my calculation. Whether or not it actually existed is 23 something I really cannot testify to. It was a number 24 documented in the work orders and presumably may have 25

NEAL R. GROSS

existed in one or more of the receivers at some time. 11 WITNESS WARD: I believe I came up with that 2 number as the example to work at here based on that being the highest number that was used -- that was recorded when 4 we had the early April question. Right, right. 5 MR. MICHAEL KOHN: Now if I understand it, 6 the trench area is approximately 80 -- has approximately an 80 foot horizontal run, is that correct? WITNESS HILL: I would say somewhere between 9 40 and 80. I don't think it's as much as 80. We can 10 check that on the drawings, however. 11 MR. MICHAEL KOHN: If the witness could 12 refresh his recollection by looking at whatever drawings 13 he needs to to determine whether it was 80 feet. WITNESS HILL: I do not have those drawings 15 here in the witness box. 16 MR. MICHAEL KOHN: I believe we returned those 17 to Licensee. If you have those drawings? 18 MR. BLAKE: Do you know where they are, Dr. 19 Hill? 20 WITNESS HILL: I believe I can put my hands on 21 that one. 22 MR. BLAKE: Well, why don't you go ahead and 23 do it? 24 CHAIRMAN BLOCH: We'll take a break recess to 25 NEAL R. GROSS

do that. We'll just wait.

(Whereupon, the proceedings went off the record from 3:17 p.m. until 3:24 p.m.)

CROSS EXAMINATION (continued)

MR. MICHAEL KOHN: Can you determine whether the length of the trench where the trip lines and supply lines are running are approximately 80 feet in length?

drawing which is 1X40J5103. It's not the best drawing in the world off of which to get the length of the trench, however it does show the end of the engine and outline and I recall approximately where the control panel is. The distance between the end of the engine where the trench starts and the control panel where it terminates is on the order of 30 feet scaled on this drawing.

MR. MICHAEL KOHN: Plus the engine? Plus the length of the engine?

witness Hill: The tubing has a vertical run at the north end of the engine which is the end closest to the control panel -- comes up out of the trench. And then runs alongside the engine. The trench only extends from the control panel to the nearest point on the engine proper.

CHAIRMAN BLOCH: For the record, I'd like to note that this drawing is not being made an exhibit and

# NEAL R. GROSS

cannot be found as part of the record. MR. MICHAEL KOHN: My understanding -- the 2 lines come in from the back side of the engine, is that 3 correct? 4 WITNESS HILL: I don't know what you're 5 referring to as the back side, Mr. Kohn. 6 CHAIRMAN BLOCH: This is the second time we've 7 had that problem. 8 WITNESS HILL: The lines extend from the 9 control panel to the northwest corner of the engine where they exit the trench, run vertically, and then resume horizontal run along the side of the engine. The trench 12 extends from the control panel, which is north of the 13 engine, up to the northwest side of the engine itself. 14 When I say the engine itself, the trench 15 extends on past the generator and up to the northwest 16 corner of the diesel motor. MR. MICHAEL KOHN: You would agree that cold 18 air would settle to the lowest areas in the diesel generator building? 20 WITNESS HILL: Generally speaking, yes. 21 MR. MICHAEL KOHN: And would you agree that 22 the foundation the diesel generator building is fairly 23 massive amount of cement? 24

WITNESS HILL: Yes.

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1	MR MICHAEL KOHN: And would you agree that
2	the ground temperature which that foundation lies on is
3	going to be cooler than the ambient air temperature in the
4	building?
5	CHAIRMAN BLOCH: You want to specify a season
6	or a time?
7	MR. MICHAEL KOHN: Coming out of winter,
8	spring time, say March 1990.
9	WITNESS HILL: I don't know what the
10	temperature inside the diesel building would be at that
11	point in time. The ground temperature I would guess just
12	based on my knowledge of temperatures and caves and ther
13	underground areas to be perhaps on the order of 55° to 60°
14	Fahrenheit.
15	MR. MICHAEL KOHN: And as I understand it,
16	your understanding is this trench has a cover on it?
17	WITNESS HILL: The trench has steel checker
18	plate cover.
19	MR. MICHAEL KOHN: On portions of it or on the
20	entire trench?
21	WITNESS HILL: Over the entire length of the
22	trench, other than a small opening at one end where it
23	exits up the side of the diesel.
24	MR. MICHAEL KOHN: So then the temperature in
25	the trench would approximate the foundation temperature?

NEAL R. GROSS

I think you indicated that between 55° and 60°?

WITNESS HILL: I would expect it to, yes.

MR. MICHAEL KOHN: And now if you would look back at Intervenor's II-264. We've gone over the 86° Fahrenheit on the top in the receiver -- the dew points in the receivers. And the next assumption assumes the trench temperature of 60° Fahrenheit?

CHAIRMAN BLOCH: Where are you?

MR. MICHAEL KOHN: On Intervenor's II-264. If

-- there's a top lay out drawing -- first has the air

receivers, and then it says assumed trench area at 60°

Fahrenheit. And in the calculations, it would be the

first sentence appearing underneath that drawing which

says water condensed cooling 240 psi air from 86°F to 60°F.

And now based on what you would assume to be the trench

area temperature, do you now believe that the calculations

presented here are reasonable approximation?

WITNESS HILL: Going through this calculation line by line, water condensed cooling 240 psig air from 86°F to 60°F, .017 ounces per foot, and I agree with that. The volume of air required to condense eight ounces of water, 470 cubic feet at 240 psig, I can agree with that. The 1594 cubic feet at 60 psig, I can agree with that. And the 7326 standard cubic feet I can agree with.

I don't know where the 2784 standard cubic

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

feet per day comes from, however. 1 MR. MICHAEL KOHN: That's coming from the 2 first page, Intervenor's II-261, based on the 76 SCFM, 3 running time for 6.1 minutes. 4 WITNESS HILL: I do have that page in front of 5 me. And at the top, it says potential leakage locations. 6 We have leakage through the 006 orifices to the sensor 7 lines. 8 MR. MICHAFL KOHN: Okay, now if you'd look 9 down below, it assumes each compressor cycles on one time 10 per eight hour shift to make up for leakage. 11 WITNESS HILL: I see where the total quantity 12 of air injected into the air receiver over a 24 hour 13 period is derived. I see how that is derived. I really 14 don't have any objection to that. But looking at the 15 potential leakage locations on the top, --16 MR. MICHAEL KOHN: Okay, you don't have to 17 look at that, sir. 18 WITNESS HILL: Oh, yes, I do. 19 MR. MICHAEL KOHN: Okay. 20 WITNESS HILL: The reason I do --21 MR. BLAKE: If you don't allow the witness to 22 look at and carry through, I'm going to object to --23 MR. MICHAEL KOHN: No, he can certainly look 24 25 at it. I don't mean --

**NEAL R. GROSS** 

CHAIRMAN BLOCH: Explain the relevance of the potential leakage location.

WITNESS HILL: Yeah, the reason I do, Mr.

Kohn, the bottom -- the last one listed here is leakage in fittings in the 250 psig supply. That 250 psig supply includes not only that little run of 3/8 tubing, it also includes a substantial run of pipe -- three inch pipe with a number of fittings. It includes a number of fittings off of the receiver itself.

And I cannot imagine that that leakage is confined to leakage through the 3/8 tubing going down through the trench and tubing downstream of that. I can concede everything in the calculation except the presumption here that all of the air that is injected into the receiver winds up as flow through the 3/8 inch tubes that supply 240 psig air to the control cabinet.

There are many other leakage paths external to that.

MR. MICHAEL KOHN: Are the 3/8 lines welded?

WITNESS HILL: The pipe itself is welded, but it has a number of valves and fittings on it which have packings, flanged connections -- there are a number of valves which can leak. There are many possibilities for leakage out of that three inch line.

MR. MICHAEL KOHN: I'd like to call your

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

attention to page ten, line 23, of the testimony, Mr. Hill.

#### BOARD EXAMINATION

CHAIRMAN BLOCH: But before we continue, is it Professor Hill, is that right?

WITNESS HILL: No.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

22

23

25

CHAIRMAN BLOCH: Dr. Hill?

WITNESS HILL: Doctor.

CHAIRMAN BLOCH: Have you estimated yourself in your testimony what the potential leakage is?

witness Hill: No, I have not. I did a calculation based on certain parameters which were, you know, way outside of any reasonable expectations to determine a lower bound on the number of days it would take to accumulate eight ounces of water inside the 60 psig control tubing.

CHAIRMAN BLOCH: Well, did you find that there was data available to make reasonable calculations of the upper bound of leakage?

witness HILL: No, sir, I didn't use data; I used leakage paths through the six -- 006 inch orifices and postulated for purposes of the calculation only that the trip lines and the sensors on the ends of those trip lines would leak sufficiently to allow critical flow through each orifice.

#### **NEAL R. GROSS**

8 9

MR. MICHAEL KOHN: So what portion of your testimony are you reading from?

CHAIRMAN BLOCH: You made an assumption that the orifice is -- yeah, what portion?

WITNESS HILL: I was actually quoting that from memory, sir. Page 12, starting on line 13.

CHAIRMAN BLOCH: And so how does your assumption about leakage compare to what you understand to be the assumption in Intervenor II-261 so that we can understand what the difference is here?

WITNESS HILL: There are two totally different approaches in the Intervenor approach. They take the total quantity of air that is injected into the receiver by the compressor and then postulate that all of that air which has to leak out of the system somewhere is leaking through pathways that have to be supplied through the 3/8 inch tube that runs in the trench from the diesel engine to the control panel.

I took a totally different approach and postulated that there was leakage in the trip lines and the sensors, which are supplied through the 006 inch orifices in the control panel which are continuously pressurized. I then calculated the total quantity of leakage, assuming that there was critical flow through each orifice. At 60 psi, you can only have so much flow

#### **NEAL R. GROSS**

through the orifice. You reach a condition called critical velocity. 2 Basically sonic velocity through the orifice, 3 and you can't have anything over and above that regardless of the pressure drop. 5 CHAIRMAN BLOCH: I take it in your opinion 6 that's a very liberal assumption for calculation purposes? 7 WITNESS HILL: Yes, sir; it's a very liberal 8 9 assumption. ADMINISTRATIVE JUDGE CARPENTER: Yeah, what 10 pressure drop does that critical velocity correspond to? 12 WITNESS HILL: It's just critical velocity. It doesn't correspond to a pressure drop. I think you 13 would reach that velocity at about 15 or 18 psi, something 14 on that order. 15 CHAIRMAN BLOCH: And I assume, if I'm reading 16 it correctly, that what you call cr. tical velocity now is 17 called in the testimony maximum possible flow? 18 WITNESS HILL: Maximum possible flow, yes, 19 20 sir. 21 CHAIRMAN BLOCH: Same thing, right? WITNESS HILL: Same thing. But no matter how 22 much you increase the pressure, you will not increase that 23 maximum possible flow and velocity. It's always going to 24 be limited to something on the order of 1,100 feet per 251

**NEAL R. GROSS** 

second.

CHAIRMAN BLOCH: So if I understand correctly, you believe that the Intervenor's assumptions create a condition that's contrary to the physical laws of this system?

WITNESS HILL: No, sir; I would just question their postulation that all of the leakage in the system is through fittings on the 3/8 inch supply tube and fittings and other devices downstream of that.

CHAIRMAN BLOCH: And if those assumptions are correct, would their calculation be correct?

witness HILL: If those assumptions are correct, then it would be possible to condense eight ounces of water in the 3/8 inch line over the period of 2.6 days, plus or minus.

CHAIRMAN BLOCH: Now if there is water condensed in the system, is there any reason to believe that it would do anything but linger and just stay there so that the next time it will just build up?

water would be pushed into the filter element in the cabinet and any liquid water that gets into the inlet of the filter element is going to wind up in the bowl down below the element. There's a baffle that covers about the bottom 50% of the bowl which holds several ounces.

# **NEAL R. GROSS**

Any water which is injected into the bowl winds up below that baffle I think would take a long time to evaporate.

So if you did have any massive condensation in that supply line leading to the cabinet, you then fill the bowl in the filter element which is necessary in order to inject that water on into the regulator and into the 60 psi tubing downstream of the regulator that at some point in time water would be found in that bowl.

The filter elements are changed on some regular basis, and --

CHAIR AN BLOCH: What is the right -- what is the basis -- what is the period between the inspections of the filter element?

witness HILL: They're changed either every 18 months or every three years. I've forgotten which.

CHAIRMAN BLOCH: And so whether or not it would be discovered would depend on whether or not there was an inspection while the accumulation occurred, is that right?

witness Hill: An inspection long after the accumulation occurred would still show some water in there because there's no flowing air in contact with that water below the baffle. So even though it will very slowly evaporate, there's no air to sweep the high humidity air above the water in a way to allow more evaporation.

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

CHAIRMAN BLOCH: Mr. Kohn?

2

3

5

6

7

8

9

11

12

13

14

15

16

1.7

18

19

20

22

23

24

25

CROSS EXAMINATION (continued)

MR. MICHAEL KOHN: Now if the compressor cycled on more frequently than assumed in Intervenor's Exhibit II-261, that would result in faster formation of water, correct?

WITNESS HILL: It could, depending on the location of the leaks.

MR. MICHAEL KOHN: And as I understand it, your calculation assumes that the leakage is occurring exclusively from the point 006 orifices?

witness Hill: My calculation is based on the postulate that the leakage out of the 60 psig side of the system is through those 006 orifices. And this particular calculation, I'm not postulating anything regarding leakage on the 240 psig side of the system.

MR. MICHAEL KOHN: Well, were you generally aware that numerous fittings associated with the 60 pound side were leaking in the 1990 time frame?

WITNESS HILL: To the best of my recollection, the leaks were all associated with trip lines, but I will not swear to that. Trip lines being lines that are downstream of the --

MR. MICHAEL KOHN: Swage lock fittings? Leaks at swage lock fittings -- were you aware of those

#### NEAL R. GROSS

1	WITNESS HILL: On the trip lines?
2	MR. MICHAEL KOHN: In the control cabinet.
3	WITNESS HILL: In the control cabinet itself?
4	MR. MICHAEL KOHN: Yes.
5	WITNESS HILL: Those I was not aware of.
6	MR. MICHAEL KOHN: And you wouldn't have taken
7	any consideration of the leaks on the 250 pound side swage
8	lock fittings in the control cabinet?
9	WITNESS HILL: Those would not enter into this
10	calculation. Because again, any leaks in the any
11	condensation in the 240 psig side of the line would
12	eventually wind up in the bowl below the filter.
13	CHAIRMAN BLOCH: Mr. Kohn, the Board doesn't
14	have any sharp recollection of where in our record you
15	established that those swage lock fittings were found to
16	have leaked.
17	MR. MICHAEL KOHN: Mr. Owyoung and Johnston, I
18	believe.
19	CHAIRMAN BLOCH: Okay.
20	MR. MICHAEL KOHN: There's also been testimony
21	in the record that there's continuous flow through control
22	elements venting. Were you aware of that fact?
23	WITNESS HILL: If you could be a little more
24	specific on where that water was venting?
25	MR. MICHAEL KOHN: Control logic elements

NEAL R. GROSS

venting -- air venting through control element logic. 1 WITNESS HILL: I'm not aware that any air was 2 venting through the control element logic with the diesels 3 shut down. I don't believe there is a path, but I can be 4 proven wrong on that. MR. MICHAEL KOHN: In this filter element 6 you've been testifying about, are you aware of a cyclonic 7 effect occurring in that -- inside the filter? WITNESS HILL: Yes, I am. 9 MR. MICHAEL KOHN: Inside the filter bowl? 10 WITNESS HILL: Yes. 11 MR. MICHAEL KOHN: And so there's some form of 12 swirling action agitating the contents of the filter bowl, 13 was that correct? 14 WITNESS HILL: It's not a swirling action to 15 agitate the contents of the filter bowl. The incoming air 16 enters tangentially and, you know, makes a few turns 17 around the top of the filter element which flings any 18 entrained particles or moisture droplets to the outside. 19 And these then trickle down the walls of the bowl and accumulate in the bottom. 21 MR. MICHAEL KOHN: There has to be some way 22 for the water to get down to the bottom of the bowl. 231 24 WITNESS HILL: Yes.

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

MR. MICHAEL KOHN: And therefore, water vapor

could therefore come back up?

1

2

3

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

25

WITNESS HILL: Water vapor can come back up.

However, because there's a baffle which covers the bottom of the bowl, there's a small gap between the baffle and the wall of the bowl. That gap is large enough to allow particles and moisture droplets entrained in the air stream which are dropping down the outside of the bowl to fall into the bottom.

Any water which accumulate below that baffle is not subject to air currents. It will evaporate, but you will -- you'll wind up with a layer of saturated air above the water interface and that saturated air will interchange with the air above it very slowly. So I would expect that any water that accumulates in the bottom of that bowl would take a long, long time to evaporate after conditions return back to the normal dew point.

MR. MICHAEL KOHN: How big is this gap? A quarter inch around the parameter of the bowl?

WITNESS HILL: Plus or minus --

MR. MICHAEL KOHN: -- excuse me, perimeter of the bowl?

WITNESS HILL: It's less than that.

MR. MICHAEL KOHN: Approximately then, can you give me your -- what you understand it to be?

WITNESS HILL: I would guess something on the

# NEAL R. GROSS

order of 1/16th or less.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

#### BOARD EXAMINATION

CHAIRMAN BLOCH: Is that memory that you consider fairly accurate, or is that speculation?

WITNESS HILL: That's based on my recollection of the drawing, Your Honor.

# CROSS EXAMINATION

MR. MICHAEL KOHN: Now the panel is heated, so the contents within inside the bowl would also be heated?

WITNESS HILL: That is true.

MR. MICHAEL KOHN: To 100° Fahrenheit?

witness Hill: The thermostat in the panel is set to shut the heating strip off at 100°. Whether or not the temperature inside the panel ever reaches that level, I don't know. It's a 250 watt heater. The panel is fairly large, so it's possible that the inside of the panel never reaches 100°, and the strip runs continuously.

MR. MICHAEL KOHN: The heater is at the bottom of the panel, isn't it?

WITNESS HILL: The heater's at the bottom of the panel.

MR. MICHAEL KOHN: Below the filter?

WITNESS HILL: The filter's off to one side.

I'm not sure exactly where the heating strip is located.

MR. MICHAEL KOHN: And this 100° Fahrenheit

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

temperature would help the water to evaporate out of the bowl, wouldn't it, once it had gotten inside? 2 WITNESS HILL: It will evaporate more rapidly 3 at higher temperature. But again, you have very still air 4 conditions above the water because of the presence of that 5 baffle, so evaporation is going to be slowed down by the 6 fact that you're not transporting the saturated air above 7 the water away and replacing that with dryer air that will 8 allow more evaporation. MR. MICHAEL KOHN: But would you agree that 10 the water could come out of the bowl in a period of 11 months? 12 WITNESS HILL: Possibly. 13 MR. MICHAEL KOHN: And what's your -- what 14 would be your lower limit in the number of months? WITNESS HILL: I'd be very hesitant to put a 16 number on it, but it will be slow process relative to a 17 wide open bowl with -- exposed to room atmosphere. 18 BOARD EXAMINATION 19 CHAIRMAN BLOCH: Well, you said you're 20 hesitant to put a number on it, but you did. How much 21 credit should we give to the number of a couple of months? 22 WITNESS HILL: I didn't put a number of a 23 couple of months on, Your Honor. I said months -- I would

NEAL R. GROSS

expect months, but I would not put a number on the -- I

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

wouldn't try to speculate as to the number of months. 1 CHAIRMAN BLOCH: So does months mean it could 2 be one month also? 3 WITNESS HILL: Conceivably. 4 CROSS EXAMINATION 5 MR. MICHAEL KOHN: If more than four ounces of 6 water entered into the filter at one time, what would 7 happen based on the cyclonic action? In other words, if 8 the water was above the baffle, what would happen to that 9 water? 10 WITNESS HILL: Water above the baffle? 11 MR. MICHAEL KOHN: Yes, sir. 12 WITNESS HILL: Water above the baffle would 13 tend to evaporate much more rapidly because it's in 1.4 contact with the moving air stream. MR. MICHAEL KOHN: Could it be stirred and 16 entrained further down into the system? 17 WITNESS HILL: I don't understand the 18 question. 19 MR. MICHAEL KOHN: Let me rephrase that 20 question. Could the cyclonic action agitate the water and push it further into the system if more than four ounces 22 was -- entered the bowl? 23 WITNESS HILL: Well, if you fill the bowl 24 completely, then water is going to enter into the 25

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

regulator and the rest of the system. MR. MICHAEL KOHN: And how about if you fill 2 it just to where the baffle begins? Is that the point where water is going to start entering the rest of the system? 5 WITNESS HILL: No, it's not. You would have 6 to have on the order of two to three times that much 7 water. The baffle is somewhere between, oh, 1/3 of the 8 height and half the height above the bottom of the bowl. MR. MICHAEL KOHN: So the eight ounces of 10 water then would be -- would that be sufficient to force 11 water further downstream if eight ounces entered the 1211 13 filter? WITNESS HILL: As I remember looking at it 14 sometime back, the volume of the bowl is on the order of 15 25 cubic inches, and one ounce is -- one ounce is on the 16 order of two cubic inches, so eight ounces is -- what, 16 17 cubic inches, something like that? Am I right there? 18 CHAIRMAN BLOCH: Aren't these numbers 19 available from standard tables? 20 MR. MICHAEL KOHN: I've been told they are, 21

Your Honor.

CHAIRMAN BLOCH: We'd be willing to take notice of the standard table. Just footnote it.

MR. MICHAEL KOHN: Thank you, Your Honor.

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

22

23

ADMINISTRATIVE JUDGE CARPENTER: Have you finished this line?

MR. MICHAEL KOHN: I have no problem with the Board asking questions at this point, Your Honor.

#### BOARD EXAMINATION

ADMINISTRATIVE JUDGE CARPENTER: Dr. Hill, at the bottom of page 11 you tell the reader you're going to address the fact that Mr. Mosbaugh testified that a 16 ounce glass jar was half filled with watery fluid that was in the controlled air tubing lines or line, as the case may be. And in response to that, you observed that this amount of water, about eight ounces, is enough to fill 20 feet of 3/8 inch tubing.

Can you imagine a leak at the end of such a tube so that humid air can flow in and water can be condensed such that when the tube becomes water solid, the air flow would not force the water out? What is this semi-permeable leak we're talking about here? It leaks air but it doesn't leak water.

WITNESS HILL: No, sir. I addressed the two issues in the response to --

ADMINISTRATIVE JUDGE CARPENTER: I'm not going further with your testimony, I'm simply saying sticking to the -- sentences one and two, what kind of a physical arrangement is this that can accumulate that much water

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1	through a mechanism of a leak which allows humid air to
2	flow through the tube but the leak doesn't let the water
3	leak out, it only lets the air leak out?
4	WITNESS HILL: I can't imagine such a
5	mechanism, sir.
6	ADMINISTRATIVE JUDGE CARPENTER: Well, where
7	are we?
8	WITNESS HILL: The reference to 20 cubic feet
9	to 20 feet of
10	ADMINISTRATIVE JUDGE CARPENTER: Could this be
11	physically
12	CHAIRMAN BLOCH: Wait, wait, he was talking.
13	Continue, Doctor.
14	ADMINISTRATIVE JUDGE CARPENTER: All right.
15	WITNESS HILL: The reference to 20 feet of 3/8
16	inch tubing was just to put the volume in perspective. It
17	was not intended to imply that somehow the water condensed
18	into a solid 20 feet of water in a piece of 3/8 tube.
19	ADMINISTRATIVE JUDGE CARPENTER: How are you
20	postulating it got there?
21	WITNESS HILL: I'm postulating that it didn't
22	get there. I am disagreeing with Mr. Mosbaugh's
23	contention that eight ounces of water was extracted out of
24	the system. And to put that quantity of water in
25	perspective, I just said that that was a quantity of water
W 1 - 1	NEAL D. ODOSS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

sufficient to fill 20 feet of 3/8 inch tubing.

It gave an idea of the volume of water in terms of the total volume of tubing available in the system.

administrative judge carpenter: My problem is seeing about these relatively small diameter pneumatic control lines. And leaks some place and humid air flowing through them -- we're not talking about the trench now necessarily. We're talking about all over the place -- is I don't see why the water doesn't move along with the air, not at the same rate, but I don't know why the water is immobile -- why it accumulates.

WITNESS HILL: I'm not postulating an accumulation, sir. I'm disagreeing with Mr. Mosbaugh's postulate on accumulation.

ADMINISTRATIVE JUDGE CARPENTER: So you can't really help me with this mystery?

witness Hill: I don't believe that you would have an accumulation of eight ounces of water in the so-called trip lines.

ADMINISTRATIVE JUDGE CARPENTER: But that's the testimony that somebody drained that much water from a trip line. That's where you start with Mr. Mosbaugh's testimony.

WITNESS HILL: I'm disagreeing with the

# **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

conclusion as to the source of that water.

ADMINISTRATIVE JUDGE CARPENTER: Thank you.

This is what I'm also wondering if there aren't other possibilities.

WITNESS HILL: As I recall the testimony, sir, the quantity of water -- water was observed in a jar in someone's office at the plant. And Mr. Mosbaugh's testimony stated that one or more individuals in that office said that water was drained out of the trip lines. Did those individuals -- did those individuals in fact concur with that, I don't know, but it's my understanding that they did not.

area I'd like you to help me with. These line from the receiver, air receivers, they go down in the trench and then supply the air to the control panel, or the main ones are posturely where this condensation might occur. Is that right?

WITNESS HILL: (Inaudible).

ADMINISTRATIVE JUDGE CARPENTER: If water were to condense in that three inch line in the trench, could you imagine that the sufficient flow force that water up the vertical run of the pipe?

WITNESS HILL: I think it would have to become water solid in order to move up the vertical run of pipe

### NEAL R. GROSS

21

22

23

24

25

into the filter, through the regulator, and then up more vertical tubing into the control logic and fenced to the high point of the system and back down to get into the trip lines, when run back through the trench.

In order for water which condenses on the high pressure side of the system to accumulate in the lines between the control panel and the sensors on the diesel, I think the entire run of tubing and all of the components inside the cabinet, all the logic components, would have to be completely flooded.

ADMINISTRATIVE JUDGE CARPENTER: I can't believe that the system would continue to operate under those conditions.

witness HILL: If the filters at the low point in the cabinet, there's a short horizontal run of tubing between the tube and the regulator.

ADMINISTRATIVE JUDGE CARPENTER: I'm just having trouble getting the water up from the trench area if it does condense there, up the vertical run, which is how long. Do you know? Approximately.

WITNESS HILL: Oh, on the order of five feet, from floor height to roughly eyeball height.

ADMINISTRATIVE JUDGE CARPENTER: So I'm not sure what point these calculations have with respect to improbable events becoming water solid in order for there

#### NEAL R. GROSS

to be real flow of water up that vertical tubing. It seems to me it's a physical barrier is what I am trying to say, the fact that the pipe line is not horizontal everywhere, but has substantial vertical sections seems to me to be a barrier to movement of water through the system.

CHAIRMAN BLOCH: Dr. Hill, do you have an opinion as to whether even if it were solid, the water could be forced up that five foot length or whether the air would bubble through it?

WITNESS HILL: It would be solid and it would be forced up the five foot --

CHAIRMAN BLOCH: If it were solid, it would be forced up.

water down below it. You would be water solid to basically the same elevation on the opposite end of the 240 psi control air line.

These control air lines take off the top of the three inch lines very close to the diesel, have a very short vertical run, then make a 180 and go down the side of the diesel to the trench.

Postulating that somehow you could conceivably have continuing condensation of this line, I think the only way condensation of that line could ever reach the

### **NEAL R. GROSS**

trip line is for that entire 240 psi supply line to be water solid from some elevation on the diesel end through 2 the entire horizontal run in the trench, into the cabinet, 3 filling the sediment bowl in the filter, filling the regulator, and then filling all of the vertical tubing 5 runs in the cabinet up to and including the logic elements on the boards in the cabinet, which are about an elevation of about five feet off the floor, then up to the high 8 point of the trip lines, back down the trip lines and out through the trip line joints or sensors, wherever the water presumably was found. I just don't think it could 11 12 happen. CHAIRMAN BLOCH: Thank you. 13 CROSS EXAMINATION 14 15

MR. MICHAEL KOHN: At the outset of your testimony you indicated that you did not have any expertise in two phase flow. Is that correct? And air water flow would be two phase flow?

WITNESS HILL: Air water flow would be two phase flow if the air were flowing at a sufficient velocity. You are going to have to have a fairly significant velocity there in order to entrain liquid water droplets and have two phase flow.

MR. MICHAEL KOHN: Do you know what slug flow

is?

16

17

18

19

20

21

22

23

24

25

## NEAL R. GROSS

1	WITNESS HILL: Oh yes.
2	CHAIRMAN BLOCH: We're looking for the time
3	for the break, Mr. Kohn.
4	MR. MICHAEL KOHN: After a few more questions,
5	Your Honor.
6	CHAIRMAN BLOCH: Sure.
7	MR. MICHAEL KOHN: You don't think slugs of
8	water could flow along with the air?
9	WITNESS HILL: It's conceivable you could have
10	slugs of water flowing along with the air in the 240 psi
11	supply tubing, but those slugs would be separated from the
12	water in the filter sediment bowl, or the slugs of water
13	would be separated from the air in the filter sediment
14	bowl.
15	MR. MICHAEL KOHN: Then when the filter
16	sediment bowl fills up almost to the filter
17	WITNESS HILL: Almost to the filter? Almost
18	to the baffle, is that what you mean?
19	MR. MICHAEL KOHN: Baffle, the bronze filter,
20	excuse me.
21	WITNESS HILL: Above the bath.
22	MR. MICHAEL KOHN: Then water would pass
23	through the system after that. Let me rephrase the
24	question. Then you would get water and air passing on
25	past the filter?

WITNESS HILL: Only if the level of water reached the level of the discharge port in the filter, which is about the same level as the inlet port. You would have to completely fill the filter assembly in order to have any water discharging out or it. MR. MICHAEL KOHN: And so you could get two phase flow on a 60 pound side lines? Excuse me, starting at the outlet of the filter? WITNESS HILL: Once you've filled the filter up, then you've got solid water flow. It's no longer two phase flow, it's single phase flow, and water only. MR. MICHAEL KOHN: Air and water are coming into the filter. WITNESS HILL: Only water is coming in at this point. MR. MICHAEL KOHN: We were talking about slug flow filling up the filter. Would slug flow filling up 17 the filter result in two phased flow at the coming out of the filter?

WITNESS HILL: Yes. You have to distinguish between slug flow and two phased flow. Two phased flow is a flow, if you will, a mixture of water droplets and air. Slug flow is flow with slugs of water alternating with slugs of air. That is not really two phased flow.

MR. MICHAEL KOHN: Isn't slug flow really one

### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1

2

3

4

5

6

8

9

10

11

12

13

14

15

16

18

19

20

21

22

23

24

regime of two phased flow? 2 3 don't think it matters. 5 6 follow up quickly on that. 7 8 9 11 12

WITNESS HILL: Not really.

CHAIRMAN BLOCH: Definitional question. I

# BOARD EXAMINATION

ADMINISTRATIVE JUDGE MURPHY: Let me just

What happens with this air water mixture if it hypothetically gets through the filter and gets to the regulator. What happens to the regulator in that case? Do you have any sense for that?

WITNESS HILL: I don't think it would have any significant effect on the regulator, sir, but I can't imagine once it reached the logic elements on the control boards that those would continue to function properly.

ADMINISTRATIVE JUDGE MURPHY: That's my next question.

WITNESS HILL: They have small orifices which are designed to pass certain quantities of air at certain pressures. Once you substitute water for the air there, I think that entire system would go completely haywire.

ADMINISTRATIVE JUDGE MURPHY: How would that be manifested? How would you know it has gone haywire? WITNESS HILL: I would imagine that you would get indications of possibly trip sensors. I would have to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

13

14

15

16

17

18

19

20

21

22

23

24

1	look at the drawings to see, to get some idea of the
2	things that should be noticeable on the enunciator panels
3	or in terms of the reaction to the diesel itself.
4	ADMINISTRATIVE JUDGE MURPHY: That was my
5	question.
6	CHAIRMAN BLOCH: Take a 10 minute recess.
7	(Whereupon, from 4:08 p.m. until 4:20 p.m. the
8	proceedings went off the record.)
9	CROSS EXAMINATION
10	MR. MICHAEL KOHN: Mr. Hill, if I understand
11	your testimony on page 11, excuse me, page 12, your
12	calculations are based on gaining water out of the 60
13	pound lines. Correct? Based on condensation coming from
14	the 60 pound lines.
15	WITNESS HILL: Yes. That's correct.
16	MR. MICHAEL KOHN: Mr. Mosbaugh's calculations
17	that we looked at were based on condensation being formed
18	in the 250 pound line, is that correct?
19	WITNESS HILL: That's correct. Let me qualify
20	that, sir. The calculations on these sheets are based on
21	condensation in the 250 pound line.
22	CHAIRMAN BLOCH: The sheets that the witness
23	apparently is referring to are Intervenor Exhibits 258,
24	261 through 264.
25	WITNESS HILL: That is correct, sir, 261

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

through 264.

MR. MICHAEL KOHN: And that would be the heart of the difference between you coming up with 22 days and the calculations we're looking at, coming up with a few day period.

witness Hill: No. That's not true. The difference in the two numbers has to do with in the one case, Mr. Mosbaugh's calculations start with a given quantity of air made up by the compressors, 400 and some odd cubic feet, whatever the number is here, 2,784 standard cubic feet per day. Then the quantity of water is based on the postulate that the moisture condenses out of that 2,784 standard cubic feet per day in the 240 psi three-eighths inch supply line.

My calculation starting on line 13 of page 12 is based on the maximum amount of air which could leak out of the 60 psi system through those 6.006 inch orifices.

It has nothing to do with how much air is made up by the compressors.

MR. MICHAEL KOHN: The other major differences, you take credit for the 30 degree dew point drop associated with the reduction in pressure from 240 to 60? Is that correct?

WITNESS HILL: That's true. I postulate that the dew point of the air entering the regulator is 86

# **NEAL R. GROSS**

**NEAL R. GROSS** 

NEAL R. GROSS

1	record. I direct for clarity of the record that they be
2	bound in where they were marked.
3	MR. MICHAEL KOHN: Your Honor, I'd like to
4	mark as Intervenor 265
5	CHAIRMAN BLOCH: That's II-265.
6	MR. BARTH: Could we wait for Ms. foung to
7	return?
8	CHAIRMAN BLOCH: Yes. Let's do that.
9	
10	MR. BARTH: I appreciate that. Thank you,
11	Your Honor.
12	(Whereupon, from 4:30 p.m. until 4:32 p.m.,
13	the proceedings went off the record.)
14	MR. MICHAEL KOHN: Mr. Ward
15	CHAIRMAN BLOCH: You were marking an exhibit.
16	MR. MICHAEL KOHN: Thank you, Your Honor. You
17	Honor, I'd like to mark, it's Intervenor's II-265, at this
18	point a one page document which is entitled Time Line
19	Sequence of Events, Project No. 003542.
20	CHAIRMAN BLOCH: Granted.
21	(Whereupon, the document was marked
22	for identification as Intervenor's
23	Exhibit II-265.)
24	CROSS EXAMINATION
25	MR. MICHAEL KOHN: Mr. Ward, do you recall
	NEAL R. GROSS

seeing this document before? WITNESS WARD: No. I have not seen this in 2 the handwritten version. You gave me a typed version of it a little while ago. I do not recall seeing the handwritten version. MR. MICHAEL KOHN: The note on the top, would 6 you decipher that to indicate NJS is Stringfellow, FYI 7 Paul? How would you interpret that note? WITNESS WARD: I would interpret that to mean 9 that Paul Rushton sent that to Jack Stringfellow for his 10 information. 11 MR. MICHAEL KOHN: Would you note at the 13-12 12 entry also it indicates that no switches are venting? 13 WITNESS WARD: That's what this says. 14 MR. MICHAEL KOHN: Do you recall discussions 15 in the corporate office concerning the fact that no 16 17 switches were venting? WITNESS WARD: This is the same sequence of 18 questions we had a little while ago on the typed version 19 20 of this? MR. MICHAEL KOHN: Yes. 21 WITNESS WARD: Same answers. 22 CHAIRMAN BLOCH: Why are we questioning about 23 the handwritten version when we have already asked about 25 the typed version?

**NEAL R. GROSS** 

1	MR. MICHAEL KOHN: I think it is important to
2	indicate that it's not just a typed version of a document
3	that was subsequently produced, but this is a time line
4	produced in handwritten form.
5	CHAIRMAN BLOCH: Well, we have it in
6	handwritten form, but we don't know who wrote it.
7	MS. YOUNG: Mr. Kohn, how many pages is
8	In rvenor II-265?
9	MR. MICHAEL KOHN: We are just using the cover
10	page that was given, the first page, project no. 003542.
11	Are you aware of any document generated that
12	states that the switches were not venting and the
13	technicians were in error in their observation?
14	WITNESS WARD: No.
15	MR. MICHAEL KOHN: Intervenor calls for
16	admission of II-265.
17	CHAIRMAN BLOCH: As what? What is it?
18	MR. MICHAEL KOHN: Handwritten notes
19	circulated to the corporate office concerning the fact
20	that no switches were venting.
21	CHAIRMAN BLOCH: I don't see any objection.
22	MR. BLAKE: I have an objection. First of
23	all, it's cumulative. Secondly, we don't know who
24	authored it. Third, we don't know where it went. We have
25	some interpretation of some initials at the top. Have no
	NEAL R. GROSS

1	idea whether those were put on there in 1995 or in 1982.
2	Therefore, when the distribution was made and what the
3	meaning of the distribution is, is totally unclear to me.
4	CHAIRMAN BLOCH: As cumulative, I will grant
5	the objection.
6	MR. MICHAEL KOHN: Intervenor has no further
7	questions.
8	CHAIRMAN BLOCH: Does the staff need some time
9	or can it start right up?
10	MS. YOUNG: Good afternoon, gentlemen. I am
11	Mitsy Young. As Mr. Ward knows, I am the attorney for the
12	NRC. I am not an engineer. I only play one when I ask
13	questions. So you have to forgive me for my imprecision.
14	CHAIRMAN BLOCH: You may forgive her, but you
15	don't have to.
16	MS. YOUNG: Thank you, Judge Bloch.
17	CROSS (by Staff)
18	MS. YOUNG: The first question that I have for
19	you, looking at the testimony at page 10. From my
20	reading, this seems to be one of the first places that
21	you, Mr. Hill, mention the 240 pound supply line. Can you
22	tell me why you use that number instead of 250?
23	WITNESS HILL: I believe I used the number 240
24	because I saw on a number of data sheets that 240 plus or
25	minus pounds recorded as the pressure in the receiver, the
	ALEMAN OF ACCOUNT

NEAL R. GROSS

1	set points for starting and stopping the compressor are
2	225 pounds and 250 pounds. So on average, you would
3	expect to find something on the order of 237, 240 pounds
4	in the receiver.
5	MS. YOUNG: Mr. Ward, I'm going to ask you
6	about an answer you gave this morning, but it requires you
7	looking at GPC Exhibit II-166. Let me ask first if your
8	counsel can provide that to you.
9	Mr. Blake, do you have a copy of II-166
10	available?
11	MR. BLAKE: Is that Intervenor?
12	MS. YOUNG: No. It's GPC, Young and Johnson.
13	WITNESS WARD: I have the exhibit.
14	MS. YOUNG: If you could turn to page two of
15	that document. Looking at the fourth paragraph, just read
16	that to yourself for the moment.
17	WITNESS WARD: Okay.
18	MS. YOUNG: I meant the fifth paragraph, I'm
19	sorry. It starts with the phrase, "Our investigation."
20	WITNESS WARD: Okay.
21	MS. YOUNG: This morning, Mr. Kohn asked you
22	about the relationship of the creep phenomena with respect
23	to weak air rolls. Do you recall that examination?
24	WITNESS WARD: Yes.
25	MS. YOUNG: Do you agree with the information
	NEAL R. GROSS

NEAL R. GROSS

1

2

3

\*

6

7

8 9

ä

11

12

13

14

12

16

17

18

20

21

22

23

24

25

that is contained in the paragraph that I pointed you to, GPC Exhibit 166?

wITNESS WARD: Yes. In general, I agree with it. These are the areas that were being examined by Cooper at that time to establish further corrective action.

MS. YOUNG: What is your overall conclusion on the cause of the weak air rolls?

witness ward: My overall conclusion, well going through this paragraph, you will notice that Cooper says that the difference of the effect of the coefficient of expansion for the different materials, subsequent to this part 21 at that time they were suggesting they were going to change the design of the cap and the piston to have the same material so there would not be any difference in coefficient of expansion.

Subsequent to this part 21 in the next two to three months, Cooper decided that there was not enough difference in the coefficients to warrant making that design change and the design did not get changed.

So that leaves the torquing issue, the body distortion due to torquing, and the close tolerance fit and the manufacturing problem associated with that. I still believe that is the cause, it was the cause at that time. Of course we have not experienced any more problems

### **NEAL R. GROSS**

1	since we have corrected that problem.
2	MS. YOUNG: I'd like to turn your attention to
3	page 15 of the pre-filed testimony.
4	Dr. Hill, I believe this is a response that
5	you prepared?
6	WITNESS HILL: Yes. It is.
7	MS. YOUNG: Looking at the third paragraph on
8	that page and exploring again the effects of flooding on
9	operation of the diesel, which is one of the areas that
10	Mr. Kohn was asking about right before the staff began its
11	questioning.
12	Can you give me an idea of if there was a
13	solid water going through the .006 inch orifice, for
14	example, how the rate of passage of that water would
15	compare to the same volume of air passing through that
16	orifice. Did you understand my question?
17	WITNESS HILL: Yes. I do. I thought I had a
18	calculation for that somewhere. I can calculate it fairly
19	quickly.
20	MS. YOUNG: I'm not really asking you
21	specifics. I'm asking it more for comparison.
22	BOARD EXAMINATION
23	CHAIRMAN BLOCH: Do you know roughly what the
24	proportion would be?
25	WITNESS HILL: No, sir. I don't.
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

CHAIRMAN BLOCH: How long would it take you to do the calculation?

WITNESS HILL: Five minutes.

MS. YOUNG: Without doing the calculation, can you tell me whether it would take water longer or a shorter period of time to pass through the orifice than air would?

witness Hill: It would take an equivalent volume of water longer.

MS. YOUNG: So if the control, the piping in the control cabinet were totally flooded, what effect would that have on the operation of trip signals?

WITNESS HILL: I would really have to go
through the drawings in some detail to get an idea of what
kinds of things happen. Just intuitively, I have said
this because you have a system that's designed to operate
with air and you completely flood it with water, I can't
imagine that it's going to operate correctly.

MS. YOUNG: I think before you stated that it would go haywire, but I'm trying to understand from you whether you have any opinion as to what effect specifically it might have on the system overall. For example, if you assume that water going through an orifice would take longer than the same amount of air going through that orifice, would a system totally flooded with

#### NEAL R. GROSS

22

3

4

11

23

CHAIRMAN BLOCH: Which alarm are you referring

24

25

to?

WITNESS WARD: I believe there's an alarm on

# NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

the local panel that's 60 psi control trouble alarm, 1 something to that effect, that comes out to 60 psi system. 2 CHAIRMAN BLOCH: What does it read that causes 3 it to be touched off, reduction in pressure or what? 4 WITNESS WARD: Well, as the system filled up 5 with water, these components that are veining the 6 remaining air out of the system would vent the air out and would not allow -- make up air flow to it is now the 8 horizontal run down beneath the grating is full of water, hypothesized to be. You vent off the remaining air on the 10 top of it. I would expect the pressure to drop, at least 11 a while, until the remaining tubing filled back up with 12 13 water. CHAIRMAN BLOCH: So which alarm would be 14 actuated? 15 WITNESS WARD: I believe it's called 60 psi 16 controlled system trouble, something to that effect. 17 CHAIRMAN BLOCH: Thank you. 18 WITNESS WARD: We would have also seen signs 19 of it in the filter in the moisture separator at one time 20 or other in the plant life. I don't recall ever having 21 seen or heard of it being seen in that filter. 22 MS. YOUNG: Would you also see any signs of 23

NEAL R. GROSS

corrosion at various fittings inside the cabinet?

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVENUE, N.W.
WASHINGTON, D.C. 20005

WITNESS WARD: Most of that system is

stainless steel, so I would not expect to see corrosion. MS. YOUNG: What about discoloration? 2 MR. MICHAEL KOHN: Excuse me. Discoloration 3 of what? 4 MS. YOUNG: Of the components inside the 5 cabinet. 6 WITNESS HILL: If I could answer that. 7 think if you had any accumulation of water in the filter bowl and that water subsequently evaporated, you would definitely have a small amount of residue, which would indicate that water had evaporated in there. 11 BOARD EXAMINATION 12 CHAIRMAN BLOCH: Residue being a white color? 13 WITNESS HILL: White or tan. 14 CROSS EXAMINATION 15 MS. YOUNG: Mr. Ward, are you aware of 16 inspections that were done inside the cabinet? 17 WITNESS WARD: Well, we changed the filter, I 18 believe every refueling outage. Inspect the bowl and 19 change the filter and inspect the filter element. Of 20 course we'd take a number of the instruments off and 21 calibrate them. I would have expected to see water at 22 some point in one of those areas, if we had a water 23 problem. To my knowledge, we have not. 24

BOARD EXAMINATION

### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

CHAIRMAN BLOCH: Were you aware of whether white residue was ever found on the filter?

WITNESS WARD: No.

ask since this hypothetical occurrence of water in the filter, represents condensation from water which has been condensed from air. I would think it would have a very small concentration of minerals or what have you, almost like you are distilling the water. What is the source of this material that we're talking about?

WITNESS HILL: This, sir, would be anything that the water had picked up in its passage through the tubing after it condensed, any residual dust that had been carried over with the air. I would expect to find something in there as a result of water evaporating.

whatever was in the air in the diesel building that was compressed, dust or whatever. There would be nothing to filter it out.

ADMINISTRATIVE JUDGE CARPENTER: Thank you.

MS. YOUNG: Would it also depend on how clean the tubing was when it was initially installed and whether you'd see any residue?

WITNESS HILL: It would.

MS. YOUNG: And where is the bronze micron

## **NEAL R. GROSS**

filter located?

2

3

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

25

witness ward: It's in the control cabinet down near the bottom on the lefthand side, is the 240 psi line comes in from the trench, and then up into the cabinet. It's in the lower section there.

MS. YOUNG: And is it possible you might get some residue from that water passing through that, if the system had been flooded?

CHAIRMAN BLOCH: Question is whether there would be some residue on the filter?

MS. YOUNG: Residue inside the cabinet, is the question we've asked about any physical indications of water having been present.

ADMINISTRATIVE JUDGE CARPENTER: It sounded like you were asking whether some of the bronze would be leached by the water as it passed through it.

MS. YOUNG: No. I am trying to understand whether there would be any indications of corrosion of the filter.

## BOARD EXAMINATION

CHAIRMAN BLOCH: Would there be any indications of corrosion of the filter?

WITNESS WARD: I think if the filter had had water in it or been filled with water, there would be some discoloration of either the filter element or the bronze

### **NEAL R. GROSS**

1	part of that assembly. Even if it had all evaporated and
2	gone away, I think you would be able to distinguish that
3	water had been there sometime.
4	MS. YOUNG: Does the elevated temperature
5	assist evaporation?
6	WITNESS WARD: Probably. The cabinet runs
7	somewhere 100 degrees or slightly less. That would
8	evaporate a little quicker than 80 or 85 and be outside
9	the cabinet, somewhat faster.
10	MS. YOUNG: Now inside the control cabinet,
11	we're talking about three-eighths inch tubing. Is that
12	correct?
13	WITNESS WARD: I believe so.
14	MS. YOUNG: Are there also filters in the
15	three inch tubing associated with the diesel three inch
16	piping, excuse me.
17	WITNESS WARD: Not that I am aware of.
18	There's a moisture trap, but I don't think there's a
19	filter.
20	MS. YOUNG: Would you agree with that answer,
21	Mr. Hill? Dr. Hill, I'm sorry.
22	WITNESS HILL: I recall seeing strainers on
23	the PNID, but I think those are only for large very coarse
24	particles.
25	MS. YOUNG: I'm sorry. I didn't hear your

answer.

WITNESS HILL: I recall seeing strainers shown on the PNID. They are called wide type strainers. But I think those are only for very large particles that would become entrained in the air.

MS. YOUNG: Would you find any indications of the presence of water by looking at those strainers, had three-inch piping been filled with water?

WITNESS HILL: Water would accumulate in the bottom leg of the strainer. That portion of the three inch line is very close to the diesel engine, so I really wouldn't expect water to remain in the strainer for very long.

MS. YOUNG: What about any discoloration in that area?

witness Hill: That's carbon steel pipe, so you would probably find a lot of rust in there, which could easily be left over from the original construction and flush or blow.

MS. YOUNG: Mr. Ward, are you familiar with any inspections of the strainers?

wITNESS HILL: I think it is periodically inspected, but I don't know the frequency of it.

MS. YCUNG: Can you tell me whether any other filters in the remainder of the system that might be

# NEAL R. GROSS

checked for water or where water could possibly collect?

WITNESS WARD: I'm not aware of any other

ones.

WITNESS HILL: I can't think of any.

MS. YOUNG: In terms of understanding the effect of water in the lines such that they might have caused problems that occurred on March 20, do you have any opinion on whether water would have selectively entered the sensors that tripped on that date? I am asking you this with respect to Mr. Mosbaugh's theory that moisture would have condensed in the trench area and have been passed on to the sensors.

witness HILL: The water condensed in the trench area completely filled the filter bowl and then flooded the components inside the cabinet, one could expect to see it I believe in all of the sensor lines. I don't think it would be selective. I think eventually it would fill each and every one.

MS. YOUNG: Mr. Ward, do you have any reaction?

WITNESS WARD: I think the other thing about that is the jacket water temperature switches are very high up on the engine. They are on top of the engine. There may be one or two other ones, turbo lube oil, I'm not exactly sure where they are, but the jacket water

# **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1	would be close to the uppermost switches on the engine in
2	terms of elevation. For them to have gotten water in such
3	that water was the cause of them, I think most of the
4	other sensors on the engine would have also been affected.
5	I don't think they would have water would not have
6	sought out just the jacket water temperature switches and
7	bypassed all the rest of them. The fact that we honed in
8	on jacket water has been a source of the trips and to me
9	rules water out.
10	MS. YOUNG: If eight ounces of water have been
11	found in one trip line, as Mr. Mosbaugh alleges in 1990,
12	would you expect water to also have been present in other
13	lines?
14	MR. MICHAEL KOHN: Excuse me. I think it mis-
15	states the testimony. Eight ounces of water were found in
16	diesel trip lines.
17	MS. YOUNG: I'm sorry. You're correct. So if
18	eight ounces of water were collected in 1990, you would
19	expect that to have been from more than one trip line?
20	CHAIRMAN BLOCH: The premise of this is of
21	course that it comes from condensation?
22	MS. YOUNG: Yes. Keeping consistent with the
23	theory we have been discussing today.
24	WITNESS WARD: I would have expected it to be
25	somewhere not in one sensor or one trip line or one group

NEAL R. GROSS

of sensors. I'm not sure where I would have -- if we'd have found it, it would have been reasonable to expect it to be in the low point in the system. If it had been sitting there accumulating for a period of days or weeks or whatever. The low point in the system is in the trench, underneath the floor.

If it had accumulated and somehow run down into that section of the trench, we would not have been able to get it out of the trip lines. It supposedly flowed freely when somebody took a line out, is the theory I have heard. I don't know how it gets from under the floor to where you can catch it in a jar to demonstrate that the water was there.

So I'm not sure I can give a good hypothesis for how it condensed and then got into a jar.

MS. YOUNG: Dr. Hill, do you have any reaction?

WITNESS HILL: I concur with Louis on that. I don't see how that could happen.

MS. YOUNG: Now your estimate of over 20 days for water to accumulate, was that premised upon no blowdowns being conducted on air receivers?

Mr. Young. It's a calculated time based on a pollulated set of very extreme conditions.

## **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1	CHAIRMAN BLOCH: It's an assumption, not an
2	estimate. Right?
3	WITNESS HILL: Postulated extreme conditions,
4	not an estimate.
5	MS. YOUNG: Was included in those extreme
6	conditions the fact that no blowdowns or feed and bleeds
7	would have been conducted in the interim period than the
8	20 days?
9	WITNESS HILL: Yes. The postulate is that
10	throughout the entire 20 day period, the receiver due
11	point temperature remains at 86 degrees Fahrenheit.
12	MS. YOUNG: Staff has no further questions.
13	CHAIRMAN BLOCH: I ask in response to what I
14	asked earlier today, have you had a chance to review the
15	staff testimony filed yesterday in this case?
16	WITNESS HILL: No.
17	WITNESS WARD: I have not.
18	CHAIRMAN BLOCH: Mr. Kohn.
19	MR. MICHAEL KOHN: Thank you, Your Honor.
20	CROSS (by Intervenor)
21	MR. MICHAEL KOHN: Would you agree that a slug
22	of water entering the system could have the same effect as
23	an entire stream of water?
24	CHAIRMAN BLOCH: Same effect on what, Mr.
25	Kohn?
	LIELL D ADAGA

MR. MICHAEL KOHN: On the operation of the 1 diesel generator, as you refer to it, the controls going 2 haywire? 3 WITNESS HILL: Yes. 4 MR. MICHAEL KOHN: Do you believe the effects 5 would also include actuation of alarms or failure to 6 7 actuate alarms? WITNESS HILL: Yes. 8 MR. MICHAEL KOHN: With respect to water 9 draining out of the trip lines, the eight ounces, is it 10 true that air pressure could blow it out of the lines 11 assembled? 12 WITNESS HILL: Yes. 13 MR. MICHAEL KOHN: Is it also true that the 14 water could be high up on the engine and back drain out 15 when the lines were disconnected? 16 WITNESS HILL: In order for that to happen, 17 the line I think would have to be water solid all the way 18 from the logic board in the cabinet to the sensor on the 19 top of the engine. 201 If that is the case, then you open up the 21 line, at a lower point, the water would probably drain 22 23 out. MR. MICHAEL KOHN: Mr. Hill, earlier you were 24 talking about an alarm. As I understand it, it is the 25 **NEAL R. GROSS** 

> COURT REPORTERS AND TRANSCPIBERS 1323 RHODE ISLAND AVENUE, N.W.

> > WASHINGTON, D.C. 20005

1	control air pressure trouble line, trouble alarm? Does
2	that more accurately state what the alarm would be?
3	WITNESS WARD: Me or him?
4	MR. MICHAEL KOHN: Yes, sir. Mr. Ward.
5	WITNESS WARD: Yes.
6	MR. MICHAEL KOHN: That's yes to my question?
7	WITNESS WARD: Would you repeat the question?
8	MR. MICHAEL KOHN: Yes. The alarm you
9	testified previously to, would that be low control air
10	pressure trouble alarm?
11	WITNESS WARD: Yes.
12	MR. MICHAEL KOHN: And are you aware that that
13	alarm has actuated in the past?
14	WITNESS WARD: I'm not aware one way or the
15	other.
16	MR. MICHAEL KOHN: Are you aware that it
17	actuated in the April 1990 time frame, March, April 1990
18	time frame?
19	WITNESS WARD: I have not heard one way or the
20	other.
21	CHAIRMAN BLOCH: Do we have that in our
22	record?
23	MR. MICHAEL KOHN: We believe it's in the
24	record, Your Honor.
25	Intervenor has no further questions.
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W.

WASHINGTON, D.C. 20005

CHAIRMAN BLOCH: Staff, based on Intervenor's 1 2 questions? CROSS EXAMINATION (by Staff) 3 MS. YOUNG: Mr. Kohn just asked you again, Dr. 4 Hill, about your opinion on what would happen to various 5 sensors if there was a slug of water passing through the 6 system. When you gave that answer, did you have in mind 7 the layout of the pneumatic controls? 8 WITNESS HILL: No. The answer was based on 9 the postulate that somehow slugs of water could arrive at 10 various positions within the system. They would cause 11 effects similar to those caused by the system being water 12 13 solid. MS. YOUNG: Have you thoroughly examined the 14 schematic diagrams associated with the pneumatic controls? 15 WITNESS HILL: I have examined most of them. 16 MS. YOUNG: Are you thoroughly far liar with 17 the arrangement and logic associated with those controls? 18 WITNESS HILL: At one time I was. Currently I 19 20 am not. MS. YOUNG: No further questions. 21 MR. MICHAEL KOHN: No questions. 22 CHAIRMAN BLOCH: Hold on a second. 23 BOARD EXAMINATION 24 CHAIRMAN BLOCH: Mr. Ward, in earlier 25 NEAL R. GROSS

> COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1	testimony did you set forth, if you recall, did you set
2	forth what you think Georgia Power's commitments are with
3	respect to dew points?
4	WITNESS WARD: I believe our FSAR commitment
5	is 32 to 50 degrees.
6	CHAIRMAN BLOCH: Okay. That as I remember, is
7	is that an ongoing commitment or is that the
8	construction design requirement?
9	WITNESS WARD: I believe it's just a statement
10	in the FSAR in the system description, that the dew point
11	is maintained in that range.
12	CHAIRMAN BLOCH: So when it is outside that
13	range, in your opinion, what is the obligation of Georgia
14	Power?
15	WITNESS WARD: My opinion is the obligation is
16	to get it back in the range as soon as possible.
17	CHAIRMAN BLOCH: Okay. And the procedures by
18	which that is done is?
19	WITNESS WARD: To feed and bleed.
20	CHAIRMAN BLOCH: In your opinion, is that the
21	only commitment?
22	WITNESS WARD: With respect to the dew point,
23	that's the only one that I know of.
24	CHAIRMAN BLOCH: Okay. When there's an out of
25	spec dew point, is there any obligation to find the root
	NEAL R. GROSS

cause or root causes?

1.8

we have problems or repeat problems is to determine why we're having continuing problems. If we're for example, continuing to turn dryers off when they should be running, we should do a root cause investigation, if necessary.

Correct the procedure and make it not happen again, or correct the design.

CHAIRMAN BLOCH: Do you know whether or not the dryer repair procedure had any provision to turn the dryer back on after you were done doing the repair in 1990?

would like to speculate that that may have been in the interface between what maintenance does following a repair and what operations does to put the equipment in service.

I am speculating it could have caught.

CHAIRMAN BLOCH: Are you aware of a recent board notification which states that the procedure was recently changed to include a provision to turn the dryer back on?

wITNESS WARD: I believe I read that this morning if that's the Board notification having to do with recent NRC inspections. Yes.

CHAIRMAN BLOCH: Do you know whether I am

## NEAL R. GROSS

correct in inferring from that that the procedures in 1990 1 did not contain a provision to turn the dryers back on? 2 WITNESS WARD: I think that's a valid 3 conclusion. I have not looked at it myself, but I believe 4 5 that's probably true. CHAIRMAN BLOCH: Based on Board questions 6 7 only, Mr. Kohn. CROSS EXAMINATION (by Intervenor) 8 MR. MICHAEL KOHN: Mr. Ward, are you aware 9 that the periodic check for dew points occurs every 31 10 11 days? WITNESS WARD: I believe it is on a monthly 12 basis. 13 MR. MICHAEL KOHN: If water could in fact form 14 in the system in a two to three day period, do you believe 15 a check of every 31 days would be sufficient to take 1.6 appropriate corrective actions, to take timely appropriate 17 corrective actions? 18 WITNESS WARD: I do, because your two to three 19 day assumption is based on some fairly radical assumptions 20 on how long it takes to build up the quantity of water 21 that you stated. 22 MR. MICHAEL KOHN: Would you say that radical 23 assumption boils down to the dryer not functioning or 24 being turned off? 25

NEAL R. GROSS

WITNESS WARD: No. Number one, it assumes that both dryers are not turned on because your calculation has both the compressors operating every shift. So both of them would have to be off to get that effect.

It also assumes that all of the air is bleeding from the receivers at 84 degrees and is all being lost somewhere down stream of the 250 psi three-eighths inch tubings, but not on beyond the filter or the strainer so that it gets caught in there. So it's got to be leaking somewhere at the end of the trench, but before the filter. That's the assumption you have to make. Plus that air continues to leak through that tube and building up water without blocking the flow of air through that tube. That's hard to believe that that could happen.

MR. MICHAEL KOHN: The assumption also only is based on the compression cycling once every eight hours.

I think you have previously testified that it cycled on every couple of hours. That would --

CHAIRMAN BLOCH: Is that correct?

WITNESS WARD: I don't recall testifying every couple of hours. I might have said every few hours, but I didn't mean that as two.

CHAIKMAN BLOCH: Mr. Ward, do we know how often the compressor cycles on, how much air is made up?

#### **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

WITNESS WARD: I don't know. 1 MR. MICHAEL KOHN: Mr. Ward, giving a 2 conservative estimate, let me rephrase it. Looking at the 3 safety factor of the dew points from a conservative standpoint, would you concede that it is conceivable that water could form in a few days? Isn't that the type of assumption you would want to make? 7 WITNESS WARD: That it could form somewhere in 8 the system? MR. MICHAEL KOHN: Yes. 10 WITNESS WARD: Yes. 11 MR. MICHAEL KOHN: Based on that assumption, 12 wouldn't you suggest -- I would state that the frequency 13 in checking the dew points may not be sufficient. 14 Couldn't you agree with me? 15 WITNESS WARD: No. I believe it is 16 sufficient. 17 MR. MICHAEL KOHN: Even if water could form in 18 19 a period of a few days? WITNESS WARD: I think if we had found water 20 in the system, if we continued to find -- if we found 21 water in the system that was due to condensation, we would 22 probably reevaluate that conclusion. But we have not 23

## **NEAL R. GROSS**

found water in the system due to condensation. That

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

25

effects the system.

We blow down the receivers much more often 1 than every 31 days. We don't typically find any water in 2 that receiver. That's the low point on the receiver. 3 believe they are blown down like every shift. 4 MR. MICHAEL KOHN: Is it my understanding that 5 it was a continuing problem after 1990 of turning the drvers off? WITNESS WARD: I think it has happened way to 8 9 many times, yes. MR. MICHAEL KOHN: No further questions. 10 CHAIRMAN BLOCH: Staff. 11 CROSS (by Staff) 12 MS. YOUNG: Mr. Ward, when you indicated that 13 the dryers being left off was a continuous problem at 14 Vogtle, what did you mean by that? Did you mean that 15 every day the dryers are off? 16 WITNESS WARD: No. I think -- I hate to 17 assign a number to it, but it's happened more than once a 18 year. I believe in the inspection report that was 19 recently issued by NRC, there were several occurrences, 20 three, four, five occurrences, something like that in the 21 last . ar, year and a half. I think that is way too many. 22 MS. YOUNG: If a dryer is off or found to be 23 off, what corrective actions does GPC take? 24

NEAL R. GROSS

WITNESS WARD: What we should do is

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVENUE, N.W.
WASHINGTON, D.C. 20005

1	immediately take a dew point and confirm whether we have a
2	problem with air quality. Then if we do, then start
3	blowing down, turn the dryer on obviously. But blow it
4	down to get it back in spec.
5	MS. YOUNG: If an out of specification dew
6	point is found on the air receiver, is that air receiver
7	isolated from the system?
8	WITNESS WARD: I can't say that it always is.
9	The last time that it happened I believe it was.
10	MS. YOUNG: No further questions.
11	BOARD EXAMINATION
12	CHAIRMAN BLOCH: Mr. Ward, when the dryers are
13	found when a dryer is found off, isn't a part of the
14	job to find out why it was off?
15	WITNESS WARD: It should be. Yes, sir.
16	CHAIRMAN BLOCH: Shouldn't part of that be to
17	find out who left it off and find out what was going
18	through his mind or her mind?
19	WITNESS WARD: (Inaudible.)
20	MR. BLAKE: Can you turn your nod into a yes?
21	CHAIRMAN BLOCH: The Witness nodded yes.
22	ADMINISTRATIVE JUDGE CARPENTER: Dr. Hill, I
23	hope you are aware that the Board is faced with an
24	Intervenor presentation of some dew point measurements,
25	the end of March of 1990 into the first week of April,

NEAL R. GROSS

which Mr. Ward and others have testified were probably due to some inability to use the equipment or some fault with the equipment. But at any rate, they argued that they are not to be trusted. In considering this massive water accumulation possibilities, did you consider that time period, if those measurements were true, why did diesel 1A start on 6 of April and run for two and a half hours in the presence of all that water? This is the worst case of real world exposure. If the dew point measurements have any

credibility at all, which isn't established yet, but I do think it raises the issue of all the speculation not born

out by occurrences at Vogtle.

WITNESS HILL: Sir, I would think that if there was a significant accumulation of water in the system that it would continue to have the same effect on diesel starts until the water was purged out of the system, and dew points were restored to normal range.

I have looked at dew point data. I really haven't looked at the start data.

ADMINISTRATIVE JUDGE CARPENTER: You just answered my question. Thank you.

CHAIRMAN BLOCH: Mr. Kohn.

MR. MICHAEL KOHN: If fluid had been drained from the trip lines prior to this April 6 start that Dr.

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

2

3

5

10

11

12

13

14

15

16

17

1.8

19

20

21

22

23

24

Carpenter was referring to, from the control system, then 1 that could have eliminated the accumulation necessary to 2 cause a problem in the diesel. Would you agree? 3 WITNESS HILL: If in fact that water were 4 drained from that portion of the system which was causing 5 the problem, I would have to agree, yes. MR. MICHAEL KOHN: No further questions. 7 CHAIRMAN BLOCH: Staff. Mr. Blake. 8 MR. BLAKE: Mr. Ward --9 CHAIRMAN BLOCH: Mr. Blake, do you now have an 10 estimate of time? 11 MR. BLAKE: Yes. My estimate is between five 12 and 10 minutes, the same as it was earlier. 13 CHAIRMAN BLOCH: We're willing to continue 14 with the witnesses to be able to finish, but I think we'd 15 like to take a 10 minute break at this point, because 16 there could also be follow-up by the staff and the 17 licensee. Is there a problem? 18 All right, so we won't take a break. We'll 19 see what happens. Mr. Blake. 20 REDIRECT 21 MR. BLAKE: Mr. Ward, you were asked some 22 questions about creep earlier. Your understanding that 23 Mr. Johnston has a view, has a professional opinion that 24 creep may have played a role? 25

NEAL R. GROSS

WITNESS WARD: That is my understanding in 1 discussing it with him, yes. 2 MR. BLAKE: And is it your opinion that creep 3 4 did not play a role? WITNESS WARD: Yes. 5 MR. BLAKE: Is there anything more to your 6 inconsistent testimony with Mr. Johnston other than a 7 difference in professional opinions? 8 WITNESS WARD: Well, I believe, I can not 9 speak for him, but I asked him when I first heard this 10 concern in late July or early August, if he had a 11 calculation to show what the creep would be, and he did 12 not. I subsequently had some work done by the Southern 13 Company Services metallurgical group, to better quantify 14 creep, other than just saying creep happens. That's 15 really all I have to base my opinion on. 16 MR. BLAKE: You were asked a number of 17 questions about January 3 abnormal diesel run. What data 18 did you use to compile your Exhibit B attachments? It is 19 20 exhibit B to your affidavit. WITNESS WARD: I used the two notebooks of 21 work orders that had been provided to the IIT, which they 22 used then to accumulate and condense into appendix I. 23 We had retained a separate copy of that. I

**NEAL R. GROSS** 

think that's been furnished to everybody here at one time

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

24

or another. I did not go looking at additional documents to see if I could track down what happened on January 3.

I should have done that in retrospect. I did not have time to do it. I apologize for 3.36 being erroneous in that regard.

MR. BLAKE: With respect to 3.36 or any other item in there, were there any pieces of data from other plant records which you purposely ignored or were aware of and chose not to recount or take into account?

witness ward: No. I took into account everything that I could lay my hands on when I was doing this evaluation. It was very time consuming just to correlate the date with the event and to try to tie it to a work order, much less go find other work orders, I did not do that.

#### BOARD EXAMINATION

CHAIRMAN BLOCH: Mr. Ward, if I understood originally, you said you used the work orders that you gave to the IIT. Is that correct?

WITNESS WARD: Yes. That's correct.

CHAIRMAN BLOCH: Now you just said you used every piece of paper you could get your hands on.

witness ward: Well, there was a lot of paper attached to those work orders.

CHAIRMAN BLOCH: So it was all the paper

#### NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

attached to the work orders, not all the paper you could 1 2 get your hands on. WITNESS WARD: Two big notebooks full, yes, 3 sir. 4 MR. BLAKE: Dr. Hill, I am going to provide 5 you a copy of GPC Exhibit II-87. 6 Have you seen this two page document before? 7 WITNESS HILL: Yes, sir. I have. 8 MR. BLAKE: Focusing you on the second page in 9 the upper lefthand corner in the description of the 10 operation of this filter. The third sentence which 11 begins, "Baffle (to) creates." Do you see that sentence? 12 WITNESS HILL: Yes. 13 MR. BLAKE: Is that sentence describing what 14 you were describing earlier in your testimony with regard 15 to the difficulties of any water being entrained in the 16 water once it has gone below that baffle in the filter? 17 WITNESS HILL: It would be any water that is 18 below the baffle would evaporate very slowly because 19 there's no air turbulence above it. The baffle effectively blocks it from air turbulence. 21 MR. BLAKE: Does this sentence describe what 22 you were earlier describing as the inhibitor of 23 reentrainment? 24

WITNESS HILL: Yes, sir.

## NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1	MR. BLAKE: There are a number of questions
2	that have been asked with regard to Mr. Mosbaugh's
3	position that eight ounces of water were drained from
4	control trip lines. Do you have one adjective to describe
5	your view of that, with all the study that you have done
6	of the control system?
7	WITNESS HILL: Effectively impossible.
8	MR. BLAKE: Mr. Ward?
9	WITNESS HILL: None that I can use in court.
10	Incredible.
11	MR. BLAKE: I have no more questions.
12	CHAIRMAN BLOCH: Mr. Kohn.
13	CROSS (by Intervenor)
14	MR. MICHAEL KOHN: Thank you. The
15	documentation I showed you with respect to 3.36 contained
16	in exhibit B indicates that the switch was replaced.
17	Isn't there a work order necessary to replace a switch?
18	WITNESS WARD: Yes.
19	MR. MICHAEL KOHN: So then would you have
20	reviewed that work order?
21	WITNESS WARD: No. I did not.
22	MR. MICHAEL KOHN: So then is it possible that
23	the work orders prepared to help with respect to exhibit B
24	only selectively pulled out certain work orders and
25	excluded others?
- 1	NEAL D. GDOSS

**NEAL R. GROSS** 

1	IIT on switch history. I believe he had somebody go run
2	off copies of all of these documents and provide them to
3	the IIT. He as a safeguard, kept a copy of those books,
4	which I have.
5	MR. MICHAEL KOHN: Do you know what
6	instructions were given to pull together that
7	documentation?
8	WITNESS WARD: Not specifically. They were
9	intended to be the full history of the switches.
10	MR. MICHAEL KOHN: I believe you testified or
11	Mr. Hill testified about water the manufacturer's
12	bulletin on the filters. That there's a still zone below
13	the baffle.
14	WITNESS HILL: Yes, sir.
15	MR. MICHAEL KOHN: And there would be a
16	turbulence above the baffle. Is that correct?
17	WITNESS HILL: Yes. There would, given a
18	significant air flow.
19	CHAIRMAN BLOCH: Are you sure this isn't
20	repetitive?
21	MR. MICHAEL KOHN: It may be. I was
22	responding to their cross, but I think it may be.
23	ADMINISTRATIVE JUDGE CARPENTER: I believe Mr.
24	Blake simply drew our attention to where in the record one
25	could view the drawing. We have referenced the one that

1	Dr. Hill had previously testified to.
2	MR. MICHAEL KOHN: If you look in the drawing,
3	would you look at the gap and tell me if that was the gap
4	you were previously referring to between the baffle and
5	the wall?
6	WITNESS HILL: I based my estimate on the
7	sketch on the second page of the exhibit, II-87.
8	MR. MICHAEL KOHN: No further questions.
9	CHAIRMAN BLOCH: Ms. Young.
10	MS. YOUNG: No.
11	CHAIRMAN BLOCH: Mr. Blake.
12	MR. BLAKE: No.
13	CHAIRMAN BLOCH: We need one more question of
14	staff, which is how long is it going to take for you to be
15	prepared to start your case?
16	MS. YOUNG: We'd like to start Thursday.
17	CHAIRMAN BLOCH: That was what they had asked.
18	They had asked that there be a gap between the last
19	witness and the beginning of their case.
20	MR. BLAKE: Why not half a day, since we're
21	all here in Washington ready.
22	CHAIRMAN BLOCH: Do you need a half a day or a
23	day?
24	MS. YOUNG: We need a day. We plan on
25	beginning with our air quality panel, which we just handed
	NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

(202) 234-4433

parties didn't even read it until this morning. 2 MR. BLAKE: I'll speak for myself. I'm ready, 3 in terms of defending myself and when I got it. But you 4 5 all ought to be ready since you've done it. CHAIRMAN BLOCH: I'll grant the staff's motion 6 7 for the day off. I'd like to thank the witnesses for being with 8 us and testifying and excuse you. So thank you. Have a nice evening. MR. BLAKE: Judge Bloch, I wonder if we should 11 have a hearing day tomorrow in order to -- I at least have 12 a couple of items that have been identified or passed out 13 that have not been incorporated into evidence. 14 I'll give you an example. There's a Bailey 15 affidavit that talks about whether or not he was in on the 16 conference call. It was distributed a long time ago. We 17 have several of these to sort of do clean-up on. 1.8 CHAIRMAN BLOCH: What time of day would you 19 like to suggest for this? 20 MR. BLAKE: It could be any time which is 21 convenient for the parties. If we're going to lose an 22 entire hearing day, I hate to eat into the staff's time on 23 Thursday. 24 CHAIRMAN BLOCH: Are you talking about an 25

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVENUE, N.W.
WASHINGTON, D.C. 20005

out their testimony on Monday, late Monday. Most of the

(202) 234-4433

hour's worth of work?

MR. BLAKE: I don't even think it would maybe take that long, at least to identify the items. Maybe it's best if tomorrow I just alert the parties to what the items are so that they are prepared to react to those the next morning.

Have the Intervenors rested their case now? I keep hearing that they haven't. If they haven't, I'd like to know on what item. If they haven't rested it, then let's hear it tomorrow.

CHAIRMAN BLOCH: Have the Intervenors rested their case?

MR. MICHAEL KOHN: Your Honor, we can not say that we have rested at this point.

MR. BLAKE: I'd like to have the hearing continued tomorrow morning at 9:00.

CHAIRMAN BLOCH: Well, I'd just like to know in what respects you have not rested.

MR. MICHAEL KOHN: Your Honor, there's outstanding issues with respect to Ester Dixon notes. There are outstanding issues that we are looking at with respect to motions you requested that we file. We are planning on looking at those issues tomorrow with respect to the filing of additional motions and thing: of that nature.

## NEAL R. GROSS

With respect to additional witnesses, at this point we do not believe we are going to call any additional witnesses, with the exception potentially of Mr. Mosbaugh. But currently, we do not intend to call Mr. Mosbaugh, but we would like the time to be able to recollect on our thoughts and review the record. CHAIRMAN BLOCH: To recollect your thoughts? Would the staff like to comment on this? MR. BARTH: Well, if he has no more witnesses, Your Honor, I don't know what he's doing besides not resting. I'm confused. CHAIRMAN BLOCH: If you have more witnesses, we'll hear them in the morning. If not, you'll be considered to have rested unless you have a motion concerning matters that were surprised by or weren't able to handle. But it would take a motion showing us cause for calling witnesses that you are not prepared to call now. MR. MICHAEL KOHN: The only thing we are planning to do is review motions and file motions tomorrow, Your Honor, outstanding motions that the Board has invited us to file. CHAIRMAN BLOCH: Well that has nothing to do

CHAIRMAN BLOCH: Well that has nothing to do with resting your case. You have presented all the witnesses you have planned to present.

# **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVENUE, N.W. WASHINGTON, D.C. 20005

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

The witnesses are excused. They can leave whenever they want to. If they want to stay and listen, they are welcome to.

MR. MICHAEL KOHN: That's fine, Your Honor.

We do not have -- identified any additional witnesses at this time. So I abide by the Board's ruling.

CHAIRMAN BLOCH: Okay. So the business tomorrow, I understand Intervenor is going to be filing some motions, so they'll be working on those. Mr. Blake is going to inform people of a few evidentiary odds and ends. We'll handle those first thing on Wednesday morning. Immediately after we handle those, we'll begin with the staff panel. We're in adjournment.

(Whereupon, at 5:37 p.m., the proceedings were adjourned, to reconvene at 9:00 a.m. the following day.)

**NEAL R. GROSS** 

### CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: GA POWER CO. ET AL. VOGTLE UNITS 1 & 2

Docket Number: 50-424/425-OLA-3

Place of Proceeding: ROCKVILLE, MARYLAND

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

SCOTT DILDINE

Official Reporter

Neal R. Gross and Co., Inc.