

17122

TROUTMAN SANDERS
ATTORNEYS AT LAW
A PARTNERSHIP INCLUDING PROFESSIONAL CORPORATIONS

DOCKETED
USNRC

NATIONSBANK PLAZA
600 PEACHTREE STREET, N.E. SUITE 5200
ATLANTA, GEORGIA 30308-2216
TELEPHONE: 404-885-3000
FACSIMILE: 404-885-3900

'95 SEP 20 P4:08

JOHN LAMBERSKI

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH
DIRECT: 404-885-3360

September 20, 1995

VIA HAND DELIVERY

Administrative Judge Peter B. Bloch, Chairman
Administrative Judge James H. Carpenter
Administrative Judge Thomas D. Murphy
Atomic Safety and Licensing Board (Georgia Power)
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Vogtle Electric Generating Plant, Units 1 and 2 License Amendment (Transfer to Southern Nuclear) ASLBP No. 93-671-01-OLA-3.

Dear Sirs:

During the August 22, 1995 hearing, following the ex parte session with Intervenor and the NRC Staff, the Licensing Board requested that Georgia Power "confirm that any 'as found' [calibration] readings for the Alnor [instrument] that's in question [have been] made available in discovery and to the Board." Tr. 12272. This request appears to have been based, at least in part, upon Michael Duncan's prior testimony, which Intervenor raised in the ex parte session. Also, the Board requested that Georgia Power respond in writing to the suggestion that the documents contained in Intervenor's Exh. II-215 should have been provided to Intervenor in response to discovery requests. Id.

Based on our investigation, Georgia Power has concluded that no "as found" data was taken with respect to the Alnor VP-2466 instrument following its last use on April 7, 1990 and prior to its recalibration on May 15, 1991. We contacted Alnor representative Ed Szymczyk, who performed the repair and calibration services in 1991 on VP-2466, and provided him with a copy of (1) the Certificate of Traceability, dated May 15, 1991, bearing his signature and the designation "AFTER DATA," and (2) the Certification Data Sheet, also bearing his signature and dated May 15, 1991, both of which are contained in Intervenor's Exh. II-215. Mr. Szymczyk informed us that those documents confirm that, following calibration of the instrument by Alnor, the instrument was within specifications. He indicated that if these documents pertained to the "as found" condition of the instrument, then they would have expressly indicated that fact with the notation "BEFORE DATA." Alnor representatives have informed us, and, we understand, the NRC Staff, that there are no records of the "as found" condition of VP-2466.

9509210114 950920
PDR ADOCK 05000424
G PDR

DS03


Atomic Safety and
Licensing Board
September 20, 1995
Page 2

Georgia Power also requested General Electric, Georgia Power's vendor for such instrument calibrations, to search its document storage facility for any documentation related to the 1991 calibration services for VP-2466. General Electric was able to locate a few documents which indicate that "as found" data was taken on VP-2466 by Alnor.

As a result of our conclusion that no "as found" data was taken on VP-2466 between April 7, 1990 and May 15, 1991, we asked Mr. Michael Duncan, who testified at the hearing on June 9, 1995 concerning VP-2466 (Tr. 8198-8200), to review his testimony and the above-described documentation. Mr. Duncan concluded that his June 9 testimony required correction. An affidavit by Mr. Duncan correcting his prior testimony is attached hereto.

Finally, Georgia Power has reviewed Intervenor's prior discovery requests and has determined that they did not ask for the documents contained in Intervenor's Exh. II-215.

Very truly yours,



John Lamberski

cc: Service List