

DMB

June 20, 1984

Docket No. 50-329
Docket No. 50-330

Consumers Power Company
ATTN: Mr. D. L. Quamme
Site Manager
P. O. Box 1963
Midland, MI 48640

Gentlemen:

The NRC staff has reviewed your letter dated June 7, 1984, requesting NRC concurrence to remove and replace the emergency diesel generator buried fuel oil lines. In view of your decision to replace rather than repair the subject fuel oil lines, you further request the NRC to waive the requirement for status assessment and Quality Verification Program (QVP) prior to initiating these actions.

The NRC staff, based on this review and on discussions with members of your staff, has concluded that adequate controls are in place. This letter, therefore, authorizes CCo to proceed with the requested activities including the waiving of status assessment and QVP.

Sincerely,

"Original Signed By J. J. Harrison"

J. J. Harrison, Chief
Midland Section 1D

cc w/ltr dtd 6/7/84:
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
The Honorable Charles Bechhoefer,
ASLB
The Honorable Jerry Harbour, ASLB
The Honorable Frederick P. Cowan,
ASLB
William Paton, ELD
Michael Miller
Ronald Callen, Michigan
Public Service Commission

Barbara Stamiris
Mary Sinclair
Wendell Marshall
Colonel Steve J. Gadler (P.E.)
Howard Levin (TERA)
Billie P. Garde, Government
Accountability Project
Lynne Bernabei, Government
Accountability Project
Stone and Webster Michigan, Inc.
Myron M. Cherry

8406260221 840620
PDR ADOCK 05000329
A PDR

IEO1

OFFICE	RIII					
SURNAME	Harrison/rl					
DATE	6/20/84					