

Duke Power Company
McGuire Nuclear Generation Department
12700 Hagers Ferry Road (MG01A)
Huntersville, NC 28078-8885

T. C. McMEEKIN
Vice President
(704)875-4800
(704)875-4809 Fax



DUKE POWER

February 5, 1992

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: McGuire Nuclear Station
Docket Nos. 50-369 & 370
Proposed Technical Specification Amendment
Auxiliary Building Filtered Ventilation Exhaust Sys.

Gentlemen:

Pursuant to 10 CFR 50.90, please find attached proposed license amendment to facility operating licenses NPF-9 and NPF-17 for McGuire Nuclear Station Units 1 and 2, respectively. The proposed revision to Technical Specification (TS) 3/4.7.7 will correct an error in Amendment Nos. 113 and 95 to Facility Operating Licenses NPF-9 and NPF-17, respectively. It was approved and issued on September 12, 1990.


Those amendments concerned the Auxiliary Building Filtered Ventilation Exhaust system. Since then, an error has been discovered in the wording of Surveillances 4.7.7.1(a)(2) and 4.7.7.1(b) involving the acceptance criteria for methyl iodide penetration.

Attachment 1 contains the proposed TS changes. Attachment 2 is the Technical Justification, and Attachment 3 is the No Significant Hazards Consideration. The proposed amendment has been reviewed and determined to have no adverse safety or environmental impact.

By copy of this letter, Duke Power is forwarding a copy of this TS Amendment request application and No Significant Hazards Analysis to the North Carolina Department of Human Resources.

For questions concerning this amendment, please contact Kathleen Mullen at (704) 875-4302.

Very truly yours,


T. C. McMeekin, Vice President
McGuire Nuclear Site

9202210365 920205
PDR ADDCK 05000369
P PDR

A001
1/1

February 5, 1992
NRC Document Control
Page 2


cc: Mr. S. D. Ebnetter
Regional Administrator, Region II

Mr. Dayne Brown, Director
Division of Radiation Protection

Mr. T. A. Reed, ONRR


Mr. P. K. VanDoorn
Senior Resident Inspector

T. C. McMeekin, being duly sworn, states that he is Vice President of Duke Power Company, that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the McGuire Nuclear Station License Nos. NPF-9 and NPF-17, and that all statements and matters set forth therein are true and correct to the best of his knowledge.



T.C. McMeekin, Vice President
McGuire Nuclear Site

Subscribed and sworn to before me this ^{12th} day of February, 1992.



Notary Public

My commission expires:

December 13, 1993

February 5, 1992
NRC Document Control
Page 4

xc: (with Attachments)

L.A. Davison (QA)
R.L. Gill, Jr. (GO)
P.F. Guill (MNS)
R.O. Sharpe (MNS)
D.A. Baxter (MNS)
P.W. Roberson (MNS)
R.E. Hall (DE)
M.A. Tartaglia (DE)
T.D. Curtis (MNS)
M.D. Rains (MNS)
R.R. Weidler (DE)
B.H. Hamilton (MNS)
File: MC-801.01/GO (Helen Forbes)
File: MC-801.01/MNS
File: MNS Master File 1.3.2.9
Corporate Records
KPM/PGF008