

APPENDIX A
NOTICE OF VIOLATION

TU Electric
Comanche Peak Steam Electric Station, Unit 2

Docket No. 50-446
Construction Permit
No. CPPR-127

During an NRC inspection conducted January 8 through February 1, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1991), the violation is listed below:

Criterion V of Appendix B to 10 CFR Part 50, as implemented by Section 5.0 of the TU Electric Quality Assurance Manual, states, in part, "Activities affecting quality shall be prescribed by documented instructions, procedures or drawings, of a type appropriate to the circumstances and shall be accomplished in accordance with these instructions, procedures, or drawings."

Brown and Root ASME Construction Procedure ACP-14.2, "Handling, Storage and Preservation of Code Materials," Attachment 7.1, states, in part, that Code valves (Level "C" items) shall be stored indoors or the equivalent, with all provisions of Level B requirements, except that heat and temperature control is not required.

Contrary to the above, on January 15, 1992, the inspector observed that the pressurizer spray valves, 2-PCV-455B and 2-PCV-455C, were inadequately stored outside.

This is a Severity Level IV violation. (Supplement II) (446/9203-01)

Pursuant to the provisions of 10 CFR Part 2.201, TU Electric is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region IV, and a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation; (2) the corrective steps that have been taken and the results achieved; (3) the corrective steps that will be taken to avoid further violations; and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in the Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas,
this 14th day of February 1992

9202240093 920214
PDR ADOCK 05000445
G PDR