



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PHILADELPHIA ELECTRIC COMPANY
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-277

PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 98
License No. DPR-44

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Philadelphia Electric Company, et al. (the licensee) dated March 16, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-44 is hereby amended to read as follows:


8406260507 840620
PDR ADOCK 05000277
P PDR

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 98, are hereby incorporated in the license. PECO shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



George W. Rivenbark, Acting Chief
Operating Reactors Branch No. 4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 20, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 98

FACILITY OPERATING LICENSE NO. DPR-44

DOCKET NO. 50-277

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the areas of change.

Remove

240j

Insert

240j

PBAPS

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS3.14.D Fire Barrier Penetrations4.14.D Fire Barrier Penetrations

1. Fire barrier penetrations including cable penetration barriers, fire doors and fire dampers, protecting the following areas shall be functional*:
 - 1) Cable Spreading Room
 - 2) Emergency Switchgear Rooms
 - 3) Diesel Generator Rooms
 - 4) Battery Rooms
 - 5) Control Room
2. All fire barrier penetrations including cable penetration barriers, fire doors and fire dampers separating portions of safety related systems, required to ensure safe shutdown capability shall be functional.**
3. If the requirements of 3.14.D.1 or 3.14.D.2 cannot be met, within one hour establish a continuous fire watch on at least one side of the affected fire barrier, or verify the operability of fire detectors on at least one side of the inoperable fire barrier and establish an hourly fire watch patrol. Reactor startup and continued reactor operation is permissible.

* Delete when the provisions of 3.14.D.2 become effective.

** Effective upon return to power following the Unit 2 refueling outage commencing in 1984.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PHILADELPHIA ELECTRIC COMPANY
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-278

PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 100
License No. DPR-56


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Philadelphia Electric Company, et al. (the licensee) dated March 16, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-56 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 100, are hereby incorporated in the license. PECO shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



George W. Rivenbark, Acting Chief
Operating Reactors Branch No. 4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 20, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 100

FACILITY OPERATING LICENSE NO. DPR-56

DOCKET NO. 50-278

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the areas of change.

Remove

240j

Insert

240j

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS3.14.D Fire Barrier Penetrations4.14.D Fire Barrier Penetrations

1. Fire barrier penetrations including cable penetration barriers, fire doors and fire dampers, protecting the following areas shall be functional*:
 - 1) Cable Spreading Room
 - 2) Emergency Switchgear Rooms
 - 3) Diesel Generator Rooms
 - 4) Battery Rooms
 - 5) Control Room
2. All fire barrier penetrations including cable penetration barriers, fire doors and fire dampers separating portions of safety related systems, required to ensure safe shutdown capability shall be functional.**
3. If the requirements of 3.14.D.1 or 3.14.D.2 cannot be met, within one hour establish a continuous fire watch on at least one side of the affected fire barrier, or verify the operability of fire detectors on at least one side of the inoperable fire barrier and establish an hourly fire watch patrol. Reactor startup and continued reactor operation is permissible.

* Delete when the provisions of 3.14.D.2 become effective.

** Effective on Unit 3 upon completion of licensee's fire barrier upgrade program, or September 15, 1984, whichever comes first.