



GPU Nuclear Corporation
 Post Office Box 480
 Route 441 South
 Middletown, Pennsylvania 17057-0191
 717 944-7621
 TELEX 84-2386
 Writer's Direct Dial Number:
 (717) 948-8005

February 18, 1992
 C311-92-2021

U. S. Nuclear Regulatory Commission
 Attn: Document Control Desk
 Washington, D.C. 20555

Dear Sir:

Subject: Three Mile Island Nuclear Station, Unit 1 (TMI-1)
 Operating License No. DPR-50
 Docket No. 50-289
 Revised Emergency Response Data System (ERDS)
 Data Point Library Sheet

Pursuant to 10 CFR 50 Appendix E, Part VI, Section 3.a, attached is a revised data point library sheet for the TMI-1 Emergency Response Data System (ERDS). This change became effective on January 27, 1992, and does not affect the transmission format or computer communication protocol. The following is a summary of the attached changes:

<u>Point ID</u>	<u>Changes</u>
ERDSDATA	New point describing origination source of ERDS data being sent to the NRC (0 - plant data, 1 - simulator data).

Sincerely,

T. G. Broughton
 T. G. Broughton
 Vice President and Director, TMI-1

DVH/mkk

Attachment

cc: Region I Administrator
 Senior Emergency Preparedness Specialist
 TMI-1 Senior Project Manager
 TMI Senior Resident Inspector

200047 GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

9202250018 920218
 PDR ADDCK 05000289
 PDR

AOZ

DATA POINT LIBRARY REFERENCE FILE

DATE:	1/15/92
REACTOR UNIT:	TM1
DATA FEEDFR:	N/A
NRC ERDS PARAMETER:	SIMULATOR DATA
POINT ID:	ERDSDATA
PLANT SPEC POINT DESC.:	ERDS Data Origination Point
GENERIC/COND DESC.:	ERDS Data Source
ANALOG/DIGITAL:	A
ENGR UNITS/DIG STATES:	N/A
ENGR UNITS CONVEPSION:	N/A
MINIMUM INSTR RANGE:	0.0
MAXIMUM INSTR RANGE:	1.0
ZERO POINT REFERENCE:	N/A
REFERENCE POINT NOTES:	N/A
PROC OR SENS:	P
NUMBER OF SENSORS:	1
HOW PROCESSED:	N/A
SENSOR LOCATIONS:	N/A
ALARM/TRIP RESET POINTS:	N/A
UNIQUE SYSTEM DESC.:	Data constant set to 0 if data originates from plant and 1 if data originates from simulator.