



GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

C321-92-2053
February 18, 1992

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Dear Sir:


Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Monthly Operating Report

In accordance with the Oyster Creek Nuclear Generating Station Operating License No. DPR-16, Appendix A, Section 6.9.1.C, enclosed are two (2) copies of the Monthly Operating Data (gray book information) for the Oyster Creek Nuclear Generating Station.

In addition to the Monthly Operating Report for January, we are resubmitting revised pages of the operating status page from June thru December of 1991 which contains revised numbers on line 17 only for cumulative Gross Thermal Energy (MWH).

If you should have any questions, please contact Brenda DeMerchant, Oyster Creek Licensing Engineer at (609) 971-4642.

Sincerely,



J.J. Barton
Vice President and Director
Oyster Creek

JJB/BDEM: jc
Attachment
(MOR-RPT. JAN)

cc: Administrator, Region 1
Senior NRC Resident Inspector
Oyster Creek NRC Project Manager

9202250043 920218
PDR ADOCK 05000219
P PDR

250029

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

1524
11

At the beginning of January, the plant was operating at 649 Mwe and load was limited to 98% by control valve position. The second stage reheaters were out of service to allow a steam leak on a reheater drain tank level column to be isolated. The second stage reheaters remained out of service through the end of the report period.