




GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 713 838-6631

June 20, 1984
RBG-18070
File Nos. G9.5, G9.25.1.1

Mr. John T. Collins, Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV, Office of Inspection and Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



Dear Mr. Collins:

River Bend Station Unit 1
Docket No. 50-458
Final Report/DR-121

Gulf States Utilities Company (GSU) has completed its evaluation of DR-121 concerning Gould, Incorporated supplied Motor Control Center (MCC) equipment wiring and intermittent 49X relay contact and has determined that the wiring differences found impact status indicating lights only and would not affect the safe operations of the MCC. The safe operation of the motor operated valve is not affected by the 49X relay contacts. These problems have been corrected. GSU concludes that this condition is not reportable under 10CFR 50.55(e).

Sincerely,

J. E. Booker

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

8406280061 840620
PDR ADOCK 05000458
S PDR

JEB/PJD/lp

cc: Director of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC Resident Inspector-Site

JE-27 1/0