

NOTICE OF VIOLATION

Wisconsin Electric Power Company
Point Beach Nuclear Plant

Docket No. 50-266
License No. DPR-24

During an NRC inspection conducted from January 1 through January 31, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions", 10 CFR Part 2, Appendix C, 1991 the violation is listed below:


10 CFR 50, Appendix B, Criterion X, requires that inspections of activities affecting quality be executed to verify conformance with procedures. Installation Procedure IWP 90-227, "4160 V Breaker Control Power Fuse Modification", dated April 12, 1991, Attachment A, Step 9.a., specified that a temporary jumper was to be installed in the top of breaker cubicle A00-62, and that double verification of this step was required.

Contrary to the above, on January 20, 1992, the specified jumper was inadvertently installed in the wrong breaker cubicle, and the activities to verify that the jumper installation conformed to the procedural requirements were not adequately performed. (266/92004-04).

This is a Severity Level IV violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Wisconsin Electric is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region III, and a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or if contested, the basis for disputing the violation; (2) corrective action taken and the results achieved; (3) corrective action to be taken to avoid further violations; and (4) the date when full compliance will be achieved. Where good cause is shown, consideration may be given to extending your response time.

Dated at Glen Ellyn, Illinois
this 14th day of February, 1992



R. C. Knop, Chief
Reactor Projects Branch 3