

Georgia Power Company  
Route 2, Box 299A  
Waynesboro, Georgia 30830  
Telephone 404 554-9961, Ext. 3360  
404 724-8114, Ext. 3360

10

PRF  
OFFICIAL COPY  
Georgia Power  
the southern electric system

7 All: 03

D. O. Foster  
Vice President and Project  
General Manager  
Vogtle Project

June 4, 1984

United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

File: X7BG03-M59  
Log: GN-369

Reference: Vogtle Electric Generating Plant-Units 1 and 2; 50-424, 50-425;  
Transamerica Delaval Diesel Generator Thrust Bearings; GN-345,  
dated 4/23/84.

Attention: Mr. James P. O'Reilly


Gentlemen:

In the letter referenced above, Georgia Power Company indicated that the corrective action to be taken relative to the subject substantial safety hazard and significant deficiency would be submitted to the NRC on or about June 5, 1984. Georgia Power Company has received a recommended corrective action from Transamerica Delaval Inc. (TDI); however, TDI has subsequently notified us that they are reevaluating the recommended corrective action previously sent and will issue a revised recommended corrective action upon completion of the reevaluation. TDI estimates that the revised recommended corrective action will be issued in mid-June.

Based on these developments, Georgia Power Company wishes to extend the submittal date for the final corrective action report for this concern to August 17, 1984.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,



D. O. Foster

REF/DOF/tdm

xc: U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

R. J. Kelly	D. E. Dutton	J. A. Bailey	L. T. Gucwa
R. E. Conway	W. F. Sanders	O. Batum	M. Malcom
G. F. Head	R. H. Pinson	G. Bockhold	H. H. Gregory, III
C. W. Hayes	P. D. Rice	B. M. Guthrie	J. T. Beckham, Jr.
D. N. MacLemore	R. A. Thomas	E. D. Groover	J. L. Vota

8406280177 840604  
PDR ADOCK 05000424  
S PDR

OFFICIAL COPY

TE 27 1/0