

JUN 21 1984

Docket No.: 50-483

Mr. D. F. Schnell
Vice President - Nuclear
Union Electric Company
P. O. Box 149
St. Louis, Missouri 63166

Dear Mr. Schnell:

Subject: Callaway Plant, Unit 1, Preservice Inspection Program Changes

Reference: D. F. Schnell (UE) letter to H. R. Denton (NRC), Subject:
"Callaway Preservice Examinations, "June 3, 1984

In the referenced letter, Union Electric (UE) informed the staff that it had identified a number of longitudinal-seam pipe welds, not previously documented in the preservice inspection (PSI) program, which required preservice examinations. The letter also describes the circumstance under which the additional welds were detected and the corrective actions taken to ensure that all welds requiring inspection were included in the PSI program.

The staff has reviewed the submitted information and has concluded that UE has identified and completed the inspection of all ASME Code Class 2 longitudinal seam pipe welds subject to preservice examination. In addition, the staff finds that UE has taken acceptable corrective actions concerning these welds. This is based on the fact that UE investigations determined the extent of the problem and that the followup actions were appropriate.

If you require any additional information, please contact the Callaway Project Manager.

Sincerely,

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

CONCURRENCES:

DL:LB#1	DL:LB#1	DL:LB#1
JHolonich:es	PO'Connor	BJYoungblood
6/20/84	6/20/84	6/21/84

DIST:

Docket File	PRC System	PO'Connor	MGrace
LB#1 Rdg	NSIC	OELD, Attorney	
NRC PDR	MRushbrook	ACRS 16	
Local PDR	JHolonich	EJordan	

8406280272 840621
PDR ADOCK 05000483
G PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUN 21 1984

Docket No.: 50-483

Mr. D. F. Schnell
Vice President - Nuclear
Union Electric Company
P. O. Box 149
St. Louis, Missouri 63166

Dear Mr. Schnell:

Subject: Callaway Plant, Unit 1, Preservice Inspection Program Changes

Reference: D. F. Schnell (UE) letter to H. R. Denton (NRC), Subject:
"Callaway Preservice Examinations, "June 3, 1984

In the referenced letter, Union Electric (UE) informed the staff that it had identified a number of longitudinal-seam pipe welds, not previously documented in the preservice inspection (PSI) program, which required preservice examinations. The letter also describes the circumstance under which the additional welds were detected and the corrective actions taken to ensure that all welds requiring inspection were included in the PSI program.

The staff has reviewed the submitted information and has concluded that UE has identified and completed the inspection of all ASME Code Class 2 longitudinal seam pipe welds subject to preservice examination. In addition, the staff finds that UE has taken acceptable corrective actions concerning these welds. This is based on the fact that UE investigations determined the extent of the problem and that the followup actions were appropriate.

If you require any additional information, please contact the Callaway Project Manager.

Sincerely,

A handwritten signature in cursive script, appearing to read "B. J. Youngblood".

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

CALLAWAY

Mr. D. F. Schnell
Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

cc: Mr. Nicholas A. Petrick
Executive Director - SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. J. E. Birk
Assistant to the General Counsel
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Mr. John Neisler
U. S. Nuclear Regulatory Commission
Resident Inspectors Office
RR#1
Steedman, Missouri 65077

Mr. Donald W. Capone, Manager
Nuclear Engineering
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

A. Scott Cauger, Esq.
Assistant General Counsel for the
Missouri Public Service Comm.
Post Office Box 360
Jefferson City, Missouri 65101

Mr. Donald Bollinger, Member
Missourians for Safe Energy
6267 Delmar Boulevard
University City, Missouri 63130

Ms. Marjorie Reilly
Energy Chairman of the League of
Women Voters of Univ. City, MO
7065 Pershing Avenue
University City, Missouri 63130

Mayor Howard Steffen
Chamois, Missouri 65024

Mr. Fred Luekey
Presiding Judge, Montgomery County
Rural Route
Rhineland, Missouri 65069

Professor William H. Miller
Missouri Kansas Section, American
Nuclear Society
Department of Nuclear Engineering
1026 Engineering Building
University of Missouri
Columbia, Missouri 65211

Mr. Robert G. Wright
Assoc. Judge, Eastern District
County Court, Callaway County,
Missouri
Route #1
Fulton, Missouri 65251

Lewis C. Green, Esq.
Green, Hennings & Henry
Attorney for Joint Intervenors
314 N. Broadway, Suite 1830
St. Louis, Missouri 63102

Mr. Earl Brown
School District Superintendent
Post Office Box 9
Kingdom City, Missouri 65262

Mr. Samuel J. Birk
R. R. #1, Box 243
Morrison, Missouri 65061

Mr. Harold Lottman
Presiding Judge, Dasconade County
Route 1
Owensville, Missouri 65066

Eric A. Eisen, Esq.
Birch, Horton, Bittner and Moore
Suite 1100
1140 Connecticut Avenue, N. W.
Washington, D. C. 10036

cc: (cont'd):

Mr. John G. Reed
Route #1
Kingdom City, Missouri 65262

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition for
the Environment
St. Louis Region
6267 Delmar Boulevard
University City, Missouri 63130

Mr. James G. Keppler
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137