



**Wisconsin
Electric**
POWER COMPANY

231 W Michigan PO Box 2046 Milwaukee WI 53201

(414) 221 2345

VPNPD-92-080

February 19, 1992

State of Wisconsin
Department of Natural Resources
WPDES Permit Section
Post Office Box 7921
Madison, Wisconsin 53707

Gentlemen:

WPDES PERMIT WI-0000957-4
POINT BEACH NUCLEAR PLANT

This is to notify you that the daily maximum total residual chlorine effluent limitation was exceeded at the Point Beach Nuclear Plant. The total residual chlorine concentration in the Unit 2 cooling water discharge (outfall 002) was 0.73 mg/l on February 14, 1992

We have commenced an investigation into this incident. When the investigation is completed, a letter will be sent to the Department outlining the results of the investigation and corrective action, if any, which has been, or will be, taken.

Sincerely,

James J. Zach
Vice President
Nuclear Power

Copies to DNR Lake Michigan District
NRC Document Control Desk
NRC Regional Administrator, Region III

9202250153 920219
PDR ADOCK 05000266
S PDR

A subsidiary of Wisconsin Energy Corporation

COOL 1/0