

FEB 13 1992

Docket No. 50-483

Union Electric Company
ATTN: Mr. Donald F. Schnell
Senior Vice President -
Nuclear
Post Office Box 149 - Mail Code 400
St. Louis, MO 63166

Dear Mr. Schnell:

This refers to the inspection conducted by Messrs. J. F. Smith, G. D. Replogle, M. N. Leach and W. D. Pegg of this office on January 6 through 17, 1992. The inspection included a review of activities authorized for your Callaway facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed report.

Areas examined during the inspection are identified in the report. These areas consisted of a review of Callaway's Motor Operated Valve (MOV) Program established in response to Generic Letter (GL) 89-10. Within these areas, the inspection consisted of a selective examination of procedures, representative records, observations, and interviews with personnel.

No violations of NRC requirements were identified during the course of this inspection. However, one oper. item was identified concerning the need to confirm the use of the proper MOV motor power factor in the calculation of degraded voltage performance. We are aware that you have made significant progress in addressing this concern. We request that within 30 days of receipt of this report, you provide us with a written summary of the actions you have taken to resolve this concern and of the scope and schedule of any additional actions you intend to take.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC Public Document Room.

FEB 13 1992

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

H. J. Miller, Director
Division of Reactor Safety

Enclosure: Inspection
Report No. 50-483/91020(DRS)

- cc w/enclosure:
- G. L. Randolph, Vice President,
Nuclear Operations
- J. V. Laux, Manager, Quality
Assurance
- Tom P. Sharkey, Supervising
Engineer, Site Licensing
DCD/DCB (RIDS)
OC/LFDCB
- T. Scarbrough, NRR
- J. Jacobson, NRR
- W. Hodges, RI
- A. Gibson, RII
- Z. Falevits, RIII
- S. Collins, RIV
- C. Paulk, RIV
- R. Zimmerman, RV
Resident Inspector, RIII
Resident Inspector, Wolf
Creek
Region IV
- K. Drey
- Chris R. Rogers, P.E.,
Utility Division, Missouri
Public Service Commission
- Gerald Charnoff, Esq.
- Thomas Baxter, Est.
- R. A. Kucera, Deputy Director,
Department of Natural Resources

RIII
[Signature]
Smith/jk
02/10/92

RIII
[Signature]
Hague
02/11/92

RIII
[Signature]
Jacobson
02/12/92

RIII
[Signature]
Ring
02/12/92

RIII
[Signature]
Martin
02/12/92

RIII
[Signature]
Miller
02/13/92