

February 18, 1992

Docket No. 50-445

Mr. William J. Cahill, Jr.  
Group Vice President, Nuclear  
TU Electric Company  
400 North Olive Street, L.B. 81  
Dallas, Texas 75201

Dear Mr. Cahill:

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION UNIT 1 RESPONSE TO BULLETIN  
88-09, "THIMBLE TUBE THINNING" (TAC NO. M72653)

By letter dated December 20, 1991, TU Electric responded to Bulletin 88-09 for Comanche Peak Steam Electric Station (CPSES), Unit 1. In the response, you confirmed that activities required to address the issues were completed for Unit 1 on November 26, 1991, during the first refueling outage. Inspections of the thimble tubes were performed, with no tubes exceeding 20 percent wear.

On the basis of our review of your submittal, the NRC staff concludes that the actions taken by TU Electric for CPSES Unit 1 fully respond to the issues in Bulletin 88-09 and are acceptable. This closes TAC No. M72653.

Sincerely,

Original Signed By

Thomas A. Bergman, Acting Project Manager  
Project Directorate IV-2  
Division of Reactor Projects - III, IV, V  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File	CYCheng
NRC/PDR	JNorberg
Local PDR	PDIV-2 RF
BBoger	PDIV-2 PF
MVirgilio	EJordan
SBlack	ACRS (10)
TBergman	LYandell, RIV
EPeyton	OGC
BBuckley	CBerlinger

NRC FILE CENTER COPY

OFC	: PDIV-2/LA	: PDIV-2/PM	: PDIV-2/D	: EMEB	: OGCB	: PDII/2	
NAME	: EPeyton	: TBergman	: SBlack	: JNorberg	: <del>CBerlinger</del>	: HBerrow	PCB 2/18/92
DATE	: 2/10/92	: 2/10/92	: 2/18/92	: 2/14/92	: 2/14/92	: 2/11/92	

9202250328 920218  
PDR ADDCK 05000445  
Q PDR

DF01  
110

Mr. William J. Cahill, Jr.

- 2 -

February 18, 1992

cc:

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 1029  
Granbury, Texas 76048

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mrs. Juanita Ellis, President  
Citizens Association for Sound Energy  
1426 South Polk  
Dallas, Texas 75224

Owen L. Thero, President  
Quality Technology Company  
Lakeview Mobile Home Park, Lot 35  
4793 East Loop 820 South  
Fort Worth, Texas 76119

Mr. Roger D. Walker  
Manager, Nuclear Licensing  
Texas Utilities Electric Company  
400 North Olive Street, L.B. 81  
Dallas, Texas 75201

Texas Utilities Electric Company  
c/o Bethesda Licensing  
3 Metro Center, Suite 610  
Bethesda, Maryland 20814

William A. Burchette, Esq.  
Counsel for Tex-La Electric  
Cooperative of Texas  
Jorden, Schulte, & Burchette  
1025 Thomas Jefferson Street, N.W.  
Washington, D.C. 20007

GDS Associates, Inc.  
Suite 720  
1850 Parkway Place  
Marietta, Georgia 30067-8237

Jack R. Newman, Esq.  
Newman & Holtzinger  
1615 L Street, N.W.  
Suite 1000  
Washington, D. C. 20036

Chief, Texas Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, Texas 78756

Honorable Dale McPherson  
County Judge  
P. O. Box 851  
Glen Rose, Texas 76045