

ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company
McGuire Units 1 and 2

Docket Nos. 50-369 and 50-370
License Nos. NPF-9 and NPF-17

During the Nuclear Regulatory Commission (NRC) inspection conducted on December 15, 1991 through January 18, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1991), the violation is identified below:

Technical Specification 6.8.1.a requires written procedures to be established, implemented, and maintained covering the applicable procedures recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978, which includes performing procedures for equipment calibration.

Technical Specification 3.6.1.8 requires that two independent annulus ventilation systems shall be operable in Modes 1 through 4.

Procedure IP/O/B/3190/26, Volumetric Leak Rate Calibration, has been performed semi-annually on each unit to verify operability of the access airlocks since initial unit startup.

Contrary to the above, procedure IP/O/B/3190/26, Volumetric Leak Rate Calibration, was inadequate in that since initial unit startup, the procedure failed to establish adequate compensatory measures to be taken during this operability test resulting in the inoperability of both trains of annulus ventilation each time the test was performed.

This is a Severity Level IV violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Duke Power Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555 with a copy to the Regional Administrator, Region 11, and a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this 7th day of Feb. 1992

9202260075 920207
PDR ADOCK 05000369
G PDR