

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of

Duquesne Light Company
(Beaver Valley Power Station, Unit No. 1)

)
)
)
Docket No. 50-334

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission (the "Commission"), Duquesne Light Company ("DLC"), holder of Operating License No. DPR-66, hereby requests that the Technical Specifications set forth in Appendix A to that license be amended to require performance of a battery service test during the fourth refueling outage and at 18-month intervals thereafter.

The proposed technical specification change is set forth in Attachment A to this Application. A safety evaluation is set forth in Attachment B. Based on the guidance provided by the Commission and examples of changes not likely to involve a significant hazards consideration, published in the Federal Register (48 FR 14864), we have determined that the proposed change falls within the following commissions examples:


(i) A purely administrative change to technical specifications.

Therefore, in accordance with 10 CFR 50.92, we have determined this proposed change is not likely to involve a significant hazards consideration.

WHEREFORE, Applicant respectfully requests that Appendix A to Operating License No. DPR-66 be amended in the form attached hereto as Attachment A.

Duquesne Light Company


By


S. J. Carey

Vice President, Nuclear

Subscribed and sworn to before me

on this 21st day of JUNE



MELVA CYANOVICH, NOTARY PUBLIC
HOPEWELL TOWNSHIP, BEAVER COUNTY
MY COMMISSION EXPIRES NOV. 17, 1985
Member, Pennsylvania Association of Notaries

8406290272 840621
PDR ADOCK 05000334
P PDR