

TABLE 3.2.B (CONTINUED)

INSTRUMENTATION THAT INITIATES OR CONTROLS THE CORE AND CONTAINMENT
COOLING SYSTEMS

Minimum No. Of Operable Instrument Channels Per Trip System(1)	Trip Function	Trip Level Setting	Number of Instrument Channels Provided by Design	Remarks
2 per 4 KV Bus	Emergency Transformer Degraded voltage (Inverse time - voltage). (CV-6)	87% (+/- 5%) of Rated Voltage. Tests at 2940 volts in 30 seconds (+/- 10%).		<ol style="list-style-type: none"> 1. Trips emergency transformer feed to 4KV emergency bus. 2. Fast transfer permissive.

8406290346 840625
PDR ADDCK 05000277
P PDR