



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV

611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-8064

AUG 24 1995

MEMORANDUM TO: Elinor G. Adensam, Deputy Director
Division of Reactor Projects - III & IV

FROM: *for* Thomas P. Gwynn, Director *Thomas P. Gwynn*
Division of Reactor Safety

SUBJECT: TASK INTERFACE AGREEMENT (TIA) - PLANNING AND SCHEDULING
MAINTENANCE ACTIVITIES DURING SHUTDOWN OPERATIONS (95TIA004)

The purpose of this memorandum is to inform you that the subject TIA, which was requested by my memorandum to you on March 2, 1995, no longer requires a response and is, hereby, withdrawn. The TIA was written to request your review and guidance concerning the appropriateness of the observed sequencing and planning of maintenance activities during a recent refueling outage at San Onofre Nuclear Generating Station, Unit 2.

Our basis for withdrawal of the subject TIA is that during a subsequent Region IV inspection of the San Onofre Nuclear Generating Station, Unit 3 refueling outage, we learned that licensee management has taken on a new philosophy in regard to planning and scheduling of maintenance activities. Now, a more conservative approach has been taken in the sequencing and planning of maintenance activities during refueling outages specifically concerning switchyard and emergency diesel generator maintenance activities during high risk evolutions involving reduced reactor coolant system inventory. In addition, the licensee provided information in a pre-outage meeting, that in the future licensee management will continue with this more conservative philosophy.

If you have any concerns or questions, please feel free to contact me.

cc:
G. Holahan, NRR/DSSA
E. Butcher, NRR/PSAB
Director, DRS - RI, II, & III
RIV Coordinator, OEDO
T. Quay, NRR

HODS 1/0

9509270160 950824
PDR ADDCK 05000361
P PDR

PDR: per E. Brown