

NOTICE OF VIOLATION

Commonwealth Edison Company
Braidwood Station
Braceville, Illinois

Docket Nos. 50-456; 50-457
License Nos. NPF-72; NPF-77

As a result of an inspection conducted from July 11 through August 21, 1995, and in accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," the following violation was identified:

10 CFR Part 50, Appendix B, Criterion XVI, requires that measures be established to assure that conditions adverse to quality, such as failures, malfunctions, deficiencies, deviations, defective material and equipment, and nonconformances are promptly identified and corrected.

Contrary to the above:

The poor material condition of the auxiliary building floor drain system, which resulted in the system's inability to fulfill its design function, was not promptly corrected.

This is a Severity Level IV violation (Supplement I) (50-456/95010-01(DRP)).

Pursuant to the provisions of 10 CFR 2.201, Commonwealth Edison is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington D.C. 20555 with a copy to the U.S. Nuclear Regulatory Commission, Region III, 801 Warrenville Road, Lisle, Illinois, 60532, and a copy to the NRC Resident Inspector at the Braidwood Station within 30 days of the date of the letter transmitting this Notice of Violation. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or a demand for information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Lisle, Illinois
this 20 day of September, 1995