

SHAW, PITTMAN, POTTS & TROWBRIDGE

A PARTNERSHIP OF PROFESSIONAL CORPORATIONS

1800 M STREET, N. W.
WASHINGTON, D. C. 20036

(202) 822-1000

TELECOPIER

(202) 822-1099 & 822-1199

RAPIFAX 100

(202) 822-1072

TELEX

89-2693 (SHAWLAW WSH)

CABLE "SHAWLAW"

JOHN F. DALY*

B. SCOTT CUSTER, JR.

COUNSEL

DEBORAH M. BAUSER
SCOTT A. ANENBERG
CAMPBELL KILLER
PAUL M. THOMAS
JOHN M. BRYSON, II
GEORGE F. ALBRIGHT, JR.*
DAVID J. CYNAMON
SETH H. HOOGASIAN
SHEILA MCC. HARVEY
DELISSA A. RIDGWAY
KENNETH J. HAUTMAN
DAVID LAWRENCE MILLER
FREDERICK L. KLEIN
STEVEN P. PITLER
RICHARD J. PARRINO
ELLEN A. FRYDEL
ROBERT C. BOEHM
MARIE N. DOLAND
THOMAS C. HILL
DIANE E. BURKLEY
L. DUANE CHEEK
HANNAH E. M. LIESERMAN
JUDITH A. SANDLER
EDWARD D. YOUNG, III
ANDREW D. ELLIS
RICHARD A. SAMP
THOMAS E. CROCKER, JR.
VICKI R. HARDING
PETER J. FERRARA
HELEN TORELLI

MARTHA BOONE ROWAN*
KENNETH R. MILLER
WENDELIN A. WHITE
STANLEY M. BARG
LESLIE M. SMITH
VIRGINIA S. RUTLEDGE
KATHERINE D. CHEEK
TRAVIS T. BROWN, JR.
RICHARD B. KRONTHAL
STEPHEN B. HEIMANN
SANDRA E. BRUSCA
EILEEN L. BROWNELL
RAMELA H. ANDERSON
ALEXANDER D. TOMASZCZUK
JEFFREY J. A. GIBBS
LAURENCE W. COHEN
PHILIP D. PORTER
MICHAEL A. SWIGER
ELLEN SHERIFF
ANITA J. FINKELSTEIN
EILEEN M. GLEIMER
DAVID R. SAHR
C. BOWDOIN TRAIN
JEFFREY W. KAMPELMAN
KENNETH A. GALLO
KENNETH D. AUERBACH
ALAN D. WASSERMAN
DAVID K. RYAN
RICHARD K. A. BECKER
WILBERT WASHINGTON II
* NOT ADMITTED IN D.C.

RAMSAY D. POTTS, P.C.
STUART L. PITTMAN, P.C.
GEORGE F. TROWBRIDGE, P.C.
STEPHEN D. POTTS, P.C.
GERALD CHARNOFF, P.C.
PHILLIP D. BOSTWICK, P.C.
R. TIMOTHY HANLON, P.C.
GEORGE M. ROGERS, JR., P.C.
FRED A. LITTLE, P.C.
JOHN B. RHINELANDER, P.C.
BRUCE W. CHURCHILL, P.C.
LESLIE A. NICHOLSON, JR., P.C.
MARTIN D. KRALL, P.C.
RICHARD J. KENDALL, P.C.
JAY E. SILBERG, P.C.
BARBARA H. ROSSOTTI, P.C.
GEORGE V. ALLEN, JR., P.C.
FRED DRASNER, P.C.
R. KENLY WEBSTER, P.C.
NATHANIEL P. BRZED, JR., P.C.
MARK AUGENBLICK, P.C.
ERNEST L. BLAKE, JR., P.C.
CARLETON S. JONES, P.C.
THOMAS A. BAXTER, P.C.
JAMES M. BURGER, P.C.
SHELDON J. WEISEL, P.C.
J. PATRICK HICKEY, P.C.
J. THOMAS LENHART, P.C.
STEVEN L. MELTZER, P.C.
DEAN D. AULICK, P.C.

JOHN ENGEL, P.C.
C. THOMAS WICKS III, P.C.
CHARLES B. TEMKIN, P.C.
STEPHEN B. HUTTNER, P.C.
WINTHROP N. BROWN, P.C.
JAMES B. HAMLIN, P.C.
RANDAL B. KELL, P.C.
ROBERT E. ZAHLER, P.C.
ROBERT S. ROBBINS, P.C.
STEVEN M. LUCAS, P.C.
DAVID M. RUBENSTEIN, P.C.
MATIAS F. TRAVIESO DIAZ, P.C.
VICTORIA J. PERKINS, P.C.
JOHN H. O'NEILL, JR., P.C.
JAY A. EPSTEIN, P.C.
JEFFERY L. YABLON, P.C.
JACK MCKAY, P.C.
RICHARD E. GALEN
ELISABETH M. PENOLETON
HARRY H. GLASSPIEGEL
THOMAS H. MCCORMICK
WILLIAM P. BARR
CHARLES H. MONTAGNE
JEAN M. CALLOWAY
JOHN L. CARR, JR.
PHILIP J. HARVEY
ROBERT M. GORDON
BARBARA J. MORGAN
BONNIE S. GOTTLIEB
HOWARD H. SHAFFERMAN

June 27, 1984

WRITER'S DIRECT DIAL NUMBER

(202) 822-1051

HAND DELIVERED

Sheldon J. Wolfe
Administrative Judge
Chairman, Atomic Safety and
Licensing Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

BY FEDERAL EXPRESS

Dr. David L. Hetrick
Administrative Judge
Atomic Safety and Licensing Board
Professor of Nuclear Engineering
University of Arizona
Tucson, Arizona 85271

BY FEDERAL EXPRESS

Dr. James C. Lamb, III
Administrative Judge
Atomic Safety and Licensing Board
313 Woodhaven Road
Chapel Hill, North Carolina 27514

In the Matter of
Metropolitan Edison Company, Et Al.
(Three Mile Island Nuclear Station, Unit No. 1)
Docket No. 50-289-OLA and ASLBP 83-491-04-OLA
(Steam Generator Repair)

Dear Administrative Judges:

For the information of the Hearing Board and the parties,
I am enclosing a copy of a letter sent today by Licensee

8406290379 840627
PDR ADDCK 05000289
G PDR

D503

SHAW, PITTMAN, POTTS & TROWBRIDGE
A PARTNERSHIP OF PROFESSIONAL CORPORATIONS

Sheldon J. Wolfe
Dr. David L. Hetrick
Dr. James C. Lamb, III
June 27, 1984
Page Two

to the NRC staff reporting on steam generator leakage recently
detected at TMI-1.

Sincerely,

Bruce W. Churchill
Bruce W. Churchill *per D&T*

BWC/pp
Enclosure
cc: Service List

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Before the Atomic Safety and Licensing Board

In the Matter of)
METROPOLITAN EDISON COMPANY, ET AL.) Docket No. 50-289-OLA
(Three Mile Island Nuclear) ASLBP 83-491-04-OLA
Station, Unit No. 1) (Steam Generator Repair)

SERVICE LIST

Sheldon J. Wolfe
Administrative Judge
Chairman, Atomic Safety and
Licensing Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Dr. David L. Hetrick
Administrative Judge
Atomic Safety and Licensing Board
Professor of Nuclear Engineering
University of Arizona
Tucson, Arizona 85271

Dr. James C. Lamb, III
Administrative Judge
Atomic Safety and Licensing Board
313 Woodhaven Road
Chapel Hill, North Carolina 27514

Richard J. Rawson, Esq.
Mary E. Wagner, Esq.
Office of Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Atomic Safety and Licensing Appeal
Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555


Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docketing and Service Section (3)
Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Joanne Doroshow, Esq.
Louise Bradford
Three Mile Island Alert, Inc.
315 Peffer Street
Harrisburg, Pennsylvania 17102

Jane Lee
183 Valley Road
Etters, Pennsylvania 17319

Norman Aamodt
R. D. 5, Box 428
Coatesville, Pennsylvania 19320



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

5211-84-2161
June 27, 1984

Office of Nuclear Reactor Regulations
Attn: John F. Stolz, Chief
Operating Reactors Branch No. 4
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Stolz:

Three Mile Island Nuclear Station, Unit I (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
TMI-1 Steam Generator Leakage Testing

This letter is to provide you with additional information now available on the condition of the TMI-1 steam generators.

As you are aware, secondary chemistry data are routinely monitored and evaluated for trends at TMI-1 as part of our steam generator leakage monitoring program. Late last week, gradually increasing boron, cesium and tritium concentrations, as well as slight decreases in pH, were found to indicate a small increase in leakage in the "B" steam generator. The leak rate was determined to be approximately 1.5 gph under the current cold RCS conditions (about 300 psig). Although a rough projection to hot RCS conditions indicates a primary-to-secondary leak rate below the GPU administrative limit of 7 gph (and the Technical Specification limit of 60 gph), additional investigations of the change in leak rate are being conducted.

Bubble tests of tubing above approximately the eleventh tube support plate have been conducted in the "A" and "B" steam generators. One tube (80-45) in the "B" steam generator was identified as bubbling significantly. Tube 80-45 has bubbled slightly and intermittantly during past bubble tests. By using stoppers at various levels in the bubbling tube, it has been determined that primary coolant can pass through a crack very high in the upper tube sheet, then down through the tight tube-to-tubesheet crevice

5211-84-2161
Mr. John F. Stolz

-2-


comprising the new joint, and into the secondary system. Some leakage via such pathways has always been predicted for the mechanical tube-to-tubesheet joints. Because of the high bubble rate for this joint, the tube will be plugged before return to service.

Additional inspection of the leaking joint is planned using a fibroscope. Drip tests of the "B" lower tubesheet area are also scheduled to identify significant leakage contributors, if any, in the lower regions of the steam generator. Eddy current testing of the full length of the tube is also planned as confirmation that leakage is past the joint, not from lower in the tube. While the ECT equipment is in place, a sample population of other tubes will also be monitored. All these tests are scheduled for completion this week or early next week.

In the course of performing the highly sensitive bubble testing, 14 other tubes, 6 plugged and 8 unplugged were seen to have faintly visible, very slight bubble formation. Seven tubes were in the "B" OTSG and seven in the "A" OTSG (which had no evidence of a leakage increase based on chemistry monitoring). Stopper tests of the unplugged bubbling tubes indicated leakage past the tube-to-tubesheet joint in all cases. This type of bubbling has been seen in past tests, and is considered to be acceptable and not unexpected for mechanical joints such as the kinetic expansion and the mechanical rolled plug. No repairs are planned or considered necessary for these tubes, but their locations have been noted for special observation during any future bubble tests.

Subject to review as further testing and examinations are completed, GPU has concluded that earlier evaluations of acceptability of the steam generators for service are unaffected by the additional information.

Sincerely,


H. D. Hukill
Director I-1

HDH/MJG/CWS/mle

cc: R. Conte
C. McCracken
H. Silver