



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-354

HOPE CREEK GENERATING STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 81
License No. NPF-57


1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company (PSE&G) dated January 11, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-57 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 81, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into the license. PSE&G shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance and shall be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: September 25, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 81

FACILITY OPERATING LICENSE NO. NPF-57

DOCKET NO. 50-354

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

<u>Remove</u>	<u>Insert</u>
ix	ix
xviii	xviii
3/4 3-103	3/4 3-103
3/4 3/104	3/4 3-104
B 3/4 3-7	B 3/4 3-7

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
Table 3.3.7.4-1 Remote Shutdown Monitoring Instrumentation	3/4 3-75
Table 3.3.7.4-2 Remote Shutdown Systems Controls	3/4 3-77
Table 4.3.7.4-1 Remote Shutdown Monitoring Instrumentation Surveillance Requirements	3/4 3-82
Accident Monitoring Instrumentation	3/4 3-84
Table 3.3.7.5-1 Accident Monitoring Instrumentation	3/4 3-85
Table 4.3.7.5-1 Accident Monitoring Instrumentation Surveillance Requirements	3/4 3-87
Source Range Monitors	3/4 3-88
Traversing In-Core Probe System	3/4 3-89
Radioactive Liquid Effluent Monitoring Instrumentation	3/4 3-91
Table 3.3.7.9-1 Radioactive Liquid Effluent Monitoring Instrumentation	3/4 3-92
Table 4.3.7.9-1 Radioactive Liquid Effluent Monitoring Instrumentation Surveillance Requirements	3/4 3-94
Radioactive Gaseous Effluent Monitoring Instrumentation	3/4 3-96
Table 3.3.7.10-1 Radioactive Gaseous Effluent Monitoring Instrumentation	3/4 3-97
Table 4.3.7.10-1 Radioactive Gaseous Effluent Monitoring Instrumentation Surveillance Requirements	3/4 3-100
3/4.3.8 DELETED	3/4 3-103
3/4.3.9 FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION	3/4 3-105
Table 3.3.9-1 Feedwater/Main Turbine Trip System Actuation Instrumentation	3/4 3-106

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>INSTRUMENTATION</u> (Continued)	
Seismic Monitoring Instrumentation	B 3/4 3-4
Meteorological Monitoring Instrumentation	B 3/4 3-4
Remote Shutdown Monitoring Instrumentation and Controls	B 3/4 3-5
Accident Monitoring Instrumentation	B 3/4 3-5
Source Range Monitors	B 3/4 3-5
Traversing In-Core Probe System	B 3/4 3-5
Radioactive Liquid Effluent Monitoring Instrumentation	B 3/4 3-6
Radioactive Gaseous Effluent Monitoring Instrumentation	B 3/4 3-6
3/4.3.8 DELETED	B 3/4 3-7
3/4.3.9 FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION	B 3/4 3-7
Figure B3/4 3-1 Reactor Vessel Water Level	B 3/4 3-8
<u>3/4.4 REACTOR COOLANT SYSTEM</u>	
3/4.4.1 RECIRCULATION SYSTEM	B 3/4 4-1
3/4.4.2 SAFETY/RELIEF VALVES	B 3/4 4-1a
3/4.4.3 REACTOR COOLANT SYSTEM LEAKAGE	
Leakage Detection Systems	B 3/4 4-3
Operational Leakage	B 3/4 4-3
3/4.4.4 CHEMISTRY	B 3/4 4-3
3/4.4.5 SPECIFIC ACTIVITY	B 3/4 4-4
3/4.4.6 PRESSURE/TEMPERATURE LIMITS	B 3/4 4-5
Table B3/4.4.6-1 Reactor Vessel Toughness	B 3/4 4-7
Figure B3/4.4.6-1 Fast Neutron Fluence (E>1Mev) at (1/4)T as a Function of Service life	B 3/4 4-8

INSTRUMENTATION

3/4.3.8 DELETED

THIS PAGE INTENTIONALLY BLANK

INSTRUMENTATION

BASES

3/4.3.8 DELETED

3/4.3.9 FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION

The feedwater/main turbine trip system actuation instrumentation is provided to initiate action of the feedwater system/main turbine trip system in the event of a high reactor vessel water level (Level 8) to mitigate potential damage to the main turbine.