

February 19, 1992

Docket No. 50-293

Mr. Roy A. Anderson  
Senior Vice President - Nuclear  
Boston Edison Company  
Pilgrim Nuclear Power Station  
Rocky Hill Road  
Plymouth, Massachusetts 02360

Dear Mr. Anderson:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11, "RESOLUTION OF GENERIC ISSUE 48, 'LCO'S FOR CLASS 1E VITAL INSTRUMENT BUSES,' AND 49, 'INTERLOCKS AND LCO'S FOR CLASS 1E TIE BREAKERS,' PURSUANT TO 10 CFR 50.54(f) FOR PILGRIM (TAC NO. MB2450)

On July 18, 1991, the NRC issued Generic Letter (GL) 91-11, which contained the staff's resolution of Generic Issues 48 and 49. The GL requires that licensees certify that their procedures contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters or other onsite power sources for VIB, and tie breakers. If such procedures do not exist, a justification demonstrating the reasons why procedural controls are not needed is required.

By letter dated February 5, 1992, you responded to the GL. You indicated that procedures for time limitations and surveillance requirements are in place at your site.

The staff has reviewed your response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's activities on TAC No. MB2450.

Sincerely,

Original signed by  
Ronald B. Eaton, Senior Project Manager  
Project Directorate I-3  
Division of Reactor Projects I/II  
Office of Nuclear Reactor Regulation

cc: See next page

OFC	:LA:PDI-3	:PM:PAH	:NRR:SELB	92	:(A)D:PDI-3
NAME	:MRushbrook	:Eaton:cir	:OChopra		:AMendiola
DATE	:02/14/92	:02/18/92	:02/19/92		:02/19/92

OFFICIAL RECORD COPY  
Document Name: PILGRIM RESP GL 9111

QFO1  
110

OFFICIAL RECORD COPY

9202270036 920219  
PDR ADDCK 05000293  
P PDR

Mr. R. A. Anderson

Pilgrim Nuclear Power Station

cc:

Mr. William C. Rothert, Acting  
Vice President of Operations  
and Station  
Pilgrim Nuclear Power Station  
RFD #1 Rocky Hill Road  
Plymouth, Massachusetts 02360

Mr. H. Vernon Oheim  
Manager, Reg. Affairs Dept.  
Pilgrim Nuclear Power Station  
RFD #1 Rocky Hill Road  
Plymouth, Massachusetts 02360

Resident Inspector  
U. S. Nuclear Regulatory Commission  
Pilgrim Nuclear Power Station  
Post Office Box 867  
Plymouth, Massachusetts 02360

Ms. Elaine D. Robinson  
Nuclear Information Manager  
Pilgrim Nuclear Power Station  
RFD #1, Rocky Hill Road  
Plymouth, Massachusetts 02360

Chairman, Board of Selectmen  
11 Lincoln Street  
Plymouth, Massachusetts 02360

Mr. Dale C. Jenkins, Jr.  
Secretary of Public Safety  
Executive Office of Public Safety  
One Ashburton Place  
Boston, Massachusetts 02108

Office of the Commissioner  
Massachusetts Department of  
Environmental Protection  
One Winter Street  
Boston, Massachusetts 02108

Mr. David Rodham, Director  
Massachusetts Civil Defense Agency  
400 Worcester Road  
P.O. Box 1496  
Framingham, Massachusetts 01701-0317  
Attn: James Muckerheide

Office of the Attorney General  
One Ashburton Place  
20th Floor  
Boston, Massachusetts 02108

Chairmen, Citizens  
Urging Responsible Energy  
P. O. Box 2621  
Duxbury, Massachusetts 02331

Mr. Robert M. Hallisey, Director  
Radiation Control Program  
Massachusetts Department of  
Public Health  
305 South Street  
Boston, Massachusetts 02130

Citizens at Risk  
P. O. Box 3803  
Plymouth, Massachusetts 02361

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

W. S. Stowe, Esquire  
Boston Edison Company  
800 Boylston St., 36th Floor  
Boston, Massachusetts 02199

Mr. John Dietrich  
Licensing Division Manager  
Boston Edison Company  
25 Braintree Hill Park  
Braintree, Massachusetts 02184

DISTRIBUTION:

~~Docket File~~ (50-293)

NRC & Local PDR

PDI-3 R/F

AVarga

JCalvo

AMendiola

MPushbrook

REaton

OGC

SHoffman

OChopra

ACRS(10)

J. Linville, Region 1

R. Lobel