

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004
(412) 393-5206
(412) 643-8089 FAX

GEORGE S. THOMAS
Division Vice President
Nuclear Services
Nuclear Power Division


September 20, 1995

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

**Subject: Beaver Valley Power Station, Unit No. 2
Docket No. 50-412, License No. NPF-73
Boration Systems Technical Specification Bases Change**

Attached is a change to Technical Specification Bases 3/4.1.2, which involves replacing "EOL" and "equilibrium" with "BOL" and "peak", respectively, and is based on a change in methodology and assumptions used for calculating boration requirements. The need for this change was identified during a conference call on this subject between the NRC staff members, Westinghouse and Beaver Valley staff, and is consistent with a similar change incorporated in the Unit 1 technical specifications, submitted by Duquesne Light Company on February 28, 1995, and approved by the NRC on June 1, 1995. Additionally, the Unit 2 boration water volumes have been evaluated and it has been determined that the current volumes are conservative; therefore, no change to these volumes is required. Based on the above, it is requested that the Commission issue the enclosed revised Bases page B 3/4 1-3 for inclusion in the technical specifications.

Sincerely,


George S. Thomas

Enclosure

c: Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. D. S. Brinkman, Sr. Project Manager

200014

9509280331 950920
PDR ADOCK 05000412
P PDR

ADD 1/1