

CP&L

Carolina Power & Light Company

Brunswick Nuclear Project
P. O. Box 10429
Southport, N.C. 28461-0429

FEB 24 1992

FILE: B09-13510C

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555


BRUNSWICK STEAM ELECTRIC PLANT UNIT 2
DOCKET NO. 50-324
LICENSE NO. DPR-62

SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (2-SR-92-001)

Gentlemen:

At 0000 hours (EST) on January 13, 1992, a fourteen day Limiting Condition for Operation (LCO) was initiated due to an inoperable fire detectors in Zone 14 located in the Unit 2 Reactor Building, 117' elevation. Appropriately stationed fire watches were established at that time. A work order was initiated to repair the detector. The fourteen day LCO was exceeded on January 27, 1992 at 0000 hours. The detectors had not been returned to service prior to the expiration of the LCO due to scheduling constraints and a lack of replacement detectors. Replacement detectors were subsequently obtained and installed. The LCO was cancelled on January 30, 1992 at 0530 hours. Until cancellation of the LCO, the required fire watches remained in effect.

Very truly yours,



J. W. Spencer, General Manager
Brunswick Nuclear Project

RSK/

cc: Mr. S. D. Ebner
Mr. N. B. Le
BSEP NRC Resident Office
NRC Document Control Desk

9202270192 920224
PDR ADOCK 05000324
S PDR

JE22 1/0