

DO NOT REMOVE

LICENSE AUTHORITY FILE COPY

APPENDIX A

CHANGE NO. 8 TO TECHNICAL SPECIFICATIONS

LICENSE NO. R-86

LOCKHEED AIRCRAFT CORPORATION

DATE: March 1, 1971

9202270193  
2218

A-34C

DO NOT REMOVE

LOCKHEED AIRCRAFT CORPORATION  
RADIATION EFFECTS REACTOR (RER)  
TECHNICAL SPECIFICATIONS

TABLE OF CONTENTS

	<u>PAGE</u>
SECTION A. SITE	
1. Physical Location	1
2. Description of Controlled Area	1
SECTION B. BUILDING	
1. Reactor Building	2
2. Operations Building	2
SECTION C. RADIATION MONITORING	
1. RER Storage Pool	3
2. Environmental Sampling	3
3. Criticality Alarm	4
SECTION D. WASTE DISPOSAL SYSTEM	5
SECTION E. EMERGENCY SYSTEMS	6
SECTION F. CORE COMPONENT STORAGE	
1. Inventory	7
2. Storage	7
3. Fuel Element Storage Racks	7
4. Preparation for Shipment	7
SECTION G. REACTOR SHIELD TANKS	9
SECTION H. REACTOR DESIGN	
1. Location	10
2. Mechanical Design of the RER Pressure Vessel	10
3. RER Vessel Internal Structure	11
4. Control System and Operating Limitations	11
5. Core Operating Limitations	13

	<u>PAGE</u>
SECTION I. NUCLEAR AND PROCESS INSTRUMENTATION	
1. Nuclear Instrumentation	14
2. Process Instrumentation	14
SECTION J. EXPERIMENTAL FACILITIES	
1. General	15
2. Lithium Hydride Shield	15
SECTION K. REACTOR COOLANT SYSTEM	16
SECTION L. ADMINISTRATIVE AND PROCEDURAL SAFEGUARDS	
1. Administrative Organization and Staffing	17
2. Procedural Safeguards	17

## A. SITE

### 1. PHYSICAL LOCATION

The reactor facility is located in Dawson County, Georgia, on a site which is nominally described by the parallels  $34^{\circ} 20.6$  minutes north latitude and  $34^{\circ} 24$  minutes north latitude, and the meridians  $84^{\circ} 08$  minutes west longitude and  $84^{\circ} 12$  minutes west longitude.

### 2. DESCRIPTION OF CONTROLLED AREA

The reactor is located within the Georgia Nuclear Laboratories, a controlled area of roughly 10,000 acres. The nearest uncontrolled areas are the south perimeter fence (8240 feet south), the east perimeter fence (9820 feet east) and the west perimeter fence (10020 feet west). The minimum distance to the north perimeter fence is 14285 feet. All land within that area is controlled by Plant Security, and the nearest routinely occupied above-ground work area is about 8845 feet from the reactor. A chain link exclusion fence surrounds the reactor generally at a radius of 3600 feet. A segment of the fence North East of the reactor is slightly closer than 3600 feet.

## B. BUILDING

### 1. REACTOR BUILDING

The reactor building is of conventional construction with steel I-beam columns and built-up truss work. Siding and roofing are corrugated aluminum. The building is not heated; however, during periods when the ambient temperature is below freezing, the reactor will not be raised from the pool unless heat is provided to prevent auxiliary piping (e.g. shield tank plumbing system) from freezing. Roof mounted fans are provided to ventilate the building as necessary.

### 2. OPERATIONS BUILDING

The operations building is an underground concrete structure with approximately 2 feet of concrete and 5 feet of earth on the roof to provide shielding.

## C. RADIATION MONITORING

### 1. RER STORAGE POOL

While reactor fuel is stored in the RER storage pool, grab samples of the storage pool water shall be collected at least weekly and analyzed for gross beta-gamma and gross alpha activity. If the pool pump is not operable at the time the sample is to be taken, the sample shall be taken from within 3 feet of one of the baskets containing stored fuel elements. If a sample has a radioactivity concentration in excess of  $1 \times 10^{-2}$   $\mu\text{C}/\text{cc}$ , an investigation shall be made as to the cause. If it is found that a fuel element is leaking, action shall then be taken to identify the leaking element and seal it in a leak-proof container.

### 2. ENVIRONMENTAL SAMPLING

A minimum of two continuous water samplers shall be located in the Etowah River, at least one being located 3600 feet or more upstream from the reactor and at least one 3600 feet or more downstream from the reactor. Samples shall be collected and analyzed at least twice monthly; the collection interval shall be approximately two weeks except when weather conditions make the sample collecting points inaccessible. Samples shall be analyzed for gross beta-gamma and gross alpha activity.

A continuous particulate air sampler at the RER demineralizer building entrance shall be operated. Filter samples from the particulate air sampler shall be collected and analyzed weekly for gross alpha activity. Operation of the air sampling system may be discontinued after all the fuel is shipped from the site.

Soil and vegetation samples shall be collected and analyzed for gross beta-gamma and gross alpha activity at least quarterly.

### 3. CRITICALITY ALARM

While reactor fuel is stored in the RER storage pool, a criticality alarm system shall be operable. The location, sensitivity, and alarm set point of the monitoring device for the criticality alarm system shall comply with the requirements set forth in the Code of Federal Regulations, Title 10, Part 70, Paragraph 70.24 (a) (1) as amended. The system shall alarm in the Reactor Building and Plant Security Headquarters. Response to alarms shall be made by Plant Security personnel in accordance with procedures approved by the Procedure Review Committee. The alarm system shall be checked for operability at least weekly. If the criticality alarm system is non-operable, the radiation level in the RER storage pool shall, during the first 72 hours of such non-operable periods, be monitored at least once every 24 hours by an individual authorized by Health Physics utilizing an operable currently-calibrated portable survey meter. After 72 hours, the monitoring frequency shall be increased to at least once every 8 hours until the criticality alarm system is operable. No activity involving fuel handling nor pool water transfer other than normal circulation shall be conducted while the criticality alarm system is inoperable.

#### D. WASTE DISPOSAL SYSTEM

The REP waste disposal system is designed to handle activation products generated by RER operation. Features incorporated in the design include demineralizer resin beds with decontamination factors of  $10^3$  to  $10^4$ ; two 5000 gallon waste decay tanks for retention of waste water with high radioactivity concentrations; and one 150,000 gallon hold and drain tank which may be used for decay and dilution of activity prior to release to the seepage basin.

The activity levels of radioactive waste released to the seepage basin will not exceed limits specified in 10 CFR 20 for restricted areas. The total annual release will not exceed 1 curie.

Radioactive waste materials will not be permanently disposed of by burial at the site except as provided by 10 CFR 20.304.



E. EMERGENCY SYSTEMS

There shall be no requirement at the REF for emergency cooling or emergency power.

## P. CORE COMPONENT STORAGE

### 1. INVENTORY

The number of irradiated fuel elements on hand at the REF is 56. The number of irradiated control rod fuel assemblies on hand at the REF is 8. There are also elsewhere at LQNL 38 new fuel elements and 5 new control rods. When being prepared for shipment off-site, these fuel elements and control rods may be brought to the REF only in accordance with procedures approved by the Procedure Review Committee. Other identifiable radioactive material (i.e., licensed byproduct material as distinguished from activated reactor components and activated tools and experimental equipment) consists of the antimony-124 reactor startup source (currently less than 10 curies) and about 10,000 curies of encapsulated cobalt-60. All core components and byproduct material may be disposed of by authorized means.

### 2. STORAGE

Irradiated fuel elements shall be stored in fuel element storage racks at the bottom of the storage pool. Irradiated control rods shall be stored either in control rod storage racks along the pool wall; or in control rod storage positions, two of which are available in each fuel element storage rack. Antimony-124 shall be stored in the pool or in the pressure vessel. Any cobalt-60 in storage at the REF shall be stored in the pool. Fuel shall not be transferred to, nor stored in, the reactor.

### 3. FUEL ELEMENT STORAGE RACKS

Fuel element storage racks are constructed of aluminum, and contain layers of aluminum-clad cadmium around the outside of the fuel plate region and between each tier of four fuel elements. Each rack shall hold a maximum of 20 fuel elements in a 4 x 5 array. The 4 x 5 array has accommodations for storing two control rods in fuel element positions. The calculated U-235 loading required for the fuel elements in one fuel element storage rack to achieve criticality, assuming no leakage, is 211 gms per element. When leakage is assumed from the sides only, a full rack of 211 gm elements would have a calculated multiplication constant of 0.78.

### 4. PREPARATION FOR SHIPMENT

When fuel is being prepared for shipment off-site, fuel element end boxes may be removed from the fuel assemblies before the fuel is loaded into the cask. The poison sections and lifting bails may be removed from the control

rods before the control rod fuel sections are loaded into the cask. Such removal shall be accomplished only in accordance with detailed procedures approved by the Procedure Review Committee. Casks used for removal and shipment of fuel shall have been duly licensed for such usage in accordance with appropriate AEC & DOT regulations. Procedural control shall be used to assure that no more than one fuel assembly at a time is out of a storage rack or a shipping cask. Individual fuel assemblies shall be handled only under the direct personal surveillance of the Reactor Supervisor.

### 0. REACTOR SHIELD TANKS

The reactor vessel is surrounded by segmented shield tanks. The shield tanks in the quadrant 180° away from car position 3/4 shall be approximately 20 inches thick. The shield tanks in any of the other three quadrants may be either 8 inches or 20 inches thick. The tanks may be either filled or drained. The shield tanks may be removed from the reactor.

## H. REACTOR DESIGN

### 1. LOCATION

The vertical center line of the reactor is located approximately 4'6" from the NE end of the reactor pool. The pool is rectangular and is 11-1/2' by 10' by 36-1/2' deep. There is also a storage pool which joins the reactor pool at the SW end. An aluminum gate is provided for separation of the pools. In plan view, the storage section resembles an un-symmetrical letter T. Rough dimensions are stem, 17' by 8'; cross, 24' by 6'. The depth of both of these parts is 21' below the finished reactor building floor. Curbing for both pools is continuous and extends one foot above the finished floor.

### 2. MECHANICAL DESIGN OF THE RER PRESSURE VESSEL

The RER stainless steel pressure vessel is designed for 150 psig at 200°F. The minimum design and construction requirements of the vessel conform to the ASME Boiler and Pressure Vessel Code, Section VIII, 1956 Edition, and the vessel bears the official code stamp. The pressure vessel is supported by two steel bands welded to four equally spaced vertical members which rest on bearing plates bolted to the platform, which in turn rests on top of the hydraulic lift. The reactor support system has been designed to support a one-fourth G side load on the reactor and shield tank.

The design loading of the hydraulic lift is 42,000 pounds, and it is designed for a total moment of 16,500 foot-pounds from eccentric loading and other causes. The lift has a stroke of 30 feet and is capable of raising the reactor at a maximum speed of 10 feet per minute. Shoes which slide on T-rails fastened to the pool walls guide the upper end of the ram through its full travel and restrain the top of the reactor to within one inch of its nominal path.

Two parallel bleed lines, controlled by individual solenoids which fail open on loss of power or on improper operation of the safety doors in the operations building, are used to lower the reactor. The bleed lines may be valved off so that the reactor may be kept in any desired position regardless of the status of electric power and other automatic interrupt devices.

The reactor upper closure is a flat, circular, forged plate 3 feet 9 inches in diameter and 5 inches thick. This closure is equipped with holes to accommodate the control rods, the regulating rod, and the fission chamber. It can be removed to provide access to the internals of the pressure vessel. The upper closure may be located either on the reactor or off the reactor. A stand at one end of the storage pool may be used for storage of the upper closure.

In addition to the opening closed by the reactor upper closure, the pressure vessel has four penetrations above the core, consisting of 6-inch instrument ports. Below the top of the core, only four penetrations exist. These are

four 8-inch pipes which serve as two primary coolant inlets and two primary coolant outlets. No new penetration shall be added to the pressure vessel or reactor closure.

### 3. RER VESSEL INTERNAL STRUCTURE

Internally the vessel consists principally of the inner tank, the hold-down plate, and the core support structure. The inner tank, which is open at the bottom and top, and otherwise has no penetration, serves as a flow guide. The hold-down plate, located above the core, covers the entire core section. Since flow through the core is down, the hydraulic loading of the hold-down plate is not a factor. If the reactor should be inverted, the maximum loading on the hold-down plate would be less than 10,000 psi. The yield stress for the hold-down plate is 32,000 psi at 200°F.

The core support structure consists of a grid plate to position the various core components, a support plate which retains fuel elements, reflector elements and the start-up source within the core and a control rod shock damper which consists of a main cone, individual shock absorber tubes, and associated structural members. Its function is to transmit the shock load which the control rods impart subsequent to scram to the pressure vessel wall. As a backup to the shock damper, a mechanical stop is welded to the bottom of the pressure vessel.

The entire core structure is supported by a ring welded to the pressure vessel wall. The design criteria on stress for these structures are a maximum stress of 7200 psi on the core support bracket, 2440 psi maximum stress on the support plate, 14,500 psi maximum stress on the grid plate, and 5600 psi on the cone. The yield stress for all of these components is in excess of 25,000 psi.

Fuel elements and control rods shall not be loaded into the RER vessel. The hold-down plate, inner tank, and grid and scram damper assembly may be in the RER vessel, or may be stored in the reactor building or storage pool. The start-up source, dummy fuel elements, reflector assemblies and flow baffles may be left in the RER vessel or may be removed from the vessel.

### 4. CONTROL SYSTEM AND OPERATING LIMITATIONS

#### a. Control Rod Design

The control rods are fuel and poison sections enclosed by aluminum tubes approximately 3" square by 85" long. Each has a grapple head at the top and a spring-loaded tip plunger at the bottom. The fuel section contains an aluminum strap extension at the top which extends the length of the poison section. The poison section, a square aluminum tube, slides onto the strap

and fits flush against the top of the fuel element assembly. The entire fuel-poison assembly fits into the control rod tube. A mechanical attachment on the fuel-poison section prevents assembly of the control rod if the fuel-poison section is inverted. The control rod is guided and supported within the core by means of four rollers above the core and four rollers below the core. The lower end of the control rod fits within a scram guide tube, which also acts as the hydraulic damper during scram. The poison section is a square cadmium tube, 0.02 inch thick and 32-1/4 inches long. It is clad with a 0.02-inch layer of aluminum on each side so that all edges are sealed. The length provides approximately 4-1/2 inches overlap at each end of the active fuel plates in the reactor core.

The fuel section, which contains about 111 grams of highly enriched U-235, is similar to a standard fuel element; however, it is smaller and contains 14 plates. A mechanical stop at the bottom, and the affixed poison, position the fuel section within the control rod.

The upper end of the control rod tube is fitted with a lifting knob, with which the control drive grapple engages by electro-magnet actuation, for lifting the control rod.

The core regulating rod is located near the periphery of the core. The regulating rod poison is a 30-70 cadmium silver alloy material. The tubular poison section, which has a nominal thickness of 0.09 inch, is enclosed in a tubular aluminum sheath approximately 1-1/4 inches in diameter.

#### b. Drive Mechanisms

The four control rods are actuated by separate mechanisms, mounted to the top head of the pressure vessel. Each control rod drive mechanism consists of an electric motor, reduction unit, a rack and pinion, limit switches, an electro-magnet and grapple, a spring loaded scram tube which provides an initial 5-g accelerating force to the rods when the grapple is released. The maximum drive speed is 4.5 inches per minute.

Magnets in the control rod and a limit switch in the hold-down plate indicate by an electric signal the position of the rod when fully scrambled as well as engagement of the rod by the mechanism. A selsyn, mounted on the gear reduction casting, gives a continuous position indication of the drive and also an indication of rod position during normal reactor operations.

The regulating rod drive mechanism, mounted to the top head of the vessel, serves to drive the regulating rod. The mechanism and rod are bolted together so that the combination is an integral unit. The regulating rod drive mechanism is very similar to the control rod drive mechanism,

but no scram attachment is provided. The drive motor is designed to operate with a servo control system or under manual control.

Including spares, there are 9 control rod drive mechanisms, 3 regulating rod drive mechanisms, and 2 fission chamber drive mechanisms. The drive mechanisms may be stored either on the upper closure or elsewhere.

## 5. CORE OPERATING LIMITATIONS

a. The core, which has an active height of 24 inches, is designed on a 3-inch modulus in a 6 x 7 array with the four corner positions omitted. The moderator and coolant are light water. The reflector may be light water, or may be solid or canned aluminum or beryllium designed to conform to the unused spaces in the grid and external to the grid but within the inner tank.

b. Fuel material is uranium-aluminum alloy. The enrichment of the fuel is nominally 93% U-235. Cladding is metallurgically bonded 1100 aluminum. The fuel elements are flat plate, modified MTR type, aluminum, uranium assemblies. Each element contains 18 fuel plates having the approximate dimensions 0.060 inch thick, 2.75 inches wide, and 24.5 inches long. Each fuel plate consists of a nominal 0.020 inch thickness of uranium-aluminum alloy in a picture frame clad with a nominal 0.020 inch thick layer of 1100 aluminum. The plates are positioned in the element by aluminum side plates so that a nominal 0.108 inch wide coolant passage is provided between fuel plates. Each element is loaded with approximately 176 gms U-235. The top end of each element has a handling device. The bottom of each element is equipped with a positioning box about 3 inches square which fits into the grid. The overall length of fuel element is nominally 38.5 inches.

c. The start-up source is an antimony gamma emitter, placed in the center of a beryllium dummy fuel element, and is positioned in one of the available spare fuel element positions in the grid plate. For operation, the source provided a neutron flux of at least 15 nv at the fission chamber location. There will be no minimum source strength requirement at present. The source shall not be reactivated.

d. Fuel content verification and other core parameter determinations will normally be conducted at the CER. The following limitations will apply, however:

- (1) The maximum number of fuel elements in the core shall not exceed 33.
- (2) The maximum U-235 content of the core shall not exceed 6.2 kg.



## I. NUCLEAR AND PROCESS INSTRUMENTATION

### 1. NUCLEAR INSTRUMENTATION

The criticality alarm system described in Section C.3 shall alarm in Plant Security headquarters. Response to alarms shall be made by Plant Security personnel in accordance with procedures approved by the Procedure Review Committee. After the reactor fuel has been removed from the pool, use of the criticality alarm system may be discontinued.

### 2. PROCESS INSTRUMENTATION

The reactor storage pool water shall be monitored for pH and conductivity at least weekly while reactor fuel is stored in the pool. Conductivity and pH shall be measured utilizing either portable or fixed instrumentation. If the pump is not operating at the time the sample is to be taken, the sample shall be taken from within 3 feet of one of the baskets containing stored fuel elements. Pool water resistivity shall be maintained greater than 250,000 ohm-cm, and pool water pH shall be maintained between 6 and 7.5. A pool level monitor shall sound an alarm in Plant Security headquarters if the pool water level drops below 15 feet. The pool level monitor shall be checked weekly for operability. If the pool level monitoring system is inoperable, the pool level shall be checked visually at least once every 24 hours. After the reactor fuel has been removed, operation of the pool circulation system and monitoring of pH, conductivity and water level may be discontinued.

## J. EXPERIMENTAL FACILITIES

### 1. GENERAL

Except for the lithium hydride shield, no experiments or equipment having significant kinetic energy shall be operated in the reactor building. No experiments or equipment involving energetic fluids or materials having a potential of sudden release of chemical energy in excess of 0.1 lb of TNT shall be stored or used closer than one foot to the reactor pressure vessel. All amounts at other distances may be determined on the basis of  $R^2$  geometric attenuation subject to the further limitation that the total potential lateral loading of the pressure vessel support structure shall not exceed the allowable design loading. There shall be no restriction on use of the locomotive.

### 2. LITHIUM HYDRIDE SHIELD

A helium environment shall be maintained on the lithium hydride at all times. When installed in the facility and not in use the shield shall be stored at a positive internal pressure. Monthly checks on pressure shall be performed in order to determine the leakage rate from the shield. Gases vented from the shield will be monitored for tritium content during release to the environment. Tritium released to the environment, when averaged monthly, shall not exceed 1% of the applicable limit of the Code of Federal Regulations, Title 10, Part 20, at the site boundaries. The lithium hydride shield may be disposed of in accordance with the Code of Federal Regulations, Title 10, Part 30.

K. REACTOR COOLANT SYSTEM

There is no further need for a reactor primary cooling system. As long as reactor fuel is stored in the storage pool, the primary cooling system valving shall be set to permit the storage pool water to be circulated through the pool demineralizer and/or bypass demineralizer.

## 1. ADMINISTRATIVE ORGANIZATION AND STAFFING

### a. Organization

The Reactor Supervisor, appointed by the Lockheed-Georgia Company Chief Engineer - Experimental and Avionics - shall be responsible for, and shall maintain surveillance over, all activities within the RER exclusion fence. He shall have responsibility for maintenance and removal of equipment, maintaining the integrity of the fuel elements, and precluding the release of radioactivity. A qualified Health Physicist, appointed by the Chief Engineer - Experimental and Avionics - shall be an advisor to the Reactor Supervisor.

### b. Procedure Review Committee

A Procedure Review Committee, appointed by the Chief Engineer - Experimental and Avionics - shall monitor activities arising as a result of activities within the RER exclusion fence. As a minimum, the Procedure Review Committee shall consist of the Reactor Supervisor, the Health Physicist, and two additional scientists/engineers, one of whom shall be chairman. Each scientist/engineer on the Procedure Review Committee shall have at least 5 years of experimental, design, or operational experience with a test or power reactor. Addendum 1 lists the names and qualifications of the incumbents. When any changes are made in the Procedure Review Committee membership, Lockheed shall advise the Commission within 30 days of the nature of the changes and the names and qualifications of new members. All procedures pertaining to activities within the RER exclusion fence shall be subject to the approval of the Procedure Review Committee. Actions of the Committee shall require unanimous agreement. The Committee shall meet at least monthly.

## 2. PROCEDURAL SAFEGUARDS

### a. Exclusion Area Access Control

Plant Security shall control access to the RER exclusion fence by controlling keys to the gates. Personnel may enter the area within the 3600-foot fence provided that each such entry is governed by the provisions of administrative procedures approved by the Procedure Review Committee. Access to the Reactor Building shall be under the control of the Reactor Supervisor. The roll doors on the RER building shall be immobilized whenever the facility is not manned. All other doors into areas of the REP where radioactive materials or radiation areas are present shall be kept locked except when authorized personnel are in the area. Areas within the exclusion fence which constitute radiation areas shall be roped off and posted with appropriate radiation warning signs in accordance with the Code of Federal Regulations, Title 10, Part 20. While the reactor fuel, start-up source, and ORNL-owned Cobalt-60 are in the facility, Plant Security shall

patrol the exclusion fence at least once per week. After the reactor fuel, start-up source and Cobalt-60 have been removed, Plant Security shall patrol the exclusion fence at least once every six months. The Radiation Effects Facility shall be patrolled at least daily by Plant Security or operating personnel.

b. Emergency Procedures

Detailed emergency plans and procedures, covering all classes of potential REF incidents, shall be prepared and published in the GNL Emergency Manual. That portion of the LGNL Emergency Manual pertaining to the REF shall be reviewed and approved by the Procedure Review Committee.

c. Fuel Element Manipulation

All fuel handling operations shall be conducted in accordance with written procedures under the direct personal supervision of the Reactor Supervisor.

d. Health Physics Surveillance

Health Physics personnel shall maintain surveillance over activity involving handling of radioactive materials. The Reactor Supervisor may act as a self monitor and may provide routine health physics services for daily activities involving routine facility surveillance only.

Health Physics personnel shall specifically establish the radiation protection requirements involving the handling of radioactive material, and shall be in attendance for such activities as deemed appropriate by the Health Physicist.

e. Maintenance

Routine maintenance shall be required only on those items and systems which these specifications state must be maintained in operable condition.

Addendum 1 - 8/14/70

The members of the Procedure Review Committee as of this date are:

F. L. Amend, Reactor Supervisor  
M. M. Ham, Health Physicist  
M. A. Dewar, Scientist, Chairman  
W. E. Krull, Scientist

Summaries of their education and experience are attached.