

NUCLEAR LICENSING & SAFETY DEPARTMENT

June 19, 1984

U.S. Nuclear Regulatory Commission Region II 101 Marietta St., N.W., Suite 2900 Atlanta, Georgia 30323

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 84-024/0 - Fire
Rated Penetrations Opened to
Implement Design Change Package
AECM-84/0314

On May 22, 1984, fire rated penetrations CE365G, CE379G, CE250D and CE208D were opened to implement a design change package. A fire watch was established in accordance with Technical Specification 3.7.7. until the penetrations were resealed. The Limiting Condition for Operation (LCO) will be restored upon the closure of paperwork.

This Special Report is submitted pursuant to Technical Specification 6.9.2 since the seven (7) day LCO time limit was exceeded. This condition had no effect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

L. F. Dale

Director of Nuclear Licensing & Safety

EBS/SHH:rg

cc: Mr. J. B. Richard

Mr. R. B. McGehee

Mr. N. S. Reynolds

Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Document Control Desk S
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
Member Middle South Utilities System

8407020286 840619 PDR ADDCK 05000416 S PDR

16 JE 22