

Corrected

OPERATING DATA REPORT

DOCKET NO. 50-260
 DATE 5/1/84
 COMPLETED BY Ted Thom
 TELEPHONE 205/729-0834

OPERATING STATUS

1. Unit Name: Browns Ferry - Two
 2. Reporting Period: April 1984
 3. Licensed Thermal Power (MWt): 3293
 4. Nameplate Rating (Gross MWe): 1152
 5. Design Electrical Rating (Net MWe): 1065
 6. Maximum Dependable Capacity (Gross MWe): 1098.4
 7. Maximum Dependable Capacity (Net MWe): 1065
 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
 10. Reasons For Restrictions, If Any: N/A

	This Month	Yr. to-Date	Cumulative
11. Hours In Reporting Period	719	2,903	80,406
12. Number Of Hours Reactor Was Critical	719	2,612.84	52,577.02
13. Reactor Reserve Shutdown Hours	0	290.16	14,190.52
14. Hours Generator On-Line	719	2,568.14	51,060.98
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	1,452,694	6,487,222	146,632,267
17. Gross Electrical Energy Generated (MWH)	461,900	2,113,160	48,710,448 *
18. Net Electrical Energy Generated (MWH)	450,808	2,056,996	47,315,599
19. Unit Service Factor	100	88.5	63.5
20. Unit Availability Factor	100	88.5	63.5
21. Unit Capacity Factor (Using MDC Net)	58.9	66.5	55.3
22. Unit Capacity Factor (Using DER Net)	58.9	66.5	55.3
23. Unit Forced Outage Rate	0	8.3	24.1
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each)			

August 1984 - Refuel

25. If Shut Down At End Of Report Period, Estimated Date of Startup
 26. Units In Test Status (Prior to Commercial Operation)

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

8407020385 840611
 PDR ADOCK 05000259
 R PDR

(9/77)