

June 15, 1984
(NMP2L 0086)

Mr. R. W. Starostecki, Director
U.S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim report in accordance with 10CFR50.55(e) for the problem concerning electrical penetration assemblies supplied by Conax Corporation (55(e)-84-17). This problem was reported in a telephone conversation between T. Loomis (Nine Mile Point Unit 2 Licensing) and Mr. S. Collins of your staff on May 16, 1984.

Very truly yours,

C. V. Mangan

C. V. Mangan
Vice President

Nuclear Engineering & Licensing

Enclosure

xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

R. A. Gramm, Resident Inspector

8407020413 840615
PDR ADOCK 05000410
S PDR

11

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT UNIT 2
DOCKET NO. 50-410

Interim Report for a Problem
Concerning Electrical Penetration Assemblies
(55(e)-84-17)

Description of the Problem

The problem concerns the low voltage power and control type penetration assemblies supplied by Conax Corporation. Nine Mile Point Unit 2 Specification No. NMP2-E021P requires that these penetration assemblies meet the requirements of IEEE 317-76. Conax qualification report concludes that the assemblies meet the requirements of IEEE 317-76.

However, the matter is still under investigation, and a final report will be submitted by August 15, 1984.