

CP&L

Carolina Power & Light Company

84 JUN 21 10:47
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

June 25, 1984

FILE: B09-13510C
SERIAL: BSEP/84-1535

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, GA 30323

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1
DOCKET NO. 50-325
LICENSE NO. DPR-62
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.7.1 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-84-2)

Dear Mr. O'Reilly:

On May 21, 1984, while performing the weekly operability test of the Fire Suppression Water System, PT-35.1, the diesel driven fire pump was rendered inoperable due to a decrease in the diesel closed cooling water expansion tank level. This was caused by leaking tubes in the heat exchanger tube bundle. A new heat exchanger tube bundle had to be ordered, thereby, causing the seven-day time frame of the involved LCO on the diesel driven fire pump to be exceeded. The new heat exchanger tube bundle was placed into the heat exchanger. After a test run of the diesel indicated that the water level was stable, the diesel driven fire pump was returned to service on June 2, 1984. Brunswick has a contingency plan for loss of redundancy in the Fire Suppression System which includes a daily channel check of the fire suppression tank, verification of operability of the alternate pump, and an agreement with the City of Southport to provide backup fire suppression equipment.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MTA/ddr/LETDD1

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8407020424 840625
PDR ADOCK 05000325
S PDR

OFFICIAL COPY

1/0 IE 22