

Southern Nuclear Operating Company
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205-868-5086



Southern Nuclear Operating Company

the southern electric system

J. D. Woodard
Vice President
Farley Project

February 25, 1992

Docket Nos. 50-348
50-364

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Joseph M. Farley Nuclear Plant
Semiannual Radioactive Effluent Release Report

Gentlemen:

In accordance with the Unit 1 and Unit 2 Technical Specifications, Section 6.9.1.8, the FNP Semiannual Radioactive Effluent Release Report for July 1, 1991 through December 31, 1991 is hereby submitted.

If you have any questions, please advise.

Respectfully,

A handwritten signature in black ink, appearing to read "J. D. Woodard".

JDW/DMH

Attachment

cc: S. D. Ebneter
S. T. Hoffman
G. F. Maxwell

260046

9202280285 911231
PDR ADDCK 0500034B
R PDR

Feb 11

SOUTHERN NUCLEAR OPERATING COMPANY
FARLEY NUCLEAR PLANT UNIT NO. ONE
LICENSE NO. NPF-2
AND
FARLEY NUCLEAR PLANT UNIT NO. TWO
LICENSE NO. NPF-8

SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
JULY 1, 1991 THROUGH DECEMBER 31, 1991

CONTENTS

CHAPTER 1 INTRODUCTION

CHAPTER 2 SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL

2.1	REGULATORY LIMITS	2-1
2.1.1	Fission And Activation Gases	2-1
2.1.2	Iodines And Particulates	2-1
2.1.3	Liquid Effluents	2-2
2.2	MAXIMUM PERMISSIBLE CONCENTRATIONS	2-2
2.3	AVERAGE ENERGY	2-2
2.4	MEASUREMENTS AND APPROXIMATIONS OF TOTAL ACTIVITY	2-2
2.4.1	Fission And Activation Gases	2-3
2.4.2	Iodines And Particulates	2-3
2.4.3	Liquid Effluents	2-4
2.5	BATCH RELEASES AND ABNORMAL RELEASES	2-5
2.6	ESTIMATE OF TOTAL ERROR	2-10
2.6.1	Liquid	2-10
2.6.2	Gaseous	2-10
2.6.3	Solid Radwaste	2-10
2.7	SOLID WASTE	2-11
2.8	RADIOLOGICAL IMPACT ON MAN	2-11
2.9	METEOROLOGICAL DATA	2-14
2.10	MINIMUM DETECTABLE CONCENTRATION (MDC)	2-14
2.11	DEVIATIONS FROM LIQUID WASTE RELEASE PROGRAM . .	2-14
2.12	DEVIATIONS FROM GASEOUS WASTE RELEASE PROGRAM .	2-14
2.13	ANNUAL RADIATION DOSE ASSESSMENT (1991)	2-15

CHAPTER 3 TABLE 1A-1 GASEOUS EFFLUENTS--SUMMATION OF ALL RELEASES,
Farley Unit 1 - 2nd Half, 1991

CHAPTER 4 TABLE 1A-2 GASEOUS EFFLUENTS--SUMMATION OF ALL RELEASES,
Farley Unit 2 - 2nd Half, 1991

CHAPTER 5 TABLE 1B-1 GASEOUS EFFLUENTS--ELEVATED RELEASE,
Farley Unit 1 - 2nd Half, 1991

CHAPTER 6 TABLE 1B-2 GASEOUS EFFLUENTS--ELEVATED RELEASE,
Farley Unit 2 - 2nd Half, 1991

CHAPTER 7	TABLE 1C-1 GASEOUS EFFLUENTS--GROUND RELEASE, Farley Unit 1 - 2nd Half, 1991
CHAPTER 8	TABLE 1C-2 GASEOUS EFFLUENTS--GROUND RELEASE, Farley Unit 2 - 2nd Half, 1991
CHAPTER 9	TABLE 2A-1 LIQUID EFFLUENTS--SUMMATION OF ALL RELEASES, Farley Unit 1 - 2nd Half, 1991
CHAPTER 10	TABLE 2A-2 LIQUID EFFLUENTS--SUMMATION OF ALL RELEASES, Farley Unit 2 - 2nd Half, 1991
CHAPTER 11	TABLE 2B-1 LIQUID EFFLUENTS--BATCH AND CONTINUOUS, Farley Unit 1 - 2nd Half, 1991
CHAPTER 12	TABLE 2B-2 LIQUID EFFLUENTS--BATCH AND CONTINUOUS, Farley Unit 2 - 2nd Half, 1991
CHAPTER 13	TABLE 3 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS, 2nd Half, 1991
CHAPTER 14	TABLE 4A-CQ3 CUMULATIVE JOINT FREQUENCY DISTRIBUTION, Continuous Mode - 3rd Quarter, 1991
CHAPTER 15	TABLE 4A-CQ4 CUMULATIVE JOINT FREQUENCY DISTRIBUTION, Continuous Mode - 4th Quarter, 1991
CHAPTER 16	TABLE 4A-1BQ3 CUMULATIVE JOINT FREQUENCY DISTRIBUTION, Unit 1 Batch Mode - 3rd Quarter, 1991
CHAPTER 17	TABLE 4A-1BQ4 CUMULATIVE JOINT FREQUENCY DISTRIBUTION, Unit 1 Batch Mode - 4th Quarter, 1991
CHAPTER 18	TABLE 4A-2BQ3 CUMULATIVE JOINT FREQUENCY DISTRIBUTION, Unit 2 Batch Mode - 3rd Quarter, 1991

CHAPTER 19	TABLE 4A-2BQ4	CUMULATIVE JOINT FREQUENCY DISTRIBUTION, Unit 2 Batch Mode - 4th Quarter, 1991
CHAPTER 20	TABLE 4B	CLASSIFICATION OF ATMOSPHERIC STABILITY
CHAPTER 21	TABLE 5	RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM, Units 1 & 2
CHAPTER 22	TABLE 6	RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM, Units 1 & 2
CHAPTER 23	TABLE 7	LIQUID DISCHARGES NOT MEETING SPECIFIED DETECTION LIMITS, Units 1 & 2
CHAPTER 24	TABLE 8-CA	CUMULATIVE JOINT FREQUENCY DISTRIBUTION, Continuous Mode - Annual, 1991
CHAPTER 25		PROCESS CONTROL PROGRAM

CHAPTER 1
INTRODUCTION

This semiannual radioactive release report, for the period July 1 through December 31, 1991, is submitted in accordance with Appendix A of License No.'s NPF-2 and NPF-8. Appendix A will hereinafter be referred to as the Technical Specifications or TS.

A single submittal is made for both units which combines those sections that are common. Separate tables of releases and release totals are included where separate processing systems exist.

This report includes an annual summary of hourly meteorological data collected over the past year and an assessment of the radiation doses due to the radioactive liquid and gaseous effluents released from the Farley Nuclear Plant site over the same period. Additionally Section 2.13 with associated dose contributions to sectors comprises an assessment of radiation doses to the likely most exposed member of the public from reactor releases and other nearby uranium fuel cycle sources (including doses from primary effluent pathways and direct radiation). All assessments of radiation doses are performed in accordance with the OFFSITE DOSE CALCULATION MANUAL (ODCM).

CHAPTER 2

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL

2.1 REGULATORY LIMITS

2.1.1 Fission And Activation Gases

- 1) The dose rate from the site at any time due to noble gases shall be less than or equal to 500 mrem/yr to the total body and 3000 mrem/yr to the skin.
- 2) The air dose from each reactor unit from the site during any calendar quarter due to noble gases shall be less than or equal to 5 mrad for gamma radiation and 10 mrad for beta radiation.
- 3) The air dose from each reactor unit from the site during any calendar year due to noble gases shall be less than or equal to 10 mrad for gamma radiation and 20 mrad for beta radiation.

2.1.2 Iodines And Particulates

- 1) The dose rate from the site at any time due to iodines, particulates and radionuclides with half-lives greater than 8 days shall be less than or equal to 1500 mrem/yr to any organ.
- 2) The dose from each reactor unit from the site during any calendar quarter due to iodines, particulates and radionuclides with half-lives greater than 8 days shall be less than or equal to 7.5 mrem to any organ.
- 3) The dose from each reactor unit from the site during any calendar year due to iodines, particulates and radionuclides with half-lives greater than 8 days shall be less than or equal to 15 mrem to any organ.

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
REGULATORY LIMITS

2.1.3 Liquid Effluents

- 1) The concentration of radioactive materials released in liquid effluents to unrestricted areas from all reactors at the site shall not exceed at any time the values specified in 10CFR Part 20, Appendix B, Table II, Column 2. The concentration of dissolved or entrained noble gases, released in liquid effluents to unrestricted areas from all reactors at the site, shall not exceed at any time 2E-4 uCi/ml in water.
- 2) The dose or dose commitment due to liquid effluents released from each reactor unit from the site during any calendar quarter shall be less than or equal to 1.5 mrem to the total body and 5 mrem to any organ.
- 3) The dose or dose commitment due to liquid effluents released from each reactor unit from the site during any calendar year shall be less than or equal to 3 mrem to the total body and 10 mrem to any organ.

2.2 MAXIMUM PERMISSIBLE CONCENTRATIONS

- a) Airborne - The maximum permissible concentration of radioactive materials in gaseous effluents is limited by the dose rate restrictions of 10 CFR 20. In this case, the maximum permissible concentrations are actually determined by the dose factors in the ODCM.
- b) Liquids - 10 CFR Part 20, Appendix B, Table II, Column 2. Note: The MPC chosen is the most conservative value of either the soluble or insoluble MPC for each isotope.

2.3 AVERAGE ENERGY

Not applicable for Farley's TS.

2.4 MEASUREMENTS AND APPROXIMATIONS OF TOTAL ACTIVITY

The following discussion details the methods used to measure and approximate total activity for the following:

- a. Fission and Activation Gases
- b. Iodines and Particulates
- c. Liquid Effluents

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
MEASUREMENTS AND APPROXIMATIONS OF TOTAL ACTIVITY

Tables 5 and 6 give sampling frequencies and minimum detectable concentration requirements for the analysis of gaseous and liquid effluent streams, respectively.

Values in the attached tables given as zero do not mean that the nuclides were not present. A zero indicates that the nuclide was not detected at levels greater than the sensitivity requirements shown in Tables 5 and 6. For some nuclides, lower detection limits than required may be readily achievable; when a nuclide is measured below its stated limit, it is reported.

2.4.1 Fission And Activation Gases

The following noble gases are considered in evaluating gaseous airborne discharge:

Kr-87	Xe-133
Kr-88	Xe-135
Xe-133m	Xe-138

Periodic grab samples from plant effluent streams are analyzed by a computerized pulse height analyzer system utilizing high resolution germanium detectors. (See Table 5 for sampling and analytical requirements). Isotopic values thus obtained are used for release rate calculations as specified in the ODCM. Only those nuclides that are detected are used in this computation. During the period between grab samples, the amount of radioactivity released is based on the effluent monitor readings.

The monitor meter response (cpm/uCi/ml) and the background (cpm) are used to adjust the activity released for variations in monitor readings, as described in the ODCM.

To ensure isotopic distributions do not change significantly during major operational occurrences, the frequency of grab sampling is increased to satisfy the requirements of footnotes (b) and (d) of TS Table 4.11-2, "Radioactive Gaseous Waste Sampling and Analysis Program".

2.4.2 Iodines And Particulates

The radioiodines and radioactive materials in particulate forms to be considered are:

Mn-54	I-131
Fe-59	I-133

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
MEASUREMENTS AND APPROXIMATIONS OF TOTAL ACTIVITY

Co-58	Cs-134
Co-60	Cs-137
Zn-65	Ce-141
Sr-89	Ce-144
Sr-90	*H-3
Mo-99	

Other nuclides with half-lives greater than 8 days which are identified and measured are also considered. The MDC's will vary and are not required to meet the MDC limits of those isotopes listed specifically.

* Tritium is considered in the gaseous or water vapor form.

Continuous Releases: Continuous sampling is performed on the continuous release points (i.e. the Plant Vent Stack, Containment Purge and the Turbine Building Vent). Particulate material is collected by filtration. Periodically these filters are removed and analyzed on the pulse height analyzer to identify and quantify radioactive materials collected on the filters. Particulate filters are then analyzed for gross alpha and strontium as required. Gross alpha determinations are made using a 2 pi gas flow proportional counter. Sr-89 and 90 values are obtained by chemical separation and subsequent analysis using 2 pi gas flow proportional counters.

Batch Releases: The processing of batch type releases (from Containment or Waste Gas Decay Tanks) is analogous to continuous releases, except that the release is not commenced until samples have been obtained and analyzed.

2.4.3 Liquid Effluents

The radionuclides listed below are considered when evaluating liquid effluents:

Mn-54	I-131
Fe-59	Cs-134
Co-58	Cs-137
Co-60	Ce-141
Zn-65	Ce-144
Sr-89	Mo-99
Sr-90	Fe-55
	H-3

Batch Releases: Representative pre-release grab samples are obtained and analyzed per Table 6. Isotopic analyses are performed using the computerized pulse height analysis system

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
MEASUREMENTS AND APPROXIMATIONS OF TOTAL ACTIVITY

previously described. Aliquots of each pre-release sample proportional to the waste volume released are composited in accordance with requirements in Table 6. Strontium determinations are made by performing a chemical separation and counting the isotope thus separated using a 2 pi gas flow proportional counter. Gross beta and gross alpha determinations are made using 2 pi gas flow proportional counters. Tritium and Iron 55 determinations are made using liquid scintillation techniques. Dissolved gases are determined employing grab sampling techniques and then counting on the pulse height analyzer.

Continuous Releases: Continuous releases (from the Steam Generator Blowdown) are analogous to that of the batch releases except that they are analyzed on a weekly composite basis per Table 6.

2.5 BATCH RELEASES AND ABNORMAL RELEASES

Batch releases and abnormal (non-routine) releases from units 1 and 2 are shown on the following pages.

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
BATCH RELEASES AND ABNORMAL RELEASES

BATCH RELEASES - UNIT 1

LIQUIDS	RELEASE(S): ALL	QUARTER 3	QUARTER 4
Number of batch releases		151.	102.
Total time period for batch releases (min)		12877.	8428.
Maximum time period for a batch release (min)		120.	105.
Average time period for a batch release (min)		85.	83.
Minimum time period for a batch release (min)		53.	63.
Average stream flow during periods of release (cfs) * 8.59E+03			* 6.83E+03
GASES	RELEASE(S): ALL		
Number of batch releases		0.	0.
Total time period for batch releases (min)		0.	0.
Maximum time period for a batch release (min)		0.	0.
Average time period for a batch release (min)		0.	0.
Minimum time period for a batch release (min)		0.	0.

* Average River Flow Rate, taken at Walter F. George Lock and Dam,
located 30.7 miles above Farley Nuclear Plant.

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
BATCH RELEASES AND ABNORMAL RELEASES

ABNORMAL RELEASES - UNIT 1

	QUARTER 3	QUARTER 4
LIQUIDS		
Number of releases	0.	0.
Total activity released	0.00E+00 Ci	0.00E+00 Ci
GASES		
Number of releases	0.	0.
Total activity released	0.00E+00 Ci	0.00E+00 Ci

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
BATCH RELEASES AND ABNORMAL RELEASES

BATCH RELEASES - UNIT 2

LIQUIDS	RELEASE(S): ALL	QUARTER 3	QUARTER 4
Number of batch releases		80.	72.
Total time period for batch releases (min)		7219.	5025.
Maximum time period for a batch release (min)		203.	110.
Average time period for a batch release (min)		90.	84.
Minimum time period for a batch release (min)		69.	66.
Average stream flow during periods of release (cf ³); * 8.59E+03			* 6.83E+03
GASES	RELEASE(S): ALL		
Number of batch releases		0.	0.
Total time period for batch releases (min)		0.	0.
Maximum time period for a batch release (min)		0.	0.
Average time period for a batch release (min)		0.	0.
Minimum time period for a batch release (min)		0.	0.

* Average River Flow Rate, taken at Walter F. George Lock and Dam,
located 30.7 miles above Farley Nuclear Plant.

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
BATCH RELEASES AND ABNORMAL RELEASES

ABNORMAL RELEASES - UNIT 2

	QUARTER 3	QUARTER 4
LIQUIDS		
Number of releases	0.	0.
Total activity released	0.00E+00 Ci	0.00E+00 Ci
GASES		
Number of releases	0.	0.
Total activity released	0.00E+00 Ci	0.00E+00 Ci

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
ESTIMATE OF TOTAL ERROR

2.6 ESTIMATE OF TOTAL ERROR

2.6.1 Liquid

- 1) The maximum error associated with volume and flow measurements, based upon plant calibration practice is estimated to be + or - 10%.
- 2) The average error associated with counting is estimated to be less than + or - 15%.

2.6.2 Gaseous

- 1) The maximum errors associated with monitor readings, sample flow, vent flow, sample collection, monitor calibration and laboratory procedure are collectively estimated to be:

Fission and Activation Gases	Iodine	Particulates	Tritium
75%	60%	50%	45%

- 2) The average error associated with counting is estimated to be:

Fission and Activation Gases	Iodine	Particulates	Tritium
19%	28%	20%	8%

2.6.3 Solid Radwaste

The error involved in determining the contents of solid radwaste shipments is estimated to be less than + or - 15%.

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
SOLID WASTE

2.7 SOLID WASTE

See Table 3

2.8 RADIOLOGICAL IMPACT ON MAN

The doses from liquid and gaseous releases for units 1 and 2 are shown on the following pages.

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
RADIOLOGICAL IMPACT ON MAN

DOSES FROM LIQUID AND GASEOUS EFFLUENTS - UNIT 1

	QUARTER 3	QUARTER 4
LIQUIDS (mrem)	RELEASE(S): ALL	
Bone	9.68E-03	4.90E-03
Liver	1.44E-02	7.20E-03
Whole body	1.02E-02	4.85E-03
Thyroid	8.77E-04	1.13E-03
Kidney	5.31E-03	2.77E-03
Lung	2.59E-02	2.59E-03
GI - LLI	1.99E-02	2.31E-03
GASES	RELEASE(S): ALL	
NOBLE GASES (mRAD)		
Gamma Air	2.16E-03	2.48E-03
Beta Air	1.67E-03	2.00E-03
PARTICULATE AND IODINE (mrem)		
Bone	0.00E+00	0.00E+00
Liver	1.26E-03	2.61E-03
Whole body	1.26E-03	2.61E-03
Thyroid	1.26E-03	2.61E-03
Kidney	1.26E-03	2.61E-03
Lung	1.26E-03	2.61E-03
GI - LLI	1.26E-03	2.61E-03
Skin	0.00E+00	0.00E+00

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
RADIOLOGICAL IMPACT ON MAN

DOSES FROM LIQUID AND GASEOUS EFFLUENTS - UNIT 2

LIQ/IIDS (mrem)	QUARTER 3	QUARTER 4
	RELEASE(S): ALL	
Bone	1.07E-02	1.08E-02
Liver	1.61E-02	1.61E-02
Whole body	1.11E-02	1.10E-02
Thyroid	5.09E-04	6.53E-04
Kidney	5.65E-03	5.46E-03
Lung	7.83E-03	3.15E-03
GI - LLI	5.24E-03	1.95E-03
GASES	RELEASE(S): ALL	
NOBLE GASES (mRAD)		
Gamma Air	4.00E-03	3.12E-03
Beta Air	1.41E-03	1.10E-03
PARTICULATE AND IODINE (mrem)		
Bone	0.00E+00	0.00E+00
Liver	6.04E-03	9.91E-03
Whole body	6.04E-03	9.91E-03
Thyroid	6.04E-03	9.91E-03
Kidney	6.04E-03	9.91E-03
Lung	6.04E-03	9.91E-03
GI - LLI	6.04E-03	9.91E-03
Skin	0.00E+00	0.00E+00

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
METEOROLOGICAL DATA

2.9 METEOROLOGICAL DATA

See Table 4A, "Cumulative Joint Frequency Distribution".

Continuous Release Mode:

3rd Quarter, 1991 : 4A-CQ3
4th Quarter, 1991 : 4A-CQ4

Batch Release Mode (Units 1 and 2):

3rd Quarter, 1991 : 4A-1BQ3 and 4A-2BQ3
4th Quarter, 1991 : 4A-1BQ4 and 4A-2BQ4

2.10 MINIMUM DETECTABLE CONCENTRATION (MDC)

Detectable limits for activity analyses are based upon the technical feasibility and on the potential significance in the environment of the quantities released. However, in practice, when an isotope's a posteriori MDC could not be met due to other nuclides being present in much greater concentrations, the a priori MDC as defined in the TS table 4.11-1 a. is relied upon.

2.11 DEVIATIONS FROM LIQUID WASTE RELEASE PROGRAM

There were no deviations from the Liquid Waste Release Program during the second half of 1991.

2.12 DEVIATIONS FROM GASEOUS WASTE RELEASE PROGRAM

There were no deviations from the Gaseous Waste Release Program during the second half of 1991.

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
ANNUAL RADIATION DOSE ASSESSMENT (1991)

2.13 ANNUAL RADIATION DOSE ASSESSMENT (1991)

DOSES FROM LIQUID AND GASEOUS EFFLUENTS

LIQUIDS (mrem) RELEASE(S): ALL

Bone	7.00E-02
Liver	1.05E-01
Whole body	7.32E-02
Thyroid	8.15E-03
Kidney	3.83E-02
Lung	1.08E-01
GI - LLI	2.37E-01

GASES RELEASE(S): ALL

NOBLE GASES (mRAD)

Gamma Air	3.57E-02
Beta Air	3.75E-02

PARTICULATE AND IODINE (mrem)

Bone	1.47E-03
Liver	2.55E-02
Whole body	2.45E-02
Thyroid	5.92E-01
Kidney	2.58E-02
Lung	2.37E-02
GI - LLI	2.38E-02
Skin	1.13E-05

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
ANNUAL RADIATION DOSE ASSESSMENT (1991)

Maximum Real Exposure

The maximum real exposure is an assessment of radiation doses to the likely most exposed member of the public from reactor releases and other nearby uranium fuel cycle sources (including doses from all primary effluent pathways and direct radiation (liquid pathways are limited to the Chattahoochee River) for the previous 12 consecutive months in conformance with 40 CFR 190.

A tabulation of doses to sixteen 22.5 degree sectors around the plant calculated at the site boundary provides the quarterly and yearly dose for each sector. The dose or dose commitment to any member of the public due to releases of radioactivity and radiation from uranium fuel cycle sources are limited to less than or equal to 25 mrem to the total body or an organ (except the thyroid which is limited to less than or equal to 75 mrem) over 4 consecutive quarters. This technical specification is provided to meet the dose limitations of 40 CFR 190.

Since the Farley Nuclear Plant is the only uranium fuel cycle source within a radius of 50 miles, the dose to any member of the public will be less than the dose in the highest sector. The tabulation below includes the quarterly and yearly doses from the highest sector for each of the following:

1. Gaseous iodine / particulate
2. Noble gases
3. Direct Radiation (Direct radiation data are actual field measurements made by thermoluminescent dosimetry as opposed to calculated data based on effluents. It should be noted that the direct radiation values reported herein include background radiation. Based on preoperational data, the reported direct radiation doses are essentially attributable to background radiation.)

SUPPLEMENTAL INFORMATION FOR EFFLUENT AND WASTE DISPOSAL
ANNUAL RADIATION DOSE ASSESSMENT (1991)

MAXIMUM OFF-SITE DOSES

Dose, Millirems *

Source	Note	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Year
Organ		GI	GI	LUNG	LIV	GI
Liquid effluents	(1)	4.43E-02	1.62E-01	3.37E-02	2.33E-02	2.37E-01
Organ		THY	THY	THY	THY	THY
Iodines and Particulates	(2)	4.36E-01	1.36E-01	7.30E-03	1.25E-02	5.92E-01
Type of Air Dose		BETA	GAMMA	GAMMA	GAMMA	BETA
Noble gases	(2)	3.04E-02	1.61E-03	6.16E-03	5.60E-03	3.75E-02
Sector		NE	E	NE	NE	E
Direct radiation	(3)	2.72E+01	3.18E+01	3.44E+01	2.25E+01	7.86E+01

Note:

1. The liquid effluent total body and organ doses are determined by the fish pathway. These are calculated using the bioaccumulation factors, dose conversion factors, and assumptions of Regulatory Guide 1.109 (October 1977).
2. Gaseous effluent doses are calculated using annual average X/Q methodology per NUREG-0133 (October 1978).
3. Direct radiation was assessed using thermoluminescent dosimetry. Two dosimeters containing three LiF TLD chips were placed at selected locations within each of 16 sectors around the plant. These chips were collected and read quarterly and annually.

* All doses in mrem except noble gas doses which are in mRAD.

CHAPTER 3

TABLE 1A-1

GASEOUS EFFLUENTS -- SUMMATION OF RELEASE(S): ALL - UNIT 1

	UNITS	QUARTER 3	QUARTER 4
A. FISSION AND ACTIVATION GASES			
1. TOTAL RELEASE	Ci	2.76E+01	4.16E+01
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/SEC	3.47E+00	5.23E+00
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	N/A	N/A
B. IODINES			
1. TOTAL IODINE-131	Ci	0.00E+00	0.00E+00
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/SEC	0.00E+00	0.00E+00
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	N/A	N/A

TABLE 1A-1

GASEOUS EFFLUENTS -- SUMMATION OF RELEASE(S): ALL - UNIT 1

	UNITS	QUARTER 3	QUARTER 4
--	-------	--------------	--------------

C. PARTICULATES

1. PARTICULATES WITH HALF-LIVES >8 DAYS	Ci	0.00E+00	0.00E+00
2. AVERAGE RELEASE RATE FOR PERIOD	$\mu\text{Ci}/\text{SEC}$	0.00E+00	0.00E+00
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	N/A	N/A
4. GROSS ALPHA RADIOACTIVITY	Ci	3.16E-08	7.59E-08

D. TRITIUM

1. TOTAL RELEASE	Ci	7.80E+00	1.49E+01
2. AVERAGE RELEASE RATE FOR PERIOD	$\mu\text{Ci}/\text{SEC}$	9.81E-01	1.87E+00
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	N/A	N/A

CHAPTER 4

TABLE 1A-2

GASEOUS EFFLUENTS -- SUMMATION OF RELEASE(S): ALL - UNIT 2

	UNITS	QUARTER 3	QUARTER 4
A. FISSION AND ACTIVATION GASES			
1. TOTAL RELEASE	Ci	1.26E+01	9.81E+00
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/SEC	1.59E+00	1.23E+00
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	N/A	N/A

B. IODINES

1. TOTAL IODINE-131	Ci	0.00E+00	0.00E+00
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/SEC	0.00E+00	0.00E+00
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	N/A	N/A

TABLE 1A-2

GASEOUS EFFLUENTS -- SUMMATION OF RELEASE(S): ALL - UNIT 2

	UNITS	QUARTER 3	QUARTER 4
--	-------	--------------	--------------

C. PARTICULATES

1. PARTICULATES WITH HALF-LIVES >8 DAYS Ci 0.00E+00 0.00E+00
2. AVERAGE RELEASE RATE FOR PERIOD $\mu\text{Ci}/\text{SEC}$ 0.00E+00 0.00E+00
3. PERCENT OF TECHNICAL, SPECIFICATION LIMIT % N/A N/A
4. GROSS ALPHA RADIOACTIVITY Ci 4.80E-08 2.22E-07

D. TRITIUM

1. TOTAL RELEASE Ci 3.42E+01 5.61E+01
2. AVERAGE RELEASE RATE FOR PERIOD $\mu\text{Ci}/\text{SEC}$ 4.31E+00 7.06E+00
3. PERCENT OF TECHNICAL % N/A N/A
SPECIFICATION LIMIT

CHAPTER 5

TABLE 1B-1

GASEOUS EFFLUENTS -	Elevated Releases	RELEASE(S): ALL - UNIT 1
---------------------	-------------------	--------------------------

CONTINUOUS MODE				BATCH MODE			
:	NUCLIDES	: UNITS	: QUARTER	:	QUARTER	:	QUARTER
:	RELEASED	:	3	:	4	:	3

1. FISSION AND ACTIVATION GASES

AR-41	Ci	4.84E+00	6.38E+00	0.00E+00	0.00E+00
XE-133	Ci	1.64E+01	3.47E+01	0.00E+00	0.00E+00
XE-135	Ci	6.37E+00	4.77E-01	0.00E+00	0.00E+00

TOTAL FOR :	:	:	:	:	:	:
PERIOD :	Ci	2.76E+01	4.16E+01	0.00E+00	0.00E+00	:
(ABOVE) :	:	:	:	:	:	:

TABLE 1B-1

GASEOUS EFFLUENTS - Elevated Releases RELEASE(S): ALL - UNIT 1

			CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	UNITS	QUARTER	QUARTER	QUARTER	QUARTER
:	RELEASED	:	3	4	3	4

2. IODINES

TOTAL FOR	:	:	:	:	:	:
PERIOD	:	Ci	: 0.00E+00	: 0.00E+00	: 0.00E+00	: 0.00E+00
(ABOVE)	:	:	:	:	:	:

TABLE 1B-1

GASEOUS EFFLUENTS - Elevated Releases RELEASE(S): ALL - UNIT 1

			CONTINUOUS MODE		BATCH MODE						
:	NUCLIDES	: UNITS	QUARTER	:	QUARTER	:	QUARTER	:	QUARTER	:	QUARTER
:	RELEASED	:	3	:	4	:	3	:	4	:	1
3. 1 ARTICULATES											
H-3	Ci		7.80E+00		1.49E+01		0.00E+00		0.00E+00		
U ALPHA	Ci		3.16E-08		7.59E-08		0.00E+00		0.00E+00		
TOTAL FOR											
PERIOD	:	Ci	7.80E+00	:	1.49E+01	:	0.00E+00	:	0.00E+00	:	
(ABOVE)	:			:		:		:		:	

CHAPTER 6

TABLE 1B-2

GASEOUS EFFLUENTS -		Elevated Releases		RELEASE(S): ALL - UNIT 2			
				CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	:	UNITS	:	QUARTER	:	QUARTER
:	RELEASED	:		:	3	:	4
:		:		:		:	
1.	FISSION AND ACTIVATION GASES						
AR-41	Ci		1.26E+01		9.81E+00		0.00E+00
TOTAL FOR	:	:		:		:	
PERIOD	:	Ci	1.26E+01	:	9.81E+00	:	0.00E+00
(ABOVE)	:	:		:		:	

TABLE 1B-2

GASEOUS EFFLUENTS - Elevated Releases RELEASE(S): ALL - UNIT 2

			CONTINUOUS MODE		BATCH MODE							
:	NUCLIDES	: UNITS :	QUARTER	:	QUARTER	:	QUARTER	:	QUARTER	:		
:	RELEASED	:	3	:	4	:	3	:	1	:	4	:
2. IODINES												
TOTAL FOR	:	:		:		:		:		:		
PERIOD	:	Ci	: 0.00E+00	:	0.00E+00	:	0.00E+00	:	0.00E+00	:		
(ABOVE)	:	:	:	:	:	:	:	:	:	:		

TABLE 1B-2

GASEOUS EFFLUENTS - Elevated Releases RELEASE(S): ALL - UNIT 2

			CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	UNITS	QUARTER	QUARTER	QUARTER	QUARTER
:	RELEASED		3	4	3	4

3. PARTICULATES

H-3	Ci	3.42E+01	5.61E+01	0.00E+00	0.00E+00
G.ALPHA	Ci	4.80E-08	2.22E-07	0.00E+00	0.00E+00

TOTAL FOR	:	:	:	:	:	:
PERIOD	:	Ci	3.42E+01	5.61E+01	0.00E+00	0.00E+00
(ABOVE)	:		:	:	:	:

CHAPTER 7

TABLE 1C-1

GASEOUS EFFLUENTS - Ground Level Releases				RELEASE(S): ALL - UNIT 1			
				CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	:	UNITS	:	QUARTER	:	QUARTER
:	RELEASED	:		:	3	:	4
:		:		:		:	
<hr/>							
1. FISSION AND ACTIVATION GASES							
<hr/>							
TOTAL FOR	:	:		:		:	
PERIOD	:	Ci	:	0.00E+00	:	0.00E+00	:
(ABOVE)	:		:		:		:
<hr/>							

TABLE 1C-1

GASEOUS EFFLUENTS - Ground Level Releases RELEASE(S): ALL - UNIT 1

		CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	UNITS	QUARTER	QUARTER	QUARTER
:	RELEASED	:	3	4	3
2. IODINES					
TOTAL FOR	:	:	:	:	:
PERIOD	:	Ci	0.00E+00	0.00E+00	0.00E+00
(ABOVE)	:	:	:	:	:

TABLE 1C-1

GASEOUS EFFLUENTS - Ground Level Releases RELEASE(S): ALL - UNIT 1

			CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	UNITS	QUARTER	QUARTER	QUARTER	QUARTER
:	RELEASED	:	3	4	3	4

3. PARTICULATES

H-3	Ci	2.40E-03	6.43E-03	0.00E+00	0.00E+00
-----	----	----------	----------	----------	----------

TOTAL FOR	:	:	:	:	:	:
PERIOD	:	Ci	2.40E-03	6.43E-03	0.00E+00	0.00E+00
(ABOVE)	:	:	:	:	:	:

CHAPTER 8

TABLE 1C-2

GASEOUS EFFLUENTS - Ground Level Releases

RELEASE(S): ALL - UNIT 2

			CONTINUOUS MODE		BATCH MODE						
:	NUCLIDES	: UNITS	:	QUARTER	:	QUARTER	:	QUARTER	:	QUARTER	:
:	RELEASED	:	:	3	:	4	:	3	:	4	:

1. FISSION AND ACTIVATION GASES

TOTAL FOR	:	:	:	:	:	:	:	:	:	:	:
PERIOD	:	Ci	:	0.00E+00	:	0.00E+00	:	0.00E+00	:	0.00E+00	:
(ABOVE)	:	:	:	:	:	:	:	:	:	:	:

TABLE 1C-2

GASEOUS EFFLUENTS - Ground Level Releases RELEASE(S): ALL - UNIT 2

CONTINUOUS MODE				BATCH MODE			
NUCLIDES	UNITS	QUARTER	QUARTER	QUARTER	QUARTER	QUARTER	QUARTER
RELEASED	:	3	4	3	4	3	4
2. IODINES							
TOTAL FOR	:						
PERIOD	:	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
(ABOVE)	:						

TABLE 1C-2

GASEOUS EFFLUENTS - Ground Level Releases RELEASE(S): ALL - UNIT 2

		CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	UNITS	QUARTER	QUARTER	QUARTER
:	RELEASED	:	3	4	3
:					

3. PARTICULATES

H-3	Ci	2.82E-03	7.97E-03	0.00E+00	0.00E+00
-----	----	----------	----------	----------	----------

TOTAL FOR	:	:	:	:	:	:
PERIOD	:	Ci	2.82E-03	7.97E-03	0.00E+00	0.00E+00
(ABOVE)	:	:	:	:	:	:

CHAPTER 9

TABLE 2A-1

LIQUID EFFLUENTS -- SUMMATION OF RELEASE(S): ALL - UNIT 1

	UNITS	QUARTER 3	QUARTER 4
--	-------	--------------	--------------

A. FISSION AND ACTIVATION PRODUCTS

1. TOTAL RELEASE (EXCL. TRIT., GASES, ALPHA)	Ci	4.16E-02	7.73E-02
2. AVERAGE DILUTED CONC. DURING PERIOD	$\mu\text{Ci}/\text{ml}$	3.03E-09	5.94E-09
3. PERCENT OF APPLICABLE LIMIT	%	N/A	N/A

B. TRITIUM

1. TOTAL RELEASE	Ci	1.10E+02	1.39E+02
2. AVERAGE DILUTED CONC. DURING PERIOD	$\mu\text{Ci}/\text{ml}$	8.06E-06	1.07E-05
3. PERCENT OF APPLICABLE LIMIT	%	N/A	N/A

TABLE 2A-1

LIQUID EFFLUENTS -- SUMMATION OF RELEASE(S): ALL - UNIT 1

	UNITS	QUARTER 3	QUARTER 4
--	-------	--------------	--------------

C. DISSOLVED AND ENTRAINED GASES

1. TOTAL RELEASE	Ci	1.05E-03	8.93E-03
2. AVERAGE DILUTED CONC. DURING PERIOD	$\mu\text{Ci}/\text{ml}$	7.65E-11	6.86E-10
3. PERCENT OF APPLICABLE LIMIT	%	N/A	N/A

D. GROSS ALPHA RADIOACTIVITY

1. TOTAL RELEASE	Ci	1.19E-05	1.43E-08
------------------	----	----------	----------

E. VOLUME WASTE RELEASED (PRIOR TO DILUTION)	LITERS	1.05E+08	8.98E+07
---	--------	----------	----------

F. VOLUME DILUTION WATER USED DURING PERIOD	LITERS	1.37E+10	1.30E+10
--	--------	----------	----------

CHAPTER 10

TABLE 2A-2

LIQUID EFFLUENTS -- SUMMATION OF RELEASE(S): ALL - UNIT 2

	UNITS	QUARTER 3	QUARTER 4
--	-------	--------------	--------------

A. FISSION AND ACTIVATION PRODUCTS

1. TOTAL RELEASE (EXCL. TRIT., GASES, ALPHA)	Ci	3.02E-02	8.66E-02
2. AVERAGE DILUTED CONC. DURING PERIOD	uCi/ml	1.92E-09	5.63E-09
3. PERCENT OF APPLICABLE LIMIT	%	N/A	N/A

B. TRITIUM

1. TOTAL RELEASE	Ci	7.43E+01	9.28E+01
2. AVERAGE DILUTED CONC. DURING PERIOD	uCi/ml	4.72E-06	6.04E-06
3. PERCENT OF APPLICABLE LIMIT	%	N/A	N/A

TABLE 2A-7

LIQUID EFFLUENTS -- SUMMATION OF RELEASE(S): ALL - UNIT 2

	UNITS	QUARTER 3	QUARTER 4
--	-------	--------------	--------------

C. DISSOLVED AND ENTRAINED GASES

1. TOTAL RELEASE	Ci	4.60E-04	1.24E-02
2. AVERAGE DILUTED CONC. DURING PERIOD	$\mu\text{Ci}/\text{ml}$	2.92E-11	8.07E-10
3. PERCENT OF APPLICABLE LIMIT	%	N/A	N/A

D. GROSS ALPHA RADIOACTIVITY

1. TOTAL RELEASE	Ci	7.29E-06	4.37E-08
------------------	----	----------	----------

E. VOLUME WASTE RELEASED (PRIOR TO DILUTION)	LITERS	1.08E+08	7.28E+07
--	--------	----------	----------

F. VOLUME DILUTION WATER USED DURING PERIOD	LITERS	1.57E+10	1.54E+10
---	--------	----------	----------

CHAPTER 11

TABLE 2B-1

LIQUID EFFLUENTS

RELEASE(S): ALL - UNIT 1

NUCLIDES RELEASED	UNITS	CONTINUOUS MODE		BATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
H-3	Ci	0.00E+00	0.00E+00	1.10E+02	1.39E+02
CR-51	Ci	0.00E+00	0.00E+00	2.99E-04	0.00E+00
MN-54	Ci	0.00E+00	0.00E+00	4.22E-05	2.61E-05
FE-55	Ci	2.15E-02	7.37E-02	1.92E-03	1.32E-03
FE-59	Ci	0.00E+00	0.00E+00	2.75E-06	0.00E+00
CO-58	Ci	0.00E+00	0.00E+00	6.56E-03	3.27E-04
CO-60	Ci	0.00E+00	0.00E+00	3.48E-03	1.38E-03
SR-90	Ci	0.00E+00	0.00E+00	7.66E-06	2.10E-06
SR-92	Ci	0.00E+00	0.00E+00	1.60E-05	0.00E+00
ZR-95	Ci	0.00E+00	0.00E+00	1.53E-04	0.00E+00
NB-95	Ci	0.00E+00	0.00E+00	3.60E-04	3.11E-06
RU-103	Ci	0.00E+00	0.00E+00	5.65E-06	0.00E+00
RU-105	Ci	0.00E+00	0.00E+00	2.37E-05	0.00E+00
AG-110M	Ci	0.00E+00	0.00E+00	1.11E-03	1.55E-04
I-131	Ci	0.00E+00	0.00E+00	8.29E-07	0.00E+00
CS-134	Ci	0.00E+00	0.00E+00	1.15E-04	5.83E-05
CS-137	Ci	0.00E+00	0.00E+00	6.54E-04	2.21E-04
CS-138	Ci	0.00E+00	0.00E+00	0.00E+00	9.96E-06

TABLE 2B-1

LIQUID EFFLUENTS

RELEASE(S): ALL - UNIT 1

			CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	UNITS	QUARTER	QUARTER	QUARTER	QUARTER
:	RELEASED	:	3	4	3	4
G.ALPHA	Ci		0.00E+00	0.00E+00	1.19E-05	1.43E-08
NB-97	Ci		0.00E+00	0.00E+00	5.14E-05	2.06E-05
SB-125	Ci		0.00E+00	0.00E+00	5.29E-03	6.01E-05
CO-57	Ci		0.00E+00	0.00E+00	1.69E-06	0.00E+00
<hr/>						
TOTAL FOR	:	:	:	:	:	:
PERIOD	:	Ci	2.15E-02	7.37E-02	1.10E+02	1.39E+02
(ABOVE)	:	:	:	:	:	:

TABLE 2B-1

LIQUID FFFLUENTS - DISSOLVED AND ENTRAINED GASES - UNIT 1

		RELEASE(S): ALL			
		CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	UNITS	QUARTER	QUARTER	QUARTER
:	RELEASED	:	3	4	3
KR-85M	Ci		0.00E+00	0.00E+00	7.03E-07
XE-131M	Ci		0.00E+00	0.00E+00	0.00E+00
XE-133	Ci		0.00E+00	0.00E+00	1.04E-03
XE-135	Ci		0.00E+00	0.00E+00	5.73E-06
TOTAL FOR	:	:	:	:	:
PERIOD	:	Ci	0.00E+00	0.00E+00	1.05E-03
(ABOVE)	:	:	:	:	8.93E-03

CHAPTER 12

TABLE 2B-2

LIQUID EFFLUENTS

RELEASE(S): ALL - UNIT 2

NUCLIDES RELEASED	UNITS	CONTINUOUS MODE		BATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
H-3	Ci	0.00E+00	0.00E+00	7.43E+01	9.28E+01
CR-51	Ci	0.00E+00	0.00E+00	4.00E-05	0.00E+00
MN-54	Ci	0.00E+00	0.00E+00	8.74E-05	1.08E-04
FE-55	Ci	2.15E-02	8.05E-02	1.35E-03	1.58E-03
CO-58	Ci	0.00E+00	0.00E+00	2.30E-03	9.22E-04
CO-60	Ci	0.00E+00	0.00E+00	2.09E-03	2.27E-03
SR-89	Ci	0.00E+00	0.00E+00	8.24E-07	0.00E+00
SR-92	Ci	0.00E+00	0.00E+00	6.68E-06	0.00E+00
ZR-95	Ci	0.00E+00	0.00E+00	5.51E-06	0.00E+00
NB-95	Ci	0.00E+00	0.00E+00	8.49E-05	0.00E+00
AG-110M	Ci	0.00E+00	0.00E+00	2.88E-04	1.05E-04
CS-134	Ci	0.00E+00	0.00E+00	1.55E-04	2.34E-04
CS-137	Ci	0.00E+00	0.00E+00	8.81E-04	7.44E-04

TABLE 2B-2

LIQUID EFFLUENTS

RELEASE(S): ALL - UNIT 2

			CONTINUOUS MODE		BATCH MODE						
:	NUCLIDES	UNITS	QUARTER	:	QUARTER	QUARTER	:	QUARTER	:	QUARTER	:
:	RELEASED		3	:	4	3	:	4	:	4	:
G.ALPHA	Ci	0.00E+00	0.00E+00		7.29E-06	4.37E-08					
NB-97	Ci	0.00E+00	0.00E+00		3.97E-05	4.47E-05					
SB-125	Ci	0.00E+00	0.00E+00		1.3E-03	7.95E-05					
<hr/>											
TOTAL FOR	:	:	:	:	:	:	:	:	:	:	
PERIOD	:	Ci	2.15E-02	:	8.05E-02	7.43E+01	:	9.28E+01	:		
(ABOVE)	:	:	:	:	:	:	:	:	:		

TABLE 2B-2

LIQUID EFFLUENTS - DISSOLVED AND ENTRAINED GASES - UNIT 2

		RELEASE(S): ALL			
		CONTINUOUS MODE		BATCH MODE	
:	NUCLIDES	UNITS	QUARTER	QUARTER	QUARTER
:	RELEASED		:	3	4
	XE-131M	Ci	0.00E+00	0.00E+00	0.00E+00
	XE-133	Ci	0.00E+00	0.00E+00	4.56E-04
	XE-135	Ci	0.00E+00	0.00E+00	4.21E-06
					0.00E+00
<hr/>					
TOTAL FOR	:	:	:	:	:
PERIOD	:	Ci	0.00E+00	0.00E+00	4.60E-04
(ABOVE)	:		:	:	1.24E-02
					:

CHAPTER 13

TABLE 3

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

2nd Half, 1991

SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL

(not irradiated fuel)

1. Type of Waste	UNITS	PERIOD
		July 1 - Dec. 31
a. Spent resins, filter sludges, evaporator bottoms, etc.	3 m Ci*	1.290E+01 1.020E+03
b. Dry compressible waste, contaminated equipment, etc.	3 m Ci*	2.250E+01 1.910E+00
c. Irradiated components, control rods, etc.	3 m Ci	None None
d. Other	3 m Ci	None None

* Measured and/or estimated by correlations in accordance with
10 CFR 61.55.

TABLE 3

2. Estimate of major nuclide composition

ISOTOPES	%
a.	
Ni-63	30.90
Fe-55	30.30
Co-60	28.00
Co-58	5.73
Mn-54	2.19
b.	
Co-58	44.70
Fe-55	16.20
Co-60	9.01
Pu-241	5.97
Cr-51	4.30
H-3	3.00
Ni-63	2.90
Ba-140	2.80
La-140	2.10
Nb-95	2.00
Zr-95	1.50
Mn-54	1.50

TABLE 3

TABLE 3 (con't)

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

2nd Half, 1991

3. Solid Waste Disposition

a. Number of Shipments	34
b. Mode of Transportation	Highway
c. Destination	Chem-Nuclear Systems, Inc. Barnwell, South Carolina

4. Type of Container

a. (1a)	High Integrity Containers. Strong Tight Containers.
b. (1b)	Strong Tight Containers.
c. (1c)	N/A

5. Solidification Agents

a. (1a)	All items shipped dewatered.
b. (1b)	N/A

B. IRRADIATED FUEL SHIPMENTS (Disposition)

1. Number of Shipments	None
2. Mode of Transportation	N/A
3. Destination	N/A

CHAPTER 14
TABLE 4A-CQ3

The Quarter 3 cumulative joint frequency table for all releases
is contained on the following pages.

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: A

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	1	0	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	1	0	0	0	1
NNW	0	0	0	0	0	0	0
VARIABLE	1	5	0	0	0	0	6
Total	1	6	1	0	0	0	8

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT
 CUMULATIVE JOINT FREQUENCY DISTRIBUTION
 HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59
 RELEASE MODE: Ground
 STABILITY CLASS: B
 ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	1	0	0	0	0	1
NE	0	0	1	0	0	0	1
ENE	0	2	3	0	0	0	5
E	0	0	1	0	0	0	1
ESE	0	1	0	0	0	0	1
SE	0	1	0	0	0	0	1
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	1	0	0	0	0	1
WSW	0	3	1	0	0	0	4
W	0	0	0	0	0	0	0
WNW	1	2	0	0	0	0	3
NW	0	2	1	0	0	0	3
NNW	0	0	1	0	0	0	1
VARIABLE	1	10	0	0	0	0	11
Total	2	23	8	0	0	0	33

Periods of calm(hours): 0

Hours of missing data: 0 (this stability class)

Hours of missing data: 0 (this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: C

ELEVATION: 10.0 m. ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	1	0	0	0	0	1
NE	0	0	2	0	0	0	2
ENE	0	12	13	0	0	0	25
E	2	10	0	0	0	0	12
ESE	0	4	1	0	0	0	5
SE	1	2	0	0	0	0	3
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	4	2	0	0	0	6
WSW	0	3	1	0	0	0	4
W	0	3	1	0	0	0	4
NNW	1	14	9	0	0	0	24
NW	0	9	8	0	0	0	17
NNW	0	0	2	0	0	0	2
VARIABLE	18	19	1	0	0	0	38
Total	22	81	40	0	0	0	143

Periods of calm(hours):

Hours of missing data:

Hours of missing data:

0

0

0

(this stability class)

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: D

ALL HOURS IN PERIOD

ELEVATION: 10.0 m.

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	3	2	0	0	0	0	5
NE	7	24	13	0	0	0	44
ENE	17	62	30	0	0	0	109
E	22	28	1	0	0	0	51
ESE	20	34	0	0	0	0	54
SE	10	12	1	0	0	0	23
SSE	4	5	0	0	0	0	9
S	4	3	0	0	0	0	7
SSW	2	4	2	0	0	0	8
SW	8	46	9	1	0	0	64
WSW	12	32	3	0	0	0	47
W	13	20	1	0	0	0	34
WNW	10	49	3	0	0	0	62
NW	2	36	9	0	0	0	47
NNW	0	6	1	0	0	0	7
VARIABLE	99	63	6	0	0	0	168
Total	233	426	79	1	0	0	739

Periods of calm(hours):

0

Hours of missing data:

0

Hours of missing data:

0

(this stability class)

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT
 CUMULATIVE JOINT FREQUENCY DISTRIBUTION
 HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: E

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	4	0	0	0	0	0	4
NNE	33	9	0	0	0	0	42
NE	44	35	0	0	0	0	79
ENE	29	21	0	0	0	0	50
E	6	13	0	0	0	0	19
ESE	9	13	0	0	0	0	22
SE	9	11	0	0	0	0	20
SSE	3	2	7	0	0	0	12
S	6	6	0	0	0	0	12
SSW	5	12	2	0	0	0	19
SW	53	66	12	0	0	0	131
WSW	36	16	0	0	0	0	52
W	38	8	1	0	0	0	47
NNW	21	9	0	0	0	0	30
NW	34	6	1	0	0	0	41
NNW	13	17	1	0	0	0	31
VARIABLE	196	35	3	0	0	0	234
Total	539	279	27	0	0	0	845

Periods of calm(hours):

2

Hours of missing data:

0

(this stability clas.)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: F

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	8	1	0	0	0	0	9
NNE	15	1	0	0	0	0	16
NE	14	2	0	0	0	0	16
ENE	11	2	0	0	0	0	13
E	4	0	0	0	0	0	4
ESE	1	1	0	0	0	0	2
SE	1	1	0	0	0	0	2
SSE	0	1	0	0	0	0	1
S	1	0	0	0	0	0	1
SSW	1	3	1	0	0	0	5
SW	3	7	2	0	0	0	12
WSW	11	1	0	0	0	0	12
W	19	5	0	0	0	0	24
NNW	17	3	0	0	0	0	20
NW	15	6	0	0	0	0	21
NNW	23	6	0	0	0	0	29
VARIABLE	146	7	0	0	0	0	153
Total	290	47	3	0	0	0	340

Periods of calm(hours):

3

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION
HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: G

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	8	0	0	0	0	0	8
NNE	1	0	0	0	0	0	1
NE	4	0	0	0	0	0	4
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	2	0	0	0	0	0	2
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	4	0	0	0	0	0	4
WNW	2	1	0	0	0	0	3
NW	9	0	0	0	0	0	9
NNW	30	0	0	0	0	0	30
VARIABLE	31	2	0	0	0	0	33
Total	91	3	0	0	0	0	94

Periods of calm(hours):

1

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: A

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	1	0	0	0	0	1
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	1	0	0	0	1
NNW	0	0	0	0	0	0	0
VARIABLE	1	5	0	0	0	0	6
Total	1	6	1	0	0	0	8

Periods of calm(hours): 0

Hours of missing data: 0

Hours of missing data: 0 (this stability class)

Hours of missing data: 0 (this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION
HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: B

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	2	0	0	0	0	2
NNE	0	2	1	0	0	0	3
NE	0	0	1	0	0	0	1
ENE	0	0	3	1	0	0	4
E	0	0	0	0	0	0	0
ESE	0	0	1	0	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	1	3	0	0	0	4
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	3	1	0	0	0	4
NNW	1	1	1	0	0	0	3
VARIABLE	0	10	1	0	0	0	11
Total	1	19	12	1	0	0	33

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: C

ALL HOURS IN PERIOD

ELEVATION: 60.3 m.

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	2	0	0	0	0	2
NNE	1	4	2	0	0	0	7
NE	0	5	3	1	0	0	9
ENE	0	3	11	5	0	0	19
E	1	0	4	0	0	0	5
ESE	0	7	2	0	0	0	9
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	1	0	0	0	0	0	1
SSW	0	0	0	0	0	0	0
SW	0	0	2	0	0	0	2
WSW	0	1	5	0	0	0	6
W	0	2	1	0	0	0	3
WNW	0	4	6	2	0	0	12
NW	1	12	13	0	0	0	26
NNW	1	3	6	0	0	0	10
VARIABLE	13	17	2	0	0	0	32
Total	18	60	57	8	0	0	143

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: D

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	4	2	0	0	0	0	6
NNE	4	7	2	0	0	0	13
NE	7	17	20	2	0	0	46
ENE	6	41	45	11	0	0	103
E	5	25	9	1	0	0	40
ESE	2	20	2	0	0	0	24
SE	4	18	5	0	0	0	27
SSE	2	3	4	1	0	0	10
S	1	2	1	0	0	0	4
SSW	2	6	2	0	0	0	10
SW	3	21	28	1	0	0	53
WSW	3	26	14	1	0	0	44
W	4	24	10	0	0	0	38
WNW	2	31	9	2	0	0	44
NW	4	36	24	4	0	0	68
NNW	2	12	6	0	0	0	20
VARIABLE	100	73	14	2	0	0	189
Total	155	364	195	25	0	0	739

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT
 CUMULATIVE JOINT FREQUENCY DISTRIBUTION
 HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59
 RELEASE MODE: Elevated
 STABILITY CLASS: E
 ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	6	2	0	0	0	8
NNE	5	17	4	0	0	0	26
NE	3	44	26	0	0	0	73
ENE	9	45	35	0	0	0	89
E	1	36	3	0	0	0	40
ESE	4	9	9	0	0	0	22
SE	2	11	9	0	0	0	22
SSE	1	12	10	1	0	0	24
S	3	6	2	1	0	0	12
SSW	3	10	7	0	0	0	20
SW	6	46	68	1	0	0	121
WSW	3	54	23	0	0	0	80
W	9	32	7	1	0	0	49
WNW	6	33	16	0	0	0	55
NW	5	13	16	1	0	0	35
NNW	2	10	9	0	0	0	21
VARIABLE	65	69	14	1	0	0	149
Total	127	453	260	6	0	0	846

Periods of calm(hours):

1

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION
HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: F

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	6	5	0	0	0	11
NNE	0	10	7	0	0	0	17
NE	3	16	22	0	0	0	41
ENE	2	22	12	0	0	0	36
E	3	7	6	0	0	0	16
ESE	0	3	2	0	0	0	5
SE	0	3	0	0	0	0	3
SSE	0	0	1	1	0	0	2
S	0	0	0	0	0	0	0
SSW	2	4	4	0	0	0	10
SW	0	5	7	3	0	0	15
WSW	2	8	7	0	0	0	17
W	1	16	9	0	0	0	26
WNW	1	21	7	0	0	0	29
NW	3	13	8	0	0	0	24
NNW	3	8	9	0	0	0	20
VARIABLE	32	33	6	0	0	0	71
Total	52	175	112	4	0	0	343

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ3

FARLEY NUCLEAR PLANT
 CUMULATIVE JOINT FREQUENCY DISTRIBUTION
 HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JUL-91 00:00 TO 30-SEP-91 23:59
 RELEASE MODE: Elevated
 STABILITY CLASS: G
 ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	3	1	0	0	0	4
NNE	1	8	12	0	0	0	21
NE	2	4	7	0	0	0	13
ENE	0	6	4	0	0	0	10
E	0	3	0	0	0	0	3
ESE	1	0	0	0	0	0	1
SE	1	1	0	0	0	0	2
SSE	0	1	0	0	0	0	1
S	0	0	0	0	0	0	0
SSW	1	0	0	0	0	0	1
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	1	0	0	0	0	1
WNW	0	2	3	0	0	0	5
NW	0	2	8	0	0	0	10
NNW	3	2	2	0	0	0	7
VARIABLE	8	6	2	0	0	0	16
Total	17	39	39	0	0	0	95

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

CHAPTER 15

TABLE 4A-CQ4

The Quarter 4 cumulative joint frequency table for all releases
is contained on the following pages.

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: A

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	1	0	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	2	0	0	0	0	2
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
VARIABLE	0	1	0	0	0	0	1
Total	0	4	0	0	0	0	4

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: B

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	1	0	0	1
NNE	0	1	0	0	0	0	1
NE	0	0	1	0	0	0	1
ENE	0	1	1	0	0	0	2
E	0	0	2	0	0	0	2
ESE	0	3	1	0	0	0	4
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	1	0	0	0	1
WSW	0	1	0	0	0	0	1
W	0	0	0	0	0	0	0
WNW	0	0	2	0	0	0	2
NW	0	0	2	2	0	0	4
NNW	0	1	7	1	0	0	9
VARIABLE	1	5	2	0	0	0	8
Total	1	12	19	4	0	0	36

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: C

ALL HOURS IN PERIOD

ELEVATION: 10.0 m.

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	1	2	0	0	0	3
NNE	0	2	4	0	0	0	6
NE	0	2	7	0	0	0	9
ENE	0	1	6	0	0	0	7
E	0	4	2	0	0	0	6
ESE	0	4	4	0	0	0	8
SE	0	0	1	0	0	0	1
SSE	0	0	2	0	0	0	2
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	1	0	0	0	0	1
WSW	0	2	0	0	0	0	2
W	0	2	2	0	0	0	4
WNW	0	3	0	0	0	0	3
NW	0	3	7	0	0	0	10
NNW	0	3	8	3	0	0	14
VARIABLE	4	15	7	1	0	0	27
Total	4	43	52	4	0	0	103

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: D

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	7	11	3	0	0	0	21
NNE	6	22	1	0	0	0	29
NE	3	54	12	0	0	0	69
ENE	6	34	30	6	0	0	76
E	1	44	13	0	0	0	58
ESE	1	28	6	0	0	0	35
SE	2	20	10	0	0	0	32
SSE	2	4	17	2	0	0	25
S	0	4	4	1	0	0	9
SSW	1	1	7	11	0	0	20
SW	1	10	8	0	0	0	19
WSW	2	15	2	0	0	0	19
W	2	11	0	0	0	0	13
NNW	1	11	3	0	0	0	15
NW	5	27	21	2	0	0	55
NNW	7	57	68	1	0	0	133
VARIABLE	47	86	8	0	0	0	141
Total	94	439	213	23	0	0	769

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: E

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	8	3	0	0	0	0	11
NNE	17	21	0	0	0	0	38
NE	22	42	1	0	0	0	65
E,JE	26	45	1	0	0	0	72
E	10	20	0	0	0	0	30
ESE	6	33	0	0	0	0	39
SE	5	29	25	0	0	0	59
SSE	2	8	9	0	0	0	19
S	0	3	3	0	0	0	6
SSW	0	5	6	1	0	0	12
SW	0	10	18	0	0	0	28
WSW	1	16	1	0	0	0	18
W	4	1	1	0	0	0	6
NNW	9	5	4	0	0	0	18
NW	6	32	4	0	0	0	42
NNW	6	80	10	0	0	0	96
VARIABLE	51	8	0	0	0	0	59
Total	173	361	83	1	0	0	61n

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: F

ALL HOURS IN PERIOD

ELEVATION: 10.0 m.

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	9	1	0	0	0	0	10
NNE	28	4	0	0	0	0	32
NE	14	4	0	0	0	0	18
ENE	10	11	1	0	0	0	22
E	8	2	0	0	0	0	10
ESE	2	9	0	0	0	0	11
SE	0	3	1	0	0	0	4
SSE	0	0	2	0	0	0	2
S	0	1	0	0	0	0	1
SSW	0	0	0	0	0	0	0
SW	0	8	0	0	0	0	8
WSW	2	8	0	0	0	0	10
W	5	2	0	0	0	0	7
WNW	6	3	0	0	0	0	9
NW	6	14	0	0	0	0	20
NNW	25	22	0	0	0	0	47
VARIABLE	60	5	0	0	0	0	65
Total	175	97	4	0	0	0	276

Periods of calm(hours):

0

Hours of missing data:

0

Hours of missing data:

0

(this stability class)

(this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: G

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	61	22	0	0	0	0	83
NNE	17	4	0	0	0	0	21
NE	7	0	0	0	0	0	7
ENE	6	0	0	0	0	0	6
E	2	2	0	0	0	0	4
ESE	1	1	0	0	0	0	2
SE	0	0	1	0	0	0	1
SSE	1	0	0	0	0	0	1
S	1	0	0	0	0	0	1
SSW	0	0	0	0	0	0	0
SW	0	1	0	0	0	0	1
WSW	1	4	0	0	0	0	5
W	8	2	0	0	0	0	10
WNW	4	0	0	0	0	0	4
NW	17	1	0	0	0	0	18
NNW	56	9	0	0	0	0	65
VARIABLE	167	4	0	0	0	0	171
Total	349	50	1	0	0	0	400

Periods of calm(hours):

2

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: A

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	1	0	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	2	0	0	0	0	2
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
VARIABLE	0	1	0	0	0	0	1
Total	0	4	0	0	0	0	4

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-C04

FARLEY NUCLEAR PLANT
 CUMULATIVE JOINT FREQUENCY DISTRIBUTION
 HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59
 RELEASE MODE: Elevated
 STABILITY CLASS: B
 ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	2	1	0	0	0	3
NE	0	0	1	0	0	0	1
ENE	0	1	1	0	0	0	2
E	0	0	2	0	0	0	2
ESE	0	0	4	0	0	0	4
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	1	0	0	1
WSW	0	0	0	0	0	0	0
W	0	0	1	0	0	0	1
WNW	0	0	0	1	0	0	1
NW	0	0	1	2	0	0	3
NNW	0	0	5	5	0	0	10
VARIABLE	0	4	3	1	0	0	8
Total	0	7	19	10	0	0	36

Periods of calm(hours): 0

Hours of missing data: 0 (this stability class)

Hours of missing data: 0 (this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: C

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	3	1	0	0	4
NNE	0	4	6	0	0	0	10
NE	0	2	5	2	0	0	9
ENE	0	0	6	0	0	0	6
E	0	2	5	1	0	0	8
ESE	0	2	6	0	0	0	8
SE	0	0	3	0	0	0	3
SSE	0	0	0	2	0	0	2
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	1	0	0	0	0	1
WSW	0	0	0	0	0	0	0
W	0	1	4	0	0	0	5
WNW	0	1	3	0	0	0	4
NW	0	2	4	3	0	0	9
NNW	0	0	6	5	0	0	11
VARIABLE	1	10	9	3	0	0	23
Total	1	25	60	17	0	0	103

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: D

ALL HOURS IN PERIOD

ELEVATION: 60.3 m.

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	4	12	19	4	0	0	39
NNE	3	20	5	3	0	0	34
NE	3	22	41	0	0	0	66
ENE	1	28	41	8	0	0	78
E	2	23	35	3	0	0	63
ESE	0	24	20	0	0	0	44
SE	1	13	16	0	0	0	30
SSE	1	2	14	16	0	0	33
S	0	4	5	4	0	0	13
SSW	0	1	3	15	4	0	23
SW	1	4	6	3	0	0	14
WSW	1	6	4	2	0	0	13
W	2	12	3	0	0	0	17
NNW	2	5	6	1	0	0	14
NW	0	8	22	15	1	0	46
NNW	4	7	44	22	0	0	77
VARIABLE	33	55	21	5	0	0	114
Total	58	246	308	101	5	0	718

Periods of calm(hours):

51

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-C04

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: E

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	10	12	0	0	0	22
NNE	2	7	9	0	0	0	18
NE	2	17	33	0	0	0	52
ENE	0	38	49	0	0	0	87
E	1	12	36	0	0	0	49
ESE	2	13	29	0	0	0	44
SE	0	7	30	0	0	0	37
SSE	2	8	24	22	0	0	56
S	2	4	6	2	0	0	14
SSW	0	1	9	13	0	0	23
SW	0	4	15	6	0	0	25
WSW	1	1	11	1	0	0	14
W	0	2	3	1	0	0	6
WNW	0	7	5	3	0	0	15
NW	0	2	36	9	0	0	47
NNW	0	7	53	5	0	0	65
VARIABLE	9	16	7	0	0	0	32
Total	21	156	367	62	0	0	606

Periods of calm(hours):

12

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: F

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	9	6	0	0	0	15
NNE	0	4	10	0	0	0	14
NE	0	4	21	0	0	0	25
ENE	0	15	36	0	0	0	51
E	0	10	15	0	0	0	25
ESE	0	1	11	0	0	0	12
SE	2	3	4	0	0	0	9
SSE	1	3	4	4	0	0	12
S	0	0	2	0	0	0	2
SSW	2	5	0	0	0	0	7
SW	1	1	6	3	0	0	11
WSW	2	0	4	0	0	0	6
W	0	3	3	0	0	0	6
WNW	0	1	5	0	0	0	6
NW	1	1	17	0	0	0	19
NNW	0	1	20	1	0	0	22
VARIABLE	5	9	6	0	0	0	20
Total	14	70	170	8	0	0	262

Periods of calm(hours): 14

Hours of missing data: 0 (this stability class)

Hours of missing data: 0 (this time period, all stability classes)

TABLE 4A-CQ4

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-OCT-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: G

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	10	18	8	0	0	0	36
NNE	3	12	47	0	0	0	62
NE	1	18	38	0	0	0	57
ENE	2	16	18	0	0	0	36
E	0	6	12	0	0	0	18
ESE	2	7	8	0	0	0	17
SE	1	4	3	0	0	0	8
SSE	3	1	0	0	0	0	4
S	0	1	0	0	0	0	1
SSW	0	2	0	0	0	0	2
SW	4	2	0	0	0	0	6
WSW	5	3	0	0	0	0	8
W	6	9	5	0	0	0	20
NNW	2	7	3	0	0	0	12
NW	2	4	13	0	0	0	19
NNW	3	14	32	0	0	0	49
VARIABLE	11	20	6	0	0	0	37
Total	55	144	193	0	0	0	392

Periods of calm(hours): 10

Hours of missing data: 0 (this stability class)

Hours of missing data: 0 (this time period, all stability classes)

CHAPTER 16

TABLE 4A-1BQ3

There were no batch releases on Unit 1 during Quarter 3.

CHAPTER 17

TABLE 4A-1BQ4

There were no batch releases on Unit 1 during Quarter 4.

CHAPTER 18

TABLE 4A-2BQ3

There were no batch releases on Unit 2 during Quarter 3.

CHAPTER 19

TABLE 4A-2BQ4

There were no batch releases on Unit 2 during Quarter 4.

CHAPTER 20

TABLE 4B

TABLE 4B
CLASSIFICATION OF ATMOSPHERIC STABILITY

Stability	Pasquill	$\sigma\theta$	a	Temperature channel
Classification	Categories	(degrees)		with height ($^{\circ}$ F/51m)
Extremely unstable	A	25.0		<-1.74
Moderately unstable	B	20.0		-1.74 to -1.56
Slightly unstable	C	15.0		-1.56 to -1.38
Neutral	D	10.0		-1.38 to -0.46
Slightly stable	E	5.0		-0.46 to 1.38
Moderately stable	F	2.5		1.38 to 3.6
Extremely stable	G	1.7		>3.6

a Standard deviations of horizontal wind direction fluctuation over a period of 15 minutes to 1 hour. The values shown are averages for each stability classification.

CHAPTER 21

TABLE 5

TABLE 5

RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM
FARLEY NUCLEAR PLANT - UNITS 1 & 2

Gaseous Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Minimum Detectable Concentration (MDC) (uCi/ml)
A. Waste Gas Storage Tank	Each Tank Grab b Sample P	Each Tank P	Principle Gamma Emitters	1E-04 g,j
B. Containment Purge	Each Purge Grab b Sample P	Each Purge Grab b Sample P	Principle Gamma Emitters	1E-04 g,j
C. Condenser Steam Jet Air Ejector Plant Vent Stack	M-b,c,e Grab Sample	b M	Principle Gamma Emitters	1E-04 1E-06 g,j

TABLE 5

TABLE 5 (Continued)

Gaseous Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Minimum Detectable Concentration (MDC) (uCi/ml)
D. Plant Vent Stack Containment Purge	Continuous	Charcoal Sample d	I-131	1E-12
	Charcoal	W	I-133	1E-10
	Continuous	Particulate Sample d	g Principle Gamma Emitters (I-131, Others)	1E-11
	Continuous	M i Composite Particulate Sample	Gross Alpha	1E-11
	Continuous	Q i Composite Particulate Sample	Sr-89, Sr-90	1E-11
	Continuous	Noble Gas Monitor	Noble Gases Gross Beta and Gamma	1E-06

TABLE 5

TABLE 5 (Continued)

TABLE NOTATION

- a. The MDC is the smallest concentration of radioactive material in a sample that will be detected with 95% probability with 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$\text{MDC} = \frac{s}{b} \cdot E \cdot V \cdot 2.22 \times 10^6 \cdot Y \cdot \exp(-\lambda \Delta t)$$

where:

MDC is the "a priori" lower limit of detection as defined above (as microcurie per unit mass or volume),

s is the standard deviation of the background counting rate
 b

or of the counting rate of a blank sample as appropriate (as counts per minute),

E is the counting efficiency (as counts per transformation),

V is the sample size (in units mass or volume),

2.22×10^6 is the number of transformations per minute per microcurie,

Y is the fractional radiochemical yield (when applicable),

λ is the radioactive decay constant for the particular radionuclide, and

Δt is the elapsed time between midpoint of sample collection and time of counting (for plant effluents, not environmental samples).

The value of s used in the calculation of the MDC for a
 b

detection system shall be based on the actual observed variance of the background counting rate or of the counting rate of the blank samples (as appropriate) rather than on an unverified theoretically predicted variance. Typical values of E , V , Y , and Δt shall be used in the calculation.

TABLE 5

TABLE 5 (Continued)

TABLE NOTATION

- b. Analyses shall also be performed following shutdown from > or = 15% RATED THERMAL POWER, startup to > or = 15% RATED THERMAL POWER or a THERMAL POWER change exceeding 15% of the RATED THERMAL POWER within a one hour period.
- c. Tritium grab samples shall be taken from the plant vent stack at least once per 24 hours when the refueling canal is flooded.
- d. Samples shall be changed at least once per 7 days and analyses shall be completed within 48 hours after changing (or after removal from sampler). Sampling shall also be performed at least once per 24 hours for at least 2 days following each shutdown from > or = 15% RATED THERMAL POWER, startup to > or = 15% RATED THERMAL POWER or THERMAL POWER change exceeding 15% of RATED THERMAL POWER in one hour and analyses shall be completed within 48 hours of changing. When samples collected for 24 hours are analyzed, the corresponding MDC may be increased by a factor of 10.
- e. Tritium grab samples shall be taken at least once per 7 days from the ventilation exhaust from the spent fuel pool area, whenever spent fuel is in the spent fuel pool.
- f. The ratio of the sample flow rate to the sampled stream flow rate shall be known for the time period covered by each dose or dose rate calculation made in accordance with Specifications 3.11.2.1, 3.11.2.2 and 3.11.2.3.
- g. The principle gamma emitters for which the MDC specification applies exclusively are the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141 and Ce-144 for particulate emissions. This list does not mean that only these nuclides are to be detected and reported. Other which are measurable and identifiable, together with the above nuclides, shall also be identified and reported.
- h. Deviations from MDC requirements of Table 4.11-2 shall be reported per Specification 6.9.1.8 in lieu of any other report.
- i. A composite particulate sample is one in which the quantity of air sampled is proportional to the quantity of air discharged. Either a specimen which is representative of the air discharged may be accumulated and analyzed or the individual samples may be analyzed and weighted in proportion to their respective volume discharged.

TABLE 5

TABLE 5 (Continued)

- j. The principle gamma emitters for which the MDC specification applies exclusively are the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 for gaseous emissions. This does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable together with the above nuclides, shall also be identified and reported.

TABLE 5

TABLE 5 (Continued)

TYPICAL GAS MDC'S FOR RCLS
COUNTING SYSTEM

Nuclide	MDC (uCi/ml)	Nuclide	MDC (uCi/ml)
Mn-54	1.46E-14	Ce-144	5.08E-14
Fe-59	4.51E-14	Kr-87	3.44E-08
Co-58	1.55E-14	Kr-88	4.71E-08
Co-60	2.81E-14	Xe-133	6.30E-08
Zn-65	3.04E-14	Xe-133M	1.54E-07
Mo-99	1.02E-13	Xe-135	1.91E-08
Cs-134	4.08E-11	Xe-138	5.04E-08
Cs-137	1.31E-14	I-131	3.20E-14
Ce-141	1.13E-14	I-133	2.87E-14

CHAPTER 22

TABLE 6

TABLE 6

RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM
FARLEY NUCLEAR PLANT - UNITS 1 & 2

Liquid Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Minimum Detectable Concentration (MDC) (uCi/ml)	a,g
A. Batch Waste Release Tanks	c P Each Batch	P Each Batch	e Principle Gamma Emitters	5E-07	
			I-131	1E-06	
	One Batch/M	M	Dissolved & Entrained Gases (Gamma Emitters)	1E-05	
	P Each Batch	b M Composite	H-3 Gross Alpha	1E-05 1E-07	

TABLE 6

TABLE 6 (Continued)

Liquid Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Minimum Detectable Concentration (MDC) ($\mu\text{Ci}/\text{ml}$)
	P Each Batch	b Q Composite	Sr-89, Sr-90 Fe-55	5E-08 1E-06
B. Continuous Releases	d,f D Grab Sample	b W Composite	e Principle Gamma Emitters I-131	5E-07 1E-06
1. Steam Generator Blowdown	M Grab Sample	M	Dissolved & Entrained Gases (Gamma Emitters)	1E-05
	D Grab Sample	b M Composite	H-3 Gross Alpha	1E-05 1E-07
	D Grab Sample	b Q Composite	Sr-89, Sr-90 Fe-55	5E-08 1E-06
2. Turbine Building Sump	P Grab Sample	b W Composite	e Principle Gamma Emitters H-3	5E-07 1E-05

TABLE 6

TABLE 6 (Continued)

TABLE NOTATION

- a. The MDC is the smallest concentration of radioactive material in a sample that will be detected with 95% probability with 5% probability of false "concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$\text{MDC} = \frac{s}{b} \cdot E \cdot V \cdot 2.22 \times 10^6 \cdot Y \cdot \exp(-\lambda \Delta t)$$

where:

MDC is the "a priori" lower limit of detection as defined above (as microcurie per unit mass or volume),

s is the standard deviation of the background counting rate
or of the counting rate of a blank sample as appropriate (as counts per minute),

E is the counting efficiency (as counts per transformation),

V is the sample size (in units mass or volume),

2.22×10^6 is the number of transformations per minute per microcurie,

Y is the fractional radiochemical yield (when applicable),

λ is the radioactive decay constant for the particular radionuclide, and

Δt is the elapsed time between midpoint of sample collection and time of counting (for plant effluents, not environmental samples).

The value of s used in the calculation of the MDC for a

detection system shall be based on the actual observed variance of the background counting rate or of the counting rate of the blank samples (as appropriate) rather than on an unverified theoretically predicted variance. Typical values of E , V , Y , and Δt shall be used in the calculation.

TABLE 6

TABLE 6 (Continued)

TABLE NOTATION

- b. A composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged and in which the method of sampling employed results in a specimen which is representative of the liquids released.
- c. A batch release is the discharge of liquid wastes of a discrete volume. Prior to sampling for analyses, each batch shall be isolated, and then thoroughly mixed, by a method described in the OI :M, to assure representative sampling.
- d. A continuous release is the discharge of liquid wastes of a nondiscrete volume; e.g., from a volume of system that has an input flow during the effluent release.
- e. The principle gamma emitters for which the MDC specification applies exclusively are the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137,Ce-141, and Ce-144. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported.
- f. Sampling will be performed only if the effluent will be discharged to the environment.
- g. Deviation from the MDC requirements of Table 4.11-1 of the TS shall be reported per Specification 6.9.1.8 in lieu of any other report.

TABLE 6

TABLE 6 (Continued)

TYPICAL LIQUID MDC'S FOR RCLS
COUNTING SYSTEM

Nuclide	MDC (uCi/ml)	Nuclide	MDC (uCi/ml)
Mn-54	2.88E-08	I-131	2.13E-08
Co-58	2.15E-08	Cs-134	1.75E-08
Fe-59	4.43E-08	Cs-137	2.67E-08
Co-60	3.86E-08	Ce-141	3.40E-08
Zn-65	7.94E-08	Ce-144	1.65E-07
Mo-99	1.88E-07		

CHAPTER 23

TABLE 7

TABLE 7

LIQUID DISCHARGES NOT MEETING SPECIFIED DETECTION LIMITS
Farley Units 1 & 2 - 2nd half, 1991

Batch #	N/A*
Date	N/A
Count Time in Seconds	N/A
Volume Discharged in Gallons	N/A
Dilution Water in Gallons	N/A
Total Isotopic Activity (uCi/ml)	N/A
Isotope of Interest	N/A
MDC Measured	N/A
% of Total Isotopic Activity	N/A
% of Total Dose	N/A

* No liquid discharges made that did not meet specified detection limits.

CHAPTER 24

TABLE 8-CA

The annual cumulative joint frequency table for all releases
is contained on the following pages.

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: A

ALL HOURS IN PERIOD

ELEVATION: 10.0 m.

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	2	0	0	0	0	2
NE	0	0	0	0	0	0	0
ENE	0	0	3	0	0	0	3
E	2	1	0	0	0	0	3
ESE	0	0	0	0	0	0	0
SE	0	0	1	0	0	0	1
SSE	1	0	0	0	0	0	1
S	0	0	0	0	0	0	0
SSW	0	2	0	2	0	0	4
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	1	0	1
NW	0	0	1	0	3	0	4
NNW	0	0	0	0	0	0	0
VARIABLE	1	6	0	0	0	0	7
Total	4	11	5	2	4	0	26

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: B

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	1	0	0	1
NNE	0	2	0	0	0	0	2
NE	0	0	2	0	0	0	2
ENE	1	4	14	2	0	0	21
E	0	2	5	0	0	0	7
ESE	0	4	1	0	0	0	5
SE	0	1	0	0	0	0	1
SSE	1	0	0	0	0	0	1
S	0	0	0	0	0	0	0
SSW	0	0	1	2	1	0	4
SW	0	3	2	0	1	0	6
WSW	0	7	1	0	0	0	8
W	0	1	3	0	0	0	4
WNW	1	5	6	1	1	0	14
NW	0	5	10	2	1	0	18
NNW	0	2	12	1	0	0	15
VARIABLE	2	19	7	1	0	0	29
Total	5	55	64	10	4	0	138

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: C

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	3	5	0	0	0	8
NNE	1	4	4	0	0	0	9
NE	0	2	18	0	0	0	20
ENE	1	18	22	0	0	0	41
E	3	19	5	0	0	0	27
ESE	0	12	8	1	0	0	21
SE	1	2	2	0	0	0	5
SSE	0	1	2	0	0	0	3
S	1	2	1	0	0	0	4
SSW	0	2	5	0	1	0	8
SW	0	20	10	1	0	0	31
WSW	1	18	3	2	0	0	24
W	2	10	7	0	0	0	19
NNW	2	28	17	3	1	0	51
NW	0	15	36	1	0	0	52
NNW	0	8	22	3	0	0	33
VARIABLE	26	49	15	1	0	0	91
Total	38	213	182	12	2	0	447

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: D

ELEVATION: 10.0 m. ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	14	34	6	0	0	0	54
NNE	18	87	10	0	0	0	115
NE	38	195	82	0	0	0	315
ENE	45	186	127	6	0	0	364
E	51	160	43	0	0	0	254
ESE	30	165	38	0	0	0	233
SE	17	118	68	1	0	0	204
SSE	11	35	86	21	0	0	153
S	7	23	21	8	1	0	60
SSW	9	21	35	22	9	0	96
SW	19	104	77	11	3	0	214
WSW	32	112	16	6	0	0	166
W	34	83	11	1	0	0	129
NNW	23	113	35	7	1	0	179
NW	12	119	104	14	0	0	249
NNW	12	121	128	4	0	0	265
VARIABLE	256	237	32	1	0	0	526
Total	628	1913	919	102	14	0	3576

Periods of calm(hours):

0

Hours of missing data:

0

Hours of missing data:

0

(this stability class)

(this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: E

ELEVATION: 10.0 m. ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	21	9	0	0	0	0	29
NNE	77	54	0	0	0	0	131
NE	106	102	2	0	0	0	210
ENE	90	93	1	0	0	0	184
E	53	75	2	0	0	0	130
ESE	29	92	3	0	0	0	124
SE	26	98	58	0	0	0	182
SSE	14	37	52	3	0	0	106
S	10	28	19	0	0	0	57
SSW	14	38	23	2	0	0	77
SW	84	140	57	0	0	0	281
WSW	79	75	2	0	0	0	156
W	75	17	5	0	0	0	97
WNW	66	25	8	0	0	0	99
NW	58	94	21	0	0	0	173
NNW	47	121	17	0	0	0	185
VARIABLE	426	90	5	0	0	0	521
Total	1275	1187	275	5	0	0	2742

Periods of calm(hours):

6

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

(this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: F

ALL HOURS IN PERIOD

ELEVATION: 10.0 m.

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3 ---	4-7 ---	8-12 ----	13-18 -----	19-24 -----	>24 ----	
N	36	5	0	0	0	0	41
NNE	60	5	0	0	0	0	65
NE	46	10	0	0	0	0	56
ENE	35	15	2	0	0	0	52
E	21	4	0	0	0	0	25
ESE	13	10	2	0	0	0	25
SE	5	18	3	0	0	0	26
SSE	3	4	2	0	0	0	9
S	3	1	2	0	0	0	6
SSE	5	4	1	0	0	0	10
SW	5	23	2	0	0	0	30
WSW	22	19	0	0	0	0	41
W	41	10	0	0	0	0	51
WNW	38	17	0	0	0	0	55
NW	45	51	0	0	0	0	96
NNW	76	42	0	0	0	0	118
VARIABLE	303	14	0	0	0	0	317
Total	757	252	14	0	0	0	1023

Periods of calm(hours):

Hours of missing data:

Hours of missing data:

6

0

0

(this stability class)

(this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Ground

STABILITY CLASS: G

ELEVATION: 10.0 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 10.0 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	119	24	0	0	0	0	143
NNE	40	6	0	0	0	0	46
NE	29	0	0	0	0	0	29
ENE	12	0	0	0	0	0	12
E	6	3	0	0	0	0	9
ESE	5	4	0	0	0	0	9
SE	4	4	1	0	0	0	9
SSE	4	0	0	0	0	0	4
S	2	0	0	0	0	0	2
SSW	1	0	0	0	0	0	1
SW	0	4	0	0	0	0	4
WSW	4	5	0	0	0	0	9
W	18	2	0	0	0	0	20
NNW	14	2	0	0	0	0	16
NW	44	2	0	0	0	0	46
NNW	147	12	0	0	0	0	159
V. 85% LE	268	6	0	0	0	0	274
Total	717	74	1	0	0	0	792

Periods of calm(hours):

4

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE B-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: A

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	2	0	0	0	0	2
NE	0	0	0	0	0	0	0
ENE	1	0	2	1	0	0	4
E	0	1	0	0	0	0	1
ESE	0	1	0	0	0	0	1
SE	0	0	0	0	0	0	0
SSE	0	1	1	0	0	0	2
S	0	0	0	0	0	0	0
SSW	0	0	0	0	2	0	2
SW	0	2	0	0	0	0	2
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
NNW	0	0	0	0	0	1	1
NW	0	0	1	0	0	3	4
NNN	0	0	0	0	0	0	0
VARIABLE	1	6	0	0	0	0	7
Total	2	13	4	1	2	4	26

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: B

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	2	3	0	0	0	5
NNE	0	5	3	0	0	0	8
NE	0	1	2	0	0	0	3
ENE	0	1	11	6	0	0	18
E	0	1	4	0	0	0	5
ESE	0	1	5	0	0	0	6
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	1	0	1
SW	0	2	0	2	1	2	7
WSW	0	1	5	0	0	0	6
W	0	1	2	1	0	0	4
NNW	0	0	0	6	0	1	7
NW	0	9	3	8	0	1	21
NNW	1	2	9	6	0	0	18
VARIABLE	1	16	11	1	0	0	29
Total	2	42	58	30	2	4	138

Periods of calm(hours):

0

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION
HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59
 RELEASE MODE: Elevated
 STABILITY CLASS: C
 ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	3	7	1	0	0	11
NNE	1	11	11	0	0	0	23
NE	1	7	14	4	0	0	26
ENE	1	6	19	9	0	0	35
E	1	4	10	3	0	0	18
ESE	1	11	13	2	0	0	27
SE	0	0	6	0	0	0	6
SSE	0	0	0	2	0	0	2
S	2	0	1	0	0	0	3
SSW	0	3	1	1	0	0	5
SW	0	9	6	6	1	1	23
WSW	1	10	12	1	0	0	24
W	0	8	8	3	2	0	21
WNW	0	10	11	5	2	1	29
NW	1	22	26	16	0	0	65
NNW	2	10	26	8	0	0	46
VARIABLE	16	42	18	7	0	0	83
Total	27	156	189	68	5	2	447

Periods of calm(hours): 0

Hours of missing data: 0 (this stability class)

Hours of missing data: 0 (this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: D

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	12	54	39	7	0	0	112
NNE	12	73	40	13	0	0	138
NE	21	108	131	12	0	0	272
ENE	17	142	170	45	0	0	374
E	14	99	113	13	0	0	239
ESE	8	106	104	4	0	0	222
SE	8	94	92	6	0	0	200
SSE	3	20	95	46	6	0	170
S	4	22	40	32	1	0	99
SSW	7	13	25	39	12	6	102
SW	9	51	75	42	7	5	189
WSW	11	89	44	12	1	0	157
W	14	76	30	12	6	0	138
NNW	10	72	48	14	3	2	149
NW	9	85	88	83	7	0	272
NNW	10	48	102	56	1	0	217
VARIABLE	188	221	54	11	0	1	475
Total	357	1373	1290	44	44	14	3525

Periods of calm(hours):

51

Hours of missing data:

0

(this stability class)

Hours of missing data:

0

(this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: E

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	5	36	18	0	0	0	59
NNE	13	50	40	0	0	0	103
NE	8	89	82	1	0	0	180
ENE	11	119	110	0	0	0	240
E	4	96	71	0	0	0	171
ESE	6	58	75	1	0	0	140
SE	5	48	69	4	0	0	126
SSE	7	39	102	47	1	0	196
S	11	24	44	29	0	0	108
SSW	7	24	45	31	0	0	107
SW	8	90	152	30	0	0	280
WSW	7	105	67	1	0	0	180
W	16	77	24	5	0	0	122
WNW	9	66	33	11	0	0	119
NW	8	25	93	23	0	0	149
NNW	5	31	93	16	0	0	145
VARIABLE	132	142	34	2	0	0	310
Total	262	1119	1152	201	1	0	2735

Periods of calm(hours): 13

Hours of missing data: 0 (this stability class)

Hours of missing data: 0 (this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: F

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	2	24	19	0	0	0	45
NNE	1	18	28	0	0	0	47
NE	6	31	73	0	0	0	110
ENE	3	47	57	0	0	0	107
E	5	24	31	1	0	0	61
ESE	3	16	25	1	0	0	45
SE	2	17	12	0	0	0	31
SSE	2	9	16	9	0	0	36
S	4	13	5	2	0	0	24
SSW	7	10	4	0	0	0	21
SW	1	12	22	6	0	0	41
WSW	4	13	23	0	0	0	40
W	5	30	22	0	0	0	57
NNW	8	36	17	0	0	0	61
NW	5	18	68	5	0	0	96
NNW	4	15	43	5	0	0	67
VARIABLE	54	58	14	0	0	0	126
Total	116	391	479	29	0	0	1015

Periods of calm(hours): 14

Hours of missing data: 0 (this stability class)

Hours of missing data: 0 (this time period, all stability classes)

TABLE 8-CA

FARLEY NUCLEAR PLANT

CUMULATIVE JOINT FREQUENCY DISTRIBUTION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD: 01-JAN-91 00:00 TO 31-DEC-91 23:59

RELEASE MODE: Elevated

STABILITY CLASS: G

ELEVATION: 60.3 m.

ALL HOURS IN PERIOD

Wind Direction	Wind Speed (mph) at 60.3 m. level						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	15	36	13	0	0	0	64
NNE	6	28	67	1	0	0	102
NE	11	27	57	0	0	0	95
ENE	3	35	35	0	0	0	73
E	2	18	29	0	0	0	49
ESE	5	19	16	0	0	0	40
SE	2	12	4	0	0	0	18
SSE	3	7	5	2	0	0	17
S	0	4	4	1	0	0	9
SSW	4	3	0	0	0	0	7
SW	5	8	2	0	0	0	15
WSW	7	5	3	0	0	0	15
W	10	13	5	0	0	0	28
WNW	7	20	6	0	0	0	33
NW	7	13	42	0	0	0	62
NNW	9	26	47	0	0	0	82
VARIABLE	28	41	8	0	0	0	77
Total	124	315	343	4	0	0	786

Periods of calm(hours): 10

Hours of missing data: 0 (this stability class)

Hours of missing data: 0 (this time period, all stability classes)

CHAPTER 25
PROCESS CONTROL PROGRAM

There were no changes to the Process Control Program during the second half of 1991.