

September 27, 1995

Mr. John P. Stetz
Vice President - Nuclear, Davis Besse
Centerior Service Company
c/o Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, OH 43449

SUBJECT: DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1 - WITHDRAWAL OF AN
AMENDMENT REQUEST (TAC NO. M93300)

Dear Mr. Stetz:

By letters dated August 17, 1995 and August 18, 1995, you requested enforcement discretion and an amendment to the Technical Specifications (TS) for Operating License No. NPF-3. Both the proposed enforcement discretion and the proposed TS change would have modified the facility TS Section 3/4.7.5.1, "Ultimate Heat Sink" to increase the maximum allowable water temperature of the Ultimate Heat Sink from ≤ 85 °F to ≤ 90 °F. Subsequently, by letter dated September 12, 1995, you withdrew both the request for enforcement discretion and the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely, ~~Original~~ signed by

Linda L. Gundrum, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure: Notice of Withdrawal

cc w/encl: See next page

DISTRIBUTION:

Docket File
PUBLIC
PDIII-3 r/f
JRoe
OGC
ACRS (4)
WAxelson, Region III

DOCUMENT NAME: G:\DAVISBES\DB93300.WIL

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures
"E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-3	C	PM:PDIII-3	E	D:PDIII-3	
NAME	DFoster-Curseen		LGundrum	RM	GMarcus	GHM
DATE	09/24/95	OS	09/26/95		09/27/95	

OFFICIAL RECORD COPY

040144

9510040306 950927
PDR ADOCK 05000346
P PDR

NRC FILE CENTER COPY

DFa 1/1



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20565-0001

September 27, 1995

Mr. John P. Stetz
Vice President - Nuclear, Davis Besse
Centerior Service Company
c/o Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, OH 43449

SUBJECT: DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1 - WITHDRAWAL OF AN
AMENDMENT REQUEST (TAC NO. M93300)

Dear Mr. Stetz:

By letters dated August 17, 1995 and August 18, 1995, you requested enforcement discretion and an amendment to the Technical Specifications (TS) for Operating License No. NPF-3. Both the proposed enforcement discretion and the proposed TS change would have modified the facility TS Section 3/4.7.5.1, "Ultimate Heat Sink" to increase the maximum allowable water temperature of the Ultimate Heat Sink from ≤ 85 °F to ≤ 90 °F. Subsequently, by letter dated September 12, 1995, you withdrew both the request for enforcement discretion and the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script that reads "Linda L. Gundrum".

Linda L. Gundrum, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Doc. No. 50-346

Enclosure: Notice of Withdrawal

cc w/encl: See next page