



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

BALTIMORE GAS AND ELECTRIC COMPANY  
DOCKET NO. 50-317  
CALVERT CLIFFS NUCLEAR POWER PLANT UNIT NO. 1  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 206  
License No. DPR-53


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Baltimore Gas and Electric Company (the licensee) dated June 2, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.2. of Facility Operating License No. DPR-53 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 206, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Ledyard B. Marsh, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: September 26, 1995



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

BALTIMORE GAS AND ELECTRIC COMPANY

DOCKET NO. 50-318

CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 184  
License No. DPR-69


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Baltimore Gas and Electric Company (the licensee) dated June 2, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.2. of Facility Operating License No. DPR-69 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 184, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Ledyard B. Marsh, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: September 26, 1995

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 206 FACILITY OPERATING LICENSE NO. DPR-53

AMENDMENT NO. 184 FACILITY OPERATING LICENSE NO. DPR-69

DOCKET NOS. 50-317 AND 50-318

Revise Appendix A as follows:

Remove Pages

3/4 4-6

Insert Pages

3/4 4-6

### 3/4.4 REACTOR COOLANT SYSTEM

#### 3/4.4.2 SAFETY VALVES

##### LIMITING CONDITION FOR OPERATION

---

3.4.2.1 The following pressurizer code safety valves shall be **OPERABLE**:

<u>Valve</u>	<u>Lift Settings</u>	<u>As-Found Tolerance</u>	<u>As-Left Tolerance</u>
RC-200	2500 psia	+2%/-1%	+ 1%
RC-201	2565 psia	+ 2%	+ 1%

APPLICABILITY: **MODES 1, 2 and 3.**

ACTION: With one pressurizer code safety valve inoperable, either restore the inoperable valve to **OPERABLE** status within 15 minutes or be in **HOT SHUTDOWN** within 12 hours.

3.4.2.2 At least one of the above pressurizer code safety valves shall be **OPERABLE**:

APPLICABILITY: **MODES 4 and 5.**

ACTION: With no pressurizer code safety valve **OPERABLE**, immediately suspend all operations involving positive reactivity changes and place an **OPERABLE** shutdown cooling loop into operation.

##### SURVEILLANCE REQUIREMENTS

---

4.4.2 No additional Surveillance Requirements other than those required by Specification 4.0.5.

\* Both valves may be removed in **MODE 5** provided at least one valve is replaced by a spool piece which allows the pressurizer to relieve directly to the quench tank.

### 3/4.4 REACTOR COOLANT SYSTEM

#### 3/4.4.2 SAFETY VALVES

##### LIMITING CONDITION FOR OPERATION

3.4.2.1 The following pressurizer code safety valves shall be **OPERABLE**:

<u>Valve</u>	<u>Lift Settings</u>	<u>As-Found Tolerance</u>	<u>As-Left Tolerance</u>
RC-200	2500 psia	+2%/-1%	± 1%
RC-201	2565 psia	± 2%	± 1%

APPLICABILITY: **MODES** 1, 2 and 3.

ACTION: With one pressurizer code safety valve inoperable, either restore the inoperable valve to **OPERABLE** status within 15 minutes or be in **HOT SHUTDOWN** within 12 hours.

3.4.2.2 At least one of the above pressurizer code safety valves shall be **OPERABLE**:

APPLICABILITY: **MODES** 4 and 5.

ACTION: With no pressurizer code safety valve **OPERABLE**, immediately suspend all operations involving positive reactivity changes and place an **OPERABLE** shutdown cooling loop into operation.

##### SURVEILLANCE REQUIREMENTS

4.4.2 No additional Surveillance Requirements other than those required by Specification 4.0.5.

\* Both valves may be removed in **MODE** 5 provided at least one valve is replaced by a spool piece which allows the pressurizer to relieve directly to the quench tank.