

### OPERATING DATA REPORT

DOCKET NO. 50-244

DATE June 25, 1984

COMPLETED BY Robert E. Dodge  
Robert E. Dodge

TELEPHONE (315) 524-4446 Ext. 396  
Ginna Station

#### OPERATING STATUS

- 1. Unit Name: GINNA STATION, UNIT #1
- 2. Reporting Period: May, 1984
- 3. Licensed Thermal Power (MWt): 1520
- 4. Nameplate Rating (Gross MWe): 490
- 5. Design Electrical Rating (Net MWe): 470
- 6. Maximum Dependable Capacity (Gross MWe): 490
- 7. Maximum Dependable Capacity (Net MWe): 470

Notes  
See Operating Summary  
Page 4.

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level to Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reasons For Restrictions, If Any: \_\_\_\_\_

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	3,647	127,223
12. Number of Hours Reactor Was Critical	237.15	1,727.23	95,327.21
13. Reactor Reserve Shutdown Hours	40.73	40.73	1,672.05
14. Hours Generator On-Line	185.50	1,675.05	93,186.68
15. Unit Reserve Shutdown Hours	0.00	0.00	8.50
16. Gross Thermal Energy Generated (MWH)	160,440	2,367,864	128,625,233
17. Gross Electrical Energy Generated (MWH)	50,384	783,872	41,948,242
18. Net Electrical Energy Generated (MWH)	46,105	743,735	39,769,980
19. Unit Service Factor	24.93%	45.93%	73.25%
20. Unit Availability Factor	24.93%	45.93%	73.25%
21. Unit Capacity Factor (Using MDC Net)	13.18%	43.39%	68.23%
22. Unit Capacity Factor (Using DER Net)	13.18%	43.39%	68.23%
23. Unit Forced Outage Rate	25.73%	3.69%	7.94%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

NOTE: Items 13 and 15 Cumulative total commencing January 1, 1975.

1/1 IE24

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244  
 UNIT #1, Ginna Station  
 DATE June 25, 1984  
 COMPLETED BY Robert E. Dodge  
 TELEPHONE 1 (315) 524-4446  
Ext. 396 at Ginna

MONTH May 1984

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1. 0  
 2. 0  
 3. 0  
 4. 0  
 5. 0  
 6. 0  
 7. 0  
 8. 0  
 9. 0  
 10. 0  
 11. 0  
 12. 0  
 13. 0  
 14. 14  
 15. 0  
 16. 0

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17. 0  
 18. 0  
 19. 0  
 20. 0  
 21. 0  
 22. 0  
 23. 12  
 24. 138  
 25. 216  
 26. 194  
 27. 236  
 28. 339  
 29. 391  
 30. 14  
 31. 0

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

## UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH May 1984

DOCKET NO. 50-244

UNIT NAME #1, Ginna Station

DATE June 25, 1984

COMPLETED BY Robert E. Dodge

TELEPHONE (315) 524-4446 Ext. 396

Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
84-1	5-14-84	F	207.80	A	1	N/A	HF	Secondary Chemistry	Secondary chemistry out of specs, crevice cleaning and sludge lancing on S/G A&B. Due to condenser tube leak.
84-2	5-23-84	S	6.67	B	1	N/A	NA	NA	T-18C Overspeed Test.
84-3	5-30-84	F	57.28	A	3	N/A	HA	Exciter Failure	Air cooler gasket poor compression. Shimmed air cooler to provide proper alignment and sealant on both sides of gasket.

1  
F: Forced  
S: Scheduled

2  
Reason:  
A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

3  
Method:  
1-Manual  
2-Manual Scram.  
3-Automatic Scram.  
4-Other (Explain)

4  
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5  
Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244  
UNIT Ginna Station, Unit#1  
DATE June 25, 1984  
COMPLETED BY Robert E. Dodge  
TELEPHONE 1 (315) 524-4446  
EXT. 396 at Ginna

MONTH May 1984

On May 14, 1984 @ 0610 hours Ginna Station completed its 1984 Annual Refueling and Maintenance Shutdown. On May 14, 1984 @ 1618 hours the unit was shutdown due to Secondary System condensate chemistry problems.

May 23, 1984 the unit was restored to service @ 0806 hours. The unit was removed from service at 1615 hours for Procedure T-18C Turbine Overspeed Test and to repair leaky exciter cooler. At 2255 hours on May 23, 1984, the unit was restored to service until May 30, 1984 @ 2221 hours, at which time exciter failure resulted in a Reactor Trip.



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

TELEPHONE  
AREA CODE 716 546-2700

GINNA STATION

June 25, 1984

Director, Office of Management Information and Program Analysis  
U.S. NUCLEAR REGULATORY COMMISSION  
Washington, DC 20555

Subject: Monthly Report for May, 1984  
Operating Status Information  
R. E. Ginna Nuclear Power Plant Unit No. 1  
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of May, 1984

Very truly yours,

Bruce A. Snow  
Plant Superintendent

BAS/eeg

Attachments

cc: Dr. Thomas E. Murley NRC (1)

IE 24  
11