

23A1765
CLASS I
MAY 1984

**SUPPLEMENTAL RELOAD
LICENSING SUBMITTAL FOR
BRUNSWICK STEAM ELECTRIC PLANT
UNIT 2, RELOAD 5**

8407050114 840626
PDR ADOCK 05000324
P PDR

GENERAL  ELECTRIC

23A1765
Revision 0
Class I
May 1984

SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR
BRUNSWICK STEAM ELECTRIC PLANT
UNIT 2, RELOAD 5

Prepared: P. A. Lambert
P. A. Lambert
Fuel Licensing

Verified: J. D. Friday
J. D. Friday
Fuel Licensing

Approved: J. O. Nielt acting for
R. L. Gridley, Manager
Fuel & Services Licensing

NUCLEAR ENERGY BUSINESS OPERATIONS • GENERAL ELECTRIC COMPANY
SAN JOSE, CALIFORNIA 95125

GENERAL  ELECTRIC

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT
PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Carolina Power and Light Company (CP&L) for CP&L's use with the U.S. Nuclear Regulatory Commission (USNRC) for amending CP&L's operating license of the Brunswick Steam Electric Plant Unit 2. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained or provided to General Electric at the time this report was prepared.

The only undertakings of the General Electric Company respecting information in this document are contained in the Supplemental Agreement to the Contract between Carolina Power and Light Company and General Electric Company for Reload Fuel Supply and Related Services for Brunswick Steam Electric Plant Unit 2, effective June 25, 1980, and nothing contained in this document shall be construed as changing said contract. The use of this information except as defined by said contract, or for any purpose other than that for which it is intended, is not authorized; and with respect to any such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy or usefulness of the information contained in this document or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.

1. PLANT UNIQUE ITEM (1.0)*

Plant Parameter Changes

Appendix A

2. RELOAD FUEL BUNDLES (1.0, 2.0, 3.3.1 AND 4.0)

	<u>Cycle Loaded</u>	<u>Number</u>	<u>Number Drilled</u>
Irradiated			
8DE274L	2	8	8
8DRB265H	3	40	40
8DRB283	3	36	36
P8DRB265H	4	132	132
P8DRE284H	5	24	24
P8DRB265H	5	136	136
New			
BP8DRB299	6	184	184
TOTAL		560	560

3. REFERENCE CORE LOADING PATTERN (3.3.1)

Nominal previous cycle core average exposure at end of cycle:	15680 Mwd/ST
Minimum previous cycle core average exposure at end of cycle from cold shutdown considerations:	15680 Mwd/ST
Assumed reload cycle core average exposure at end of cycle:	16336 Mwd/ST
Core loading pattern:	Figure 1

* () Refers to area of discussion in "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-6, April 1983. A letter "S" preceding the number refers to the appropriate section in the United States Supplement, NEDE-24011-P-A-6-US, April 1983.

4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM WORTH -
NO VOIDS, 20°C (3.3.2.1.1 AND 3.3.2.1.2)

Beginning of Cycle, k_{eff}	
Uncontrolled	1.110
Fully Controlled	0.955
Strongest Control Rod Out	0.986
R, Maximum Increase in Cold Core Reactivity with Exposure into Cycle, Δk	0.0

5. STANDBY LIQUID CONTROL SYSTEM SHUTDOWN CAPABILITY (3.3.2.1.3)

<u>ppm</u>	<u>Shutdown Margin (Δ) (20°C, Xenon Free)</u>
600	0.036

6. RELOAD UNIQUE TRANSIENT ANALYSIS INPUT (3.3.2.1.5 AND S.2.2)

(COLD WATER INJECTION EVENTS ONLY)

Void Fraction (%)	41.3
Average Fuel Temperature (°F)	1292
Void Coefficient N/A* (ρ /% Rg)	-7.00/-8.75
Doppler Coefficient N/A (ρ /°F)	-0.175/0.166
Scram Worth N/A (ρ)	**

*N = Nuclear Input Data, A = Used in Transient Analysis

**Generic exposure independent values are used as given in "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-6-US, April 1983.

7. RELOAD UNIQUE GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS (S.2.2)

Fuel Design	Peaking Factors			R-Factor	Bundle Power (MWt)	Bundle Flow (1000 lb/hr)	Initial MCPR
	Local	Radial	Axial				
Exposure: BOC to EOC-2000 MWd/ST							
BP/P8x8R	1.20	1.55	1.40	1.051	6.583	113.5	1.23
8x8R	1.20	1.54	1.40	1.051	6.545	112.3	1.23
8x8	1.22	1.40	1.40	1.098	5.975	112.0	1.23

Exposure: EOC-2000 MWd/ST to EOC

BP/P8x8R	1.20	1.42	1.40	1.051	6.062	116.5	1.34
8x8R	1.20	1.46	1.40	1.051	6.199	114.2	1.31
8x8	1.22	1.33	1.40	1.098	5.674	113.9	1.30

8. SELECTED MARGIN IMPROVEMENT OPTIONS (S.2.2.2)

Transient Recategorization:	No
Recirculation Pump Trip:	No
Rod Withdrawal Limiter:	No
Thermal Power Monitor:	Yes
Improved Scram Time:	No
Exposure Dependent Limits:	Yes
Exposure Points Analyzed:	EOC and EOC-2000 MWd/ST

9. OPERATING FLEXIBILITY OPTIONS (S.2.2.3)

Single Loop Operation:	No
Load Line Limit:	No
Extended Load Line Limit:	No
Increased Core Flow:	No
Flow Point Analyzed:	N/A
Feedwater Temperature Reduction:	No

10. CORE-WIDE TRANSIENT ANALYSIS RESULTS (S.2.2.1)

Exposure Range: BOC to EOC-2000 MWd/ST

<u>Transient</u>	<u>Flux</u> <u>(% NBR)</u>	<u>Q/A</u> <u>(% NBR)</u>	<u>ΔCPR</u>			<u>Figure</u>
			<u>BP/P8x8R</u>	<u>8x8R</u>	<u>8x8</u>	
Load Rejection Without Bypass	469	119	0.16	0.14	0.13	2a
Loss of Feedwater Heater	126	124	0.16	0.16	0.16	3
Feedwater Controller Failure	115	110	0.05	0.05	0.05	4a

Exposure Range: EOC-2000 MWd/ST to EOC

<u>Transient</u>	<u>Flux</u> <u>(% NBR)</u>	<u>Q/A</u> <u>(% NBR)</u>	<u>ΔCPR</u>			<u>Figure</u>
			<u>BP/P8x8R</u>	<u>8x8R</u>	<u>8x8</u>	
Load Rejection without Bypass	516	128	0.27	0.24	0.23	2b
Loss of Feedwater Heater	126	124	0.16	0.16	0.16	3
Feedwater Controller Failure	141	111	0.05	0.05	0.05	4b

11. LOCAL ROD WITHDRAWAL ERROR (WITH LIMITING INSTRUMENT FAILURE) TRANSIENT SUMMARY (S.2.2.1)

Limiting Rod Pattern: Figure 5

Includes 2.2% Power Spiking Penalty: Yes

<u>Rod Block</u> <u>Reading</u>	<u>Rod Position</u> <u>(feet withdrawn)</u>	<u>ΔCPR</u>			<u>MLHGR (kW/ft)</u>	
		<u>BP/P8x8R</u>	<u>8x8R</u>	<u>8x8*</u>	<u>BP/P/8x8R</u>	<u>8x8*</u>
104	3.5	0.12	0.12		17.68	
105	4.0	0.15	0.15		18.23	
106	4.0	0.15	0.15		18.23	
107	4.5	0.17	0.17		18.40	
108	5.0	0.19	0.19		18.40	
109	5.5	0.20	0.20		18.40	
110	6.5	0.23	0.23		18.40	

Setpoint Selected: 107

*On periphery of core (low power region) and not limiting

12. CYCLE MCPR VALUES (S.2.2)

Non-Pressurization Events

Exposure Range: BOC to EOC	<u>BP/P8x8R</u>	<u>8x8R</u>	<u>8x8</u>
Loss of Feedwater Heater	1.23	1.23	1.23
Fuel Loading Error	1.20		
Rod Withdrawal Error	1.24	1.24	

Pressurization Events

	<u>Option A</u>			<u>Option B</u>		
	<u>BP/P8x8R</u>	<u>8x8R</u>	<u>8x8</u>	<u>BP/P8x8R</u>	<u>8x8R</u>	<u>8x8</u>
Exposure Range:						
BOC to EOC-2000 MWd/ST						
Load Rejection	1.28	1.26	1.25	1.09	1.08	1.08
Without Bypass						
Feedwater Controller	1.17	1.17	1.17	1.11	1.11	1.11
Failure						
Exposure Range:						
EOC-2000 MWd/ST to EOC						
Load Rejection	1.40	1.37	1.36	1.28	1.25	1.24
Without Bypass						
Feedwater Controller	1.17	1.17	1.17	1.11	1.11	1.11
Failure						

13. OVERPRESSURIZATION ANALYSIS SUMMARY (S.2.3)

<u>Transient</u>	<u>P_{sl}</u> (psig)	<u>P_v</u> (psig)	<u>Plant Response</u>
MSIV Closure (Flux Scram)	1218	1255	Figure 6

14. STABILITY ANALYSIS RESULTS (S.2.4)

Rod Line Analyzed:	105%
Decay Ratio:	Figure 7
Reactor Core Stability Decay Ratio, x_2/x_0 :	0.67
Channel Hydrodynamic Performance Decay Ratio, x_2/x_0	
Channel Type	
BP/P8x8R	0.20
8x8R	0.20
8x8	0.28

15. LOADING ERROR RESULTS (S.2.5.4)

Variable Water Gap Misoriented Bundle Analysis:	Yes*
---	------

<u>Event</u>	<u>Initial MCPR</u>	<u>Resulting MCPR</u>
Misoriented	1.18	1.07

16. CONTROL ROD DROP ANALYSIS RESULTS (S.2.5.1)

Bounding Analysis Results:

Doppler Reactivity Coefficient:	Figure 8
Accident Reactivity Shape Functions:	Figures 9 and 10
Scram Reactivity Functions:	Figures 11 and 12

Plant Specific Analysis Results:

Parameter(s) not Bounded, Cold:	None
Resultant Peak Enthalpy, Cold:	N/A
Parameter(s) not Bounded, HSB:	Accident Reactivity
Resultant Peak Enthalpy, HSB:	197.6


* Δ CPR penalty of 0.02 for the tilted misoriented bundle is applied to the cycle MCPR value reported in Section 12.

17. LOSS-OF-COOLANT ACCIDENT RESULT (S.2.5.2)

See "Loss-of-Coolant Analysis Report for Brunswick Steam Electric Plant Unit No. 2," September 1977 (NEDO-24053, as amended).

Fuel Type: BP8DRB299

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	10.9	2061	0.022
1000	11.0	2063	0.022
5000	11.5	2108	0.025
10000	12.2	2194	0.032
15000	12.1	2198	0.032
20000	12.0	2197	0.032
25000	11.5	2141	0.027
30000	11.0	2048	0.020
35000	10.3	1960	0.029
40000	9.7	1846	0.009
45000	9.0	1772	0.007



FUEL TYPE	
A = 8DB274L	E = P8DRB265H
B = 8DRB265H	F = P8DRB284H
C = 8DRB283	H = BP8DRB299
D = P8DRB265H	

Figure 1. Reference Core Loading Pattern







Figure 2a. Plant Response to Generator Load Rejection Without Bypass (EOC-2000)







Figure 2b. Plant Response to Generator Load Rejection Without Bypass (EOC)







Figure 3. Plant Response to Loss of 100°F Feedwater Heating







Figure 4a. Plant Response to Feedwater Controller Failure, Maximum Demand (EOC-2000)







Figure 4b. Plant Response to Feedwater Controller Failure, Maximum Demand (EOC)

- NOTES: 1. ROD PATTERN IS 1/4 CORE MIRROR SYMMETRIC.
 2. NO. INDICATES NUMBER OF NOTCHES WITHDRAWN OUT OF 48. BLANK IS A WITHDRAWN ROD.
 3. ERROR ROD IS (22, 31).

	2	6	10	14	18	22	26
51					32		32
47				2		6	
43			32		36		36
39		2		6		14	
35	32		36		44		44
31		6		14		0	
27	32		36		44		44

Figure 5. Limiting Rod Withdrawal Error Rod Pattern







Figure 6. Plant Response to MSIV Closure (Flux Scram)




Figure 7. Reactor Core Decay Ratio

Figure 8. Fuel Doppler Coefficient in $1/\Delta^{\circ}\text{C}$




Figure 9. Accident Reactivity Shape Function Cold Startup




Figure 10. Accident Reactivity Shape Function Hot Startup




Figure 11. Scram Reactivity Function Cold Startup




Figure 12. Scram Reactivity Function Hot Startup

APPENDIX A

Plant Parameter Changes:

Pressure Relief Systems (Table S.2-4.1, pg. US.2-93, NEDO-24011)

Safety/Relief Valve Type: E
(i.e., capacity at reference pressure of
1080 +3% psig is 789,000 lb/hr for each S/RV)

GENERAL  ELECTRIC