

yellow

JUN 20 1984

Georgia Power Company  
ATTN: Mr. R. J. Kelly  
Executive Vice President  
P. O. Box 4545  
Atlanta, GA 30302

Gentlemen:

SUBJECT: REPORT NOS. 50-424/84-04 AND 50-425/84-04

Thank you for your responses of April 9 and May 18, 1984, to our Notice of Violation issued on March 9, 1984, concerning activities conducted at your Vogtle facility. After careful consideration of the bases for your denial, we agree with your position with respect to the failure to follow inspection procedures, and have deleted it from our records as a violation. However, your arguments have raised questions about how much relaxation of anchors is being considered by your designers. These questions have been designated as Unresolved Item No. 424/84-04-01 "Validity of Anchor Bolt Inspection Acceptance Criteria," pending further NRC inspection.

We appreciate your cooperation in this matter.

Sincerely,  
*RL*  
Richard C. Lewis, Director  
Division of Reactor Projects

cc: D. O. Foster, Vice President  
and General Manager  
H. H. Gregory, III, Construction  
Project Manager  
G. Bockhold, Jr., Plant Manager  
E. D. Groover, QA Site Supervisor

bcc: NRC Resident Inspector  
Document Control Desk  
State of Georgia

RII  
*WCLiu*  
WCLiu:sa  
06/13/84

RII  
*JBlake*  
JBlake  
06/14/84

RII  
*ARHerdt*  
ARHerdt  
06/14/84

RII  
*JAOIshinski*  
JAOIshinski  
06/15/84

RII  
*HCDance*  
HCDance  
06/18/84

RII  
*JMPuckett*  
JMPuckett  
06/18/84

RII  
*RCLewis*  
RCLewis  
06/18/84

*RL 6/18/84*

*IE 07*

8407050323 840620  
PDR ADOCK 05000424  
G PDR