

Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30308
Telephone 404 526-6526

Mailing Address:
Post Office Box 4545
Atlanta, Georgia 30302

84 JUN 12 A 9:00



the southern electric system
NED-84-308

L. T. Gucwa
Manager Nuclear Engineering
and Chief Nuclear Engineer

June 8, 1984

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 2900
101 Marietta Street, NW
Atlanta, Georgia 30303

REFERENCE:
RII: JPO
50-321/50-366
I&E Inspection Report
84-07

ATTENTION: Mr. James P. O'Reilly

GENTLEMEN:

Georgia Power Company provides the following additional information as amplification of our letter of April 13, 1984, which responded to violations identified during an inspection conducted January 21 - February 20, 1984, and reported by your letter dated March 14, 1984.

RESPONSE TO VIOLATION 3:

Reasons for the Violation: The subject drawing revision was a manual revision of a drawing which had been produced by a new automated drafting system. It is current practice that as drawings are revised to reflect design changes, those requiring redrafting are accomplished by an automated drafting system (which uses new symbols for globe and ball valves). It was decided, in this particular case, that it was more expedient to manually correct the drawing rather than use the automated system since the change was relatively minor. The old symbol for the ball valve is almost identical to the new symbol for the globe valve, and the wrong symbol was inadvertently incorporated into the drawing. We reiterate that we believe this to be an isolated case and is not indicative of a programmatic problem.

Additional Corrective Steps Which Have Been Taken and the Results Achieved: A Site Engineer has reviewed a sample of 10 drawings which incorporated As Built Notices and found no additional discrepancies. A letter has been issued to all Southern Company Services, Inc. departments working on Plant Hatch drawings cautioning the proper incorporation of symbols.

If you have any further questions regarding this response or require further information regarding our actions in this matter, please contact this office.

Very truly yours,

L. T. Gucwa

8407050403 840620
PDR ADOCK 05000321
G PDR

MJB

xc: H. C. Nix, Jr.
Senior Resident Inspector